

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A.C. SOURCES

OPERATING

LIMITING CONDITION FOR OPERATION

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent A.C. circuits between the offsite transmission network and the onsite Class 1E distribution system (vital bus system), and
- b. Three separate and independent diesel generators with:
 1. Separate day tanks containing a minimum volume of 130 gallons of fuel, and
 2. A common fuel storage system consisting of two storage tanks, each containing a minimum volume of 23,000 gallons of fuel, and two fuel transfer pumps.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With an independent A.C. circuit of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining independent A.C. circuit by performing Surveillance Requirement 4.8.1.1.1.a within one hour and at least once per 8 hours thereafter; restore the inoperable independent A.C. circuit to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the independent A.C. circuits by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter. Determine the two remaining OPERABLE diesel generators are not inoperable due to common cause failure or perform Surveillance Requirement 4.8.1.1.2.a.2 within 24 hours. If the diesel generator is inoperable for preventive maintenance, the two remaining OPERABLE diesel generators need not be tested nor the OPERABILITY evaluated. In any case, restore the inoperable diesel generator to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS

=====

4.8.1.1.1 Two physically independent A.C. circuits between the offsite transmission network and the onsite Class 1E distribution system (vital bus system) shall be:

- a. Determined OPERABLE at least once per 7 days by verifying correct breaker alignments, power availability, and
- b. Demonstrated OPERABLE at least once per 18 months during shutdown by transferring (manually and automatically) vital bus supply from one 13/4 kv transformer to the other 13/4 kv transformer.

4.8.1.1.2 Each diesel generator shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by:
 - 1. Verifying the fuel level in its day tank.
 - 2. Verifying the diesel generator starts from standby conditions* and achieves ≥ 3910 volts and ≥ 58.8 Hz in ≤ 13 seconds, and subsequently achieves steady state voltage of ≥ 3910 and ≤ 4400 volts and frequency of 60 ± 1.2 Hz.

Subsequently, verifying the generator is synchronized with voltage maintained ≥ 3910 and ≤ 4580 volts, gradually loaded to 2340-2600 kw**, and operates at a load of 2340-2600 kw for greater than or equal to 60 minutes.

- 3. Verifying the diesel generator is aligned to provide standby power to the associated vital bus.
- b. At least once per 31 days and after each operation of the diesel where the period of operation was greater than or equal to one hour by checking for and removing accumulated water from the day tanks.
- c. At least once per 6 months by verifying the diesel generator starts from standby conditions* and achieves ≥ 3910 volts and ≥ 58.8 Hz in ≤ 13 seconds, and subsequently achieves steady state voltage of ≥ 3910 and ≤ 4400 volts and frequency of 60 ± 1.2 Hz.

The generator shall be synchronized to its emergency bus with voltage maintained ≥ 3910 and ≤ 4580 volts, loaded to 2340-2600** kw in less than or equal to 60 seconds, and operate at a load of 2340-2600 kw for at least 60 minutes.

This test, if it is performed so it coincides with the testing required by Surveillance Requirement 4.8.1.1.2.a.2, may also serve to concurrently meet those requirements.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- c) Verifying that all nonessential automatic diesel generator trips (i.e., other than engine overspeed, lube oil pressure low, 4 KV bus differential and generator differential), are automatically bypassed upon loss of voltage on the vital bus concurrent with a safety injection actuation signal.
 - 7. Deleted
 - 8. Verifying that the auto-connected loads to each diesel generator do not exceed the two hour rating of 2860 kw.
 - 9. Verifying that with the diesel generator operating in a test mode (connected to its bus), a simulated safety injection signal overrides the test mode by (1) returning the diesel generator to standby operation and (2) automatically energizing the emergency loads with offsite power.
 - e. At least once per ten years or after any modifications which could affect diesel generator interdependence by starting all diesel generators simultaneously*, during shutdown, and verifying that all diesel generators accelerate to at least 58.8 Hz in less than or equal to 13 seconds.
 - f. At least once per 18 months, the following test shall be performed within 5 minutes of diesel shutdown after the diesel has operated for at least two hours at 2340-2600 kw**:

Verifying the diesel generator starts and achieves ≥ 3910 volts and ≥ 58.8 Hz in ≤ 13 seconds, and subsequently achieves steady state voltage of ≥ 3910 and ≤ 4400 volts and frequency of 60 ± 1.2 Hz.
 - g. At least once per 18 months verifying the diesel generator operates for at least 24 hours*. During the first 2 hours of this test, the diesel generators shall be loaded to 2760-2860 Kw**. During the remaining 22 hours of this test, the diesel generator shall be loaded to 2500-2600 Kw**. The steady state voltage and frequency shall be maintained at ≥ 3910 and ≤ 4580 volts and 60 ± 1.2 Hz during this test.
- 4.8.1.1.3 The diesel fuel oil storage and transfer system shall be demonstrated OPERABLE:
- a. At least once per 31 days by:
 - 1. Verifying the level in each of the above required fuel storage tanks.
 - 2. Verifying that both fuel transfer pumps can be started and transfer fuel from the fuel storage tanks to the day tanks.

ELECTRICAL POWER SYSTEMS

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system (vital bus system), and
- b. Two separate and independent diesel generators with:
 1. Separate day tanks containing a minimum volume of 130 gallons of fuel, and
 2. A common fuel storage system containing a minimum volume of 23,000 gallons of fuel, and
 3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes until the minimum required A.C. electrical power sources are restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

-----NOTE-----

The following surveillances are not required to be performed to maintain operability during Modes 5 and 6. These surveillances are: 4.8.1.1.1.b, 4.8.1.1.2.d.2, 4.8.1.1.2.d.3, 4.8.1.1.2.d.4, 4.8.1.1.2.d.6, 4.8.1.1.2.d.9, 4.8.1.1.2.e, 4.8.1.1.2.f, and 4.8.1.1.2.g.

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the Surveillance Requirements of 4.8.1.1.1, 4.8.1.1.2, 4.8.1.1.3 (except for requirement 4.8.1.1.3.a.2) and 4.8.1.1.4.

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A.C. SOURCES

OPERATING

LIMITING CONDITION FOR OPERATION

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent A.C. circuits between the offsite transmission network and the onsite Class 1E distribution system (vital bus system), and
- b. Three separate and independent diesel generators with:
 1. Separate day tanks containing a minimum volume of 130 gallons of fuel, and
 2. A common fuel storage system consisting of two storage tanks, each containing a minimum volume of 23,000 gallons of fuel, and two fuel transfer pumps.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With an independent A.C. circuit of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining independent A.C. circuit by performing Surveillance Requirement 4.8.1.1.1.a within one hour and at least once per 8 hours thereafter; restore the inoperable independent A.C. circuit to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the independent A.C. circuits by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter. Determine the two remaining OPERABLE diesel generators are not inoperable due to common cause failure or perform Surveillance Requirement 4.8.1.1.2.a.2 within 24 hours. If the diesel generator is inoperable for preventive maintenance, the two remaining OPERABLE diesel generators need not be tested nor the OPERABILITY evaluated. In any case, restore the inoperable diesel generator to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS

=====

4.8.1.1.1 Two physically independent A.C. circuits between the offsite transmission network and the onsite Class 1E distribution system (vital bus system) shall be:

- a. Determined OPERABLE at least once per 7 days by verifying correct breaker alignments, power availability, and
- b. Demonstrated OPERABLE at least once per 18 months during shutdown by transferring (manually and automatically) vital bus supply from one 13/4 kv transformer to the other 13/4 kv transformer.

4.8.1.1.2 Each diesel generator shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by:
 1. Verifying the fuel level in its day tank.
 2. Verifying the diesel generator starts from standby conditions* and achieves ≥ 3910 volts and ≥ 58.8 Hz in ≤ 13 seconds, and subsequently achieves steady state voltage of ≥ 3910 and ≤ 4400 volts and frequency of 60 ± 1.2 Hz.

Subsequently, verifying the generator is synchronized with voltage maintained ≥ 3910 and ≤ 4580 volts, gradually loaded to 2340-2600 kw**, and operates at a load of 2340-2600 kw for greater than or equal to 60 minutes.
 3. Verifying the diesel generator is aligned to provide standby power to the associated vital bus.
- b. At least once per 31 days and after each operation of the diesel where the period of operation was greater than or equal to 1 hour by checking for and removing accumulated water from the day tanks.
- c. At least once per 6 months by verifying the diesel generator starts from standby conditions* and achieves ≥ 3910 volts and ≥ 58.8 Hz in ≤ 13 seconds, and subsequently achieves steady state voltage of ≥ 3910 and ≤ 4400 volts and frequency of 60 ± 1.2 Hz.

The generator shall be synchronized to its emergency bus with voltage maintained ≥ 3910 and ≤ 4580 volts, loaded to 2340-2600** kw in less than or equal to 60 seconds, and operate at a load of 2340-2600 kw for at least 60 minutes.

This test, if it is performed so it coincides with the testing required by Surveillance Requirement 4.8.1.1.2.a.2, may also serve to concurrently meet those requirements.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

=====

- c) Verifying that all nonessential automatic diesel generator trips (i.e., other than engine overspeed, lube oil pressure low, 4 KV Bus differential and generator differential) are automatically bypassed upon loss of voltage on the vital bus concurrent with a safety injection actuation signal.
- 7. Deleted
- 8. Verifying that the auto-connected loads to each diesel generator do not exceed the two hour rating of 2860 kw.
- 9. Verifying that with the diesel generator operating in a test mode (connected to its bus), a simulated safety injection signal overrides the test mode by (1) returning the diesel generator to standby operation and (2) automatically energizing the emergency loads with offsite power.
- e. At least once per 10 years or after any modifications which could affect diesel generator interdependence by starting all diesel generators simultaneously*, during shutdown, and verifying that all diesel generators accelerate to at least 58.8 Hz in less than or equal to 13 seconds.
- f. At least once per 18 months, the following test shall be performed within 5 minutes of diesel shutdown after the diesel has operated for at least two hours at 2340-2600 kw**:

Verifying the diesel generator starts and achieves ≥ 3910 volts and ≥ 58.8 Hz in ≤ 13 seconds, and subsequently achieves steady state voltage of ≥ 3910 and ≤ 4400 volts and frequency of 60 ± 1.2 Hz.
- g. At least once per 18 months verifying the diesel generator operates for at least 24 hours*. During the first 2 hours of this test, the diesel generators shall be loaded to 2760-2860 Kw**. During the remaining 22 hours of this test, the diesel generator shall be loaded to 2500-2600 Kw**. The steady state voltage and frequency shall be maintained at ≥ 3910 and ≤ 4580 volts and 60 ± 1.2 Hz during this test.

4.8.1.1.3 The diesel fuel oil storage and transfer system shall be demonstrated OPERABLE:

- a. At least once per 31 days by:
 - 1. Verifying the level in each of the above required fuel storage tanks.
 - 2. Verifying that both fuel transfer pumps can be started and transfer fuel from the fuel storage tanks to the day tanks.

ELECTRICAL POWER SYSTEMS

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system (vital bus system), and
- b. Two separate and independent diesel generators with:
 1. Separate day tanks containing a minimum volume of 130 gallons of fuel, and
 2. A common fuel storage system containing a minimum volume of 23,000 gallons of fuel, and
 3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes until the minimum required A.C. electrical power sources are restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

-----NOTE-----
The following surveillances are not required to be performed to maintain operability during Modes 5 and 6. These surveillances are: 4.8.1.1.1.b, 4.8.1.1.2.d.2, 4.8.1.1.2.d.3, 4.8.1.1.2.d.4, 4.8.1.1.2.d.6, 4.8.1.1.2.d.9, 4.8.1.1.2.e, 4.8.1.1.2.f, and 4.8.1.1.2.g.

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the Surveillance Requirements of 4.8.1.1.1, 4.8.1.1.2, 4.8.1.1.3 (except for requirement 4.8.1.1.3.a.2) and 4.8.1.1.4.