

JANUARY 2 1980

Docket No. 50-220

DISTRIBUTION:

Docket LShao  
 NRC PDR SSheppard  
 Local PDR PPolk  
 ORB#3 Rdg OELD  
 NRR Rdg DVerrelli  
 HDenton OI&E (3)  
 ECase BJones (4)  
 RHartfield,MPA BScharf (10)  
 GBennington,MPA ACRS (16)  
 DEisenhut CMiles  
 RTedesco NSIC  
 RVoilmer TERA  
 BGrimes SECY  
 WGammill File  
 JMiller

Mr. Donald P. Dise  
 Vice President - Engineering  
 Niagara Mohawk Power Corporation  
 300 Erie Boulevard West  
 Syracuse, New York 13202

Dear Mr. Dise:

The Commission has issued the enclosed Show Cause Order for the Nine Mile Point Nuclear Station. Your submittals of October 18, November 26, and December 19, 1979, regarding implementation of the short-term lessons learned requirements indicate that you do not intend to implement some of the "Category A" requirements until after January 31, 1980. We have determined that implementation of the "Category A" requirements by January 31, 1980, is necessary to provide continued assurance of public health and safety.

The Show Cause Order requires that you implement, by January 31, 1980, the "Category A" requirements of NUREG-0578 regarding short-term lessons learned, as supplemented by our letters of September 13, and October 30, 1979; or show cause why you should not. Because this Order is immediately effective it also requires that the "Category A" requirements be implemented by January 31, 1980, or the plant be shut down. A provision regarding equipment availability problems is included.

In your submittals, you did indicate that many of the "Category A" requirements would be implemented by January 1, 1980. It is not the Commission's intent, in issuing this Order, to encourage delays in implementation of those "Category A" items you currently have scheduled to complete by January 1, 1980. Therefore, you should still submit, on or shortly after January 1, 1980, a description of the methods used to implement the "Category A" requirements completed by that time.

"Category B" lessons learned requirements, those scheduled for implementation by January 1, 1981, will be the subject of future correspondence.

A copy of this Order is being filed with the Office of the Federal Register for Publication.

Sincerely,

Original signed by

Harold R. Denton, Director  
 Office of Nuclear Reactor Regulation

8002010283 Cps

ORB#3  
 Tippo Mto  
 12/31/79

Enclosure:

OFFICE	Order to Show Cause	CE/IT	OELD	AtAD/ORP	AtD/DOR	D/NRR
SURNAME	PPolk:ar	DVerrelli	Hute	WGammill	DEisenhut	HDenton
DATE	12/31/79	12/31/79	12/2/79	12/3/79	12/2/79	12/2/79

Mr. Donald P. Dise  
Niagara Mohawk Power Corporation

- 2 -

cc:

Eugene B. Thomas, Jr., Esquire  
LeBoeuf, Lamb, Leiby & MacRae  
1757 N Street, N. W.  
Washington, D. C. 20036

Anthony Z. Roisman  
Natural Resources Defense Council  
917 15th Street, N. W.  
Washington, D. C. 20005

T. K. BeBoer, Director  
Technological Development Programs  
State of New York  
Energy Office  
Swan Street Building  
CORE 1 - Second Floor  
Empire State Plaza  
Albany, New York 12223

Mr. Robert P. Jones, Supervisor  
Town of Scriba  
R. D. #4  
Oswego, New York 13126

Niagara Mohawk Power Corporation  
ATTN: Mr. Thomas Perkins  
Plant Superintendent  
Nine Mile Point Plant  
300 Erie Boulevard West  
Syracuse, New York 13202

Director, Technical Assessment Division  
Office of Radiation Programs (AW 459)  
US EPA  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection Agency  
Region II Office  
ATTN: EIS COORDINATOR  
26 Federal Plaza  
New York, New York 10007

Oswego County Office Building  
46 E. Bridge Street  
Oswego, New York 13126

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
NIAGARA MOHAWK POWER CORPORATION ) Docket No. 50-220  
(Nine Mile Point Nuclear Station) )

ORDER TO SHOW CAUSE

I

The Niagara Mohawk Power Corporation (the Licensee) is the holder of Facility Operating License No. DPR-63 which authorizes the Licensee to operate the Nine Mile Point Nuclear Station at power levels not in excess of 1850 megawatts thermal (rated power). The facility is a boiling water reactor located at the Licensee's site in Oswego County, New York.

II

Following the Three Mile Island Unit 2 (TMI-2) accident on March 28, 1979, a TMI-2 Lessons Learned Task Force of the Nuclear Regulatory Commission (NRC) Staff conducted an intensive review of the design and operational aspects of nuclear power plants and the emergency procedures for coping with potential accidents. The Task Force identified measures to be taken in the short-term to reduce the likelihood of accidents and to improve emergency preparedness in responding to accidents. These measures are set forth in NUREG-0578, "TMI-2 Lessons Learned Task Force Status Report and Short-term Recommendations". The

8002010291

NRC has concluded that prompt implementation of the actions denominated "Category A" requirements at operating nuclear power plants is necessary to provide continued assurance of public health and safety. These "Category A" requirements were transmitted to all licensees operating nuclear power plants by letter dated September 13, 1979. By letter to affected licensees dated October 30, 1979, further clarification of these requirements was provided.

III

The Licensee has committed to implementation of each "Category A" requirement albeit not in all cases prior to January 31, 1980. NUREG-0578 and my letters of September 13 and October 30, 1979, which are hereby incorporated into this Order by reference, describe in detail the basis for implementing "Category A" requirements. The majority of licensees have committed to implement the "Category A" requirements by January 31, 1980 or the reactor will shutdown until such implementation is complete. However, other licensees have indicated that additional necessary equipment, which is on order, will be delivered after this date. Thirty days after delivery of equipment is a practical time period during which the equipment can be installed. Based on available information, all equipment should be delivered and capable of being installed by June 1, 1980. Licensees are required to meet the January 31, 1980 schedule unless they adequately demonstrate, in accordance with this Order, that delay based on equipment availability is justified. For reasons discussed, timely

implementation of these requirements is necessary to provide continued assurance of public health and safety. Requirements should be satisfied as soon as practicable and in no instance shall a licensee with incomplete "Category A" actions continue operation beyond June 1, 1980.

IV

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED THAT the Licensee show cause, in the manner hereinafter provided, why it should not:

By January 31, 1980, implement all "Category A" requirements (except the requirement of 2.1.7.a of NUREG-0578) referred to in Part II of this Order, except those for which necessary equipment is shown, by appropriate and timely documentary justification to the Director, Office of NRR, to be unavailable, or in the alternative, place and maintain its facilities in a cold shutdown or refueling mode of operation. "Category A" requirements not implemented by January 31, 1980, owing to the unavailability of necessary equipment shall be implemented within 30 days of the date such equipment becomes available but no later than June 1, 1980.

In view of the importance of the prompt implementation of "Category A" requirements to the health and safety of the public, I have determined that the public health, safety or interest requires that this Order be temporarily effective as of this date, pending further Order of the Commission.

V

The Licensee may file a written answer to this Order under oath or affirmation within twenty (20) days of the date of the Order. The Licensee or any other person whose interest may be affected by this Order may request a hearing within twenty (20) days of the date of the Order. Any request for a hearing will not stay the temporary effectiveness of this Order. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U. S. Nuclear Regulatory Commission, Washington, D. C., 20555. If a hearing is requested by a person whose interest may be affected by this Order, the Commission will issue an Order designating the time and place of any such hearing.

In light of the Licensee's expressed willingness to implement "Category A" requirements, except as indicated in Part III of this Order, in the event a hearing is requested, the issue to be considered at such hearing shall be: whether all "Category A" requirements (except the requirements of 2.1.7.a of NUREG-0578) should be implemented in accordance with the schedule prescribed by this Order.

Operation of the facility on terms consistent with this Order is not stayed by the pendency of any proceedings on the Order.

FOR THE NUCLEAR REGULATORY COMMISSION



Harold R. Denton, Director  
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland  
this 2 day of January, 1980