

May 2, 1985

Docket No. 50-220

Mr. B. G. Hooten
Executive Director, Nuclear Operations
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Dear Mr. Hooten:

<u>DISTRIBUTION:</u>	LHarmon
<u>Docket File</u>	ORB#2 Gray File
NRC PDR	ACRS (10)
Local PDR	RFerguson
ORB#2 Reading	EJordan
HThompson	JPartlow
DVassallo	BGrimes
SNorris	OELD
RHermann	TBarnhart (4)
WJones	DBrinkman
RDiggs	RBallard
OPA, CMiles	

On October 29, 1984, the Commission issued Amendment No. 65 to Facility Operating License No. DPR-63 for the Nine Mile Point Nuclear Station, Unit No. 1, which related to Section 6, Administrative Controls. Page 246 when issued failed to reflect the 2 hour grace period for the facility shift staffing compliment. The two hour grace period is addressed in the SE as well as contained on page 245 of the Technical Specifications. Enclosed is a corrected page 246.

On November 2, 1984, the Commission issued Amendment No. 66 relating to Radiological Environmental Technical Specifications and Administrative Controls. When issued, page 261 of Amendment No. 65 was inadvertently removed. Page 261a containing Section 6.9.1 b and c is enclosed for completeness.

We regret any inconvenience these changes may have created.

Sincerely,

Original signed by/

Robert A. Hermann, Project Manger
Operating Reactors Branch #2
Division of Licensing

Enclosures:
As stated

cc:
See next page

8505170615 850502
PDR ADDCK 05000220
P PDR

ORB#2:DL
SNorris:rc
05/2/85

ORB#2:DL
RHermann
05/8/85

ORB#2:DL
DVassallo
05/2/85

~~OELD~~
~~05/ /85~~

~~AD-OR:DL~~
~~GLainas~~
~~05/ /85~~

Mr. B. G. Hooten
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station, Unit No. 1

cc:

Troy B. Conner, Jr., Esquire
Conner & Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Frank R. Church, Supervisor
Town of Scriba
R. D. #2
Oswego, New York 13126

Niagara Mohawk Power Corporation
ATTN: Mr. Thomas Perkins
Plant Superintendent
Nine Mile Point Nuclear Station
Post Office Box 32
Lycoming, New York 13093

Resident Inspector
U. S. Nuclear Regulatory Commission
Post Office Box 126
Lycoming, New York 13093

John W. Keib, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Thomas A. Murley
Regional Administrator
Region I Office
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Jay Dunkleberger
Division of Policy Analysis
and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Facility Staff (Cont'd)

- e. A licensed Senior Reactor Operator shall be required in the Control Room during power operations and when the emergency plan is activated. This may be the Station Shift Supervisor - Nuclear or the Assistant Station Shift Supervisor - Nuclear during power operations. When the emergency plan is activated, the Assistant Station Shift Supervisor - Nuclear becomes the Shift Technical Advisor and the Station Shift Supervisor - Nuclear is restricted to the control room until an additional licensed Senior Reactor Operator arrives.
- f. A licensed Senior Reactor Operator shall be responsible for all movement of new and irradiated fuel within the site boundary. All core alterations shall be directly supervised by a licensed senior reactor operator who has no other concurrent responsibilities during this operation. A Licensed Operator will be required to manipulate the controls of all fuel handling equipment except movement of new fuel from receipt through dry storage. All fuel moves within the core shall be directly monitored by a member of the reactor analyst group.
- g. A Fire Brigade of five (5) members* shall be maintained on site as defined by 5.1 at all times.
- h. Administrative procedures shall be developed and implemented to limit the working hours of facility staff who perform safety-related functions; e.g., licensed Senior Operators, licensed Operators, health physicists, auxiliary operators and key maintenance personnel.

Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a normal 8-hour day, 40-hour week while the facility is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shutdown for refueling, major maintenance or major plant modifications on a temporary basis, the following guidelines shall be followed:

* The Radiation Protection qualified individual and Fire Brigade composition may be less than the minimum requirements for a period of time not to exceed two hours in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.

Amendment No. 65
Corrected

8505170621 850502
PDR ADOCK 05000220
P PDR

Facility Staff (Cont'd)

- e. A licensed Senior Reactor Operator shall be required in the Control Room during power operations and when the emergency plan is activated. This may be the Station Shift Supervisor - Nuclear or the Assistant Station Shift Supervisor - Nuclear during power operations. When the emergency plan is activated, the Assistant Station Shift Supervisor - Nuclear becomes the Shift Technical Advisor and the Station Shift Supervisor - Nuclear is restricted to the control room until an additional licensed Senior Reactor Operator arrives.
- f. A licensed Senior Reactor Operator shall be responsible for all movement of new and irradiated fuel within the site boundary. All core alterations shall be directly supervised by a licensed senior reactor operator who has no other concurrent responsibilities during this operation. A Licensed Operator will be required to manipulate the controls of all fuel handling equipment except movement of new fuel from receipt through dry storage. All fuel moves within the core shall be directly monitored by a member of the reactor analyst group.
- g. A Fire Brigade of five (5) members* shall be maintained on site as defined by 5.1 at all times.
- h. Administrative procedures shall be developed and implemented to limit the working hours of facility staff who perform safety-related functions; e.g., licensed Senior Operators, licensed Operators, health physicists, auxiliary operators and key maintenance personnel.

Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a normal 8-hour day, 40-hour week while the facility is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shutdown for refueling, major maintenance or major plant modifications on a temporary basis, the following guidelines shall be followed:

* The Radiation Protection qualified individual and Fire Brigade composition may be less than the minimum requirements for a period of time not to exceed two hours in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.

6.9.1 Routine Reports (Cont'd)

Startup reports shall be submitted within (1) 90 days following completion of the startup test program, (2) 90 days following resumption or commencement of commercial power operation, or (3) 9 months following initial criticality, whichever is earliest. If the Startup Report does not cover all three events (i.e., initial criticality, completion of startup test program, and resumption or commencement of commercial power operation), supplementary reports shall be submitted at least every three months until all three events have been completed.

- b. Annual Occupational Exposure Report. A tabulation shall be submitted on an annual basis which includes the number of station, utility and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man rem exposure according to work and job functions, 1/ e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling. The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totaling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions.
- c. Monthly Operating Report. Routine reports of operating statistics and shutdown experience including documentation of challenges to the safety relief valves or safety valves, shall be submitted on a monthly basis, which will include a narrative of operating experience, to the Director, Office of Management Information and Program Control, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the Regional Office of I&E, no later than the 15th of each month following the calendar month covered by the report.

1/ This tabulation supplements the requirements of 20.407 of 10 CFR Part 20.

6.9.1 Routine Reports (Cont'd)

Startup reports shall be submitted within (1) 90 days following completion of the startup test program, (2) 90 days following resumption or commencement of commercial power operation, or (3) 9 months following initial criticality, whichever is earliest. If the Startup Report does not cover all three events (i.e., initial criticality, completion of startup test program, and resumption or commencement of commercial power operation), supplementary reports shall be submitted at least every three months until all three events have been completed.

- b. Annual Occupational Exposure Report. A tabulation shall be submitted on an annual basis which includes the number of station, utility and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man rem exposure according to work and job functions, 1/ e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling. The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totaling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions.
- c. Monthly Operating Report. Routine reports of operating statistics and shutdown experience including documentation of challenges to the safety relief valves or safety valves, shall be submitted on a monthly basis, which will include a narrative of operating experience, to the Director, Office of Management Information and Program Control, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the Regional Office of I&E, no later than the 15th of each month following the calendar month covered by the report.

1/ This tabulation supplements the requirements of 20.407 of 10 CFR Part 20.