March 27, 1985

Docket No.: 50-220

and the second second

Mr. B. G. Hooten Executive Director, Nuclear Operations Niagara Mohawk Power Corporation 300 Erie Boulevard West Syracuse, New York 13202

Dear Mr. Hooten:

On February 19, 1985, the Commission issued Amendment No. 68 to Facility Operating License No. DPR-63 for the Nine Mile Point Nuclear Station, Unit No. 1. The Amendment revised Figure 6.2-1 (page 248) of the Technical Specifications. Our instructions erroneously indicated page 246 should be removed. Enclosed is Figure 6.2-1 (page 248) to replace the current page 248.

On February 27, 1985, the Commission issued Amendment No. 70 relating to reactor coolant leakage limits. When this Amendment was issued we failed to incorporate changes that were made by Amendment No. 66; therefore, we are reissuing the instruction page and page 4c of the Technical Specifications.

We are sorry for any inconvenience these changes may have created.

Sincerely,

Original signed by/

Robert A. Hermann, Project Manager Operating Reactors Branch #2 Division of Licensing

Enclosures: As stated

cc w/enclosures: See next page

DISTRIBUTION

Docket File	SNorris	BGrimes TRannhant (4)	OPA, CMiles
Local PDR	OELD	WJones	Gray File
ORB#2 Reading	LJHarmon	EButcher	Extra - 5
HThompson	ELJordan	ACRS (10)	JPartlow

ORB#2:DL	ORB#2:DL	ORB#22DL
SNorris/dn 3/ <i>22</i> /85	RHermann 3/27/85	DVassallo 3/2-7/85

ADDC

85032

Mr. B. G. Hooten Niagara Mohawk Power Corporation Nine Mile Point Nuclear Station, Unit No. 1

cc:

and the second strategies and the

Troy B. Conner, Jr., Esquire Conner & Wetterhahn Suite 1050 1747 Pennsylvania Avenue, N. W. Washington, D. C. 20006

Frank R. Church, Supervisor Town of Scriba R. D. #2 Oswego, New York 13126

Niagara Mohawk Power Corporation ATTN: Mr. Thomas Perkins Plant Superintendent Nine Mile Point Nuclear Station Post Office Box 32 Lycoming, New York 13093

Resident Inspector U. S. Nuclear Regulatory Commission Post Office Box 126 Lycoming, New York 13093

John W. Keib, Esquire Niagara Mohawk Power Corporation 300 Erie Boulevard West Syracuse, New York 13202 Thomas A. Murley Regional Administrator Region I Office U. S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406

Mr. Jay Dunkleberger Division of Policy Analysis and Planning New York State Energy Office Agency Building 2 Empire State Plaza Albany, New York 12223



•:

Amendment No. 68

248

,

ATTACHMENT TO LICENSE AMENDMENT NO. 70

FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise the Appendix A Technical Specifications by removing and inserting the following pages:

Existing Page	Revised Page	
4c	4c	
89	89	
	89a	
90	90	
91	91	

3

The revised areas are indicated by marginal lines.

: 1. «K

1.28 Ventilation Exhaust Treatment System

A ventilation exhaust treatment system is any system designed and installed to reduce gaseous radioiodine or radioactive material in particulate form in effluents by passing ventilation or vent exhaust gases through charcoal adsorbers and/or HEPA filters for the purpose of removing iodines or particulates from the gaseous exhaust stream prior to the release to the environment. Such a system is not considered to have any effect on noble gas effluents. Engineered Safety Feature (ESF) atmospheric cleanup systems are not considered to be ventilation exhaust treatment system components.

1.29 Venting

Venting is the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration, or other operating condition, in such a manner that replacement air or gas is not provided or required during venting. Vent, used in system names, does not imply a venting process.

1.30 Reactor Coolant Leakage

- a. Identified Leakage
 - (1) Leakage into closed systems, such as pump seal or valve packing leaks that are captured, flow metered and conducted to a sump or collecting tank. or
 - (2) Leakage into the primary containment atmosphere from sources that are both specifically located and known not to be from a through-wall crack in the piping within the reactor coolant pressure boundary.

b. Unidentified Leakage

All other leakage of reactor coolant into the primary containment area.

4c