

**PNPS
TABLE 4.2.F (Cont)**

MINIMUM TEST AND CALIBRATION FREQUENCY FOR SURVEILLANCE INSTRUMENTATION

<u>Instrument Channel</u>	<u>Calibration Frequency</u>	<u>Instrument Check</u>
13) Torus Water Level (Wide Range)	Each refueling outage	Once every 30 days
14) Containment Pressure	Each refueling outage	Once every 30 days
15) Containment High Radiation Monitor	Once/Operating Cycle	Once every 30 days
16) Reactor Building Vent Radiation Monitor	Once/Operating Cycle	Once every 30 days
17) Main Stack Vent Radiation Monitor	Once/Operating Cycle	Once every 30 days
18) Turbine Building Vent Radiation Monitor	Once/Operating Cycle	Once every 30 days