## **Assessment of Human Errors**

An assessment was performed for the DOE Savannah River Site to quantify human errors, "Savannah River Site Human Error Data Base Development for Nonreactor Nuclear Facilities," Westinghouse Savannah River Co., WSRC-TR-93-581, February 28. 1994. This data base includes models and quantification for 35 representative human errors.

Results of the DOE survey indicated that two main human reliability analysis (HRA) models are typically used to quantify human error:

- THERP Technique for Human Error Rate Prediction (Ref.: *Handbook of Human Reliability Analysis with Emphasis on Nuclear Power Plant Applications*, A.D. Swain and H.E. Guttmann, NUREG/CR-1278, August 1983.
- ASEP Accident Sequence Evaluation Program Human Reliability Analysis Procedure, Martin Marietta Energy Systems, Inc., ES/CSET-16, May 1993.

In addition, several other human reliability models have been used:

- HCR Human Cognitive Model for PRA Analysis (draft), NUS Corporation, NUS-4531, December 1984.
- INTENT "INTENT: A method for estimating human error probabilities for discisionbased errors," *Reliability Engineering and System Safety*, 35, 1992, pp. 127-138.

Actual national or regional data for transportation accidents and expert judgment elicitations (based on T.A. Wheeler, et al., *Analysis of Core Damage Frequency from Internal Events: Expert Judgment Elicitation*, NUREG/CR-4450, Vol. 2, 1989) have also been used to quantify human errors.

Guidelines for selecting error factors (EFs), the 95<sup>th</sup> percentile divided by the 50<sup>th</sup> percentile, based on a assumed lognormal distribution are summarized in a Table 1.

Human error mean failure probability (P)	Suggested error factor (EF)
0.0 < P < 0.01	10
0.01 ≤ P < 0.1	5
0.1 ≤ P ≤ 0.3	3
0.3 < P ≤ 0.5	2

Table 1 - Guidelines for selection of EFs

0.5 < P ≤ 1.0	1	
		L

The human error events listed in Table 2 may be considered to be applicable to this riskinformed evaluation. (Recommended cross-reference scheme examples are: 1N, 3H or 10L.)

Human error event		Туре	Failure probability e or rate		Notes
			Mean	EF	
1.	1. Failure of administrative control (Failure to follow a policy or procedure)	Nominal	0.01	5	Typical circumstances
		High	0.1	3	Unusual circumstances
		Low	0.001	10	Routine, repetitive
2.	Failure to respond	Nominal	0.01	5	Several competing signals
	to compelling signal	High	0.1	3	Many competing signals
		Low	0.003	10	Few competing signals
3.	3. Failure to verify	Nominal	0.01	5	Good layout, procedures
	inside control room (Commission and	High	0.05	5	Poor layout, procedures
	omission)	Low	0.003	10	Excellent layout, procedures
4.	4. Failure to verify	Nominal	0.03	5	Good layout, procedures
outsid (Com omiss	outside control room (Commission and	High	0.1	3	Poor layout, procedures
	omission)	Low	0.01	5	Excellent layout, procedures
5.	5. Error in selecting control inside control room (Commission and omission)	Nominal	0.01	5	Good layout, procedures
		High	0.03	5	Poor layout, procedures
		Low	0.001	10	Excellent layout, procedures
6.	Error in selecting	Nominal	0.01	5	Good layout, procedures
	outside control room	High	0.05	5	Poor layout, procedures
	(Commission and omission)	Low	0.003	10	Excellent layout, procedures

Table 2 - Recommended human error probabilities and rates

Human error event		Failure prol Type or rat		bability te	Notes
			Mean	EF	
7. Cor	nmunication	Nominal	0.05	5	Moderate information
erro	or	High	0.5	2	Complex information
		Low	0.001	10	Simple information
8. Fail	ure to restore	Nominal	0.01	5	Single-person, operator check
follo	owing test	High	0.03	5	Single-person, no check
		Low	0.005	10	Two-person team, operator check
9. Fail	ure to restore	Nominal	0.01	5	Single-person, operator check
follo mai	owing intenance	High	0.1	3	Single-person, no check
		Low	0.005	10	Two-person team, operator check
10. Rai	ndom actuation	Nominal	1x10⁻⁵/hr	10	Some activities could affect system
or shutdown of system	shutdown of stem	High	1x10⁴ /hr	10	Many activities could affect system
		Low	1x10⁻⁵ /hr	10	Almost no activities affect system
11. Diagnosis error,	Nominal	0.01	5	30 to 120 minutes	
Kno	(nowledge-based	High	0.1	3	10 to 30 minutes
		Low	0.001	10	> 120 minutes
12. Fai	lure of visual	Nominal	0.1	3	Procedure, easy to observe
inspection to observe abnormal	pection to serve abnormal	High	0.5	2	Difficult to observe
cha	characteristics	Low	0.01	5	Procedure, very easy to observe
13. Inc	Incorrect reading or	Nominal	0.01	5	Good display
recordir	ording of data	High	0.5	2	Poor display
		Low	0.003	10	Excellent display
14. Mis	scalibration	Nominal	0.01	5	Single-person, operator check
		High	0.05	5	Single-person, no check
		Low	0.005	10	Two-person team, operator check

Human error event		Туре	Failure probability or rate		Notes
			Mean	EF	
15. Fai	Failure to verify	Nominal	0.03	5	Procedure usually used
	parameter with calculation	High	0.1	3	No verification
		Low	0.005	10	Procedure mostly used
16.	Failure of manual	Nominal	0.1	3	Area occupied 80% of time
	fire detection	High	0.5	2	Area unoccupied
		Low	0.05	5	Area occupied 100% of time
17.	Failure of manual	Nominal	0.1	3	Typical fire extinguisher
- - - -	fire suppression by occupant	High	0.5	2	Poor fire extinguisher
		Low	0.05	5	Excellent fire extinguisher
18.	Failure of manual fir suppression by non-occupant	Nominal	0.5	2	10 minute response time
		High	1.0	1	> 10 minute response time
		Low	0.1	3	< 10 minute response time
19.	Failure of long-term accident recovery	Nominal	0.003	10	24 to 48 hours to recover
		High	0.1	3	< 24 hours to recover
		Low	3x10⁻⁵	10	3 to 7 days to recover
20.	TBD	Nominal			
		High			
		Low			
21.	TBD	Nominal			
		High			
		Low	-		
22.	TBD	Nominal			
		High			

----

**-**..

Human error event	Туре	Failure probability or rate		Notes
		Mean	EF	
	Low			
23. TBD	Nominal			
	High			
	Low			