

From: Goutam Bagchi *NRN*
To: Glenn Kelly *NRN*
Date: Wednesday, July 12, 2000 08:21 AM
Subject: Revision:Seismic Risk: Spent Fuel Pool Failures at 69 Sites

Glenn,

The distribution of the subject risk numbers is as follows:

All risk numbers are for spent fuel pool failure mat the screening level of 1.2 g peak spectral acceleration (0.5 g peak ground acceleration) per year.

34 sites: $> 10E-6$

9 sites: between $1x10E-6$ and $1.25X10E-6$

11 sites: between $1.3X10E-6$ and $1.8X10E-6$

7 sites: between $2.2X10E-6$ and $2.8X10E-6$

4 sites: between $4.1X10E-6$ and $4.5X10E-6$

4 sites: between 5.5 and $13.6X10E-6$

Total = 69 sites

In the last batch of 4 sites with risk above $4.5X10E-6$, only 3 sites are currently operating and they are Pilgrim, H. B. Robinson and Vogtle.

Thank you,
Goutam
301-415-3305

Thank you,
Goutam
301-415-3305

CC: Diane Jackson, George Hubbard, Jack Strosnider, ...

B1294