8/23/2000

Meeting with NEI on SFP Seismic

B. Kennedy If meet check list rigerously, HCLPF capacity at least 1.2g PSA. ⇒ have (to have) at least twice SSE to reach the point where capacity is threatened.

Application - NEI

B/325