

April 17, 2001

Mr. Gregg R. Overbeck
Senior Vice President, Nuclear
Arizona Public Service Company
P. O. Box 52034
Phoenix, AZ 85072-2034

SUBJECT: PALO VERDE NUCLEAR GENERATING STATION, UNITS 1, 2, AND 3 -
ISSUANCE OF AMENDMENTS TO CHANGING THE MINIMUM DEPARTURE
OF THE NUCLEATE BOILING RATIO (TAC NOS. MB0745, MB0746, AND
MB0747)

Dear Mr. Overbeck:

In its letter dated March 28, 2001, the Commission issued Amendment No. 133 to Facility Operating License Nos. NPF-41, NPF-51, and NPF-74 for the Palo Verde Nuclear Generating Station, Units 1, 2, and 3, respectively. The amendments consisted of changes to the Technical Specifications (TSs) in response to your application dated December 1, 2000 (102-04506). The amendments changed the minimum departure from nucleate boiling ratio (DNBR) to " ≥ 1.3 (through operating cycle 10)" and " ≥ 1.34 (operating cycle 11 and later)" in TS 2.1.1.1 and in function 15, DNBR - Low, in TS Table 3.3.1-1, "Reactor Protective System Instrumentation." The amendments are structured such that the " ≥ 1.34 " would become effective for each unit in operating cycle 11 and later.

Copies of pages 2.0-1, 2.0-2, and 3.3.1-10 of the TSs, which were changed in the amendment, were enclosed in the letter dated March 28, 2001; however, in enclosing these pages, Amendment No. 133 was inadvertently listed three times in the lower-right-hand corner of the pages. Enclosed are corrected pages which have the amendment number listed only once on each page.

Sincerely,

/RA/

Jack N. Donohew, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-528, STN 50-529,
and STN 50-530

Enclosure: Corrected TS Pages 2.0-1, 2.0-2, and 3.3.1-10

cc w/encl: See next page

Mr. Gregg R. Overbeck
Senior Vice President, Nuclear
Arizona Public Service Company
P. O. Box 52034
Phoenix, AZ 85072-2034

April 17, 2001

SUBJECT: PALO VERDE NUCLEAR GENERATING STATION, UNITS 1, 2, AND 3 - ISSUANCE OF AMENDMENTS TO CHANGING THE MINIMUM DEPARTURE OF THE NUCLEATE BOILING RATIO (TAC NOS. MB0745, MB0746, AND MB0747)

Dear Mr. Overbeck:

In its letter dated March 28, 2001, the Commission issued Amendment No. 133 to Facility Operating License Nos. NPF-41, NPF-51, and NPF-74 for the Palo Verde Nuclear Generating Station, Units 1, 2, and 3, respectively. The amendments consisted of changes to the Technical Specifications (TSs) in response to your application dated December 1, 2000 (102-04506). The amendments changed the minimum departure from nucleate boiling ratio (DNBR) to " ≥ 1.3 (through operating cycle 10)" and " ≥ 1.34 (operating cycle 11 and later)" in TS 2.1.1.1 and in function 15, DNBR - Low, in TS Table 3.3.1-1, "Reactor Protective System Instrumentation." The amendments are structured such that the " ≥ 1.34 " would become effective for each unit in operating cycle 11 and later.

Copies of pages 2.0-1, 2.0-2, and 3.3.1-10 of the TSs, which were changed in the amendment, were enclosed in the letter dated March 28, 2001; however, in enclosing these pages, Amendment No. 133 was inadvertently listed three times in the lower-right-hand corner of the pages. Enclosed are corrected pages which have the amendment number listed only once on each page.

Sincerely,

/RA/

Jack N. Donohew, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-528, STN 50-529,
and STN 50-530

Enclosure: Corrected TS Pages 2.0-1, 2.0-2, and 3.3.1-10

cc w/encls: See next page

DISTRIBUTION:

PUBLIC

RidsNrrDlpmLpdiv (S.Richards)

RidsAcrsAcnwMailCenter

RidsRgn4MailCenter (LSmith/LHurley/DBujol/KBrockman)

PDIV-2 r/f

RidsNrrPMJDonohew RidsNrrLAMMcAllister

RidsOgcRp

G. Hill (6)

WBeckner (RidsNrrDripRtsb)

PACKAGE: ML01170086

ENCLOSURE: ML011070409

ADAMS ACCESSION NO: ML01170064

* Not Required

OFFICE	PDIV-2/PM	PDIV-D/LA	PDIV-2/SC	PDIV-D*
NAME	JDonohew:am	MMcAllister	SDembek	SRichards
DATE	4/16/2001	4/16/01	4/16/01	SD

OFFICIAL RECORD COPY

Palo Verde Generating Station, Units 1, 2, and 3

cc:

Mr. Steve Olea
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, AZ 85007

Douglas Kent Porter
Senior Counsel
Southern California Edison Company
Law Department, Generation Resources
P.O. Box 800
Rosemead, CA 91770

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 40
Buckeye, AZ 85326

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavillion
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Chairman
Maricopa County Board of Supervisors
301 W. Jefferson, 10th Floor
Phoenix, AZ 85003

Mr. Aubrey V. Godwin, Director

Arizona Radiation Regulatory Agency
4814 South 40 Street
Phoenix, AZ 85040

Mr. Craig K. Seaman, Director
Regulatory Affairs
Arizona Public Service Company
P.O. Box 52034
Phoenix, AZ 85072-2034

Mr. John C. Horne
Vice President, Power Generation
El Paso Electric Company
2702 N. Third Street, Suite 3040
Phoenix, AZ 85004

Mr. David Summers
Public Service Company of New Mexico
414 Silver SW, #1206
Albuquerque, NM 87102

Mr. Jarlath Curran
Southern California Edison Company
5000 Pacific Coast Hwy Bldg DIN
San Clemente, CA 92672

Mr. Robert Henry
Salt River Project
6504 East Thomas Road

Scottsdale, AZ 85251

Terry Bassham, Esq.
General Counsel
El Paso Electric Company
123 W. Mills
El Paso, TX 79901

Mr. John Schumann
Los Angeles Department of Water & Power
Southern California Public Power Authority
P.O. Box 51111, Room 1255-C
Los Angeles, CA 90051-0100