2.0 SAFETY LIMITS (SLs)

2.1 SLs

- 2.1.1 Reactor Core SLs
 - 2.1.1.1 In MODES 1 and 2. Departure from Nucleate Boiling Ratio (DNBR) shall be maintained as follows:
 - \geq 1.3 (through operating cycle 10)
 - \geq 1.34 (operating cycle 11 and later)
 - 2.1.1.2 In MODES 1 and 2, the peak Linear Heat Rate (LHR) (adjusted for fuel rod dynamics) shall be maintained at \leq 21.0 kW/ft.
- 2.1.2 Reactor Coolant System (RCS) Pressure SL

In MODES 1, 2, 3, 4, and 5, the RCS pressure shall be maintained at \leq 2750 psia.

- 2.2 SL Violations
 - 2.2.1 If SL 2.1.1.1 or SL 2.1.1.2 is violated, restore compliance and be in MODE 3 within 1 hour.
 - 2.2.2 If SL 2.1.2 is violated:
 - 2.2.2.1 In MODE 1 or 2, restore compliance and be in MODE 3 within 1 hour.
 - 2.2.2.2 In MODE 3, 4, or 5, restore compliance within 5 minutes.
 - 2.2.3 Within 1 hour, notify the NRC Operations Center, in accordance with 10 CFR 50.72.
 - 2.2.4 Within 24 hours, notify the Director. Operations and Vice President. Nuclear Production.

(continued)

PALO VERDE UNITS 1,2,3	2.0-1	AMENDMENT NO. 117-133

SLs 2.0 .

.5

• ...

- 2.2.5 Within 30 days of the violation, a Licensee Event Report (LER) shall be prepared pursuant to 10 CFR 50.73. The LER shall be submitted to the NRC and the Director. Operations and Vice President, Nuclear Production.
- 2.2.6 Operation of the unit shall not be resumed until authorized by the $_{\mbox{NRC.}}$

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
14. Local Power Density - High(b)	1.2	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.3 SR 3.3.1.4 SR 3.3.1.5 SR 3.3.1.5 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.11 SR 3.3.1.12 SR 3.3.1.13	≤ 21.0 kW/ft
15. Departure From Nucleate Boiling Ratio (DNBR) - Low(D)	1.2	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.3 SR 3.3.1.4 SR 3.3.1.5 SR 3.3.1.5 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.11 SR 3.3.1.12 SR 3.3.1.13	<pre>≥ 1.3 (through operating cycle 10) ≥ 1.34 (operating cycle 11 and later)</pre>

Table 3.3.1-1 (page 3 of 3) Reactor Protective System Instrumentation

(b) Trip may be bypassed when logarithmic power is < 1E-4% NRTP. Bypass shall be automatically removed when logarithmic power is ≥ 1E-4% NRTP.

PALO VERDE UNITS 1,2,3

• :

.

•

3.3.1-10 AMENDMENT NO. 117, 119-133