



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

April 15, 1992

Docket No. 50-220

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13211

Dear Mr. Sylvia:

SUBJECT: CORRECTED PAGE FOR NINE MILE POINT UNIT NO. 1 LICENSE AMENDMENT
NO. 127 (TAC NO. M80394)

By letter dated May 13, 1991, Niagara Mohawk Power Corporation (NMPC) submitted a license amendment request for Nine Mile Point Unit No. 1. The proposed license amendment included a revised page 80c of the Nine Mile Point Unit 1 Technical Specifications. The revised page 80c was issued on February 10, 1992, as part of License Amendment No. 127 without the typographical error being detected. Your staff subsequently detected this error. A corrected page 80c, a copy of which is enclosed, was then provided by your letter of April 6, 1992. The enclosed page 80c should be used to replace the technical specification page 80c that was issued on February 10, 1992, as part of License Amendment No. 127 to Nine Mile Point Unit No. 1 Operating License DPR-63.

Sincerely,

Donald S. Brinkman

Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
Nine Mile Point Unit 1
Technical Specification Page 80c

cc w/enclosure:
See next page

9204280442 920415
PDR ADOCK 05000220
P PDR

*DF01
11*

*CP
ell*

Mr. B. Ralph Sylvia
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit No. 1

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Mr. Kim Dahlberg
Unit 1 Station Superintendent
Nine Mile Point Nuclear Station
Post Office Box 32
Lycoming, New York 13093

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, New York 13126

Mr. David K. Greene
Manager Licensing
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Mr. Joseph F. Firlit
Vice President - Nuclear Generation
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
Post Office Box 32
Lycoming, New York 13093

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 126
Lycoming, New York 13093

Mr. Paul D. Eddy
State of New York
Department of Public Service
Power Division, System Operations
3 Empire State Plaza
Albany, New York 12223

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

April 15, 1992

Docket No. 50-220

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13211

Dear Mr. Sylvia:

By letter dated May 13, 1991, Niagara Mohawk Power Corporation (NMPC) submitted a license amendment request for Nine Mile Point Unit No. 1. The proposed license amendment included a revised page 80c of the Nine Mile Point Unit 1 Technical Specifications. The revised page 80c was issued on February 10, 1992, as part of License Amendment No. 127 without the typographical error being detected. Your staff subsequently detected this error. A corrected page 80c, a copy of which is enclosed, was then provided by your letter of April 6, 1992. The enclosed page 80c should be used to replace the technical specification page 80c that was issued on February 10, 1992, as part of License Amendment No. 127 to Nine Mile Point Unit No. 1 Operating License DPR-63.

Sincerely,

Original Signed By

Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
Nine Mile Point Unit 1
Technical Specification Page 80c
cc w/enclosure:
See next page

OFFICE	PDI-1:LA	PDI-1:PM <i>AJB</i>	PDI-1:D		
NAME	CVogan <i>CV</i>	DBrinkman:avl	RACapra <i>ROC</i>		
DATE	<i>4/14/92</i>	<i>4/14/92</i>	<i>4/15/92</i>	<i>/ /</i>	<i>/ /</i>

OFFICIAL RECORD COPY
FILENAME:A:\NMP80394.LTR

DATED: April 15, 1992

AMENDMENT NO. 127 TO FACILITY OPERATING LICENSE NO. DPR-63-NINE MILE POINT
UNIT 1

Docket File

NRC & Local PDRs

PDI-1 Reading

S. Varga, 14/E/4

J. Calvo, 14/A/4

R. Capra

C. Vogan

D. Brinkman

J. Wiggins, 7/D/4

T. Tsao, 7/D/4

OGC-WF

D. Hagan, 3302 MNBB

G. Hill (4), P-137

Wanda Jones, P-130A

C. Grimes, 11/F/23

ACRS (10)

OPA

OC/LFMB

C. Cowgill, Region I

cc: Plant Service list

LIMIT FOR POWER OPERATION (CORE CRITICAL)
COOLDOWN AT UP TO 100F/HR

<u>REACTOR PRESSURE (psig)</u> <u>IN TOP DOME</u>	<u>REACTOR VESSEL BELTLINE</u> <u>DOWNCOMER WATER</u> <u>TEMPERATURE (F)</u>
202	100
210	110
222	120
235	130
250	140
268	150
288	160
312	170
340	180
360	190
360	200
360	210
360	220
558	230
624	240
701	250
784	260
868	270
953	280
1049	290
1161	300
1289	310
1437	320

TABLE 3.2.2.d

**MINIMUM TEMPERATURE FOR PRESSURIZATION DURING
COOLDOWN (REACTOR CRITICAL) (COOLING RATE \leq 100F/HR)
FOR UP TO 18 EFFECTIVE FULL POWER YEARS OF CORE OPERATION**

(reactor vessel beltline downcomer water temperature
is measured at recirculation loop suction)