

July 10, 1989

Mr. Lawrence Burkhardt III
Executive Vice President, Nuclear Operations
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Dear Mr. Burkhardt:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 69201)

DISTRIBUTION

Docket file	NRC PDR
PDI-1 Rdg	Local PDR
SVarga	BBoger
RCapra	CVogan
VMcCree	MSlosson
RBenedict	OGC
TDunning	DHagan
EJordan	BGrimes
TMeek (4)	WJones
JCalvo	ACRS (10)
GPA/PA	ARM/LFMB
JWiggins, RI	

The Commission has issued the enclosed Amendment No. 108 to Facility Operating License No. DPR-63 for the Nine Mile Point Nuclear Station Unit No. 1 (NMP-1). The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated June 3, 1988, as amended by letters dated September 28 and November 15, 1988.

This amendment deletes Figure 6.2-1 "Management Organizational Chart," and Figure 6.2-2 "Nuclear Site Organization," in accordance with Generic Letter 88-06, "Removal of Organization Charts From Technical Specifications." Administrative changes to Sections 6.1, 6.2, 6.5, 6.6, and 6.7 are included and Specification 6.9 is being revised to make the Unit 1 Specifications consistent with 10 CFR 50.4. By letter dated November 15, 1988, the licensee amended the amendment application to propose additional administrative changes to the Specifications. These changes reflect the creation of the position of Executive Vice President-Nuclear Operations. This title replaces all current references to Senior Vice President in the Specifications.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

Original signed by

Marylee M. Slosson, Project Manager
Project Directorate I-1
Division of Reactor Projects, I/II

Enclosures:

1. Amendment No. 108 to DPR-63
2. Safety Evaluation

cc: w/enclosures
See next page

changes incorporated - MS 7/7/89
C/P/

[AMEND 220 TAC 69201]

OFC	:PDI-1	:PDI-1	:PDI-1	:OGC	:PDI-1	:	:
NAME	:CVogan	:VMcCree	:MSlosson	:NRomney	:RCapra	:	:
DATE	: 6/8/89	: 6/9/89	: 6/9/89	: 6/26/89	: 7/10/89	:	:

8907180448 890710
FOR ADDCK 05000220
P PIC

SUBJECT TO
OFFICIAL RECORD COPY
CHANGES -
SEE NOTE

DF01
11

Mr. L. Burkhardt III
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station,
Unit No. 1

cc:

Mr. Troy R. Conner, Jr., Esquire
Conner & Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Mr. Kim Dahlberg
Unit 1 Station Superintendent
Nine Mile Point Nuclear Station
Post Office Box 32
Lycoming, New York 13093

Mr. Frank R. Church, Supervisor
Town of Scriba
R. D. #2
Oswego, New York 13126

Mr. Peter E. Francisco, Licensing
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Mr. James L. Willis
General Supt.-Nuclear Generation
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
Post Office Box 32
Lycoming, New York 13093

Charlie Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Resident Inspector
U. S. Nuclear Regulatory Commission
Post Office Box 126
Lycoming, New York 13093

Mr. Paul D. Eddy
State of New York
Department of Public Service
Power Division, System Operations
3 Empire State Plaza
Albany, New York 12223

Mr. Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220

NINE MILE POINT NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 108
License No. DPR-63


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated June 3, 1988, as amended September 28 and November 15, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-63 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 108, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance, to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects, I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 10, 1989

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 108 TO FACILITY OPERATING LICENSE NO. DPR-63

DOCKET NO. 50-220

Revise Appendix A as follows:

Remove Pages

245
--
247
248
249
252
253
254
255
258
259
260
261
261a
265
266

Insert Pages

245
245a
247
248
249
252
253
254
255
258
259
260
261
261a
265
266

6.0 ADMINISTRATIVE CONTROLS

6.1 Responsibility

- 6.1.1 The General Superintendent - Nuclear Generation shall be responsible for overall unit operation and shall delegate in writing the succession to this responsibility during his absence.
- 6.1.2 The Station Shift Supervisor - Nuclear (or during his absence from the control room, a designated individual) shall be responsible for the control room command function. A management directive to this effect, signed by the Executive Vice President - Nuclear Operations shall be re-issued to station personnel on an annual basis.

6.2 Organization

Onsite and Offsite Organization

- 6.2.1 An onsite and an offsite organization shall be established for unit operation and corporate management. The onsite and offsite organization shall include the positions for activities affecting the safety of the nuclear power plant.
 - a. Lines of authority, responsibility and communication shall be established and defined from the highest management levels through intermediate levels to and including all operating organization positions. Those relationships shall be documented and updated, as appropriate, in the form of organization charts, functional descriptions of departmental responsibilities and relationships, and job descriptions for key personnel positions or in equivalent forms of documentation. The organization charts shall be documented in the Final Safety Analysis Report, and the functional descriptions of departmental responsibilities and relationships and job descriptions for key personnel positions are documented in procedures.
 - b. The Executive Vice President - Nuclear Operations shall have corporate responsibility for overall plant nuclear safety. The Executive Vice President - Nuclear Operations shall take any measures needed to assure acceptable performance of the staff in operating, maintaining, and providing technical support in the plant so that continued nuclear safety is assured.
 - c. The General Superintendent - Nuclear Generation shall have responsibility for overall unit operation and shall have control over those resources necessary for safe operation and maintenance of the plant.

Onsite and Offsite Organization (Cont'd)

- d. The persons responsible for the training, health physics and quality assurance functions may report to an appropriate manager onsite, but shall have direct access to responsible corporate management at a level where action appropriate to the mitigation of training, health physics and quality assurance concerns can be accomplished.

Facility Staff

6.2.2 The unit organization shall be subject to the following:

- a. Each on-duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1.
- b. At least one licensed Operator shall be in the control room when fuel is in the reactor. During reactor operation, this licensed operator shall be present at the controls of the facility.
- c. At least two licensed Operators shall be present in the control room during reactor start-up, scheduled reactor shutdown and during recovery from reactor trips.
- d. An individual qualified in radiation protection* procedures shall be on site when fuel is in the reactor.

* The Radiation Protection qualified individual and Fire Brigade composition may be less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.

Facility Staff (Cont'd)

- 1) An individual should not be permitted to work more than 16 hours straight (excluding shift turnover time).
- 2) An individual should not be permitted to work more than 16 hours in any 24-hour period, nor more than 24 hours in any 48-hour period, nor more than 72 hours in any 7 day period (all excluding shift turnover time).
- 3) A break of at least 8-hours should be allowed between work periods (including shift turnover time).
- 4) Except during extended shutdown periods, the use of overtime should be considered on an individual basis and not for the entire staff on a shift.

Any deviation from the above guidelines shall be authorized by the Plant Superintendent, or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation. Controls shall be included in the procedures such that individual overtime shall be reviewed monthly by the General Superintendent - Nuclear Generation or designee to assure that excessive hours have not been assigned. Routine deviation from the above guidelines is not authorized.

- i. The Superintendent Operations Nuclear, Assistant Superintendent Operations Nuclear, Station Shift Supervisor Nuclear and Assistant Station Shift Supervisor Nuclear shall hold senior reactor operator licenses.

FIGURE DELETED

FIGURE DELETED

Alternates

- 6.5.1.3 Alternate members shall be appointed in writing by the SORC Chairman to serve on a temporary basis; however, no more than two alternates shall participate in SORC activities at any one time.

Meeting Frequency

- 6.5.1.4 The SORC shall meet at least once per calendar month and as convened by the SORC Chairman.

Quorum

- 6.5.1.5 A quorum of the SORC shall consist of the Chairman and four members including alternates.

Responsibilities

- 6.5.1.6 The Site Operations Review Committee shall be responsible for:
- a. Review of all REPORTABLE EVENTS.
 - b. Review of unit operations to detect potential safety hazards.
 - c. Performance of special reviews investigations or analyses and reports thereon as requested by the Chairman of the Safety Review and Audit Board.
 - d. Investigation of violations of the Technical Specifications and shall prepare and forward a report covering evaluation and recommendations to prevent recurrence to the Executive Vice President - Nuclear Operations and to the Safety Review and Audit Board.

Authority

- 6.5.1.7 The Site Operations Review Committee shall:
- a. Render determinations in writing with regard to whether or not each item considered under 6.5.1.6 (a) through (d) above constitutes an unreviewed safety question.
 - b. Provide immediate written notification to the Executive Vice President - Nuclear Operations and the Safety Review and Audit Board of disagreement between the SORC and the General Superintendent - Nuclear Generation; however, the General Superintendent - Nuclear Generation shall have the responsibility for resolution of such disagreements pursuant to 6.1.1 above.

Records

- 6.5.1.8 The Site Operations Review Committee shall maintain written minutes of each meeting and copies shall be provided to the Executive Vice President - Nuclear Operations and the Safety Review and Audit Board.

6.5.2 Technical Review and Control

Activities

- 6.5.2.1 Each procedure and program required by Specification 6.8 and other procedures which affect nuclear safety, and changes thereto, shall be prepared by a qualified individual/organization. Each such procedure, and changes thereto, shall be reviewed by an individual/group other than the individual/group which prepared the procedure, or changes thereto, but who may be from the same organization as the individual/group which prepared the procedure, or changes thereto. Approval of procedures and programs and changes thereto and their safety evaluations, shall be controlled by administrative procedures.
- 6.5.2.2 Proposed changes to the Technical Specifications shall be prepared by a qualified individual/organization. The preparation of each proposed Technical Specifications change shall be reviewed by an individual/group other than the individual/group which prepared the proposed change, but who may be from the same organization as the individual/group which prepared the proposed change. Proposed changes to the Technical Specifications shall be approved by the General Superintendent-Nuclear Generation.

Activities (Cont'd)

- 6.5.2.3 Proposed modifications to unit structures, systems and components that affect nuclear safety shall be designed by a qualified individual/organization. Each such modification shall be reviewed by an individual/group other than the individual/group which designed the modification, but who may be from the same organization as the individual/group which designed the modification. Proposed modifications to structures, systems and components and the safety evaluations shall be approved prior to implementation by the General Superintendent-Nuclear Generation; or the Station Superintendent-Nuclear Generation; or the Technical Superintendent-Nuclear Generation as previously designated by the General Superintendent-Nuclear Generation.
- 6.5.2.4 Individuals responsible for reviews performed in accordance with Specifications 6.5.2.1, 6.5.2.2 and 6.5.2.3 shall be members of the station supervisory staff, previously designated by the General Superintendent-Nuclear Generation to perform such reviews. Each such review shall include a determination of whether or not additional, cross-disciplinary, review is necessary. If deemed necessary such review shall be performed by the appropriate designated station review personnel.
- 6.5.2.5 Proposed tests and experiments which affect station nuclear safety and are not addressed in the FSAR or Technical Specifications and their safety evaluations shall be reviewed by the General Superintendent-Nuclear Generation; or by the Station Superintendent-Nuclear Generation, or the Technical Superintendent-Nuclear Generation as previously designated by the General Superintendent-Nuclear Generation.
- 6.5.2.6 The General Superintendent-Nuclear Generation shall assure the performance of special reviews and investigations, and the preparation and submittal of reports thereon, as requested by the Executive Vice President - Nuclear Operations.
- 6.5.2.7 The facility security program, and implementing procedures, shall be reviewed at least every 12 months. Recommended changes shall be approved by the General Superintendent-Nuclear Generation and transmitted to the Executive Vice President - Nuclear Operations, and to the Chairman of the Safety Review and Audit Board.
- 6.5.2.8 The facility emergency plan, and implementing procedures shall be reviewed at least every 12 months. Recommended changes shall be approved by the General Superintendent-Nuclear Generation and transmitted to the Executive Vice President - Nuclear Operations and to the Chairman of the Safety Review and Audit Board.

Activities (Cont'd)

- 6.5.2.9 The General Superintendent-Nuclear Generation shall assure the performance of a review by a qualified individual/organization of changes to the Radiological Waste Treatment systems.
- 6.5.2.10 Review of any accidental, unplanned, or uncontrolled radioactive release including the preparation of reports covering evaluation, recommendations and disposition of the corrective action to prevent recurrence and the forwarding of these reports to the Executive Vice President - Nuclear Operations and to the Safety Review and Audit Board.
- 6.5.2.11 Review of changes to the Process Control Program and the Offsite Dose Calculation Manual. Approval of any changes shall be made by the General Superintendent - Nuclear Generation or his designee before implementation of such changes.
- 6.5.2.12 Reports documenting each of the activities performed under Specifications 6.5.2.1 through 6.5.2.9 shall be maintained. Copies shall be provided to the Executive Vice President - Nuclear Operations and the Safety Review and Audit Board.

6.5.3 Safety Review and Audit Board (SRAB)

Function

- 6.5.3.1 The Safety Review and Audit Board shall function to provide independent review and audit of designated activities in the areas of:
 - a. nuclear power plant operations
 - b. nuclear engineering
 - c. chemistry and radiochemistry
 - d. metallurgy
 - e. instrumentation and control
 - f. radiological safety
 - g. mechanical and electrical engineering
 - h. quality assurance practices
 - i. (other appropriate fields associated with the unique characteristics of the nuclear power plant)

Audits

- 6.5.3.8 Audits of facility activities shall be performed under the cognizance of the SRAB. These audits shall encompass:
- a. The conformance of facility operation to all provisions contained within the Technical Specifications and applicable license conditions at least once per year.
 - b. The performance, training and qualifications of the entire facility staff at least once per year.
 - c. The results of actions taken to correct deficiencies occurring in facility equipment, structures, systems or method of operation that affect nuclear safety at least once per six months.
 - d. The performance of all activities required by the Quality Assurance Program to meet the criteria of Appendix "B", 10CFR50, at least once per two years.
 - e. The Facility Emergency Plan and implementing procedures at least once every 12 months.
 - f. The Facility Security Plan and implementing procedures at least once every 12 months.
 - g. The Facility Fire Protection Program and implementing procedures at least once per two years.
 - h. Any other area of facility operation considered appropriate by the SRAB or the Executive Vice President - Nuclear Operations.
 - i. The radiological environmental monitoring program and the results thereof at least once per 12 months.
 - j. The Offsite Dose Calculation Manual and implementing procedures at least once per 24 months.
 - k. The Process Control Program and implementing procedures for processing and packaging of radioactive wastes at least once per 24 months.

Authority

6.5.3.9 The SRAB shall report to and advise the Executive Vice President - Nuclear Operations on those areas of responsibility specified in Section 6.5.3.7 and 6.5.3.8.

Records

6.5.3.10 Records of SRAB activities shall be prepared, approved and distributed as indicated below:

- a. Minutes of each SRAB meeting shall be prepared, approved and forwarded to the Executive Vice President - Nuclear Operations within 30 days following each meeting.
- b. Reports of reviews encompassed by Section 6.5.3.7 e,f,g and h above, shall be prepared, approved and forwarded to the Executive Vice President - Nuclear Operations within 14 days following completion of the review.
- c. Audit reports encompassed by Section 6.5.3.8 above, shall be forwarded to the Executive Vice President - Nuclear Operations within 90 days following completion of the review.

6.6 Reportable Occurrence Action

6.6.1 The following actions shall be taken for REPORTABLE EVENTS:

- a. The Commission shall be notified and a report submitted pursuant to the requirements of Sections 50.72 and 50.73 to 10CFR Part 50, and
- b. Each REPORTABLE EVENT shall be reviewed by the SORC and the results of this review submitted to the SRAB and the Executive Vice President - Nuclear Operations.

6.7 Safety Limit Violation

6.7.1 The following actions shall be taken in the event a Safety Limit is violated:

- a. The provisions of 10 CFR 50.36(c)(1)(i) shall be complied with immediately.
- b. The Safety Limit violation shall be reported to the Commission, the Executive Vice President - Nuclear Operations and to the SRAB immediately.
- c. A Safety Limit Violation Report shall be prepared. The report shall be reviewed by the SORC. This report shall describe (1) applicable circumstances preceding the violation, (2) effects of the violation upon facility components, systems or structures, and (3) corrective action taken to prevent recurrence.
- d. The Safety Limit Violation Report shall be submitted to the Commission, within 30 days of the violation, and to the SRAB, and the Executive Vice President - Nuclear Operations within 14 days.

6.8 Procedures

- 6.8.1 Written procedures and administrative policies shall be established, implemented and maintained that meet or exceed the requirements and recommendations of Sections 5.1 and 5.3 of ANSI N18.7-1972 and Appendix "A" of USAEC Regulatory Guide 1.33 except as provided in 6.8.2 and 6.8.3 below.
- 6.8.2 Each procedure and administrative policy of 6.8.1 above, and changes thereto, shall be reviewed and approved by the General Superintendent-Nuclear Generation or designee prior to implementation and periodically as set forth in each document.

6.8 Procedures (Continued)

6.8.3 Temporary changes to procedures of 6.8.1 above may be made provided:

- a. The intent of the original procedure is not altered.
- b. The change is approved by two members of the plant management staff, at least one of whom holds a Senior Reactor Operator's License on the unit affected.
- c. The change is documented, reviewed and approved by the General Superintendent-Nuclear Generation or designee within 14 days of implementation.

6.9 Reporting Requirements

In addition to the applicable reporting requirements of Title 10, Code of Federal Regulations, the following identified reports shall be submitted in accordance with 10 CFR 50.4.

6.9.1 Routine Reports

- a. Startup Report. A summary report of plant startup and power escalation testing shall be submitted following (1) receipt of an operating license, (2) amendment to the license involving a planned increase power level, (3) installation of fuel that has a different design or has been manufactured by a different fuel supplier, and (4) modifications that may have significantly altered the nuclear, thermal, or hydraulic performance of the plant. The report shall address each of the tests identified in the FSAR and shall in general include a description of the measured values of the operating conditions or characteristics obtained during the test program and a comparison of these values with design predictions and specifications. Any corrective actions that were required to obtain satisfactory operation shall also be described. Any additional specific details required in license conditions based on other commitments shall be included in this report.

6.9.1 Routine Reports (Cont'd)

Startup reports shall be submitted within (1) 90 days following completion of the startup test program, (2) 90 days following resumption or commencement of commercial power operation, or (3) 9 months following initial criticality, whichever is earliest. If the Startup Report does not cover all three events (i.e., initial criticality, completion of startup test program, and resumption or commencement of commercial power operation), supplementary reports shall be submitted at least every three months until all three events have been completed.

- b. Annual Occupational Exposure Report. A tabulation shall be submitted on an annual basis which includes the number of station, utility and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man rem exposure according to work and job functions, 1/ e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling. The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totaling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions.
- c. Monthly Operating Report. Routine reports of operating statistics and shutdown experience including documentation of challenges to the safety relief valves or safety valves, shall be submitted on a monthly basis, which will include a narrative of operating experience, in accordance with 10 CFR 50.4, no later than the 15th of each month following the calendar month covered by the report.

1/ This tabulation supplements the requirements of 20.407 of 10 CFR Part 20.

6.9.1 Routine Reports (cont'd)

Changes to the Offsite Dose Calculation Manual (ODCM): Shall be reported to the Commission in the Semiannual Radioactive Effluent Release Report for the period in which the change(s) was made effective. This submittal shall contain:

- a. Sufficiently detailed information to totally support the rationale for the change without benefit of additional or supplemental information. Information submitted should consist of a package of those pages of the Offsite Dose Calculation Manual to be changed, together with appropriate analyses or evaluations justifying the change(s);
- b. A determination that the change will not reduce the accuracy or reliability of dose calculations or setpoint determinations; and
- c. Documentation of the fact that the change has been reviewed and found acceptable.

6.9.2 Fire Protection Program Reports

- a. Submit a special report in accordance with 10 CFR 50.4 as follows:
 - Notify the Regional Administrator of the appropriate Regional Office by telephone within 24 hours.
 - Confirm by telegraph, mailgram or facsimile transmission no later than the first working day following the event, and
 - Follow-up in writing within 14 days after the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to an operable status.
- b. Submit a special report in accordance with 10 CFR 50.4 within 30 days following the event outlining the plans and procedures to be used to restore the inoperable equipment to an operable status.

6.9.3 Special Reports

Special reports shall be submitted in accordance with 10 CFR 50.4 Regional Office within the time period specified for each report. These reports shall be submitted covering the activities identified below pursuant to the requirements of the applicable reference specification:

- a. Reactor Vessel Material Surveillance Specimen Examination, Specification 4.2.2(b) (12 months)
- b. Safety Class 1 Inservice Inspection, Specification (See Table 4.2.6(a)) (Three months)
- c. Safety Class 2 Inservice Inspections, Specification (See Table 4.2.6(b)) (Three months)
- d. Safety Class 3 Inservice Inspections; Specification (See Table 4.2.6(c)) (Three months)
- e. Primary Containment Leakage Testing, Specification 3.3.3 (Three months)
- f. Secondary Containment Leakage Testing, Specification 3.4.1 (Three months)
- g. Sealed Source Leakage In Excess Of Limits, Specification 3.6.5.2 (Three months)
- h. Calculate Dose from Liquid Effluent in Excess of Limits, Specification 3.6.15.a(2)(b) (30 days from the end of the affected calendar quarter).
- i. Calculate Air Dose from Noble Gases Effluent in Excess of Limits, Specification 3.6.15.b(2)(b) (30 days from the end of the affected calendar quarter).
- j. Calculate Dose from I-131, H-3 and Radioactive Particulates with half lives greater than eight days in Excess of Limits, Specification 3.6.15.b(3)(b) (30 days from the end of the affected calendar quarter).
- k. Calculated Doses from Uranium Fuel Cycle Source in Excess of Limits, Specification 3.6.15.d (30 days from the end of the affected calendar year).
- l. Inoperable Gaseous Radwaste Treatment System, Specification 3.6.16.b (30 days from the event).
- m. Environmental Radiological Reports. With the level of radioactivity (as the result of plant effluents) in an environmental sampling medium exceeding the reporting level of Table 6.9.3-1, when averaged over any calendar quarter, in lieu of a Licensee Event Report, prepare and submit to the Commission within thirty (30) days from the end of the calendar quarter a special report identifying the cause(s) for exceeding the limits, and define the corrective action to be taken.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 108 TO FACILITY OPERATING LICENSE NO. DPR-63

NIAGARA MOHAWK POWER CORPORATION

NINE MILE POINT NUCLEAR POWER STATION, UNIT NO. 1

DOCKET NO. 50-220

INTRODUCTION

By letters dated June 3, 1988 as amended September 28 and November 15, 1988, Niagara Mohawk Power Corporation (the licensee) proposed changes to Technical Specifications (TS) 6.2.1, Offsite Organization, and 6.2.2, Unit Staff. The proposed changes would remove Figure 6.2-1, Offsite Organization, and Figure 6.2-2, Unit Organization, and replace them with a narrative description of the offsite and onsite organizations functional requirements in TS 6.2.1 (and unit staff qualifications in 6.2.2). Guidance for these proposed changes to the TS was provided to licensees and applicants by Generic Letter 88-06, dated March 22, 1988. The proposed amendment would also add administrative changes to Sections 6.1, "Responsibility," 6.2, "Organization," 6.5, "Review and Audit," 6.6, "Reportable Event Action," and 6.7, "Safety Limit Violation." Section 6.9, "Reporting Requirements," is being revised to make the Unit 2 Specifications consistent with 10 CFR 50.4. Additional administrative changes are included in the amendment to reflect the creation of the Executive Vice President-Nuclear Operations position. This title replaces all current references to Senior Vice President in the Specifications.

BACKGROUND

Consistent with the guidance provided in the Standard Technical Specifications, Specifications 6.2.1 and 6.2.2 of the administrative control requirements have referenced offsite and unit (onsite) organization charts that are provided as figures to these sections. On a plant specific basis, these organization charts have been provided by applicants and included in the TS issued with the operating license. Subsequent restructuring of either the offsite or unit organizations, following the issuance of an operating license, has required licensees to submit a license amendment for NRC approval to reflect the desired changes in these organizations. As a consequence, organizational changes have necessitated the need to request an amendment of the operating license.

Because of these limitations on organizational structure, the nuclear industry has highlighted this as an area for improvement in the TS. The

Shearon Harris licensee proposed changes to remove organization charts from its TS under the lead-plant concept that included the endorsement of the proposed changes by the Westinghouse Owners Group. In its review of the Shearon Harris proposal, the staff concluded that most of the essential elements of offsite and onsite organization charts are captured by other regulatory requirements, notably, Appendix B to 10 CFR Part 50. However, there were aspects of the organizational structure that are important to ensure that the administrative control requirements of 10 CFR 50.36 would be met and that would not be retained with the removal of the organization charts. The applicable regulatory requirements are those administrative controls that are necessary to ensure safe operation of the facility. Therefore, those aspects of organization charts for Shearon Harris that were essential for conformance with regulatory requirements are added (1) to Specification 6.2.1 to define functional requirements for the offsite and onsite organizations and (2) to Specification 6.2.2 to define qualification requirements of the unit staff.

By letter dated January 27, 1988, the staff issued Amendment No. 3 to Facility Operating License NFP-63 for the Shearon Harris Nuclear Power Plant that incorporated these changes to their TS. Subsequently the staff developed guidance on an acceptable format for license amendment requests to remove the organization charts from TS. Generic Letter 88-06 provided this guidance to all power reactors.

The Section 6.9, "Reporting Requirements," are changed to be consistent with the written communications requirements of 10 CFR 50.4.

Creation of the position entitled, Executive Vice President-Nuclear Operations, requires administrative changes to the Nuclear Division Management Organization. The changes involve replacing all references to Senior Vice President in the Specifications with the new title. The new position incorporates the authority and functions formerly performed by the Senior Vice President.

EVALUATION

The licensee's proposed changes to its TS addressed the items below and are in accordance with the guidance provided by Generic Letter 88-06.

- (1) Specifications 6.2.1 and 6.2.2 were revised to delete the references to Figures 6.2-1 and 6.2-2 that were removed from the TS.
- (2) Functional requirements of the offsite and onsite organizations were defined and added to Specification 6.2.1, and they are consistent with the guidance provided in Generic Letter 88-06. The specification notes that implementation of these requirements is documented in the Final Safety Analysis Report (FSAR).

- (3) The senior reactor operator and reactor operator license qualified positions, identified on the organization chart for the facility staff, were noted as being required by Specification 6.2.2. Therefore, this requirement will be retained as a requirement following the removal of the organization chart for the unit staff.
- (4) Consistent with requirements to document the offsite and onsite organization relationships in the form of organization charts, the licensee has confirmed that this documentation currently exists in the FSAR.
- (5) The licensee has confirmed that no specifications, other than those noted in item (1) above, include references to the figures of the organization charts that are being removed from TS for their plant. Hence, this is not an applicable consideration, with regard to the need to redefine referenced requirements as a result of the removal of these figures.

On the basis of its review of the above items, the staff concludes that the licensee has provided an acceptable response to these items as addressed in the NRC guidance on removing organization charts from the administrative control requirements of the TS. Furthermore, the staff finds that these changes are consistent with the staff's generic finding on the acceptability of such changes as noted in Generic Letter 88-06. Accordingly, the staff finds the proposed changes to be acceptable.

The change to Section 6.9, "Reporting Requirements," is an administrative revision, citing 10 CFR 50.4 for written communications requirements. The licensee's proposal to replace the position and title of Senior Vice President, with Executive Vice President-Nuclear Operations is essentially only a title change to the Specifications. On the basis of the staff's review, the proposed changes are acceptable.

ENVIRONMENTAL CONSIDERATION

This amendment involves a change in record keeping, or administrative procedures requirements. The staff has determined that this amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Sec 51.22(c)(10). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Dated: July 10, 1989

PRINCIPAL CONTRIBUTORS:

T. Dunning
V. McCree