

June 3, 1988

Docket No. 50-410

Mr. Charles V. Mangan  
Senior Vice President  
Niagara Mohawk Power Corporation  
301 Plainfield Road  
Syracuse, New York 13212

DISTRIBUTION

Docket File	MHaughey
NRC PDR	RStevens
Local PDR	OGC-WF
PDI-1 Rdg.	EJordan
TMurley/JSniezek	JPartlow
CRossi	TBarnhart(4)
FMiraglia	ACRS(10)
SVarga	GPA/PA
BBoger	ARM/LFMB

Dear Mr. Mangan:

SUBJECT: SCHEDULAR EXEMPTION TO THE REQUIREMENTS OF GDC 50,  
APPENDIX A TO 10 CFR 50

On May 26, 1988 you submitted a letter stating that actions relating to schedular exemption 2.D(v) of the Nine Mile Point, Unit 2 Facility Operating License No. NPF-69 have been completed. These actions involved installing redundant fuses in circuits that use transformers for redundant penetration protection to meet the requirements of GDC 50, Appendix A to 10 CFR 50. By this letter, we acknowledge receipt of your letter indicating completion of the actions required to close the schedular exemption to GDC 50.

Sincerely,

*Original signed by*

Mary F. Haughey, Project Manager  
Project Directorate I-1  
Division of Reactor Projects, I/II

PDI-1  
CVogancw  
6/2/88

*M. Haughey*  
PDI-1  
MHaughey:d1g  
6/2/88

*roc*  
PDI-1  
RCapra  
6/3/88

8806170287 880603  
PDR ADDCK 05000410  
PDR  
P

Mr. C. V. Mangan  
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station  
Unit 2

cc:

Mr. Troy B. Conner, Jr., Esq.  
Conner & Wetterhahn  
Suite 1050  
1747 Pennsylvania Avenue, N.W.  
Washington, D.C. 20006

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Mr. Richard Goldsmith  
Syracuse University  
College of Law  
E. I. White Hall Campus  
Syracuse, New York 12223

Mr. Paul D. Eddy  
New York State Public Service  
Commission  
Nine Mile Point Nuclear Station -  
Unit 2  
P.O. Box 63  
Lycoming, New York 13093

Mr. Don Hill  
Niagara Mohawk Power Corporation  
Suite 550  
4520 East West Highway  
Bethesda, MD 20814

Mr. Richard M. Kessel  
Chair and Executive Director  
State Consumer Protection Board  
99 Washington Avenue  
Albany, New York 12210

Resident Inspector  
Nine Mile Point Nuclear Power Station  
P. O. Box 99  
Lycoming, New York 13093

Mr. Richard Abbott, Unit 2 Station  
Superintendent  
Nine Mile Point Nuclear Station  
Niagara Mohawk Power Corporation  
P. O. Box 32  
Lycoming, NY 13093

Mr. Gary D. Wilson, Esquire  
Niagara Mohawk Power Corporation  
300 Erie Boulevard West  
Syracuse, New York 13202

Mr. James L. Willis, General Supt.,  
Nuclear Generation  
Nine Mile Point Nuclear Station  
Niagara Mohawk Power Corporation  
P. O. Box 32  
Lycoming, NY 13093

Mr. Peter E. Francisco, Licensing  
Niagara Mohawk Power Corporation  
301 Plainfield Road  
Syracuse, New York 13212

Ms. Donna Ross  
New York State Energy Office  
2 Empire State Plaza  
16th Floor  
Albany, New York 12223