



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 24, 1992

Docket No. 50-410

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Dear Mr. Sylvia:

SUBJECT: ISSUANCE OF AMENDMENT FOR NINE MILE POINT NUCLEAR STATION,
UNIT 2 (TAC NO. M82636)

The Commission has issued the enclosed Amendment No. 38 to Facility Operating License No. NPF-69 for the Nine Mile Point Nuclear Station Unit 2 (NMP-2). The amendment consists of changes to the Facility Operating License in response to your application transmitted by letter dated January 17, 1992.

The amendment revises License Conditions 2.C.(3)b and 2.C.(3)c to increase the number of fuel assemblies allowed out of approved storage locations in the spent fuel pool from one to three. This allows rechanneling of fuel using both fuel preparation machines at the same time.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

Donald S. Brinton
for Richard A. Laura, Acting Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 38 to NPF-69
2. Safety Evaluation

cc w/enclosures:
See next page

REG FILE CENTER COPY

9204060242 920324
PDR ADDCK 05000410
PDR

CP-1
JFol
111

Mr. B. Ralph Sylvia
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit No. 2

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW.
Washington, DC 20005-3502

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, New York 12223

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271

Resident Inspector
Nine Mile Point Nuclear Station
P. O. Box 126
Lycoming, New York 13093

Mr. Richard M. Kessel
Chair and Executive Director
State Consumer Protection Board
99 Washington Avenue
Albany, New York 12210

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Mr. Martin J. McCormick Jr.
Plant Manager, Unit 2
Nine Mile Point Nuclear Station
Niagara Mohawk Power Corporation
P. O. Box 32
Lycoming, New York 13093

Mr. David K. Greene
Manager Licensing
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Mr. Joseph F. Firlit
Vice President - Nuclear Generation
Nine Mile Point Nuclear Station
Niagara Mohawk Power Corporation
P. O. Box 32
Lycoming, New York 13093

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, New York 13126

March 24, 1992

Docket No. 50-410

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Dear Mr. Sylvia:

SUBJECT: ISSUANCE OF AMENDMENT FOR NINE MILE POINT NUCLEAR STATION,
UNIT 2 (TAC NO. M82636)

The Commission has issued the enclosed Amendment No. 38 to Facility Operating License No. NPF-69 for the Nine Mile Point Nuclear Station Unit 2 (NMP-2). The amendment consists of changes to the Facility Operating License in response to your application transmitted by letter dated January 17, 1992.

The amendment revises License Conditions 2.C.(3)b and 2.C.(3)c to increase the number of fuel assemblies allowed out of approved storage locations in the spent fuel pool from one to three. This allows rechanneling of fuel using both fuel preparation machines at the same time.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

Original Signed By Donald Brinkman for Richard Laura
Richard A. Laura, Acting Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 38 to NPF-69
2. Safety Evaluation

cc w/enclosures:
See next page

OFFICE	PDI-1	PEI-1:PM	BC:SRXB	OGC	D:PDI-1 <i>rac</i>
NAME	CSVogan <i>cv</i>	RLaura <i>pc</i>	RJones	<i>APH</i>	RACapra
DATE	<i>3/9/92</i>	<i>03/9/92</i>	<i>03/09/92</i>	<i>03/12/92</i>	<i>03/24/92</i>

OFFICIAL RECORD COPY
FILENAME: B:\M82636.AMD

DATED: March 24, 1992

AMENDMENT NO. 38 TO FACILITY OPERATING LICENSE NO. NPF-69-NINE MILE POINT
UNIT 2

Docket File
NRC & Local PDRs
PDI-1 Reading
SVarga, 14/E/4
JCalvo, 14/A/4
RCapra
CVogan
JMenning
CCowgill
OGC
DHagan, 3302 MNBB
GHill (4), P-137
Wanda Jones, P-130A
CGrimes, 11/F/23
RJones, 8E23
ACRS (10)
OPA
OC/LFMB
PD Plant-specific file

cc: Plant Service list



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

NIAGARA MOHAWK POWER CORPORATION
DOCKET NO. 50-410
NINE MILE POINT NUCLEAR STATION, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 38
License No. NPF-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated January 17, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, page 4, Section 2.C(3), of Facility Operating License No. NPF-69 is hereby amended to read as follows:
 - (3) Fuel Storage and Handling (Section 9.1, SSER 4)*
 - a. Fuel assemblies, when stored in their shipping containers, shall be stacked no more than three containers high.
 - b. When not in the reactor vessel, no more than three fuel assemblies shall be allowed outside of their shipping containers or storage racks in the New Fuel Vault or Spent Fuel Storage Facility.

- c. The above three fuel assemblies shall maintain a minimum edge-to-edge spacing of twelve (12) inches from the shipping container array and approved storage rack locations.
 - d. The New Fuel Storage Vault shall have no more than ten fresh fuel assemblies uncovered at any one time.
3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Page 4 of License

Date of Issuance: March 24, 1992

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

(3) Fuel Storage and Handling (Section 9.1, SSER 4)*

- a. Fuel assemblies, when stored in their shipping containers, shall be stacked no more than three containers high.
- b. When not in the reactor vessel, no more than three fuel assemblies shall be allowed outside of their shipping containers or storage racks in the New Fuel Vault or Spent Fuel Storage Facility.
- c. The above three fuel assemblies shall maintain a minimum edge-to-edge spacing of twelve (12) inches from the shipping container array and approved storage rack locations.
- d. The New Fuel Storage Vault shall have no more than ten fresh fuel assemblies uncovered at any one time.

(4) Turbine System Maintenance Program (Section 3.5.1.3.10, SER)

Niagara Mohawk Power Corporation shall submit for NRC approval by October 31, 1989, a turbine system maintenance program based on the manufacturer's calculations of missile generation probabilities.

(5) Inservice Inspection (Sections 5.2.4.3 and 6.6.3, SSER 5)

Niagara Mohawk Power Corporation shall submit an inservice inspection program in accordance with 10 CFR § 50.55a(g)(4) for staff review by July 31, 1987.

* The parenthetical notation following the title of many license conditions denotes the section of the Safety Evaluation Report (SER) and/or its supplements wherein the license condition is discussed.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 38 TO FACILITY OPERATING LICENSE NO. NPF-69
NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT NUCLEAR STATION, UNIT 2
DOCKET NO. 50-410

1.0 INTRODUCTION

By letter dated January 17, 1992, the Niagara Mohawk Power Corporation (the licensee) requested an amendment to the Facility Operating License No. NPF-69 for Nine Mile Point Nuclear Station Unit 2 (NMP-2). The requested amendment would increase the number of fuel assemblies allowed out of the approved storage locations in the spent fuel pool from one to three. This allows simultaneous use of both fuel preparation machines during fuel channeling and dechanneling operations.

2.0 EVALUATION

The proposed change to the license revises License Condition 2.C(3) to increase the number of fuel assemblies allowed out of the storage racks in the spent fuel pool from one to three. Currently, this license condition allows up to three assemblies above the refuel floor to be outside of the new fuel vault or normal shipping containers, and also allows only one fuel assembly to be outside of the storage rack in the spent fuel pool below the refuel floor. The purpose of this change is to allow simultaneous use of the two fuel preparation machines located in the spent fuel pool. The use of two machines allows simultaneous removal of channels from irradiated fuel bundles and installation of such a reusable channel on new unirradiated fuel bundles. The Nine Mile Point Unit 2 Updated Safety Analysis Report Section 9.1.4.2.11 describes rechanneling of fuel using both fuel preparation machines. However, in accordance with the requirements of NRC Bulletin No. 90-02, "Loss of Thermal Margin Caused By Channel Box Bow," March 20, 1990, any proposed reuse of channel boxes will require prior NRC approval.

Increasing the number of fuel assemblies allowed out of their storage racks in the spent fuel pool from one to three does not represent a decrease in nuclear criticality safety. General Electric (GE) Direction Document 22A6042 Revision 4, Step 10.2.2, allows a fuel array of up to three fuel bundles or assemblies outside of a storage area or shipping container provided an edge-to-edge spacing of 12 inches or more exists from all other fuel. This fuel handling requirement is again stated in Procedural Recommendation 3 in GE SIL 152, titled "Critically Margins for Storage of New Fuel," dated March 31, 1976. The NRC Safety Evaluation Report Supplement 4, dated September 1986, states in Section 9.1 the following:

9204060257 920324
PDR ADOCK 05000410
P PDR

"Calculations have indicated that three assemblies out of storage cannot be made critical under any conditions. In addition, the applicant has committed to maintain a minimum edge-to-edge distance of more than 12 in. between fuel assemblies out of storage and fuel assemblies in their shipping container array and the storage rack arrays."

The supporting information for the license change states that GE has performed calculations that demonstrate four fuel assemblies in any configuration will remain subcritical in the fuel pool provided a minimum distance of 12 inches is maintained between these four assemblies and any surrounding assemblies. This method of fuel handling was reviewed and found acceptable as documented in the NRC Safety Evaluation for the Nine Mile Point Unit 2 License Amendment No. 21 for the Facility Operating License. License Amendment No. 21 authorized spiral reload of fuel assemblies and the amendment states that four fuel assemblies cannot be made critical. The proposed change limits the number of assemblies outside of approved locations to three, and requires a 12-inch spacing be maintained from any other fuel. Since only three assemblies can be outside of approved locations at one time and a GE analysis, which was reviewed by the NRC, determined 4 fuel assemblies cannot be made critical, adequate assurance exists that fuel handling in accordance with the proposed amendment will not result in an inadvertent criticality.

The proposed change of license condition 2.C(3)c from "four" to "three" fuel assemblies reflects the proposed change in License Condition 2.C(3)b and maintains consistency. This change is administrative in nature and does not affect the probability of an inadvertent criticality or any other accident.

The staff has reviewed the proposed changes and we find them to be acceptable because three fuel assemblies in any position cannot cause criticality, and it is normal practice in a boiling water reactor to simultaneously use both fuel preparation machines during fuel rechanneling operations.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the New York State official was notified of the proposed issuance of the amendment. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (57 FR 6038). Accordingly, the amendment meets

the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor:
Richard A. Laura

Date: March 24, 1992