

August 12, 1987

Docket No. 50-410

DISTRIBUTION  
Docket File  
NRC/PDR  
Local PDR  
PDI-1 Rdg.  
C. Vogan  
M. Haughey  
S. Varga  
B. Boger  
OGC  
D. Hagan  
ACRS(10)  
GPA/PA

Mr. Charles V. Mangan  
Senior Vice President  
Niagara Mohawk Power Corporation  
301 Plainfield Road  
Syracuse, New York 13212

Dear Mr. Mangan:

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. This notice relates to your request of August 3, 1987, as revised August 6, 1987, to amend the Technical Specifications to Operating License NPF-69 for Nine Mile Point Nuclear Station Unit 2. The amendment would revise the provisions of the Technical Specifications to allow a service water supply header discharge temperature limit of 81°F.


Sincerely,

Mary F. Haughey, Project Manager  
Project Directorate I-1  
Division of Reactor Projects, I/II

Enclosure:  
Notice of Consideration of  
Issuance of Amendment to  
Facility Operating License  
and Opportunity for Prior  
Hearing

cc: See next page

PDI-1  
CVogan  
8/14/87

  
PDI-1  
MHaughey  
8/12/87

8708170130 870812  
PDR ADOCK 05000410  
P PDR

Mr. C. V. Mangan  
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station  
Unit 2

cc:

Mr. Troy B. Conner, Jr., Esq.  
Conner & Wetterhahn  
Suite 1050  
1747 Pennsylvania Avenue, N.W.  
Washington, D.C. 20006

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Richard Goldsmith  
Syracuse University  
College of Law  
E. I. White Hall Campus  
Syracuse, New York 12223

Mr. Paul D. Eddy  
New York State Public Service  
Commission  
Nine Mile Point Nuclear Station -  
Unit II  
P.O. Box 63  
Lycoming, New York 13093

Ezra I. Bialik  
Assistant Attorney General  
Environmental Protection Bureau  
New York State Department of Law  
2 World Trade Center  
New York, New York 10047

Mr. Richard M. Kessel  
Chair and Executive Director  
State Consumer Protection Board  
99 Washington Avenue  
Albany, New York 12210

Resident Inspector  
Nine Mile Point Nuclear Power Station  
P. O. Box 99  
Lycoming, New York 13093

Mr. John W. Keib, Esq.  
Niagara Mohawk Power Corporation  
300 Erie Boulevard West  
Syracuse, New York 13202

Mr. James Linville  
U. S. Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Peter E. Francisco, Licensing  
Niagara Mohawk Power Corporation  
300 Erie Boulevard West  
Syracuse, New York 13202

Don Hill  
Niagara Mohawk Power Corporation  
Suite 550  
4520 East West Highway  
Bethesda, Maryland 20814

UNITED STATES NUCLEAR REGULATORY COMMISSIONNIAGARA MOHAWK POWER CORPORATIONDOCKET NO. 50-410NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO  
FACILITY OPERATING LICENSE AND PROPOSED NO SIGNIFICANT HAZARDS  
CONSIDERATION DETERMINATION AND OPPORTUNITY FOR HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-69 issued to Niagara Mohawk Power Corporation, Rochester Gas and Electric Corporation, Central Hudson Gas and Electric Corporation, New York Electric and Gas Corporation, and Long Island Lighting Company (the licensee)\*, for operation of the Nine Mile Point Nuclear Station Unit 2 plant, located in Oswego County, New York.

The proposed amendment would revise the service water supply header discharge temperature limit in Technical Specification 3/4.7.1 to 81°F. The proposed amendment is in accordance with the licensee's application of August 3, 1987 as amended August 6, 1987.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant

\*Niagara Mohawk Power Corporation is authorized to act as agent for the other listed owners and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety.

The Commission has provided guidance for the application of these criteria by providing examples of amendments that are considered not likely to involve significant hazards considerations (48 FR 14870).

The proposed changes will not involve a significant increase in the probability or consequences of an accident previously evaluated for the following reasons.

The proposed amendment involves increasing the plant service water system operating temperature limit in the Technical Specifications from 76°F to 81°F. The licensee has stated that all components cooled by the plant service water system have been evaluated and been found to be able to perform their intended function under normal operation, shutdown, abnormal and accident conditions with a service water temperature of up to 82°F. Further, the licensee has stated that the proposed change does not adversely affect the environmental qualification of any plant equipment, nor does it impact post-accident containment response. By the determination that the suppression pool is not affected in the post-accident containment response, assurance is provided that the LOCA analysis also remains valid. Finally, the integrity of the service water operating temperature limit to 81°F will not involve a significant increase in the probability or consequences of an accident previously evaluated.

The proposed changes will not create the possibility of a new or different kind of accident from any accident previously evaluated for the following reasons.

The containment post-accident response to previously evaluated accidents remains within previously assessed limits of temperature and pressure. This also applies to the LOCA analysis. Further, all safety-related systems and components remain within their applicable design limits. Thus, system and component performance is not adversely affected by this change, thereby assuring that the design capabilities of those systems and components are not challenged in a manner not previously assessed so as to create the possibility of a new or different kind of accident.

In addition, the environmental qualification of plant equipment is not adversely affected by the proposed changes, further assuring that components are not challenged in a manner not previously assessed. In summary, the proposed changes does not create the possibility of a new or different kind of accident from any previously evaluated.

The proposed changes will not involve a significant reduction in a margin of safety for the following reasons. A number of conservatisms were used in establishing the design basis for the service water system. The margins of safety resulting from these conservatisms are not significantly affected by the proposed change to the Technical Specifications. The change in the margin of safety is insignificant compared to the remaining margin of safety from conservatisms applied in the analyses.

Therefore, based on these considerations and the three criteria given above, the Commission has made a proposed determination that the amendment request involves no significant hazards consideration.

The Commission has determined that failure to act in a timely way would result in a shutdown of the plant.

Therefore, the Commission has insufficient time to issue its usual 30-day notice of the proposed action for public comment.

If during the comment period, the lake temperature should exceed 77 degrees Fahrenheit for sustained periods, the Commission may issue the license amendment before August 31, 1987, provided that its final determination involves no significant hazards considerations and that the application satisfies the provisions of 10 CFR 50.92(a)(5).

If the proposed determination becomes final, an opportunity for a hearing will be published in the Federal Register at a later date and any hearing request will not delay the effective date of the amendment.


If the Commission decides in its final determination that the amendment does involve a significant hazards consideration, a notice of opportunity for a prior hearing will be published in the Federal Register and, if a hearing is granted, it will be held before any amendment is issued.

The Commission is seeking public comments on this proposed determination of no significant hazards consideration. Comments on the proposed determination may be telephoned to Robert A. Capra, Acting Director, Project Directorate I-1, by collect call to 301-492-4556 or submitted in writing to the Secretary of the Commission, U.S. Nuclear Regulatory Commission,

Washington, DC 20555, ATTN: Docketing and Service Branch. All comments received by August 31, 1987 will be considered in reaching a final determination. A copy of the application may be examined at the Commission's Public Document Room, 1717 H Street, N.W., Washington, DC and at the Local Public Document Room, Penfield Library, State University College, Oswego, New York 13126.

Dated at Bethesda, Maryland, this 10th day of August 1987.

FOR THE NUCLEAR REGULATORY COMMISSION



Joseph D. Neighbors, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects, I/II