

50-410



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

August 30, 1994

Mr. B. Ralph Sylvia
Executive Vice President, Nuclear
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

SUBJECT: ISSUANCE OF AMENDMENT FOR NINE MILE POINT NUCLEAR STATION, UNIT 2
(TAC NO. M89785)

Dear Mr. Sylvia:

The Commission has issued the enclosed Amendment No. 56 to Facility Operating License No. NPF-69 for the Nine Mile Point Nuclear Station, Unit 2. The amendment consists of changes to the Technical Specifications (TSs) in response to your application transmitted by letter dated July 1, 1994.

The amendment revises the secondary containment drawdown time testing requirement of TS 4.6.5.1.c.1 and the secondary containment inleakage testing requirement of TS 4.6.5.1.c.2. The amendment supports a revised design basis radiological analysis which supports an increase in secondary containment drawdown time from 6 to 60 minutes by taking credit for fission product scrubbing and retention in the suppression pool which were not assumed in the original radiological analysis but are currently assumed in the NRC's Standard Review Plan (NUREG-0800). The revised analysis also takes credit for additional mixing of primary containment and engineered safety feature system leakage with 50 percent of the secondary containment free air volume prior to the release of radioactivity to the environment. The revised radiological evaluation has determined that the radiological doses remain below 10 CFR Part 100 guideline values and General Design Criterion 19 criteria.

9409070273 940830
PDR ADOCK 05000410
P PDR

NRC FILE CENTER COPY

DFU


B. Sylvia

-2-

August 30, 1994

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,



Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-410

Enclosures: 1. Amendment No.56 to NPF-69
2. Safety Evaluation

cc w/encls: See next page

Mr. B. Ralph Sylvia
Niagara Mohawk Power Corporation

Nine Mile Point Nuclear Station
Unit 2

cc:

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW.
Washington, DC 20005-3502

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, NY 12223

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Resident Inspector
Nine Mile Point Nuclear Station
P.O. Box 126
Lycoming, NY 13093

Mr. Richard M. Kessel
Chair and Executive Director
State Consumer Protection Board
99 Washington Avenue
Albany, NY 12210

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, NY 13202

Mr. Kim A. Dahlberg
Plant Manager, Unit 2
Nine Mile Point Nuclear Station
Niagara Mohawk Power Corporation
P.O. Box 63
Lycoming, NY 13093

Mr. David K. Greene
Manager Licensing
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Mr. Louis F. Storz
Vice President - Nuclear Generation
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, NY 12223

Mr. Martin J. McCormick, Jr.
Vice President
Nuclear Safety Assessment
and Support
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
P.O. Box 63
Lycoming, NY 13093

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

DATED: August 30, 1994

AMENDMENT NO. 56 TO FACILITY OPERATING LICENSE NO. NPF-69-NINE MILE POINT
UNIT 2

Docket File

NRC & Local PDRs

PDI-1 Reading

S. Varga, 14/E/4

C. Miller, 14/A/4

M. Case

C. Vogan

D. Brinkman

OGC

D. Hagan, 3302 MNBB

G. Hill (2), P1-22

C. Grimes, 11/F/23

W. Long, 8/H/7

J. Lee, 10/D/4

L. Cunningham, 10/D/4

R. Barrett, 8/H/7

C. McCracken, 8/D/1

ACRS (10)

OPA

OC/LFDCB

PD plant-specific file

C. Cowgill, Region I

Others as required

cc: Plant Service list



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

NIAGARA MOHAWK POWER CORPORATION
DOCKET NO. 50-410
NINE MILE POINT NUCLEAR STATION, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 56
License No. NPF-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Niagara Mohawk Power Corporation (the licensee) dated July 1, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-69 is hereby amended to read as follows:


9409070275 940830
PDR ADOCK 05000410
P PDR

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, as revised through Amendment No. 56 are hereby incorporated into this license. Niagara Mohawk Power Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Michael J. Case, Acting Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 30, 1994

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 56 TO FACILITY OPERATING LICENSE NO. NPF-69

DOCKET NO. 50-410

Revise Appendix A as follows:

Remove Pages

xix
3/4 6-39
B3/4 6-6
-

Insert Pages

xix
3/4 6-39
B3/4 6-6
B3/4 6-7 (added)

INDEX

BASES

	<u>PAGE</u>
<u>CONTAINMENT SYSTEMS (Continued)</u>	
Primary Containment Purge System	B3/4 6-2
3/4.6.2 DEPRESSURIZATION SYSTEMS	B3/4 6-3
3/4.6.3 PRIMARY CONTAINMENT ISOLATION VALVES	B3/4 6-4
3/4.6.4 SUPPRESSION CHAMBER - DRYWELL VACUUM BREAKERS	B3/4 6-5
3/4.6.5 SECONDARY CONTAINMENT	B3/4 6-6
3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL	B3/4 6-7
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 PLANT SERVICE WATER SYSTEMS	B3/4 7-1
3/4.7.2 REVETMENT-DITCH STRUCTURE	B3/4 7-1
3/4.7.3 CONTROL ROOM OUTDOOR AIR SPECIAL FILTER TRAIN SYSTEM	B3/4 7-1
Bases Figure B3/4.7.2-1 Plan View - Revetment-Ditch Structure, Inservice Inspection Service Station Locations	B3/4 7-2
Bases Figure B3/4.7.2-2 Typical Section - Revetment-Ditch Structure, Inservice Inspection Service Station Locations	B3/4 7-3
3/4.7.4 REACTOR CORE ISOLATION COOLING SYSTEM	B3/4 7-4
3/4.7.5 SNUBBERS	B3/4 7-4
3/4.7.6 SEALED SOURCE CONTAMINATION	B3/4 7-6
3/4.7.7 MAIN TURBINE BYPASS SYSTEM	B3/4 7-6
<u>3/4.8 ELECTRICAL POWER SYSTEMS</u>	
3/4.8.1 } 3/4.8.2 } AC SOURCES, DC SOURCES, AND ONSITE POWER 3/4.8.3 } DISTRIBUTION SYSTEMS	B3/4 8-1
3/4.8.4 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES	B3/4 8-3

CONTAINMENT SYSTEMS

SECONDARY CONTAINMENT

SECONDARY CONTAINMENT INTEGRITY

SURVEILLANCE REQUIREMENTS

4.6.5.1 (Continued)

c. At least once per 18 months:

1. Verifying that each standby gas treatment subsystem will draw down the secondary containment to greater than or equal to 0.25 inch of vacuum water gauge in less than or equal to 66.7 seconds by adjusting test conditions to drawdown analysis conditions when starting at a pressure no less than zero psig, and
2. Operating one standby gas treatment subsystem for 1 hour and maintaining greater than or equal to 0.25 inch of vacuum water gauge in the secondary containment at an adjusted flow rate not exceeding 2670 cfm.

CONTAINMENT SYSTEMS

BASES

3/4.6.5 SECONDARY CONTAINMENT

Secondary containment is designed to minimize any ground level release of radioactive material which may result from an accident. The reactor building and associated structures provide secondary containment during normal operation when the drywell is sealed and in service. At other times, the drywell may be open and, when required, secondary containment integrity is specified.

Establishing and maintaining a subatmospheric condition in the reactor building with the standby gas treatment system once per 18 months, along with the surveillance of the doors, hatches, dampers, and valves, is adequate to ensure that there are no violations of the integrity of the secondary containment.

To prevent exfiltration, secondary containment leakage is limited to less than 100 percent of the containment free air volume per day. Since the exhaust air flow rate is measured after it passes through the SGTS, the surveillance test result must be adjusted for the volumetric changes that occur as the exhaust air flows through the SGTS to reflect the volume of air exhausted from the building. In addition, the surveillance test result must be adjusted to account for the negative pressure present in the secondary containment during the surveillance test, which is normally more negative than the required -0.25 inch water gauge. Secondary containment leakage varies with secondary containment air and outside air temperatures, with the highest leakage occurring at the highest anticipated secondary containment temperature and at the lowest anticipated outside air temperature. The test data is adjusted to the limiting conditions of -20°F outside air and 105°F secondary containment air temperature to assure that the actual leakage is within the design limit of secondary containment leakage. These adjustments are discussed in USAR Section 6.2.3.4.

The drawdown time limit has been established considering the same fan performance as in the post-LOCA response analysis. The post-LOCA heat load is not considered in the surveillance drawdown time limit because the test is conducted when the plant is shutdown. In addition, the initial building vacuum is assumed to be zero to reflect the test condition. To assure that the SGTS is capable of meeting its function, the drawdown time limit is calculated as a function of actual leakage that occurs during the surveillance test. Meeting this drawdown time verifies that the SGTS performance is consistent with the assumptions of the LOCA analysis. The methodology to determine the drawdown time is discussed in USAR Section 6.2.3.4.

The OPERABILITY of the standby gas treatment systems ensures that sufficient iodine removal capability will be available in the event of a LOCA. The reduction in containment iodine inventory reduces the resulting site boundary radiation doses associated with containment leakage. The operation of this system and resultant iodine removal capacity are consistent with the assumptions used in the LOCA analyses. Continuous operation of the system with the heaters operating for 10 hours during each 31-day period is sufficient to reduce the buildup of moisture on the adsorbers and high-efficiency particulate air (HEPA) filters.

CONTAINMENT SYSTEMS

BASES

3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL

The OPERABILITY of the systems required for the detection and control of hydrogen gas ensures that these systems will be available to maintain the hydrogen concentration within the primary containment below its flammable limit during post-LOCA conditions. The drywell and suppression chamber hydrogen recombiner system is capable of controlling the expected hydrogen and oxygen generation associated with (1) zirconium-water reactions, (2) radiolytic decomposition of water, and (3) corrosion of metals within containment. The hydrogen control system is consistent with the recommendations of RG 1.7, "Control of Combustible Gas Concentrations in Containment Following a LOCA," March 1971.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 56 * TO FACILITY OPERATING LICENSE NO. NPF-69
NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT NUCLEAR STATION, UNIT 2
DOCKET NO. 50-410

1.0 INTRODUCTION

By letter dated July 1, 1994, Niagara Mohawk Power Corporation (NMP-2 or the licensee) submitted a request for changes to the Nine Mile Point Nuclear Station, Unit 2, Technical Specifications (TSs). The requested changes would revise the drawdown time testing requirement of TS 4.6.5.1.c.1 and the secondary containment inleakage testing requirement of TS 4.6.5.1.c.2. These revisions would support a revised design basis radiological analysis which would support an increase in secondary containment drawdown time from 6 to 60 minutes by taking credit for fission product scrubbing and retention in the suppression pool. The current design basis radiological analysis does not take credit for the pressure suppression pool as a fission product cleanup system as permitted in NUREG-0800, Section 6.5.5, "Pressure Suppression Pool as a Fission Product Cleanup System." The proposed amendment would also take credit for additional mixing of primary containment and engineered safety feature systems leakage with 50 percent of the secondary containment free air volume prior to the release of radioactivity to the environment. In the revised analysis, mixing is assumed to occur at the onset of a Design Basis Loss-of-Coolant Accident (LOCA) as the primary containment and the engineered safety feature systems leak into secondary containment. The current analysis takes credit for mixing within secondary containment only after achieving a -0.25 inch water gauge (WG) pressure in secondary containment with respect to the outside surrounding atmosphere. The licensee's radiological evaluation for this accident, which reflects these proposed changes and an assumed drawdown time to 60 minutes, has determined that the radiological doses remain below 10 CFR Part 100 guidelines values and General Design Criterion 19 criteria. The revised radiological doses, as calculated by the licensee, are lower than the doses currently presented in the Updated Safety Analysis Report (USAR).

2.0 BACKGROUND

In order that our review of the licensee's submittal is sufficiently complete and comprehensive, it is necessary to recount the following chronological findings from the NRC staff's radiological consequence analyses performed for Nine Mile Point Nuclear Station, Unit 2 (NMP-2) design basis LOCA.

9409070280 940830
PDR ADDCK 05000410
P PDR

(1) Safety Evaluation Report (NUREG-1047) (February 1985)

In Section 15.6.5.2 of the NMP-2 Safety Evaluation Report (SER), the NRC staff stated in part, the following findings:

"The applicant has proposed to maintain all isolation valves in the main steamlines and related drain lines so that total bypass leakage will be less than 6 standard cubic feet per hour (scfh) through these lines. This is a small fraction of the leakage usually measured in existing U.S. boiling-water reactors or similar design, and places great reliance upon the novel valve design. The applicant has informed the staff that a Swiss plant also using this valve design has experienced difficulties in achieving low leakage. The staff has used 6 scfh in computing LOCA dose consequences in Table 15.1, but considers this as an open item pending additional information concerning the operating experience, and successful preoperational testing of the valves."

Using 6 scfh total bypass leakage and the original 90-second drawdown time, the staff calculated the following LOCA offsite doses:

	<u>EAB (rem)</u>		<u>LPZ (rem)</u>	
	<u>Thyroid</u>	<u>Whole Body</u>	<u>Thyroid</u>	<u>Whole Body</u>
LOCA	224	2.6	292	2.4
10 CFR Part 100 Guidelines	300	25	300	25

Subsequently, experience with the ball-type MSIVs during preoperational testing at NMP-2 and laboratory prototype testing has failed to demonstrate that these valves will function as anticipated. The licensee replaced the NMP-2 ball-type main steam isolation valves (MSIVs) with wye pattern globe valves, manufactured by Rockwell, which are similar to those being used in other BWRs.

(2) Supplement No. 2 to NUREG-1047 (November 1985)

In Amendment No. 21 of the NMP-2 Final Safety Analysis Report (FSAR), the licensee identified 20 additional new potential pathways by which containment leakage could bypass the secondary containment. The staff reevaluated LOCA dose consequences in Supplement No. 2 using: (1) the additional 20 new potential bypass pathways, (2) the original 90 second drawdown time, and (3) the TS limit (6 scfh per MSIV) for the MSIV leakage and stated the following, in part, in Section 15.6.5 of Supplement No. 2:

"The applicant submitted two analyses of flows through the bypass leak paths, corresponding to isothermal and adiabatic gas expansions, respectively. Both analyses accounted for slow depressurization of the containment because of leakage, and the cooling of the pipes carrying the bypass flow. The depletion of molecular and particulate iodine fission products was modeled using deposition rate equations developed by an NRC contractor (NUREG/CR-2713). Both analyses concluded that virtually no molecular or particulate iodine would survive passage through the bypass leakage paths, and that iodine could escape to the environment principally as organic vapor (iodomethane), and only after considerable delay in transiting the bypass pathways."

"Following applicable portions of SRP [Standard Review Plan] Sections 6.5.3 and 15.6.5, Appendices A and D, wherever possible, the staff performed an independent analysis. The SRP suggests that the staff assume that bypass leakage occurs at the proposed Technical Specification limit for each valve. Such an assumption is conservative, but prevents any physically consistent treatment of flow variation with temperature. The staff, therefore, assumed constant laminar flow at the Technical Specification limiting rate. This assumption is a deviation from the SRP and more realistically models the release that would occur in such an accident."

"All available information indicated that particulate matter and molecular iodine would be expected to deposit on surfaces, with rates of deposition varying with temperature, pressure, gas composition, surface material, and particulate size. Since these parameters cannot be predicted reliably, the staff assumed simple first-order depletion at a constant rate of 10% per hour. Organic iodine was assumed to pass without depletion. Bypass leakage was assumed to enter the environment at ground level."

Therefore, in Supplement No. 2, the staff recalculated, the following revised LOCA doses:

	<u>EAB (rem)</u>		<u>LPZ (rem)</u>	
	<u>Thyroid</u>	<u>Whole Body</u>	<u>Thyroid</u>	<u>Whole Body</u>
LOCA	55	0.8	265	2.0
10 CFR Part 100 Guidelines	300	25	300	25

(3) Supplement No. 4 to NUREG-1047 (September 1986)

In FSAR Amendment 23, the licensee increased the drawdown time from 90 seconds to 120 seconds and also identified, in their letter dated June 30, 1986, 8 more additional bypass pathways that had not been incorporated in the staff's previous LOCA dose analysis as reported in Supplement 2 to the SER. The staff reevaluated LOCA doses in Supplement 4 and stated the following, in part, in Section 15.6.5:

"The staff notes that the resulting doses are significantly different from those reported in Supplement 2. This is primarily attributable to the different atmospheric dispersion coefficients used in the analyses. For the bypass contribution reported in Supplement 2, the dispersion factors used were those reported in the SER dated February 1985, not the updated factors reported in Section 2 of Supplement 2 dated November 1985. The staff has used the approved updated dispersion factors given in Section 2.3.4 of Supplement 2. Since the revised dispersion coefficients are a factor of 2 to 3 lower than the original values, the resulting bypass dose contribution is lower in spite of the increased leakage rate."

"For the containment leakage contribution reported in the Supplement 2, elevated release dispersion factors were used for the first 2 hours. In this supplement the staff has used, for the containment contribution, the more conservative assumption of a ground release for the first 129 seconds. This results in the increased containment leakage dose relative to that in Supplement 2."

The staff recalculated, in Supplement 4, the following LOCA doses using the revised atmospheric dispersion coefficients.

	<u>EAB (rem)</u>		<u>LPZ (rem)</u>	
	<u>Thyroid</u>	<u>Whole Body</u>	<u>Thyroid</u>	<u>Whole Body</u>
Bypass Leakage	18	0.12	98	0.45
Containment Leakage	35	0.67	14	0.83
ESF Leakage	4	0.10	10	0.10
Total	57	0.89	122	1.38

(4) Supplement No. 5 to NUREG-1047 (October 1986)

In Section 6.4 of Supplement No. 5, the staff performed an independent NMP-2 control room habitability assessment. In its assessment, the staff accepted the licensee's proposed atmospheric diffusion model for determining

atmospheric relative concentrations (χ/Q_s) at control room air intakes. The staff further concluded that the NMP-2 control room habitability system meets the General Design Criterion (GDC) 19 requirements.

3.0 EVALUATION

3.1 Radiological Evaluation

By letter dated July 1, 1994, the licensee submitted a request for a license amendment to increase secondary containment pressure drawdown time for the purpose of inleakage testing evaluation from 2 to 60 minutes following design basis LOCA. This request is represented in changes to: (1) NMP-2 TS 4.6.5.1.c.1, drawdown time testing, and (2) TS 4.6.5.1.c.2, inleakage testing, both for SECONDARY CONTAINMENT INTEGRITY.

In its evaluation, the NRC staff performed an independent radiological consequence assessment as a result of design basis LOCA at the NMP-2 site boundaries and for control room operators as a result of increased secondary containment pressure drawdown time. In its analysis, the NRC staff assumed that containment leakage is released directly to the environment bypassing secondary containment (thus bypassing the standby gas treatment system (SGTS)) for 60 minutes from the onset of a LOCA.

The NRC staff considered in its previous analyses the following three potential fission-product leakage pathways from the primary containment to the environment:

- (1) containment leakage
- (2) leakage bypassing secondary containment including MSIV leakage
- (3) leakage from engineered safety feature (ESF) systems outside containment

In this evaluation, the staff performed radiological consequence analyses for containment leakage pathway only since: (1) no new bypass pathways were identified in this request and the TS limits for the MSIV leakage have not been changed, and (2) no changes are proposed for design basis assumptions used in evaluating leakages from ESF systems outside containment. Therefore, the staff's previously calculated doses resulting from the pathways 2 and 3 should remain the same as presented in Supplement No. 4 to NUREG-1047.

The recalculated doses at the Exclusion Area Boundary (EAB) and Low Population Zone (LPZ) as well as control room operator doses through pathway 1 are presented in Table 1 of this safety evaluation (SE) along with previously calculated doses through pathways 2 and 3 as presented in Supplement No. 4. The assumptions and parameters used in this evaluation are provided in Tables 2 through 4 of this SE. The major assumptions that differ from those used in NUREG-1047 are as follows:

- (1) containment leakage is released directly to the environment bypassing secondary containment (thus bypassing SGTS) for 60 minutes from the onset of a LOCA.
- (2) revised atmospheric relative concentrations (χ/Q_s) reported in Supplement No. 2 (November 1985) to the NMP-2 SER.
- (3) control room χ/Q values reported in FSAR Table 15.6-3 (4.b) and accepted by the staff in Supplement No. 5 to NMP-2 SER.
- (4) dose conversion factors based on ICRP Publication 30, "Limits for Intakes of Radionuclides by Workers."
- (5) fission-product attenuation credit in the main steamlines as given in Supplement Nos. 2 and 4 (September 1986) to the SER.
- (6) fission-product attenuation credit (decontamination factor of 10) in the pressure suppression pool.
- (7) secondary containment 50 percent air mixing credit at the onset of a LOCA as the primary containment and ESF systems leak into secondary containment.

Summary of Radiological Evaluation

Based on the above evaluation, we find that the requested secondary containment pressure drawdown time of 60 minutes is acceptable. The bases for our acceptance are that: (1) the distances to the exclusion area and low population zone outer boundaries for the NMP-2 are still sufficient with the increased pressure drawdown time of 60 minutes to provide reasonable assurance that the calculated radiological consequence of a postulated design basis LOCA will meet the dose guideline values given in 10 CFR Part 100, and (2) the increased drawdown time also meets control room operator dose limits given in GDC 19.

Table 1
RADIOLOGICAL CONSEQUENCES
OF
DESIGN BASIS LOSS OF COOLANT ACCIDENT
(rem)

	EAB		LPZ	
	<u>Thyroid</u>	<u>Whole Body</u>	<u>Thyroid</u>	<u>Whole Body</u>
Bypass Leakage	18	0.12	98	0.45
Containment Leakage	56	1.98	30	0.38
ESF Leakage	4	0.10	10	0.10
Total	78	2.2	138	0.93

CONTROL ROOM OPERATOR DOSE
(rem)

<u>Thyroid</u>	<u>Whole body</u>
20.4	0.6

Table 2 Assumptions Used to Evaluate the Loss-of-Coolant Accident

Parameter	Value
Power level	3489 Mwt
Fraction of core inventory released	
Noble gases	100%
Iodine	50%
Iodine initial plate-out fraction	50%
Iodine chemical species	
Elemental	91%
Particulate	5%
Organic	4%
Suppression pool decontamination factor	
Noble gas	1
Organic iodine	1
Elemental iodine	10
Particulate	10
Iodine dose conversion factors	ICRP-30
Primary containment bypass leakage	1.31%/day
Standby gas treatment system	
Filter efficiency	99%
Flow rate	2670 ft ³ /min
Drawdown time	60 minutes
Primary containment free volume	4.73E+5 ft ³
Secondary containment free volume	3.88E+6 ft ³
Secondary containment mixing efficiency	50 percent

Table 3 Atmospheric Dispersion (χ/Q) Values
Used in Accident Evaluations

Time period	χ/Q value (sec/m ³)	
0-01 hour EAB	8.4E-4	Ground-level release
0-01 hour LPZ	7.9E-6	Ground-level release
1-02 hour EAB	3.4E-5	Elevated/fumigation
1-02 hour LPZ	1.4E-5	Elevated/fumigation
2-08 hour LPZ	8.4E-6	Elevated
8-24 hour LPZ	4.5E-6	Elevated
1-04 day LPZ	1.5E-6	Elevated
4-30 day LPZ	3.2E-7	Elevated

Table 4
CONTROL ROOM ATMOSPHERIC RELATIVE CONCENTRATIONS (χ/Q)
(second/cubic meter)

0-8 hour	2.13E-4
8-24 hour	1.66E-4
1-4 day	9.88E-5
4-30 day	4.70E-5

3.2 Modification of Surveillance Test Drawdown Time Limit

NMP-2 TS 4.6.5.1.c.1 currently specifies that the SGTS be periodically tested to demonstrate that it can drawdown the secondary containment pressure to 0.25 inches of water negative gauge pressure in less than 120 seconds. However, since LOCA conditions and test conditions differ considerably, the licensee proposed that the surveillance test acceptance criteria be adjusted to reflect test conditions. Accordingly, the licensee has analyzed the secondary containment pressure response for both the accident condition and the test condition. The analysis indicates that the same SGTS performance that is capable of reducing secondary containment pressure to 0.25 inches of water negative pressure under LOCA conditions (i.e., with LOCA heat loads) in 1 hour, is capable of reducing the secondary containment pressure to 0.25 inches of water negative gauge pressure in 66.7 seconds under normal surveillance test conditions (which do not include the primary-to-secondary containment heat load). We have reviewed the licensee's analysis and have determined that it is acceptable. Since the revised radiological dose models assume a 1-hour exfiltration period, a 66.7 second drawdown test will verify operability of the SGTS. Accordingly, the proposed change to the surveillance test is acceptable.

3.3 Modification of SGTS Flow rate

NMP-2 TS 4.6.5.1.c.2 currently requires the SGTS to be operated for 1 hour once per 18 months while maintaining a secondary containment pressure of greater than or equal to 0.25 inches of water negative gauge pressure while not exceeding a flow rate of 3190 cfm. The license proposed to reduce this

flow rate to not to exceed 2670 cfm. The proposed flow rate of 2670 cfm is consistent with the assumed secondary containment leak rate during the drawdown period.

The operability of the SGTS is demonstrated by TS 4.6.5.3.b which requires a SGTS flow rate of 4000 cfm \pm 10%. Operation of the SGTS at the reduced secondary containment leak rate of not to exceed 2670 cfm is conservative since the lower flow rate provides additional effluent residence time in the charcoal beds of the SGTS. Therefore, this proposed change is acceptable.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the New York State official was notified of the proposed issuance of the amendment. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes the surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (59 FR 37074). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors:
Donald S. Brinkman
William O. Long
Jay Y. Lee

Date: August 30, 1994

B. Sylvia

-2-

August 30, 1994

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-410

Enclosures: 1. Amendment No. 56 to NPF-69
2. Safety Evaluation

cc w/encls: See next page

DOCUMENT NAME: G:\NMP2\NM289785.AMD

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDI-1	<input checked="" type="checkbox"/>	PM:PDI-1	<input type="checkbox"/>	PRPB:BC	<input type="checkbox"/>	SPLB:BC	<input checked="" type="checkbox"/>	#16	SCSB:BC	<input type="checkbox"/>
NAME	CVogan	<input checked="" type="checkbox"/>	DBrinkman:avh	<input checked="" type="checkbox"/>	LCunningham	<input checked="" type="checkbox"/>	CMcCracken	<input checked="" type="checkbox"/>	WFA	RBarrett	<input checked="" type="checkbox"/>
DATE	08/23/94	8/30/94	08/23/94	10/5	08/24/94	<input checked="" type="checkbox"/>	08/29/94	13.84		08/26/94	<input checked="" type="checkbox"/>
OFFICE	OGC	<input type="checkbox"/>	D:PDI-1	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			<input type="checkbox"/>
NAME	C. Powell	<input type="checkbox"/>	MCase	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			<input type="checkbox"/>
DATE	08/29/94	<input type="checkbox"/>	08/30/94	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			<input type="checkbox"/>

OFFICIAL RECORD COPY