

JAN 22 1974

Docket No. 50-219

Jersey Central Power & Light Company
ATTN: Mr. I. R. Finfrock, Jr.
Vice President - Generation
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Change No. 19
License No. DPR-16

Gentlemen:

Your letter dated January 22, 1974, submitted a proposed change to the Technical Specifications of Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Power Plant Unit No. 1. The proposed change would allow continued operation at 50% power with the oxygen content of the containment atmosphere above 5 volume percent for an additional 48 hours over that specified in Section 3.5.A.6 of the Technical Specifications.

Section V-1 of the SAR states that inerting of the primary containment provides margin against the generation of a flammable mixture of oxygen and hydrogen which may occur in a loss-of-coolant accident (LOCA). The generation of hydrogen following a LOCA is dependent upon the resulting fuel clad temperature which is dependent upon power level in the reactor prior to the accident. With the reactor operating at not greater than 50% rated power, there is additional margin to provide reasonable assurance that the fuel clad temperatures will be below that required to generate a flammable mixture of hydrogen and oxygen following a LOCA.

Based on our review of the proposed change, we have concluded that implementation of the change will not present significant hazards considerations and that there is reasonable assurance that the health and safety of the public will not be endangered by operation in the manner proposed.

C/P
R

JAN 22 1974

Accordingly, pursuant to Section 50.59 of 10 CFR Part 50, the Technical Specifications of Provisional Operating License No. DPR-16 are hereby changed as follows:

On page 3.5-1 of the Technical Specifications add the following to the first sentence of paragraph 3.5.A.6:

"except that between 12:30 p.m., January 22, 1974, and 12:30 p.m., January 24, 1974, the reactor may be operated at power levels up to 50% of rated with O₂ in the primary containment greater than 5%."

This change to the Technical Specifications shall be deleted as of 12:30 p.m., January 24, 1974.

Sincerely,

Donald J. Skovholt
Donald J. Skovholt

for Donald J. Skovholt
Assistant Director for
Operating Reactors
Directorate of Licensing

cc: See next page

Distribution

- ✓ Docket File
- AEC PDR
- Local PDR
- RP REading
- Branch Reading
- JRBuchanan, ORNL
- TBAbernathy, DTIE
- DJskovholt, L:OR
- TJCarter, L:OR
- ACRS (16)
- RO (3)
- O GC
- DLZiemann, L:ORB #2
- JIRiesland, L:ORB #2
- RMDiggs, L:ORB #2
- NDube, L:OPS
- MJinks, DRA (4)
- SKari, L:RP
- PCollins, L:OLB
- BScharf, DRA (15)
- VMoore, L:BWR
- SVarga, L:PR

OFFICE >	L:ORB #2	L:ORB #2	L:ORB #2	L:ORB #2		
X7403	<i>JIRiesland</i>	<i>RMDiggs</i>	<i>DLZiemann</i>	<i>DJskovholt</i>		
SURNAME >	JIRiesland:sjh	RMDiggs	DLZiemann	DJskovholt		
DATE >	1/22/74	1/22/74	1/22/74	1/22/74		

Jersey Central Power & Light
Company

- 3 -

JAN 22 1974

cc: G. F. Trowbridge, Esquire
Shaw, Pittman, Potts, Trowbridge
and Madden
910 - 17th Street, N. W.
Washington, D. C. 20006

GPU Service Corporation
ATTN: Mr. Thomas M. Crimmins
Safety & Licensing Manager
260 Cherry Hill Road
Parsippany, New Jersey 07054

Mr. Kenneth B. Walton
Brigantine Tutoring
309 - 21st Street, S
Brigantine, New Jersey 08203

Miss Dorothy R. Horner
Township Clerk
Township of Ocean
Waretown, New Jersey 08753

Danial Rappoport, Esquire
2323 S. Broad Street
Trenton, New Jersey 08610

Ocean County Library
15 Hooper Avenue
Toms River, New Jersey 08753

cc w/cy of JCPL ltr dtd 1/22/74:
Mr. Hans L. Hamester
ATTN: Joan Sause
Office of Radiation Programs
Environmental Protection Agency
Room 647A East Tower, Waterside Mall
401 M Street, S. W.
Washington, D. C. 20460

Mr. Paul Arbesman
Environmental Protection Agency
JFK Federal Building
Boston, Massachusetts 02203

Anthony Z. Roisman, Esquire
Berlin, Roisman and Kessler
1712 N Street, N. W.
Washington, D. C. 20036

OFFICE ➤						
SURNAME ➤						
DATE ➤						