

MAY 18 1972

DISTRIBUTION
W. Dooly, DR
CO (3)
H. Shapar, OGC
N. Dube, DL (5)
J. Buchanan, ORNL
T. Laughlin, DTIE
PDR
Local PDR
Docket File
DL Reading
Branch Reading
ACRS (16)
R. Boyd
R. DeYoung
Craig Roberts, EPA
D. Skovholt, John Thorpe
T. Carter
Change No. 11
License No. DPR-16

Docket No. 50-219

Jersey Central Power & Light Company
ATTN: Mr. R. H. Sims, Vice President
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Gentlemen:

Your letter dated May 17, 1972, submitted Change Request No. 11 to the Technical Specifications of Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Power Plant Unit No. I. The proposed change would remove the requirement for containment spray system operability when primary containment integrity is not required.

Based on our review of the proposed change, we have concluded that implementation of the change will not present significant hazards considerations not described or implicit in the Safety Analysis Report and that there is reasonable assurance that the health and safety of the public will not be endangered by operation in the manner proposed.

Accordingly, pursuant to Section 50.59 of 10 CFR Part 50, the Technical Specifications of Provisional Operating License No. DPR-16 are hereby changed as indicated in Attachment A.

Sincerely,

151

Donald J. Skovholt
Assistant Director
for Operating Reactors
Directorate of Licensing


Enclosure:
Attachment A - Change to the
Technical Specifications

R. Schemel
T. Wambach
S. Teets

cc: George F. Trowbridge, Esquire
Shaw, Pittman, Potts, Trowbridge & Madden

10-5123/72

OFFICE ▶	L:OR-1	L:OR-1	L:OR-1	L:OR		
SURNAME ▶	TWambach:pd1	SATeets	RJSchemel	DJSkovholt		LB
DATE ▶	5/18/72	5/18/72	5/18/72	5/18/72		



UNITED STATES
ATOMIC ENERGY COMMISSION

WASHINGTON, D.C. 20545

MAY 18 1972

Docket No. 50-219

Jersey Central Power & Light Company
ATTN: Mr. R. H. Sims, Vice President
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Change No. 11
License No. DPR-16

Gentlemen:

Your letter dated May 17, 1972, submitted Change Request No. 11 to the Technical Specifications of Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Power Plant Unit No. I. The proposed change would remove the requirement for containment spray system operability when primary containment integrity is not required.

Based on our review of the proposed change, we have concluded that implementation of the change will not present significant hazards considerations not described or implicit in the Safety Analysis Report and that there is reasonable assurance that the health and safety of the public will not be endangered by operation in the manner proposed.

Accordingly, pursuant to Section 50.59 of 10 CFR Part 50, the Technical Specifications of Provisional Operating License No. DPR-16 are hereby changed as indicated in Attachment A.

Sincerely,

A handwritten signature in dark ink, appearing to read "Donald J. Skovholt", is written over the typed name.

Donald J. Skovholt
Assistant Director
for Operating Reactors
Directorate of Licensing

Enclosure:
Attachment A - Change to the
Technical Specifications

cc: George F. Trowbridge, Esquire
Shaw, Pittman, Potts, Trowbridge & Madden

ATTACHMENT A

CHANGE NO. 11 TO THE TECHNICAL SPECIFICATIONS

PROVISIONAL OPERATING LICENSE NO. DPR-16

JERSEY CENTRAL POWER & LIGHT COMPANY

DOCKET NO. 50-219

1. On page 3.4-2, change the last two lines of paragraph 3.4.C.1 to read:
"specified in Specifications 3.4.C.3, 3.4.C.4, 3.4.C.6 and 3.4.C.8."
2. On page 3.4-2, add the following paragraph after paragraph 3.4.C.5:
"6. If primary containment integrity is not required (see Specification 3.5.A.1), the containment spray system may be made inoperable."
3. On page 3.4-3, change the present paragraph 3.4.C.6 to read:
"7. If Specifications 3.4.C.3, 3.4.C.4, 3.4.C.5 or 3.4.C.6 are not met, . . ."
4. On page 3.4-3, change paragraph number "7" on the second paragraph to "8".
5. On page 3.4-5, add the following to the first full paragraph on that page:
"Similarly, since a loss-of-coolant accident when primary containment integrity is not being maintained would not result in pressure build-up in the drywell or torus, the system may be made inoperable under these conditions. This prevents possible personnel injury associated with contact with chromated torus water."

MAY 18 1972