

DEC 16 1976

Distribution

- ✓ Docket
- ORB #3
- Local PDR
- NRC PDR
- VStello
- KGoller
- TJCarter
- GLear
- CParrish
- TWambach
- JShea
- Attorney, OELD
- OI&E (3)
- DEisenhut
- TBAbernathy
- JRBuchanan
- ACRS (16)

Docket No. 50-219

Jersey Central Power & Light Company
 ATTN: Mr. I. R. Finfrock, Jr.
 Vice President - Generation
 Madison Avenue at Punch Bowl Road
 Morristown, New Jersey 07960

Gentlemen:

RE: OYSTER CREEK NUCLEAR GENERATING STATION UNIT NO. 1

We are enclosing a corrected Specification 4.7.11.2 that has been sent to you as part of the Standard Technical Specifications (STS) for Fire Protection by letter dated December 2, 1976.

Sincerely,

Original signed by

George Lear, Chief
 Operating Reactors Branch #3
 Division of Operating Reactors

Enclosure:
 Specification 4.7.11.2

cc w/encl:
 See next page

[Handwritten signature]
 Const 2

OFFICE →	ORB #1 <i>JVM</i>	ORB #3	ORB #3			
SURNAME →	Twambach:mjf	JShea <i>JH</i>	GLear <i>GL</i>			
DATE →	12/15/76	12/17/76	12/10/76			

Jersey Central Power & Light Company - 2 -

cc: G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
Barr Building
910 17th Street, N. W.
Washington, D. C. 20006

Jersey Central Power & Light Company
ATTN: Mr. Thomas M. Crimmins, Jr.
Safety and Licensing Manager
GPU Service Corporation
260 Cherry Hill Road
Parsippany, New Jersey 07054

Anthony Z. Roisman, Esquire
Roisman, Kessler and Cashdan
1025 15th Street, N. W.
5th Floor
Washington, D. C. 20005

Steven P. Russo, Esquire
248 Washington Street
P. O. Box 1060
Toms River, New Jersey 08753

Ocean County Library
Brick Township Branch
401 Chambers Bridge Road
Brick Town, New Jersey 08723

NOV 03 1976

PLANT SYSTEMS

SPRAY AND/OR SPRINKLER SYSTEMS

LIMITING CONDITION FOR OPERATION

3.7.11.2 The spray and/or sprinkler systems located in the following areas shall be OPERABLE:

- a.
- b. (Plant dependent)
- c.

APPLICABILITY: All modes

ACTIONS:

With a spray and/or sprinkler system inoperable establish a continuous fire watch with backup fire suppression equipment in the unprotected area(s), and

- 1. In MODES 1, 2, 3 or 4 restore the system to OPERABLE status within 7 days or be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- 2. In MODES 5 or 6 restore the system to OPERABLE status within 7 days or prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within the next 10 days outlining the cause of inoperability and the plans for restoring the system to OPERABLE status.

SURVEILLANCE REQUIREMENTS

4.7.11.2 The spray and/or spinkler systems shall be demonstrated to be OPERABLE:

- a. At least once per 92 days by cycling each testable valve through one complete cycle.
- b. At least once per 12 months:
 - 1. By performing a system functional test which includes simulated automatic actuation of the system and verifying that the automatic valves in the flow path actuate to their correct positions.
 - 2. By inspection of spray headers to verify their integrity
 - 3. By inspection of each nozzle to verify no blockage.
- c. At least once per 5 years by an air flow test of the open head spray and/or sprinkler system.