

DEC 17 1969

Docket No. 50-219

DISTRIBUTION:

- W. Dooly, DR
- R. Engelken, CO (2)
- H. K. Shapar, OGC
- N. Dube, DRL (5)
- J. R. Buchanan, ORNL
- H. J. McAlduff, OROO
- T. W. Laughlin, DTIE
- Document Room
- ✓ Docket File
- DR Reading
- DRL Reading
- Branch Reading
- ACRS (3)
- S. D. MacKay
- D. Thompson

Jersey Central Power & Light Company
 Madison Avenue at Punch Bowl Road
 Morristown, New Jersey 07960

Attention: George H. Ritter
 Vice President

Supplement No. 1 to
 Change No. 1

Gentlemen:

Change No. 1 dated November 13, 1969, authorized the substitution of Figure TS-1 (your designation) for Figure 2.1.1. and changed Section 2.1.B. to the Technical Specifications to Provisional Operating License No. DPR-16, to extend the fuel cladding safety limit to include the region of operation between 5% core coolant flow and 20% core coolant flow.

Pursuant to the discussions between our respective staff members, Figure TS-1 should have been designated Figure 2.1.1 (Revised). Accordingly, Figure TS-1 issued with Change No. 1 is hereby redesignated Figure 2.1.1. (Revised November 13, 1969). Wherever reference is made to Figure 2.1.1. in the Technical Specifications it refers to the revised figure dated November 13, 1969.

We have also noted that the bases to Section 2.1.B. of the Technical Specifications should be revised to show a figure of 5% flow instead of 20% flow on line 5 in the fifth paragraph on page 2.1-3.


Sincerely,

Peter A. Morris, Director
 Division of Reactor Licensing

License

*dispatched
 12-18-69.*

OFFICE ▶	DRL:ORB 1	DRL:ORB 1	DRL:ORB 1	DRL:OSB	DRL	DRL
SURNAME ▶	<i>SAT</i> SATEcts:sjg	<i>SDM</i> SDMacKay	<i>RS</i> RJSchemel	<i>DT</i> DThompson	<i>DJS</i> DJSkovholt	<i>PM</i> PAMorris
DATE ▶	12/11/69	12/15/69	12/15/69	12/16/69	12/16/69	12/16/69



UNITED STATES
ATOMIC ENERGY COMMISSION

WASHINGTON, D.C. 20545

December 17, 1969

Docket No. 50-219

Jersey Central Power & Light Company
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Attention: George H. Ritter
Vice President

Supplement No. 1 to
Change No. 1

Gentlemen:

Change No. 1 dated November 13, 1969, authorized the substitution of Figure TS-1 (your designation) for Figure 2.1.1. and changed Section 2.1.B. to the Technical Specifications to Provisional Operating License No. DPR-16, to extend the fuel cladding safety limit to include the region of operation between 5% core coolant flow and 20% core coolant flow.

Pursuant to the discussions between our respective staff members, Figure TS-1 should have been designated Figure 2.1.1. (Revised). Accordingly, Figure TS-1 issued with Change No. 1 is hereby redesignated Figure 2.1.1. (Revised November 13, 1969). Wherever reference is made to Figure 2.1.1. in the Technical Specifications it refers to the revised figure dated November 13, 1969.

We have also noted that the bases to Section 2.1.B. of the Technical Specifications should be revised to show a figure of 5% flow instead of 20% flow on line 5 in the fifth paragraph on page 2.1-3.

Sincerely,


Peter A. Morris, Director
Division of Reactor Licensing