

NOV 22 1978

Docket No. 50-219

Jersey Central Power & Light Company
ATTN: Mr. I. R. Finfrock, Jr.
Vice President - Generation
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Gentlemen:

By Amendment No. 33 to License No. DPR-16, dated November 11, 1978, we inadvertently issued erroneous LHGR's for fuel types III E and III F. Therefore, you are requested to replace Page 3.10-2 of the Appendix A Technical Specifications for the Oyster Creek Nuclear Generating Station with the enclosed page.

We regret any inconvenience caused by this administrative error.

Sincerely,

*original signed by
R. Silver fox*

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosure:
Page 3.10-2

cc:
See next page

DISTRIBUTION:
Docket (50-219)
NRC PDR
Local PDR
ORB#2 RDG
VStello
BGrimes
HSmith
SNowicki
OELD
OI&E(5)
BJones(4)
BScharf(15)
STS Group

BHarless
DEisenhut
ACRS(16)
CMiles, OPA
RDiggs
DDavis
TERA
JRBuchanan

7812060420

9 CP=1

OFFICE >	DOR:ORB#2	DOR:ORB#2	DOR:ORB#2		
SURNAME >	HSmith:sah	SNowicki	DLZiemann		
DATE >	11/22/78	11/22/78	11/22/78		

cc
G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

GPU Service Corporation
ATTN: Mr. E. G. Wallace
Licensing Manager
260 Cherry Hill Road
Parsippany, New Jersey 07054

Anthony Z. Roisman
Natural Resources Defense Council
917 15th Street, N. W.
Washington, D. C. 20005

Steven P. Russo, Esquire
248 Washington Street
P. O. Box 1060
Toms River, New Jersey 08753

Joseph W. Ferraro, Jr., Esquire
Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
1100 Raymond Boulevard
Newark, New Jersey 07012

Ocean County Library
Brick Township Branch
401 Chambers Bridge Road
Brick Town, New Jersey 08723

Mayor
Lacey Township
P. O. Box 475
Forked River, New Jersey 08731

Department of Public Utilities
State of New Jersey
101 Commerce Street
Newark, New Jersey 07102

Gene Fisher
Bureau Chief
Bureau of Radiation Protection
380 Scotts Road
Trenton, New Jersey 08628

Mark L. First
Deputy Attorney General
State of New Jersey
Department of Law & Public
Safety
Environmental Protection Agency
36 West State Street
Trenton, New Jersey 08625

Joseph T. Carroll, Jr.
Plant Superintendent
Oyster Creek Nuclear Generating
Station
Post Office Box 388
Forked River, New Jersey 08731

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
US EPA
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection
Agency
Region II Office
ATTN: EIS COORDINATOR
26 Federal Plaza
New York, New York 10007

and

<u>Fuel Type</u>	<u>LHGR_d</u>	<u>ΔP/P</u>
II	17.2	.032
IIIE	17.2	.046
IIIF	17.2	.033
V	14.5	.033
VB	14.5	.039

If at any time during operation it is determined by normal surveillance that the limiting value for LHGR is being exceeded, action shall be initiated to restore operation to within the prescribed limits. If the LHGR is not returned to within the prescribed limits within two (2) hours, action shall be initiated to bring the reactor to the cold shutdown condition within 36 hours. During this period, surveillance and corresponding action shall continue until reactor operation is within the prescribed limits at which time power operation may be continued.

C. Assembly Averaged Power Void Relationship (Applied to type II fuel only)

During power operation, the assembly average void fraction and assembly power shall be such that the following relationship is satisfied:

$$\left(\frac{1-VF}{PR \times FCP} \right) \geq B$$

Where: VF = Bundle average void fraction
 PR = Assembly radial power factor
 FCP = Fractional core power (relative to 1930 Mwt)
 B = Power-Void limit

The limiting value of "B" for fuel type II is .365.

D. Minimum Critical Power Ratio (MCPR)

During steady state power operation, MCPR shall be greater than or equal to the following:

<u>ARPM Status</u>	<u>MCPR Limit</u>
1. If any two (2) LPRM assemblies which are input to the APRM system and are separated in distance by less than	1.64