

June 12, 1984

Docket No. 50-219
LS05-84-06-022

Mr. P.B. Fiedler
Vice President & Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: ORDER CONFIRMING LICENSEE COMMITMENTS ON EMERGENCY RESPONSE
CAPABILITY SCHEDULES (GENERIC LETTER 82-33)

Oyster Creek Nuclear Generating Station

The Commission has issued the enclosed Order confirming your commitments on emergency response capability. This Order is based on your letters dated April 15, 1983 and July 18, 1983, and March 9 and April 9, 1984 committing to the actions specified in the Order.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Original signed by James Lyons
for

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

*SEO1
DO USE 51*
*ADD: T. BARNHART (4)
L. HARMON (2)
R. DIGGS (1)
C. MILES (1)
O BEO, J.
LIEBERMAN*

Enclosure:
Order

cc w/enclosure:
see next page

DISTRIBUTION

Docket
NRC PDR
Local PDR
NSIC
ORB Reading
DCrutchfield
HSmith
JLombardo
OELD, JLieberman
ELJordan
JMTaylor
TBarnhart
RDiggs
OPA, C. Miles

8406250283 840612
PDR ADOCK 05000219
F PDR

*SEE PREVIOUS PAGES FOR CONCURRENCE

DL: ORB #5* DL: ORB #5* OELD* DL: ORB #5* DL: AD/SA* DL: ~~DER~~
HSmith:cc JLombardo JLieberman DCrutchfield FMiraglia DEtschhut
08/10/83 08/26/83 09/9/83 09/14/83 09/15/83 6/12/84

Docket No. 50-219

Mr. P.B. Fiedler
Vice President & Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: ORDER CONFIRMING LICENSEE COMMITMENTS ON EMERGENCY RESPONSE
CAPABILITY SCHEDULES (GENERIC LETTER 82-33)

Oyster Creek Nuclear Generating Station

The Commission has issued the enclosed Order confirming your commitments on emergency response capability. This Order is based on your letters dated April 15, 1983 and July 18, 1983, committing to the actions specified in the Order.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Order

cc w/enclosure:
see next page

DISTRIBUTION

Docket	JLombardo
NRC PDR	OELD, JLieberman
Local PDR	ELJordan
NSIC	JMTaylor
ORB Reading	TBarnhart
DCrutchfield	RDiggs
HSmith	OPA, C. Miles

*SEE PREVIOUS TISSUE FOR CONCURRENCE

DL: ORB #5*
HSmith:cc
8/10/83 &
8/26/83

DL: ORB #5*
JLombardo
8/26/83

OELD*
JLieberman
9/9/83

DL: ORB #5
DCrutchfield
9/14/83

DL: ADISA
FMITaglia
9/16/83

DL: DIR
DEisenhut
1/83

Docket No. 50-219

DISTRIBUTION
Docket
NRC PDR
Local PDR
NSIC
ORB Reading
DCrutchfield
HSmith
JLombardo
OELD, Lieberman
ELJordan
JMTaylor
TBarnhart (4)
RDiggs
OPA, C. Miles

Mr. P. B. Fiedler
Vice President & Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: ORDER CONFIRMING LICENSEE COMMITMENTS ON EMERGENCY RESPONSE
CAPABILITY SCHEDULES (GENERIC LETTER 82-33)

Oyster Creek Nuclear Generating Station

The Commission has issued the enclosed Order confirming your commitments on emergency response capability. This Order is based on your letters dated April 15, 1983 and July 18, 1983, committing to the actions specified in the Orders.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Order

cc w/enclosure:
See next page

L. Crutchfield J. Lieberman

*SEE PREVIOUS TISSUE FOR CONCURRENCE *subject to concurrence*

OFFICE	DL: ORB #5	DL: ORB #5	OELD	DL: ORB #5	DL: AD/SA	DL: DIR
SURNAME	HSmith, cc	JLombardo	J. Lieberman	DCrutchfield	FMiraglia	DEisenhut
DATE	8/10/83	8/26/83	9/9/83	1/83	1/83	1/83



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 12, 1984

Docket No. 50-219
LS05-84-06-022

Mr. P.B. Fiedler
Vice President & Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:


SUBJECT: ORDER CONFIRMING LICENSEE COMMITMENTS ON EMERGENCY RESPONSE
CAPABILITY SCHEDULES (GENERIC LETTER 82-33)

Oyster Creek Nuclear Generating Station

The Commission has issued the enclosed Order confirming your commitments on emergency response capability. This Order is based on your letters dated April 15, 1983 and July 18, 1983, and March 9 and April 9, 1984 committing to the actions specified in the Order.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

for 
Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Order

cc w/enclosure:
see next page

Mr. P. B. Fiedler

cc
G.F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

J.B. Lieberman, Esquire
Berlack, Isreals & Lieberman
26 Broadway
New York, New York 10004

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Dr. Thomas E. Murley
Regional Administrator
Nuclear Regulatory Commission
Region I Office
631 Park Avenue
King of Prussia, Pennsylvania 19406

Frank Cosolito, Acting Chief
Bureau of Radiation Protection
Department of Environmental
Protection
380 Scotch Road
Trenton, New Jersey 08628

Jim Knubel
BWR Licensing Manager
GPU Nuclear
100 Interplace Parkway
Parsippany, New Jersey 08625

Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
36 West State Street - CN 112
Trenton, New Jersey 08625

Mayor
Lacey Township
818 Lacey Road
Forked River, New Jersey 08731

U.S. Environmental Protection Agency
Region II Office
ATTN: Regional Radiation Representative
26 Federal Plaza
New York, New York 10007

Licensing Supervisor
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of

GPU NUCLEAR CORPORATION AND JERSEY
CENTRAL POWER AND LIGHT COMPANY

(Oyster Creek Nuclear Generating
Station)

Docket No. 50-219

ORDER CONFIRMING LICENSEE COMMITMENTS
ON EMERGENCY RESPONSE CAPABILITY

I.

GPU Nuclear Corporation (GPUNC) and Jersey Central Power and Light Company (the licensees) are the holders of Provisional Operating License No. DPR-16 which authorizes the operation of the Oyster Creek Nuclear Generating Station (the facility) at steady-state power levels not in excess of 1930 megawatts thermal. The facility is a boiling water reactor (BWR) located in Ocean County, New Jersey.

II.

Following the accident at Three Mile Island Unit No. 2 (TMI-2) on March 28, 1979, the Nuclear Regulatory Commission (NRC) staff developed a number of proposed requirements to be implemented on operating reactors and on plants under construction. These requirements include Operational Safety, Siting and Design, and Emergency Preparedness and are intended to provide substantial additional protection in the operation of nuclear facilities and significant upgrading of emergency response capability based on the experience from the accident at TMI-2 and the official studies and investigations of the

8406250297 840612
PDR ADDCK 05000219
F PDR

- 2 -

accident. The requirements are set forth in NUREG-0737, "Clarification of TMI Action PPlan Requirements," and in Supplement 1 to NUREG-0737, "Requirements for Emergency Response Capability." Among these requirements are a number of items consisting of emergency response facility operability, emergency procedure implementation, addition of instrumentation, possible control room design modifications, and specific information to be submitted.

On December 17, 1982, a letter (Generic Letter 82-33) was sent to all licensees of operating reactors, applicants for operating licenses, and holders of construction permits enclosing Supplement 1 to NUREG-0737. In this letter operating reactor licensees and holders of construction permits were requested to furnish the following information, pursuant to 10 CFR 50.54(f), no later than April 15, 1983:

- (1) A proposed schedule for completing each of the basic requirements for the items identified in Supplement 1 to NUREG-0737, and
- (2) A description of plans for phased implementation and integration of emergency response activities including training.

III.

GPUNC responded to Generic Letter 82-33 by letter dated April 15, 1983, and provided supplemental information by letter dated July 18, 1983, March 9 and April 9, 1984. In these submittals, GPUNC made commitments to complete the basic requirements. The attached Table summarizing GPUNC schedular commitments or status was developed by the NRC staff from the Generic Letter and the information provided by GPUNC.

- 3 -

GPUNC commitments include (1) dates for providing required submittals to the NRC, (2) dates for implementing certain requirements, and (3) a schedule for providing implementation dates for other requirements. These latter implementation dates will be reviewed, negotiated and confirmed by a subsequent order.

The NRC staff reviewed GPUNC's April 15, 1983 letter and entered into negotiations with the licensee regarding schedules for meeting the requirements of Supplement 1 to NUREG-0737. As a result of these negotiations, the licensee provided additional information and a detailed schedule of interim events in letters dated July 18, 1983, March 9 and April 9, 1984. The NRC staff finds that the dates are reasonable, achievable dates for meeting the Commission requirements. The NRC staff concludes that the schedule proposed by the licensee will provide timely upgrading of the licensee's emergency response capability.

In view of the foregoing, I have determined that the implementation of GPUNC commitments are required in the interest of the public health and safety and should, therefore, be confirmed by an immediately effective Order.

IV.

Accordingly, pursuant to Sections 103, 161i, 161o and 182 of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED, EFFECTIVE IMMEDIATELY, THAT the licensee shall:

Implement the specific items described in the Attachment to this ORDER in the manner described in GPUNC's submittals noted in Section III herein no later than the dates specified in the Attachment.

- 4 -

Extensions of time for completing these items may be granted by the Director, Division of Licensing, for good cause shown.

V.


The licensees may request a hearing on this Order within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing should be addressed to the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555. A copy should also be sent to the Executive Legal Director at the same address. A REQUEST FOR HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.

If a hearing is to be held, the Commission will issue an Order designating the time and place of any such hearing.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether the licensees should comply with the requirements set forth in Section IV of this Order.

This Order is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland,
this 12 day of June 1984.

Attachment:
Licensees' Commitments on
Requirements Specified in
Supplement 1 to NUREG-0737

OYSTER CREEK NUCLEAR GENERATING STATION

LICENSEE'S COMMITMENTS ON SUPPLEMENT 1 TO NUREG-0737

TITLE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)
1. Safety Parameter Display System (SPDS)	1a. Submit a safety analysis and an implementation plan to the NRC.	Safety Analysis Complete Implementation Plan 4/84
	1b. SPDS fully operational and operators trained.	11/85*
2. Detailed Control Room Design:	2a. Submit a program plan to the NRC.	Complete
	2b. Submit a summary report to the NRC including a proposed schedule for implementation.	4/84G
3. Regulatory Guide 1.97 Application to Emergency Response Facilities	3a. Submit a report to the NRC describing how the requirements of Supplement 1 to NUREG-0737 have been or will be met.	5/84
	3b. Implement (installation or upgrade) requirements.	Date will be provided in the 5/84 report.

*Beginning of Cycle 11 outage. Basic SPDS will be available at end of outage. - Future Enhancements will be made along with the development of additional soft ware.

OYSTER CREEK NUCLEAR GENERATING STATION

LICENSEE'S COMMITMENTS ON SUPPLEMENT 1 TO NUREG-0737

TITLE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)
4. Upgrade Emergency Operating Procedures (EOPs)	4a. Submit a Procedures Generation Package to the NRC.	Complete
	4b. Implement the upgraded EOPs.	1/86 (Prior to restart from Cycle 11 outage)
5. Emergency Response Facilities	5a. Technical Support Center fully functional.	11/85 (SPDS Dependent)
	5b. Operational Support Center fully functional.	Complete
	5c. Emergency Operations Facility fully functional.	11/85 (SPDS Dependent)