

June 7, 1985

Amdt. 86 to DPR-16

Docket No. 50-219
LS05-85-06-013

Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:

DISTRIBUTION

Docket File	NRC PDR
Local PDR	NSIC
ORB# 5 Rdg	JDonohew
CJamerson	EButcher
JZwolinski	JPartlow
FEltawilia	ELJordan
OELD	ACRS (10)
LJHarmon	RDiggs (w/TACS)
TBarnhart (4)	WJones
CMiles	BGrimes
BGrimes	JKudrick

SUBJECT: PRIMARY CONTAINMENT ATMOSPHERE OXYGEN CONCENTRATION

Re: Oyster Creek Nuclear Generating Station

The Commission has issued the enclosed Amendment No. 86 to Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Generating Station (OCNGS). This amendment is in response to your application dated July 19, 1984, as supplemented by the agreement in meeting minutes dated February 22, 1985.

The amendment authorizes changes to the Appendix A Technical Specifications (TS) related to the primary containment atmosphere to (1) reduce the maximum oxygen limit for the primary containment atmosphere in Section 3.5 from less than 5% to less than 4% within 24 hours after the reactor mode selector switch is placed in the run mode and (2) correct a typographical spelling error in the Bases for Section 4.5.

A Notice of Consideration of Issuance of Amendment to License and Proposed No Significant Hazards Consideration Determination and Opportunity for Hearing related to the requested action was published in the Federal Register on March 27, 1985 (50 FR 12145). No public comments or requests for hearing were received.

A copy of our related Safety Evaluation is also enclosed. A notice of issuance pertaining to this action will appear in the Commission's Monthly Notice publication in the Federal Register.

Sincerely,

Original signed by:

John A. Zwolinski, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosures:

- Amendment No. 86 to License No. DPR-16
- Safety Evaluation

8506120318 850607
PDR ADDCK 05000219
P PDR

*SEE 1
DSU USE 51*

cc w/enclosures:
See next page

DL: ORB #5
CJamerson:cs
5/25/85

DL: ORB #5
JDonohew
5/23/85

OELD
5/29/85

DL: ORB #5
JZwolinski
6/1/85

DL: ADVSA
DCrutchfield
6/7/85

Mr. P. B. Fiedler
Oyster Creek Nuclear Generating Station

Oyster Creek Nuclear Generating Station

cc
G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

J.B. Liberman, Esquire
Bishop, Liberman, Cook, et al.
1155 Avenue of the Americas
New York, New York 10036

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Regional Administrator
Nuclear Regulatory Commission
Region I Office
631 Park Avenue
King of Prussia, Pennsylvania 19406

Eugene Fisher, Assistant Director
Division of Environmental Quality
Department of Environmental
Protection
380 Scotch Road
Trenton, New Jersey 08628

BWR Licensing Manager
GPU Nuclear
100 Interpace Parkway
Parsippany, New Jersey 07054

Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
36 West State Street - CN 112
Trenton, New Jersey 08625

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

U.S. Environmental Protection Agency
Region II Office
ATTN: Regional Radiation Representative
26 Federal Plaza
New York, New York 10007

D. G. Holland
Licensing Manager
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GPU NUCLEAR CORPORATION

AND

JERSEY CENTRAL POWER & LIGHT COMPANY

OYSTER CREEK NUCLEAR GENERATING STATION

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 86
License No. DPR-16

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by GPU Nuclear Corporation and Jersey Central Power and Light Company (the licensees) dated July 19, 1984, as supplemented by agreement noted in meeting minutes of February 22, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8506120325 850607
PDR ADDCK 05000219
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C(2) of Provisional Operating License No. DPR-16 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 86, are hereby incorporated in the license. GPU Nuclear Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John A. Zwolinski, Chief
Operating Reactors Branch #5
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 7, 1985.

ATTACHMENT TO LICENSE AMENDMENT NO.86

PROVISIONAL OPERATING LICENSE NO. DPR-16

DOCKET NO. 50-219

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain vertical lines indicating the area of change.

REMOVE

3.5-3
3.5-5
3.5-7
4.5-10

INSERT

3.5-3
3.5-5
3.5-7
4.5-10

- b. Two of the fourteen suppression chamber - drywell vacuum breakers may be inoperable provided that they are secured in the closed position.
 - c. One position alarm circuit for each operable vacuum breaker may be inoperable for up to 15 days provided that each operable suppression chamber - drywell vacuum breaker with one defective alarm circuit is physically verified to be closed immediately and daily during this period.
6. After completion of the startup test program and demonstration of plant electrical output, the primary containment atmosphere shall be reduced to less than 4.0% O₂ with nitrogen gas within 24 hours after the reactor mode selector switch is placed in the run mode. Primary containment deinerting may commence 24 hours prior to a scheduled shutdown.
 7. If specifications 3.5.A.1.a, b, c(1) and 3.5.A.2 through 3.5.A.5 cannot be met, reactor shutdown shall be initiated and the reactor shall be in the cold shutdown condition within 24 hours.
 8. Shock Suppressors (Snubbers)
 - a. During all modes of operation except cold shutdown and refuel, all safety related snubbers listed in Table 3.5.1 shall be operable except as noted 3.5.A.8.b, c and d below.
 - b. From and after the time that a snubber is determined to be inoperable, continued reactor operation is permissible only during the succeeding 72 hours unless the snubber is sooner made operable or replaced.
 - c. If the requirements of 3.5.A.8.a and 3.5.A.8.b cannot be met, an orderly shutdown shall be initiated and the reactor shall be in a cold shutdown condition within 36 hours.
 - d. If a snubber is determined to be inoperable while the reactor is in the shutdown or refuel mode, the snubber shall be made operable or replaced prior to reactor startup.
 - e. Snubbers may be added to safety related systems without prior License Amendment to Table 3.5.1 provided that a revision to Table 3.5.1 is included with the next License Amendment request.
 9. Drywell-Suppression Chamber Differential Pressure
 - a. Differential pressure between the drywell and suppression chamber shall be maintained within the acceptable operating range shown on Figure 3.5-1 within 24 hours after the reactor mode selector switch is placed in the run mode. The differential pressure may be reduced to less than the range shown on Figure 3.5-1 24 hours prior to a scheduled shutdown. The differential pressure may be decreased to less than the required value for a maximum of four hours during required operability testing of the drywell-pressure suppression chamber vacuum breakers.

importantly, the accessibility of the valve lever arm and position reference external to the valve. The fail-safe feature of the alarm circuits assures operator attention if a line fault occurs.

Conservative estimates of the hydrogen produced, consistent with the core cooling system provided, show that the hydrogen air mixture resulting from a loss-of-coolant accident is considerably below the flammability limit and hence it cannot burn, and inerting would not be needed. However, inerting of the primary containment was included in the proposed design and operation. The 5% oxygen limit is the oxygen concentration limit stated by the American Gas Association for hydrogen-oxygen mixtures below which combustion will not occur. (4) The 4% oxygen limit was established by analysis of the Generation and Mitigation of (12) Combustible Gas Mixtures in Inerted BWR Mark I Containments.

To preclude the possibility of starting up the reactor and operating a long period of time with a significant leak in the primary system, leak checks must be made when the system is at or near rated temperature and pressure. It has been shown that an acceptable margin with respect to flammability exists without containment inerting. Inerting the primary containment provides additional margin to that already considered acceptable. Therefore, permitting access to the drywell for the purpose of leak checking would not reduce the margin of safety below that considered adequate and is judged prudent in terms of the added plant safety offered by the opportunity for leak inspection. The 24-hour time to provide inerting is judged to be a reasonable time to perform the operation and establish the required O₂ limit.

Snubbers are designed to prevent unrestrained pipe motion under dynamic loads as might occur during an earthquake or severe transient, while allowing normal thermal motion during startup and shutdown. The consequence of an inoperable snubber is an increase in the probability of structural damage to piping as a result of a seismic or other event initiating dynamic loads. It is, therefore, required that all snubbers required to protect the primary coolant system or any other safety system or component be operable during reactor operation.

All safety related hydraulic snubbers are visually inspected for overall integrity and operability. The

When secondary containment is not maintained, the additional restrictions on operation and maintenance give assurance that the probability of inadvertent releases of radioactive material will be minimized. Maintenance will not be performed on systems which connect to the reactor vessel lower than the top of the active fuel unless the system is isolated by at least one locked closed isolation valve.

The standby gas treatment system (6) filters and exhausts the reactor building atmosphere to the stack during secondary containment isolation conditions, with a minimum release of radioactive materials from the reactor building to the environs.

Two separate filter trains are provided each having 100% capacity. (6) If one filter train becomes inoperable, there is no immediate threat to secondary containment and reactor operation may continue while repairs are being made. Since the test interval for this system is one month (Specification 4.5), the time out-of-service allowance of 7 days is based on considerations presented in the Bases in Specification 3.2 for a one-out-of-two system.

- References:
- (1) FDSAR, Volume I, Section V-1
 - (2) FDSAR, Volume I, Section V-1.4.1
 - (3) FDSAR, Volume I, Section V-1.7
 - (4) Licensing Application, Amendment 11, Question III-25
 - (5) FDSAR, Volume I, Section V-2
 - (6) FDSAR, Volume I, Section V-2.4
 - (7) Licensing Application, Amendment 42
 - (8) Licensing Application, Amendment 32, Question 3
 - (9) Robbins, C. H., "Tests on a Full Scale 1/48 Segment of the Humboldt Bay Pressure Suppression Containment," GEAP-3596, November 17, 1960.
 - (10) Bodega Bay Preliminary Hazards Summary Report, Appendix I, Docket 50-205, December 28, 1962.
 - (11) Report H. R. Erickson, Bergen-Paterson to K. R. Goller, NRC, October 7, 1974. Subject: Hydraulic Shock Sway Arrestors.
 - (12) General Electric NEDO-22155 "Generation and Mitigation of Combustible Gas Mixtures in Inerted BWR Mark I Containments" June 1982.

In conjunction with the Mark I Containment Short Term Program, a plant unique analysis was performed on August 2, 1976, which demonstrated a factor of safety of at least two for the weakest element in the suppression chamber support system. The maintenance of a drywell-suppression chamber differential pressure within the range shown on Figure 3.5-1 with a suppression chamber water level corresponding to a downcomer submergence range of 3.0 to 5.3 feet will assure the integrity of the suppression chamber when subjected to post-LOCA suppression pool hydrodynamic forces.

After the containment oxygen concentration has been reduced to meet the specification initially, the containment atmosphere is maintained above atmospheric pressure by the primary containment inerting system. This system supplies nitrogen makeup to the containment so that the very slight leakage from the containment is replaced by nitrogen, further reducing the oxygen concentration. In addition, the oxygen concentration is continuously recorded and high oxygen concentration is annunciated. Therefore, a weekly check of oxygen concentration is adequate. This system also provides capability for determining if there is gross leakage from the containment.

The drywell exterior was coated with Firebar D prior to concrete pouring during construction. The Firebar D separated the drywell steel plate from the concrete. After installation, the drywell liner was heated and expanded to compress the Firebar D to supply a gap between the steel drywell and the concrete. The gap prevents contact of the drywell wall with the concrete which might cause excessive local stresses during drywell expansion in a loss-of-coolant accident. The surveillance program is being conducted to demonstrate that the Firebar D will maintain its integrity and not deteriorate throughout plant life. The surveillance frequency is adequate to detect any deterioration tendency of the material. (8)

The operability of the instrument line flow check valves are demonstrated to assure isolation capability for excess flow and to assure the operability of the instrument sensor when required.

Because of the large volume and thermal capacity of the suppression pool, the volume and temperature normally changes very slowly and monitoring these parameters daily is sufficient to establish any temperature trends. By requiring the suppression pool temperature to be continually monitored and also observed during periods of significant heat addition, the temperature trends will be closely followed so that appropriate action can be taken. The requirement for an external visual examination following any event where potentially high loadings could occur provides assurance that no significant damage was encountered. Particular attention should be focused on structural discontinuities in the vicinity of the relief valve discharge since these are expected to be the points of highest stress.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO. 86 TO PROVISIONAL OPERATING LICENSE NO. DPR-16

GPU NUCLEAR CORPORATION AND
JERSEY CENTRAL POWER & LIGHT COMPANY
OYSTER CREEK NUCLEAR GENERATING STATION

DOCKET NO. 50-219

1.0 INTRODUCTION

By letter dated July 19, 1984, and supplemented by the agreement noted in meeting minutes dated February 22, 1985, GPU Nuclear (the licensee) requested an amendment to Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Generating Station (OCNGS). This amendment would authorize changes to the Appendix A Technical Specifications (TS), Section 3.5 and 4.5, Containment, which (1) decrease the maximum oxygen concentration allowed in the primary containment atmosphere within 24 hours after the reactor mode selector switch is placed in the run mode from less than 5% to less than 4% and (2) correct a typographical spelling error in the Bases.

A Notice of Consideration of Issuance of Amendment to License and Proposed No Significant Hazards Consideration Determination and Opportunity for Hearing related to the requested action was published in the Federal Register on March 27, 1985, (50 FR 12145). No public comments or requests for hearing were received.

2.0 DISCUSSION AND EVALUATION

TS 3.5.A.6 currently requires that the primary containment atmosphere oxygen concentration shall be less than 5% within 24 hours after the reactor mode selector switch is placed in the run mode. The licensee's proposed change to the TS would require the primary containment oxygen concentration to be reduced to less than 4% within 24 hours after the switch is placed in the run mode. The oxygen concentration is reduced with nitrogen gas.

When the primary containment atmosphere oxygen concentration is reduced below the TS limit, the primary containment is in the inerted condition. Inerting is required to reduce the oxygen concentration to a level such that a flammable mixture would not be produced in the primary containment following onset of a Loss-of-Coolant Accident (LOCA).

Regulatory Guide 1.7 defines the limiting oxygen concentration, if more than 4 volume percent hydrogen is present, to be 5 volume percent. In our evaluation of the General Electric report, NEDO-22155, the staff concluded that the "recombiner capability" called for in 10 CFR 50.44 was not needed in plants with Mark I containments if certain criteria were met. Among these subsidiary criteria was a requirement that a 4% value be used for the limiting oxygen concentration when the inerted condition was required.

The licensee has also proposed changes to the Bases of Section 3.5 of the TS. These changes are to add text to the Bases to explain that the proposed 4% oxygen limit was established by analysis of the generation and mitigation of combustible gas mixtures in inerted BWR Mark I containments in General Electric document NEDO-22155 dated June 1982 and to reference this document. This document has been evaluated by the staff and the staff considers the text being proposed by the licensee to be correct.

The licensee's proposed change to state in the Bases for Section 3.5 that "The 48 hour time... establish the required O₂ limit" is not being made. This was withdrawn by the licensee when the licensee agreed to have the maximum oxygen concentration in the primary containment less than 4% within 24 hours after the reactor mode selector switch is placed in the run mode. This was agreed to in the meeting minutes dated February 22, 1985.

The licensee also proposed to correct a typographical spelling error in the Bases for Section 4.5, Containment, of the TS. This would be to spell "concentration" on TS page 4.5-10 correctly.

Therefore, based on the above, the staff concludes that decreasing the maximum oxygen concentration in the primary containment during the run mode from less than 5% to less than 4%, adding text to the Section 3.5 Bases and correcting the spelling of "concentration" in the Section 4.5 Bases is acceptable.

3.0 ENVIRONMENTAL QUALIFICATION

This amendment involves a change to a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environment assessment need be prepared in connection with the issuance of this amendment.

4.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner; and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

5.0 ACKNOWLEDGEMENT

This evaluation was prepared by F. Eltawila and J. Donohew.

Dated: June 7, 1985.