

March 21, 1985

Docket No. 50-219
LS05-85-03-015

*Correction to Admt 80
to DPR-16*

Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fielder:

SUBJECT: CORRECTION TO AMENDMENT NO. 80 TO THE TECHNICAL SPECIFICATIONS

Re: Oyster Creek Nuclear Generating Station

By letter dated February 11, 1985, the Commission issued Amendment No. 80 to Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Generating Station. We have discovered that page 3.1-14 in the amendment was issued with a typographical error in footnote dd. This footnote was not part of the actions being taken in this amendment. Please replace the previously issued TS page 3.1-14 with the enclosed corrected page 3.1-14.

Sincerely,

Original signed by

John A. Zwolinski, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Corrected TS page
to Amendment No. 80

cc w/enclosure:
See next page

DISTRIBUTION

Docket File	EJordan
NRC PDR	BGrimes
Local PDR	ACRS (10)
ORB Reading	SEP8
NSIC	TBarnhart (4)
JZwolinski	LJHarmon
CJamerson	WJones
JDonohew	CMiles, OPA
OELD	JEmami
EButcher	

8503260337 850321
PDR ADOCK 05000219
P PDR

DL:ORB#5
CJamerson jib
3/20/85

DL:ORB#5
JDonohew
3/21/85

DL:ORB#5
JZwolinski
3/21/85

*SEO1
DSU Use 51*

Mr. P. B. Fiedler

- 2 -

March 21, 1985

cc

G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

J.B. Liberman, Esquire
Bishop, Liberman, Cook, et al.
1155 Avenue of the Americas
New York, New York 10036

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Dr. Thomas E. Murley
Regional Administrator
Nuclear Regulatory Commission
Region I Office
631 Park Avenue
King of Prussia, Pennsylvania 19406

Eugene Fisher, Assistant Director
Division of Environmental Quality
Department of Environmental
Protection
380 Scotch Road
Trenton, New Jersey 08628

BWR Licensing Manager
GPU Nuclear
100 Interpace Parkway
Parsippany, New Jersey 07054

Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
36 West State Street - CN 112
Trenton, New Jersey 08625

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

U.S. Environmental Protection Agency
Region II Office
ATTN: Regional Radiation Representative
26 Federal Plaza
New York, New York 10007

D. G. Holland
Licensing Manager
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

TABLE 3.1.1 (Cont'd)

- v. These functions not required to be operable when the ADS is not required to be operable.
- w. These functions must be operable only when irradiated fuel is in the fuel pool or reactor vessel and secondary containment integrity is required per specification 3.5.B.
- y. The number of operable channels may be reduced to 2 per Specification 3.9-E and F.
- z. The bypass function to permit scram reset in the shutdown or refuel mode with control rod block must be operable in this mode.
- aa. Pump circuit breakers will be tripped in 10 seconds \pm 15% during a LOCA by relays SK7A and SK8A.
- bb. Pump circuit breakers will trip instantaneously during a LOCA.
- cc. Only applicable during startup mode while operating in IRM range 10.
- dd. If an isolation condenser inlet (steam side) isolation valve becomes or is made inoperable in the open position during the run mode comply with Specification 3.8.E. If an AC motor-operated outlet (condensate return) isolation valve becomes or is made inoperable in the open position during the run mode comply with Specification 3.8.F.
- ee. With the number of operable channels one less than the Min. No. of Operable Instrument Channels per Operable Trip Systems, operation may proceed until performance of the next required Channel Functional Test provided the inoperable channel is placed in the tripped condition within 1 hour.
- ff. This function is not required to be operable when the associated safety bus is not required to be energized or fully operable as per applicable sections of these technical specifications.

Amendment No. 44, 60, 65, 71, 72
80
Corrected MAR 21 1985

8503260339 850321
PDR ADOCK 05000219
PDR