


Peter E. Katz
Plant General Manager

1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101



**Constellation
Nuclear**

**Calvert Cliffs
Nuclear Power Plant**

*A Member of the
Constellation Energy Group*

April 20, 2001

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit No. 2; Docket No. 50-318
Report of Steam Generator Tube Plugging

REFERENCE: (a) Calvert Cliffs Unit 2 Technical Specifications 5.6.9.a

As required by Reference (a), this letter reports the number of tubes plugged or repaired in the Calvert Cliffs Unit 2 steam generators during the recently completed Inservice Inspection:

- ◆ In the No. 21 Steam Generator, a total of 51 tubes were plugged and 210 tubes were repaired this outage. Prior to this outage, 957 tubes had been plugged and no tubes had been repaired in the No. 21 Steam Generator. To date, a total of 1,008 tubes are plugged and 210 tubes are repaired in the No. 21 Steam Generator.
- ◆ In the No. 22 Steam Generator, a total of 138 tubes were plugged and 155 tubes were repaired this outage. Prior to this outage, 744 tubes had been plugged and no tubes had been repaired in the No. 22 Steam Generator. To date, a total of 882 tubes are plugged and 155 tubes are repaired in the No. 22 Steam Generator.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

PEK/GT/bjd

cc: R. S. Fleishman, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC
D. M. Skay, NRC

H. J. Miller, NRC
Resident Inspector, NRC
R. I. McLean, DNR

A1047