

November 26, 1984

Docket No. 50-219
LS05-84-11-028

*Correction letter to
Admt. 77 to DPR-16*

Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: CORRECTION TO AMENDMENT NO. 77 TO THE TECHNICAL SPECIFICATIONS

Re: Oyster Creek Nuclear Generating Station

By letter dated October 29, 1984, the Commission issued Amendment No. 77 to Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Generating Station. We have discovered that Amendment No. 77 was issued on an out-of-date Technical Specification page. The TS page that was issued in Amendment 77 did not include the changes that were issued in Amendment 76. Please replace the previously issued TS page 5.3-1 with the enclosed corrected TS page 5.3-1.

Sincerely,

Original signed by

John A. Zwolinski, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Corrected TS page
5.3-1 to Amendment
No. 77 to License
No. DPR-16

DISTRIBUTION

Docket	PM	CMiles
NRC PDR	OELD	WJones
Local PDR	ELJordan	TBarnhart (4)
ORB Reading	JNGrace	LHarmon
NSIC	ACRS (10)	ASingh
JZwolinski	SEP8	DBrinkman
CJamerson		

DL:ORB#5
CJamerson:ib
11/19/84

DL:ORB#5
JWolinski
11/26/84

DL:ORB#5
JZwolinski
11/26/84

8411280140 841126
PDR ADCK 05000219
P PDR

(EX-51) 5E01
11

November 26, 1984

cc

G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

J.B. Liberman, Esquire
Bishop, Liberman, Cook, et al.
1155 Sixth Avenue
New York, New York 10036

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Dr. Thomas E. Murley
Regional Administrator
Nuclear Regulatory Commission
Region I Office
631 Park Avenue
King of Prussia, Pennsylvania 19406

Eugene Fisher, Assistant Director
Division of Environmental Quality
Department of Environmental
Protection
380 Scotch Road
Trenton, New Jersey 08628

BWR Licensing Manager
GPU Nuclear
100 Interpace Parkway
Parsippany, New Jersey 07054

Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
36 West State Street - CN 112
Trenton, New Jersey 08625

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

U.S. Environmental Protection Agency
Region II Office
ATTN: Regional Radiation Representative
26 Federal Plaza
New York, New York 10007

D. G. Holland
Licensing Manager
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

5.3 AUXILIARY EQUIPMENT

5.3.1 Fuel Storage

- A. Normal storage for unirradiated fuel assemblies is in critically safe new fuel storage racks in the reactor building storage vault; otherwise, fuel shall be stored in arrays which have a K_{eff} less than 0.95 under optimum conditions of moderation or in NRC-approved shipping containers.
- B. The spent fuel shall be stored in the spent fuel storage facility which shall be designed to maintain fuel in a geometry providing a K_{oo} less than or equal to 0.95.
- C. The fuel to be stored in spent fuel storage facility shall not exceed a maximum average-planar enrichment of 3.01 w/o U-235.
- D. Loads greater than the weight of one fuel assembly shall not be moved over stored irradiated fuel in the spent fuel storage facility.
- E. The spent fuel shipping cask shall not be lifted more than six inches above the top plate of the cask drop protection system. Vertical limit switches shall be operable to assure the six inch vertical limit is met when the cask is above the top plate of the cask drop protection system.
- F. The temperature of the water in the spent fuel stored pool, measured at or near the surface, shall not exceed 125°F.
- G. The maximum amount of spent fuel assemblies stored in the spent fuel storage pool shall be 2600.

BASIS

The specification of K_{oo} less than or equal to 0.95 in the spent fuel storage facility assures an ample margin from criticality. Criticality analysis was performed on the poison racks to insure that a K_{oo} of 0.95 would not be exceeded. The basis for this analysis assumed an average planar lattice enrichment of 3.01 w/o U-235 and includes manufacturing tolerances.

The effects of a dropped fuel bundle onto stored fuel in the spent fuel storage facility have been analyzed. This analysis shows that the fuel bundle drop would not cause doses resulting from ruptured fuel pins that exceed 10 CFR 100 limits (1,2,3) and that dropped waste cans will not damage the pool liner.

Amendment No. ~~72~~, ~~75~~, 77

8411280144 841126
PDR ADCK 05000219
P PDR

Correction Letter of 9-26-84
Correction Letter of 11-26-84