

April 2, 1990

April 23, 1990

Docket No. 50-219

Mr. E. E. Fitzpatrick
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fitzpatrick:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 76087)

The Commission has issued the enclosed Amendment No.138 to Provisional Operating License No. DPR-16 for the Oyster Creek Nuclear Generating Station, in response to your application dated February 23, 1990.

The amendment modifies the Oyster Creek Nuclear Generating Station Technical Specifications to remove the 3.25 limit on extending surveillance intervals and to add the bases for the existing allowance, in accordance with the guidance contained in NRC Generic Letter 89-14, dated August 21, 1989.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's bi-weekly Federal Register notice.

Sincerely,

/s/

Alexander W. Dromerick, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 138 to DPR-16
- 2. Safety Evaluation

cc w/enclosures:
See next page

OFC	:LA:PDI-4	:PM:PDI-4	: PM:PDII-2	:PD:PDI-4	:OGC	:
NAME	:SNorris	:ADromerick/tm	:HSilver	:JStolz	:CPW	:
DATE	:03/30/90	:03/30/90	:03/ /90	:03/20/90	:03/4/90	:

OFFICIAL RECORD COPY
Document Name: AMEND 76087

9005010295 900423
PDR ADDCK 05000219
P PDC

CP-1
DF01
1/1

DATED: 4/23/90 AMENDMENT NO. 138 TO PROVISIONAL OPERATING LICENSE NO. DPR-16

DISTRIBUTION:

Docket File

NRC & Local PDR

Plant File

S. Varga (14E4)

B. Boger (14A2)

J. Stolz

S. Norris

A. Dromerick

OGC

D. Hagan (MNBB 3302)

E. Jordan (MNBB 3302)

G. Hill(4) (P1-137)

W. Jones (P-130A)

J. Calvo (11F23)

ACRS (10)

GPA/PA

ARM/LFMB

cc: Licensee/Applicant Service List

DF01
111

Mr. E. E. Fitzpatrick
Oyster Creek Nuclear Generating Station

Oyster Creek Nuclear
Generating Station

cc:

Ernest L. Blake, Jr.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, D.C. 20037

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

J.B. Liberman, Esquire
Bishop, Liberman, Cook, et al.
1155 Avenue of the Americas
New York, New York 10036

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Kent Tosch, Chief
New Jersey Department of Environmental
Protection
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625

BWR Licensing Manager
GPU Nuclear Corporation
1 Upper Pond Road
Parsippany, New Jersey 07054

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

Licensing Manager
Oyster Creek Nuclear Generating Station
Mail Stop: Site Emergency Bldg.
P. O. Box 388
Forked River, New Jersey 08731



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GPU NUCLEAR CORPORATION

AND

JERSEY CENTRAL POWER & LIGHT COMPANY

DOCKET NO. 50-219

OYSTER CREEK NUCLEAR GENERATING STATION

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 138
License No. DPR-16

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by GPU Nuclear Corporation, et al., (the licensee), dated February 23, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9005010298 900423
PDR ADOCK 05000219
P PDC

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Provisional Operating License No. DPR-16 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 138, are hereby incorporated in the license. GPU Nuclear Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 23, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 138
PROVISIONAL OPERATING LICENSE NO. DPR-16
DOCKET NO. 50-219

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages as indicated. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

Page 1.0-5
Page 1.0-6
Page 1.0-7

Insert

Page 1.0-5
Page 1.0-6
Page 1.0 7

B. the testing of one system, subsystem, train or other designated component at the beginning of each subinterval.

1.24 SURVEILLANCE REQUIREMENTS

Surveillance requirements are requirements relating to test, calibration, or inspection to assure that the necessary quality of systems and components is maintained, that facility operation will be within the safety limits, and that the limiting conditions of operation will be met. Each surveillance requirement shall be performed within the specified time interval with a maximum allowable extension not to exceed 25% of the surveillance interval.*

Surveillance requirements for systems and components are applicable only during the modes of operation for which the system or components are required to be operable, unless otherwise stated in the specification.

This definition establishes the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance, eg., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with a fuel cycle length surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of this definition is based on engineering judgement and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

1.25 FIRE SUPPRESSION WATER SYSTEM

A FIRE SUPPRESSION WATER SYSTEM shall consist of: a water source; pump; and distribution piping with associated sectionizing control or isolation valves. Such valves shall include yard hydrant curb valves, and the first valve ahead of the water flow alarm device on each sprinkler, hose stand-up or spray system riser.

1.26 FRACTION OF LIMITING POWER DENSITY (FLPD)

The fraction of limiting power density is the ratio of the linear heat generation rate (LHGR) existing at a given location to the design LHGR for that bundle type.

1.27 MAXIMUM FRACTION OF LIMITING POWER DENSITY (MFLPD)

The maximum fraction of limiting power density is the highest value existing in the core of the fraction of limiting power density (FLPD).

*Not applicable to containment leak rate test.

1.28 FRACTION OF RATED POWER (FRP)

The fraction of rated power is the ratio of core thermal power to rated thermal power.

1.29 TOP OF ACTIVE FUEL (TAF) - 353.3 inches above vessel zero.

1.30 REPORTABLE EVENT

A REPORTABLE EVENT shall be any of those conditions specified in Section 50.73 to 10 CFR Part 50.

1.31 IDENTIFIED LEAKAGE

IDENTIFIED LEAKAGE is that leakage which is collected in the primary containment equipment drain tank and eventually transferred to radwaste for processing.

1.32 UNIDENTIFIED LEAKAGE

UNIDENTIFIED LEAKAGE is all measured leakage that is other than identified leakage.

1.33 PROCESS CONTROL PLAN

The PROCESS CONTROL PLAN shall generally describe the essential operational controls and surveillance checks for processing wet radioactive waste in order to provide reasonable assurance of compliance with class B or C stability requirements of 10 CFR Part 61.56 (b) before disposal.

1.34 AUGMENTED OFFGAS SYSTEM (AOG)

The AUGMENTED OFFGAS SYSTEM is a system designed and installed to holdup and/or process radioactive gases from the main condenser offgas system for the purpose of reducing the radioactive material content of the gases before release to the environs.

1.35 MEMBER OF THE PUBLIC

A MEMBER OF THE PUBLIC is a person who is not occupationally associated with GPU Nuclear and who does not normally frequent the Oyster Creek Nuclear Generating Station site. The category does not include contractors, contractor employees, vendors, or persons who enter the site to make deliveries, to service equipment, work on the site, or for other purposes associated with plant functions.

1.36 OFFSITE DOSE CALCULATION MANUAL

An OFFSITE DOSE CALCULATION MANUAL (ODCM) states the methodology and parameters to be used in the calculation of radiation doses offsite due to radioactive gaseous and liquid effluents and in the calculation of radioactive gaseous and liquid effluent monitoring instrumentation alarm/trip setpoints.

1.37 PURGE

PURGE OR PURGING is the controlled process of discharging air or gas from a confinement and replacing it with air or gas.

1.38 EXCLUSION AREA

EXCLUSION AREA is defined in 10 CFR part 100.3(2). As used in these technical specification, the Exclusion Area boundary is the perimeter line around the OCNCS beyond which the land is neither owned, leased, nor otherwise subject to control by GPU (ref. ODCM Figure 1-1). The area outside the Exclusion Area is termed OFFSITE.

1.39 REACTOR VESSEL PRESSURE TESTING

System pressure testing required by ASME Code Section XI, Article IWA-5000, including system leakage and hydrostatic tests, with reactor vessel completely water solid, core not critical and section 3.2.A satisfied.

1.40 SUBSTANTIVE CHANGES

SUBSTANTIVE CHANGES are those which affect the activities associated with a document or the document's meaning or intent. Examples of non-substantive changes are: (1) correcting spelling, (2) adding (but not deleting) sign-off spaces, (3) blocking in notes, cautions, etc, (4) changes in corporate and personnel titles which do not reassign responsibilities and which are not referenced in the Appendix A Technical Specifications, and (5) changes in nomenclature or editorial changes which clearly do not change function, meaning or intent.

1.41 DOSE EQUIVALENT I-131

DOSE EQUIVALENT I-131 shall be that concentration of I-131 microcuries per gram which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in Table E-7 or Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluences for the Purpose of Evaluating Compliance with 10 CFR Par 40 Appendix I".



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 138

TO PROVISIONAL OPERATING LICENSE NO. DPR-16

GPU NUCLEAR CORPORATION AND
JERSEY CENTRAL POWER & LIGHT COMPANY

OYSTER CREEK NUCLEAR GENERATING STATION

DOCKET NO. 50-219

INTRODUCTION

By letter dated February 23, 1990, GPU Nuclear Corporation (the licensee) proposed changes to the Technical Specifications (TS) for Oyster Creek Nuclear Generating Station. The proposed change removes the provision of Specification 1.24 that limits the combined time interval for three consecutive surveillances to less than 3.25 times the specified interval. Guidance on this proposed change to TS was provided to all power reactor licensees and applicants by Generic Letter 89-14 dated August 21, 1989.

EVALUATION

Specification 1.24 includes the provision that allows a surveillance interval to be extended by 25 percent of the specified time interval. This extension provides flexibility for scheduling the performance of surveillances and to permit consideration of plant operating conditions that may not be suitable for conducting a surveillance at the specified time interval. Such operating conditions include transient plant operation or ongoing surveillance or maintenance activities. Specification 1.24 further limits the allowance for extending surveillance intervals by requiring that the combined time interval for any three consecutive surveillances not exceed 3.25 times the specified time interval. The purpose of this provision is to assure that surveillances are not extended repeatedly as an operational convenience to provide an overall increase in the surveillance interval.

Experience has shown that the 18-month surveillance interval, with the provision to extend it by 25 percent, is usually sufficient to accommodate normal variations in the length of a fuel cycle. However, the NRC staff has routinely granted requests for one-time exceptions to the 3.25 limit on extending refueling surveillances because the risk to safety is low in contrast to the alternative of a forced shutdown to perform these surveillances.

9005010300 900423
PDR ADOCK 05000219
F PIC

Therefore, the 3.25 limitation on extending surveillances has not been a practical limit on the use of the 25 percent allowance for extending surveillances that are performed on a refueling outage basis.

Extending surveillance intervals during plant operation can also result in a benefit to safety when a scheduled surveillance is due at a time that is not suitable for conducting the surveillance. This may occur when transient plant operating conditions exist or when safety systems are out of service for maintenance or other surveillance activities. In such cases, the benefit to safety of extending a surveillance interval would exceed any safety benefit derived by limiting the use of the 25 percent allowance to extend a surveillance. Furthermore, there is the administrative burden associated with tracking the use of the 25 percent allowance to ensure compliance with the 3.25 limit.

In view of these findings, the staff concluded that Specification 1.24 should be changed to remove the 3.25 limit for all surveillances because its removal will have an overall positive effect on safety. The guidance provided in Generic Letter 89-14 included the following change to this specification and removes the 3.25 limit on three consecutive surveillances with the following statement:

1.24 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval.

In addition, the Bases of this specification were updated to reflect this change and noted that it is not the intent of the allowance for extending surveillance intervals that it be used repeatedly merely as an operational convenience to extend surveillance beyond that specified.

The licensee has proposed changes to Specification 1.24 that are consistent with the guidance provided in Generic Letter 89-14, as noted above. On the basis of its review of this matter, the staff finds that the above changes to the TS for Oyster Creek Nuclear Generating Station are acceptable.

ENVIRONMENTAL CONSIDERATION

This amendment changes surveillance requirements. We have determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The staff has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

CONCLUSION

The staff has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security nor to the health and safety of the public.

Dated: April 23, 1990

Principal Contributor: Thomas G. Dunning