

November 8, 1994

Mr. John J. Barton
Vice President and Director
GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, NJ 08731

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION (TAC NO. M89845)

Dear Mr. Barton:

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact related to your application for amendment dated July 8, 1994, as supplemented October 10, 1994. The proposed amendment would revise the Technical Specifications to provide improved protection to safety related electrical equipment from loss of capability in the event of a sustained degraded voltage condition on the offsite electrical grid system.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by:

Alexander W. Dromerick, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-219

Enclosure: Environmental Assessment

cc w/encl: See next page

DISTRIBUTION:

~~Docket File~~
PUBLIC
PDI-4 Plant
SVarga
CMiller (A)
SNorris
ADromerick
OGC
EJordan, D/AEOD
ACRS (10)
OPA 4
JRogge, RGI

CP-1
FEDERAL FILE CENTER COPY

DOCUMENT NAME: G:\DROMERICK\M.ENV

| | | | | | |
|--------|----------|---------------|----------|---------|---------|
| OFFICE | LA:PDI-4 | PM:PDI-4 | D:PDI-4 | OGC | |
| NAME | SNorris | ADromerick:bf | JStoltz | PMcKee | |
| DATE | 10/26/94 | 10/26/94 | 10/28/94 | 10/ /94 | 10/ /94 |

9411160215 941108
PDR ADOCK 05000219
P PDR

OFFICIAL RECORD COPY

11/1/94

DF01

November 8, 1994

Mr. John J. Barton
Vice President and Director
GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, NJ 08731

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION (TAC NO. M89845)

Dear Mr. Barton:

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact related to your application for amendment dated July 8, 1994, as supplemented October 10, 1994. The proposed amendment would revise the Technical Specifications to provide improved protection to safety related electrical equipment from loss of capability in the event of a sustained degraded voltage condition on the offsite electrical grid system.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by:

Alexander W. Dromerick, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-219

Enclosure: Environmental Assessment

cc w/encl: See next page

DISTRIBUTION:

Docket File
PUBLIC
PDI-4 Plant
SVarga
CMiller (A)
SNorris
ADromerick
OGC
EJordan, D/AEOD
ACRS (10)
OPA 4
JRogge, RGI

DOCUMENT NAME: G:\DROMERICK\M.ENV

| | | | | | | |
|--------|----------|---------------|----------|---------|---------|--|
| OFFICE | LA:PDI-4 | PM:PDI-4 | D:PDI-4 | OGC | | |
| NAME | SNorris | ADromerick:bf | JStolz | PMcKee | | |
| DATE | 10/26/94 | 10/26/94 | 10/28/94 | 10/ /94 | 10/ /94 | |

OFFICIAL RECORD COPY

Handwritten signatures and dates:
11/1/94



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 8, 1994

Mr. John J. Barton
Vice President and Director
GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, NJ 08731

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION (TAC NO. M89845)

Dear Mr. Barton:

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact related to your application for amendment dated July 8, 1994, as supplemented October 10, 1994. The proposed amendment would revise the Technical Specifications to provide improved protection to safety related electrical equipment from loss of capability in the event of a sustained degraded voltage condition on the offsite electrical grid system.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in black ink, appearing to read "Alexander W. Dromerick, Sr.".

Alexander W. Dromerick, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-219

Enclosure: Environmental Assessment

cc w/encl: See next page

Mr. John J. Barton
Vice President and Director

Oyster Creek Nuclear
Generating Station

cc:

Ernest L. Blake, Jr., Esquire
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road

King of Prussia, Pennsylvania 19406

BWR Licensing Manager
GPU Nuclear Corporation
1 Upper Pond Road
Parsippany, New Jersey 07054

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

Licensing Manager
Oyster Creek Nuclear Generating Station
Mail Stop: Site Emergency Bldg.
Post Office Box 388
Forked River, New Jersey 08731

Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Post Office Box 445
Forked River, New Jersey 08731

Kent Tosch, Chief
New Jersey Department of
Environmental Protection
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625

Robert Hargrove
Environmental Review Coordinator
26 Federal Plaza
New York, NY 10278

UNITED STATES NUCLEAR REGULATORY COMMISSIONGPU NUCLEAR CORPORATIONDOCKET NO. 50-219OYSTER CREEK NUCLEAR GENERATING STATIONENVIRONMENTAL ASSESSMENT AND FINDING OFNO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DPR-16, issued to GPU Nuclear Corporation, et al. (the licensee), for operation of the Oyster Creek Nuclear Generating Station, located in Ocean County, New Jersey.

ENVIRONMENTAL ASSESSMENTIdentification of the Proposed Action:

The proposed amendment would revise the Technical Specification Section 2.3.P(2) to raise the degraded voltage setpoints from 3671 volts to 3840 volts, and to revise the allowable setpoint range from $\pm 1\%$ to +20V, -40V. The revised setpoint tolerance values in volts represents a range of +0.5%, -1.0% compared to the existing setpoint tolerance range of $\pm 1\%$.

The proposed action is in accordance with the licensee's application for amendment dated July 8, 1994.

The Need for the Proposed Action:

The proposed action is needed to provide improved protection to safety related electrical equipment from loss of capability in the event of a sustained degraded voltage condition of the offsite electrical grid system.

Environmental Impacts of the Proposed Action:

The Commission has completed its evaluation of the proposed action and concludes that the proposed change provides improved protection to safety related equipment from loss of capability in the event of a sustained degraded voltage condition on the offsite electrical grid system.

The change will not increase the probability or consequences of accidents, no changes are being made in the types of any effluents that may be released offsite, and there is no significant increase in the allowable individual or cumulative occupational radiation exposure. Accordingly, the Commission concludes that there are no significant radiological environmental impacts associated with the proposed action.

With regard to potential nonradiological impacts, the proposed action does involve features located entirely within the restricted area as defined in 10 CFR Part 20. It does not affect nonradiological plant effluents and has no other environmental impact. Accordingly, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed action.

Alternatives to the Proposed Action:

Since the Commission has concluded there is no measurable environmental impact associated with the proposed action, any alternatives with equal or greater environmental impact need not be evaluated. The principal alternative to the action would be to deny the request. Such action would not provide the improved protection to safety related equipment from loss of capability in the event of a sustained degraded voltage condition on the offsite electrical grid system.

Alternative Use of Resources:

This action does not involve the use of any resources not previously considered in the Final Environmental Statement for the Oyster Creek Nuclear Generating Station dated December 1974.

Agencies and Persons Consulted:

The NRC staff consulted with the New Jersey State official regarding the environmental impact of the proposed action. The State official had no comments.


FINDING OF NO SIGNIFICANT IMPACT

Based upon the environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated July 8, 1994, as supplemented October 10, 1994, which are available for public inspection at the Commission's Public Document Room, The Gelman Building, 2120 L Street, NW., Washington, DC 20555, and at the local public document room located at the Ocean County Library, Reference Department, 101 Washington Street, Toms River, NJ 08753.

Dated at Rockville, Maryland, this 8th day of November 1994.

FOR THE NUCLEAR REGULATORY COMMISSION



Phillip F. McKee, Director
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation