April 25, 2001

One Ameren Plaza 1901 Chouteau Avenue PO Box 66149 St. Louis, MO 63166-6149 314.621.3222

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Mail Station P1-137 Washington, D.C. 20555

ULNRC-04461

Gentlemen:

a*meren*

DOCKET NUMBER 50-483
UNION ELECTRIC COMPANY
CALLAWAY PLANT
LICENSE AMENDMENTS 137 AND 141

Union Electric Company hereby informs the Commission of the implementation of Amendments 137 and 141 to Facility Operating License NPF-30 for Callaway Plant. Both amendments were implemented at Callaway on April 25, 2001.

Amendment 137 approved changes to the lift setting and setpoint tolerance of the pressurizer safety valves and added requirements associated with upgrading the design of the pressurizer PORVs. Implementation of Amendment 137 included issuing the revision to Emergency Operating Procedure E-0 and training all control room operator crews on the revised procedure, as discussed in the NRC amendment issuance letter dated September 25, 2000.

Amendment 141 added response time testing requirements for two AFW trip functions in Technical Specification Table 3.3.2-1. Implementation of Amendment 141 included issuing the FSAR revisions to reflect the new ESFAS response time limits, as discussed in the NRC amendment issuance letter dated February 12, 2001.

Very truly yours,

Alan C. Passwater

Manager - Corporate Nuclear Services

A001

cc: M. H. Fletcher
Professional Nuclear Consulting, Inc.
19041 Raines Drive
Derwood, MD 20855-2432

Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 400
Arlington, TX 76011-8064

Senior Resident Inspector Callaway Resident Office U.S. Nuclear Regulatory Commission 8201 NRC Road Steedman, MO 65077

Mr. Jack Donohew (2) - OPEN BY ADDRESSEE ONLY Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission 1 White Flint, North, Mail Stop OWFN 7E1 11555 Rockville Pike Rockville, MD 20852-2738

Manager, Electric Department Missouri Public Service Commission P.O. Box 360 Jefferson City, MO 65102

Ron Kucera Department of Natural Resources P.O. Box 176 Jefferson City, MO 65102

Denny Buschbaum TU Electric P.O. Box 1002 Glen Rose, TX 76043

Pat Nugent
Pacific Gas & Electric
Regulatory Services
P.O. Box 56
Avila Beach, CA 93424