Exelon Nuclear Peach Bottom Atomic Power Station 1848 Lay Road Delta, PA 17314-9032 Telephone 717.456.7014 www.exeloncorp.com

April 20, 2001

Docket Nos. 50-277 50-278

U.S. Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

SUBJECT: Radioactive Effluent Release Report No. 43 January 1, 2000 through December 31, 2000 Peach Bottom Atomic Power Station Unit Nos. 2 and 3

Gentlemen:

Enclosed are two copies of the Radioactive Effluent Release Report No. 43, January 1, 2000 through December 31, 2000 for Peach Bottom Atomic Power Station Unit Nos. 2 and 3.

This report is being submitted in compliance with 10CFR 50.36a (2) and the Technical Specifications of Operating Licenses DPR-44 and DPR-56, and to fulfill the requirements of Regulatory Guide 10.1.

Revisions were made to the Offsite Dose Calculation Manual (ODCM) during this report period. A copy of the revised ODCM is included.

Sincerely, perin Doerina

Vice President, Peach Bottom Atomic Power Station

JD/GEJ/IWS:aa

Enclosure

cc: H. J. Miller, Administrator, Region I, USNRC A. C. McMurtray, USNRC Senior Resident Inspector, PBAPS Senior Project Manager, USNRC

CCN 01- 14038

JE48

Exel⁴n...

Nuclear

PEACH BOTTOM ATOMIC POWER STATION Unit Numbers 2 and 3 Docket Numbers 50-277 and 50-278

RADIOACTIVE EFFLUENT RELEASE REPORT

NO. 43

JANUARY 1, 2000 THROUGH DECEMBER 31, 2000

Submitted to The United States Nuclear Regulatory Commission Pursuant to Facility Operating Licenses DPR-44 and DPR-56

TABLE OF CONTENTS

SECT	ΓΙΟΝ		PAGE
I.	Intro	oduction	1
II.	Tabl	es	
	1A.	Gaseous Effluents - Summation of All Releases	2
	1B.	Gaseous Effluents for Release Point - Main Stack	4
	1C.	Gaseous Effluents for Release Point - Unit 2, Unit 3 Roof Vents and Aux Boiler Stacks	6
	2A.	Liquid Effluents - Summation of All Releases	8
	2B.	Liquid Effluents	10
III.	Clas	ses of Solid Radioactive Waste Shipments	12
IV.	Atta	chments	
	А.	Supplemental Information	13

Technical Concurrences: (for accuracy of information)

ms

Chemistry / Radwaste Manager

1. **INTRODUCTION**

In accordance with the Reporting Requirements of Technical Specification 5.6.3 applicable during the reporting period, this report summarizes the Effluent Release Data for Peach Bottom Atomic Power Station Units 2 and 3 for the period January 1, 2000 through December 31, 2000. The notations E and E- are used to denote positive and negative exponents to the base 10, respectively.

The release of radioactive materials during the reporting period was within the Offsite Dose Calculation Manual Specification limits.

The Offsite Dose Calculation Manual (ODCM) was revised during the reporting period. ODCM Revision 12, approved on 5/17/00 and issued 5/22/00, included the following changes:

- 1. Radiological Environmental Monitoring Program (REMP) changes were incorporated.
 - a. Replaced milk farm G with milk farm O.
 - b. Added 1 TLD location (3768 feet SSE of site) to measure dose to real individual for 40 CFR 190 and 10 CFR 72.104 dose calculations.
- 2. Requirements for monitoring and limiting annual dose equivalent to a real individual were added.
 - a. ODCMS 3.8.D: New specification provided to meet the dose limitations of 40 CFR 190 that have been incorporated into 10 CFR 20.1301(d) as well as the dose limitations specific to Independent Spent Fuel Storage Installation (ISFSI) operations in accordance with 10 CFR 72.104.
 - b. ODCMS BASES: New section to describe 40 CFR 190 and 10 CFR 72.104 dose requirements.
- 3. Methodology for calculating total dose in accordance with 40 CFR 190 and 10 CFR 72.104 was added.
- 4. Minor non-technical revisions.

There were two unplanned releases of liquid radioactive material.

There was no burning of contaminated oil in 2000 and therefore no radioactive gaseous effluent from the aux boiler stack.

.

Table 1A Page 1 of 2 Gaseous Effluents - Summation of All Releases

	UNITS	QUARTER 1	QUARTER 2	EST. ERROR TOTAL %
A. Fission & activation gases			• · · · · · · · · · · · · · · · · · · ·	<u> </u>
1. Total release	Ci	8.64E1	1.13E2	18.8
2. Average release rate for period	µCi/sec	1.10E1	1.44E1	18.8
3. Gamma air dose	Millirad	1.94E-2	2.42E-2	18.8
Percent of Technical Specification limit	%	1.94E-1	2.42E-1	18.8
4. Beta air dose	Millirad	1.34E-2	1.65E-2	18.8
Percent of Technical Specification limit	%	6.70E-2	8.25E-2	18.8
B. lodines				
1. Total iodine-131	Ci	1.20E-4	1.64E-4	22.9
2. Average release rate for period	µCi/sec	1.52E-5	2.09E-5	22.9
3. Critical organ dose	Millirem	9.82E-4	1.25E-3	22.9
Percent of Technical Specification limit	%	6.55E-3	8.33E-3	22.9
C. Particulates				
1. Particulates with half-lives greater than 8 days (includes Alpha and Strontium 89,90)	Ci	1.78E-4	1.92E-4	22.9
2. Average release rate for period	μ Ci/sec	2.26E-5	2.44E-5	22.9
3. Gross alpha radioactivity	Ci	3.80E-6	2.21E-6	22.9
D. Tritium				
1. Total release	Ci	9.98E1	0	23.5
2. Average release rate for period	µCi/sec	1.27E1	0	23.5

Table 1A Page 2 of 2 Gaseous Effluents - Summation of All Releases

	UNITS	QUARTER 3	QUARTER 4	EST. ERROR TOTAL %
A. Fission & activation gases				
1. Total release	Ci	1.01E2	1.09E2	18.8
2. Average release rate for period	μ Ci/sec	1.28E1	1.39E1	18.8
3. Gamma air dose	Millirad	2.08E-2	2.30E-2	18.8
Percent of Technical Specification limit	%	2.08E-1	2.30E-1	18.8
4. Beta air dose	Millirad	1.45E-2	1.59E-2	18.8
Percent of Technical Specification limit	%	7.25E-2	7.95E-2	18.8
B. Iodines				
1. Total iodine-131	Ci	1.30E-4	1.06E-4	22.9
2. Average release rate for period	µCi/sec	1.65E-5	1.34E-5	22.9
3. Critical organ dose	Millirem	7.58E-4	6.37E-4	22.9
Percent of Technical Specification limit	%	5.05E-3	4.25E-3	22.9
C. Particulates				<u>.</u>
1. Particulates with half-lives greater than 8 days (includes Alpha and Strontium 89,90)	Ci	7.54E-5	8.81E-5	22.9
2. Average release rate for period	µCi/sec	9.59E-6	1.12E-5	22.9
3. Gross alpha radioactivity	Ci	1.28E-6	0	22.9
D. Tritium				-
1. Total release	Ci	0	0	23.5
2. Average release rate for period	µCi/sec	0	0	23.5

Table 1BPage 1 of 2Gaseous Effluents for Release Point - Main Stack

		Continuous Mode		Batch Mode					
Nuclides Released	Units	Quarter 1	Quarter 2	Quarter 1	Quarter 2				
1. Fission gases	1. Fission gases								
Krypton - 85M	Ci	0	9.60E-1	0	0				
Krypton - 87	Ci	0	0	0	0				
Krypton - 88	Ci	0	0	0	0				
Xenon - 133	Ci	0	1.63E0	0	0				
Xenon - 135	Ci	2.08E0	6.80E0	0	0				
Xenon - 135M	Ci	0	2.53E0	0	0				
Xenon - 138	Ci	0	4.18E0	0	0				
Unidentified	Ci	9.13E0	2.72E0	0	0				
Total for Period	Ci	1.12E1	1.88E1	0	0				
2. Iodines		<u> </u>							
Iodine - 131	Ci	8.76E-5	7.90E-5	0	0				
Iodine - 133	Ci	1.45E-4	1.15E-4	0	0				
Iodine - 135	Ci	0	0	0	0				
Total for Period	Ci	2.33E-4	1.94E-4	0	0				
3. Particulates	۱ <u>ــــــــــــــــــــــــــــــــــــ</u>								
Strontium - 89	Ci	6.52E-5	6.78E-5	0	0				
Strontium - 90	Ci	1.57E-7	1.91E-7	0	0				
Manganese - 54	Ci	2.80E-7	0	0	0				
Cobalt - 60	Ci	4.80E-7	0	0	0				
Cesium - 137	Ci	0	5.70E-7	0	0				
Barium - 140	Ci	8.09E-5	1.03E-4	0	0				
Cerium - 144	Ci	0	8.60E-7	0	0				
TOTAL FOR PERIOD	Ci	1.47E-4	1.72E-4	0	0				

 Table 1B Page 2 of 2

 Gaseous Effluents for Release Point - Main Stack

	Units	Continuo	us Mode	Batch Mode		
Nuclides Released	Cint	Quarter	Quarter	Quarter	Quarter	
		3	4	3	4	
1. Fission gases				·····		
Krypton - 85M	Ci	0	0	0	0	
Krypton - 87	Ci	0	0	0	0	
Krypton - 88	Ci	0	0	0	0	
Xenon - 133	Ci	5.46E0	2.22E0	0	0	
Xenon - 135	Ci	3.98E0	4.76E0	0	0	
Xenon - 135M	Ci	0	0	0	0	
Xenon - 138	Ci	0	2.05E0	0	0	
Xenon - 133M	Ci	0	0	0	0	
Unidentified	Ci	1.04E1	1.15E1	0	0	
Total for Period	Ci	1.98E1	2.05E1	0	0	
2. Iodines						
Iodine - 131	Ci	7.25E-5	5.37E-5	0	0	
Iodine - 133	Ci	1.09E-4	6.86E-5	0	0	
Iodine - 135	Ci	1.32E-5	0	0	0	
Total for Period	Ci	1.95E-4	1.22E-4	0	0	
3. Particulates						
Strontium - 89	Ci	4.17E-5	3.81E-5	0	0	
Strontium - 90	Ci	0	0	0	0	
Chromium - 51	Ci	0	2.68E-6	0	0	
Manganese - 54	Ci	0	6.70E-7	0	0	
Cobalt - 58	Ci	0	3.70E-7	0	0	
Cobalt - 60	Ci	6.70E-7	4.36E-6	0	0	
Silver - 110M	Ci	0	5.50E-7	0	0	
Tellurium - 123M	Ci	5.04E-6	9.80E-6	0	0	
Cesium - 137	Ci	0	3.00E-7	0	0	
Barium - 140	Ci	3.53E-6	2.77E-5	0	0	
Cerium - 144	Ci	1.18E-6	0	0	0	
TOTAL FOR PERIOD	Ci	5.21E-5	8.45E-5	0	0	

Table 1C Page 1 of 2

Gaseous Effluents for Release Point - Unit 2 & Unit 3 Roof Vents & Aux Boiler Stacks

		Continuous Mode		Batch Mode	
Nuclides Released	Units		<u> </u>		
		Quarter 1	Quarter 2	Quarter 1	Quarter 2
1. Fission gases	I	I_	L	I	I
Krypton - 85M	Ci	0	0	0	0
Krypton - 87	Ci	0	0	0	0
Krypton - 88	Ci	0	0	0	0
.Xenon - 133	Ci	0	0	0	0
Xenon - 135	Ci	0	0	0	0
Xenon - 135M	Ci	0	0	0	0
Xenon - 138	Ci	0	0	0	0
Unidentified	Ci	7.53E1	9.39E1	0	0
Total for Period	Ci	7.53E1	9.39E1	0	0
2. Iodines					
Iodine - 131	Ci	3.22E-5	8.52E-5	0	0
Iodine - 133	Ci	3.25E-5	1.76E-4	0	0
Iodine - 135	Ci	0	0	0	0
Total for Period	Ci	6.47E-5	2.61E-4	0	0
3. Particulates					
Strontium - 89	Ci	1.59E-5	1.67E-5	0	0
Strontium - 90	Ci	1.30E-7	2.60E-7	0	0
Cobalt - 60	Ci	1.14E-5	0	0	0
Cesium - 137	Ci	0	0	0	0
TOTAL FOR PERIOD	Ci	2.74E-5	1.70E-5	0	0

Table 1CPage 2 of 2Gaseous Effluents for Release Point - Unit 2 & Unit 3 Roof Vents & Aux Boiler Stacks

		Continuc	ous Mode	Batch Mode	
Nuclides Released	Units	Quarter 3	Quarter 4	Quarter 3	Quarter 4
1. Fission gases	• • • • • • • • • • • • • • • • • • • •				
Krypton - 85M	Ci	0	0	0	0
Krypton - 87	Ci	0	0	0	0
Krypton - 88	Ci	0	0	0	0
Xenon - 133	Ci	0	0	0	0
Xenon - 135	Ci	0	0	0	0
Xenon - 135M	Ci	0	0	0	0
Xenon - 138	Ci	0	0	0	0
Unidentified	Ci	8.11E1	8.86E1	0	0
Total for Period	Ci	8.11E1	8.86E1	0	0
2. lodines		• • • • • • • • • • • • • • • • • • • •			
Iodine - 131	Ci	5.72E-5	5.22E-5	0	0
Iodine - 133	Ci	4.72E-5	6.64E-5	0	0
Iodine - 135	Ci	0	0	0	0
Total for Period	Ci	1.04E-4	1.19E-4	0	0
3. Particulates					
Strontium - 89	Ci	8.75E-6	0	0	0
Strontium - 90	Ci	0	0	0	0
Chromium - 51	Ci	9.16E-6	0	0	0
Manganese - 54	Ci	4.12E-6	0	0	0
Cobalt - 58	Ci	0	3.47E-6	0	0
TOTAL FOR PERIOD	Ci	2.20E-5	3.47E-6	0	0

Table 2APage 1 of 2Liquid Effluents - Summation of All Releases

	Units	Quarter 1	Quarter 2	Est. Error Total %
A. Fission & activation products				
1. Total release (not including tritium, gases, alpha)	Ci	1.06E-4	2.93E-5	22.9
2. Average diluted concentration during period	μ Ci/m l	5.05E-12	5.21E-12	22.9
3. Total Body Dose	Millirem	3.71E-4	7.52E-5	22.9
Percent of Technical Specification limit	%	1.24E-2	2.51E-3	22.9
4. Maximally Exposed Organ Dose	Millirem	3.99E-4	1.00E-4	22.9
Percent of Technical Specification limit	%	3.99E-3	1.00E-3	22.9
B. Tritium				
1. Total release	Ci	2.48E1	6.49E0	15.0
2. Average diluted concentration during period	μ Ci/m l	1.18E-6	1.15E-6	15.0
C. Dissolved and entrained gases				
1. Total release	Ci	7.66E-5	4.85E-5	22.9
2. Average diluted concentration during period	µCi/ml	3.65E-12	8.63E-12	22.9
D. Gross alpha radioactivity				
1. Total release	Ci	5.15E-4	0	22.9
2. Average diluted concentration during period	µ Ci/m l	2.45E-11	0	22.9
E. Volume of waste released (prior to dilution)	liters	1.39E6	2.44E5	12.7
F. Volume of dilution water used during period	liters	2.10E10	5.62E9	10.9

Table 2A Page 2 of 2 Liquid Effluents - Summation of All Releases

	Units	Quarter 3	Quarter 4	Est. Error Total %
A. Fission & activation products				
1. Total release (not including tritium, gases, alpha)	Ci	5.83E-4	1.75E-3	22.9
2. Average diluted concentration during period	µCi/ml	1.03E-10	7.46E-11	22.9
3. Total Body Dose	Millirem	1.74E-4	4.89E-4	22.9
Percent of Technical Specification limit	%	5.80E-3	1.63E-2	22.9
4. Maximally Exposed Organ Dose	Millirem	2.13E-4	7.01E-4	22.9
Percent of Technical Specification limit	%	2.13E-3	7.01E-3	22.9
B. Tritium				
1. Total release	Ci	9.55E0	3.72E1	15.0
2. Average diluted concentration during period	µCi/ml	1.69E-6	1.58E-6	15.0
C. Dissolved and entrained gases				
1. Total release	Ci	5.79E-5	5.50E-5	22.9
2. Average diluted concentration during period	μCi/ml	1.02E-11	2.34E-12	22.9
D. Gross alpha radioactivity				• · · · · · · · · · · · · · · · · · · ·
1. Total release	Ci	0	0	22.9
2. Average diluted concentration during period	μ Ci/ml	0	0	22.9
E. Volume of waste released (prior to dilution)	liters	3.83E5	1.61E6	12.7
F. Volume of dilution water used during period	liters	5.65E9	2.35E10	10.9

Table 2BPage 1 of 2Liquid Effluents

		Continuous Mode		Batch Mode	
Nuchdes Released	Units	Quarter 1	Quarter 2	Quarter 1	Quarter 2
Strontium - 89	Ci	0	0	0	0
Strontium - 90	Ci	0	0	0	0
Alpha	Ci	0	0	5.15E-4	0
Tritium	Ci	1.22E-6	0	2.48E1	6.49E0
Phosphorus - 32	Ci	0	0	0	0
Iron - 55	Ci	0	0	0	0
Xenon - 133	Ci	0	0	3.53E-5	3.31E-5
Xenon - 135	Ci	2.73E-9	0	4.13E-5	1.54E-5
Sodium - 24	Ci	1.10E-8	0	0	0
Manganese - 54	Ci	0	0	1.64E-5	4.33E-6
Manganese - 56	Ci	1.12E-8	0	0	0
Cobalt - 60	Ci	0	0	7.89E-5	7.05E-6
Molybdenum - 99	Ci	5.09E-9	0	0	0
Technetium - 99M	Ci	5.46E-9	0	0	0
Silver – 110M	Ci	0	0	0	0
Cesium - 137	Ci	0	0	1.09E-5	1.79E-5
TOTAL FOR PERIOD	Ci	1.26E-6	0	2.48E1	6.49E0

Table 2BPage 2 of 2Liquid Effluents

		Continu	ous Mode	Batch Mode		
Nuclides Released	Units					
		Quarter 3	Quarter 4	Quarter 3	Quarter 4	
Strontium - 89	Ci	0	1.16E-7	1.46E-5	0	
Strontium - 90	Ci	0	1.21E-8	0	0	
Alpha	Ci	0	0	0	0	
Tritium	Ci	0	2.10E0	9.55E0	3.51E1	
Phosphorus - 32	Ci	0	1.91E-4	0	0	
Iron - 55	Ci	0	2.43E-6	2.54E-4	0	
Xenon - 133	Ci	0	0	4.52E-5	3.83E-5	
Xenon - 135	Ci	0	0	1.27E-5	1.66E-5	
Chromium - 51	Ci	0	0	0	8.37E-5	
Manganese - 54	Ci	0	0	8.19E-5	2.61E-4	
Cobalt - 58	Ci	0	0	4.44E-6	2.17E-6	
Cobalt - 60	Ci	0	1.71E-4	1.58E-4	4.12E-4	
Zinc - 65	Ci	0	0	4.27E-5	6.19E-6	
Niobium - 97	Ci	0	0	6.98E-6	0	
Zirconium - 97	Ci	0	0	0	1.09E-5	
Silver -110M	Ci	0	0	4.57E-6	5.50E-4	
Iodine - 135	Ci	0	0	0	2.76E-5	
Cesium - 137	Ci	0	9.18E-6	1.54E-5	8.52E-6	
Lanthanum - 140	Ci	0	0	0	1.38E-5	
TOTAL FOR PERIOD	Ci	0	2.10E0	9.55E0	3.51E1	

EFFLUENT & WASTE DISPOSAL ANNUAL REPORT (1/01/00-12/31/00) PEACH BOTTOM UNITS 2 & 3

CLASSES OF SOLID RADIOACTIVE WASTE SHIPMENTS

Total # of Shipments	Waste Description (source of waste)	Container/Type	Individual Volume (cubic ft)	Total Volume (cubic ft)	Total Curies	Principal Radionuclides
CLASS A						
14	Dewatered Resin	HIC/Type A Cask	195.7	2739.	1.11E+02	Co-60, Cs-137, Zn-65, Mn-54. Ni-63
10	Solidified Resin (1)	HIC/Type A Cask	variable	98.	1.53E+01	Co-60, Cs-137. Zn-65, Mn-54, Ag-110m
1	DAW (2)	Metal Box/STC	variable	220.	1.30E-03	Co-60, Zn-65, Mn-54, Cs-137, Cr-51
32	DAW (3)	Metal Box/STC	variable	352.	9.27E-01	Co-60, Zn-65, Cs-137, Mn-54, Fe-55
(*)	Dewatered Filters (3)	Metal Box/STC	variable	198.	1.29E+00	Co-60, Zn-65, Cs-137, Mn-54, H-3
(*)	Incinerator Ash (3)	Metal Box/STC	variable	4.	1.83E-02	Co-60, H-3, Zn-65, Cs-137, Mn-54
(*)	Asbestos (3)	Metal Box/STC	variable	6.	1.66E-03	Co-60, Zn-65, Cs-137, H-3, Mn-54
45	DAW (4)	Metal Box/STC	variable	1941.	2.93E-01	Co-60, Zn-65, Cs-137, Mn-54, Fe-55
12	DAW (5)	Metal Box/STC	variable	798.	6.68E-01	Co-60, Zn-65, Cs-137, Mn-54, Ni-63

CLASS B

1	Dewatered Resin		105.7	105	1.675+01	Co 60 Co 427 75 65
		,	100.1	100.	1.07 2.01	Mn-54, Ni-63

TOTALS				
115		6557.	1.46E+02	

NOTES:

(1) - Indicates actual total Peach Bottom Atomic Power Station (PBAPS) waste shipped from Studsvik to burial after processing.

(2) - Indicates actual total PBAPS waste shipped from Manufacturing Sciences Corp. (MSC) to burial after processing.

(3) - Indicates actual total PBAPS waste shipped from Duratek (formerly GTS/Duratek) to burial after processing.

(4) - Indicates actual total PBAPS waste shipped from American Ecology Recycle Center (AERC) to burial after processing.

(5) - Indicates actual total PBAPS waste shipped from Allied Technology Group (ATG) to burial after processing.

(*) - Shipment total included with DAW from Duratek as these shipments contained comingled waste streams.

ATTACHMENT A SUPPLEMENT INFORMATION

Facility: Peach Bottom Units 2 & 3

Licenses: DPR-44 DPR-56

1. Regulatory Limits (Offsite Dose Calculation Manual Specification Limits)

A. Noble Gases:

	1.	≤500 ≤3000	mRem/Yr mRem/Yr	- total body - skin	-	"instantaneous" limits ODCMS 3.8.C.1.a
	2.	≤10 ≤20	mRad mRad	- air gamma - air beta	-	quarterly air dose limits ODCMS 3.8.C.2.a and b
	3.	≤20 ≤40	mRad mRad	- air gamma - air beta	-	yearly air dose limits ODCMS 3.8.C.2.c and d
B.	<u>Iodin</u>	<u>es, Triti</u>	um, Particulate	s with Half Life >8	<u>days:</u>	
	1.	≤1500 (inhal	mRem/Yr ation path)	- any organ	-	"instantaneous" limits ODCMS 3.8.C.1.b
	2.	≤1 5	mRem	- any organ	-	quarterly dose limits ODCMS 3.8.C.3.a

3.	≤ 3 0	mRem	- any organ	-	yearly dose limits ODCMS 3.8.C.3.b
----	--------------	------	-------------	---	------------------------------------

C. Liquid Effluents

1.Concentration ≤ 10 times 10 CFR 20,
Appendix B, Table 2, Col. 2-"instantaneous" limits
ODCMS 3.8.B.1

2.	≤3.0 ≤10	mRem mRem	- total body - any organ	-	quarterly dose limits ODCMS 3.8.B.2.a
3.	<6.0	mRem	- total body	-	yearly dose limits

≤6.0	mRem	- total body	-	yearry dose mints
≤20	mRem	- any organ		ODCMS 3.8.B.2.b

D. 40 CFR 190 and 10 CFR 72.104

≤25	mRem	- total body	-	yearly dose limits
_ ≤75	mRem	- thyroid		ODCMS 3.8.D.1
<25	mRem	- any other organ		

ATTACHMENT A (continued)

2. Maximum Permissible Concentrations:

Effluent Concentrations are not used to calculate permissible release rates and concentrations for gaseous releases.

The Effluent Concentrations specified in 10 CFR 20, Appendix B, Table 2, Column 2 times 10, for identified nuclides, are used to calculate permissible release rates and concentrations for liquid release per Peach Bottom Offsite Dose Calculation Manual Specification 3.8.B.1.

3. Average Energy:

Not Applicable

- 4. Measurements and Approximations of Total Radioactivity:
 - A. Fission and Activation Gases:

The method used is the Canberra Genie-ESP Counting System - Gas Marinelli -

B. Iodine:

The method used is the Canberra Genie-ESP Counting System - Charcoal Cartridge -

C. Particulates:

The method used is the Canberra Genie-ESP Counting System - Air Particulate Sample, (37mm and 47mm) -

D. Liquid Effluents:

The method used is the Canberra Genie-ESP Counting System and the Radwaste Liquid Discharge Pre-Release Method with a one liter marinelli or one liter bottle.

ATTACHMENT A (continued)

5. Batch Releases:

A. Liquid:

	QTR 1	QRT 2	QTR 3	QTR 4
Number of batch releases:	27	7	10	25
Total Time for batch releases (minutes)	5711	1163	1695	5916
Maximum time period for batch release (minutes):	295	298	300	315
Average time period for batch release (minutes):	211.52	166.14	169.50	236.64
Minimum time period for batch release (minutes):	33	60	60	70
Dilution volume (liters):	1.76E10	5.63E9	5.65E9	2.35E10

B. Gaseous:

Not Applicable

ATTACHMENT A (Continued)

6. Abnormal Releases:

A. Liquid:

 Event description - On 2/23/00 radioactive contamination was detected in Unit 3 Reactor Building Closed Cooling Water (RBCCW). A previously identified heat exchanger leak of approximately 11 gallons per day from the RBCCW to the service water resulted in the release of slightly contaminated water to the discharge canal. The release was terminated 22 hours later by isolating the leaking heat exchanger

It was estimated that the contaminated water released 3.57E-11 mrem total body dose to the discharge canal. This dose contribution was well below the limits specified in the ODCM.

Analysis of Release - A representative sample was analyzed for all the parameters of a radioactive effluent release. The dose contributions and isotope quantity from this continuous release were added to this Radioactive Effluent Release Report for the applicable reporting period.

2. Event description – On 11/9/00 approximately 22,500 gallons of slightly contaminated High Pressure Service Water (HPSW) was released to the discharge canal. Routine sampling had detected low levels of contamination in the 2B HPSW loop. During an attempt to identify the source of this contamination, the HPSW system was placed in service for an estimated 5 minutes and the contaminated water was discharged. Further sampling verified that no detectable activity remained in the 2B HPSW system.

It was estimated that the contaminated water released 8.81E-5 mrem total body dose to the discharge canal. This dose contribution was well below the limits specified in the ODCM.

Analysis of Release - Representative samples were analyzed for all the parameters of a radioactive effluent release. The dose contributions and isotope quantity from this continuous release were added to this Radioactive Effluent Release Report for the applicable reporting period.

B. Gaseous:

1. Event Description - During 2000 several potential unmonitored release paths were discovered in the turbine building, radwaste building and reactor buildings. These release points were due, in part, to the aging of caulking at concrete-to-metal interfaces.

As each release point was discovered, the direction of the air flow was determined. If flow was out of the structure, a continuous air sample was obtained. No detectable activity was measured at any of the release points.

2. Event Description – The Main Stack flow monitor was declared inoperable on 11/13/00 when incorrect wiring between the flow elements and the flow transmitters was discovered.

Flows were estimated at least every four hours in accordance with ODCMS 3.8.C.4.C.

7. Minimum Detectable Concentrations:

A. Liquid:

If a radionuclide was not detected, zero activity was reported for that isotope. A zero activity indicates that no activity was positively detected in any sample when samples were analyzed with techniques which achieved the required Lower Limits of Detection (LLD) as specified in Offsite Dose Calculation Manual Specification Table 4.8.B.1 Radioactive Liquid Waste Sampling and Analysis. In all but one case, these LLDs were less than the values required by Offsite Dose Calculation Manual Specifications. For one sample, the required LLD for Sr-89 could not be achieved. Sample analysis was delayed during relocation of the vendor laboratory and the long decay time raised the LLD above the required value. In this case, the calculated a-posteriori LLD value, rather than zero activity, was reported.

B. Gaseous:

1

If a radionuclide was not detected, zero activity was reported for that isotope. A zero activity indicates that no activity was positively detected in any sample when samples were analyzed with techniques which achieved the required Lower Limits of Detection (LLD) as specified in Offsite Dose Calculation Manual Specification Table 4.8.C.1 Radioactive Gaseous Waste Sampling and Analysis from Main Stack and Vent Stack. In all cases, these LLDs were less than the values required by Offsite Dose Calculation Manual Specifications.

Offsite Dose Calculation Manual Revision 12

Peach Bottom Atomic Power Station Units 2 and 3

PECO Energy Company Docket Nos. 50-277 & 50-278

PORC Approval : ____

PORC Chairman

Date

PORC Meeting # : _____

Date

Table of Contents

- I. Purpose
- II. Instrument Setpoints
- III. Liquid Pathway Dose Calculations

Α.	Liquid Radwaste	Release	Flow	Rate	Determination
В.	ODCMS 4.8.B.2.1				
С.	ODCMS 4.8.B.4.1				

IV. Gaseous Pathway Dose Calculations

Α.	ODCMS 4.8.C.1.1 and 4.8.C.1.2	
в.	ODCMS 4.8.C.2.1	
С.	ODCMS 4.8.C.3.1	
D.	ODCMS 4.8.C.5.1	
Ε.	Technical Requirements Manual Test Requirement 3.5.3	(TR)
F.	ODCMS 4.8.C.7.1 and 4.8.C.7.2	

- V. Nuclear Fuel Cycle Dose Assessment 40 CFR 190 and 10 CFR 72.104
 - A. ODCMS 4.8.D.1.1 and 4.8.D.1.2
- VI. Calendar Year Dose Calculations
 - A. Unique Reporting Requirement ODCMS 3.10.3
- VII. Radiological Environmental Monitoring Program
 - A. ODCMS 4.8.E.1.1 and 4.8.E.1.2
- VIII. Bases
- Appendix A Radioactive Effluents Control Program

I. <u>Purpose</u>

The purpose of the Offsite Dose Calculation Manual is to establish methodologies and procedures for calculating doses to individuals in areas at and beyond the SITE BOUNDARY due to radioactive effluents from Peach Bottom Atomic Power Station. The results of these calculations are required to determine compliance with the requirements of Specification 5.5.4, "Radioactive Effluent Controls Program" of Appendix A to Operating Licenses DPR-44 and DPR-56, "Technical Specifications for Peach Bottom Atomic Power Station Units No. 2 and 3". The Radioactive Effluents Control Program is located in Appendix A of this Offsite Dose Calculation Manual and contains Offsite Dose Calculation Manual Specifications (ODCMS) and their associated Bases which implement the requirements of Technical Specification 5.5.4.

II. <u>Setpoint Determination for Liquid & Gaseous Monitors</u>

II.A Liquid Radwaste Activity Monitor Setpoint

Each tank of radioactive waste is sampled prior to release. A small liquid volume of this sample is analyzed for gross gamma activity in a NaI well counter. This NaI well counter activity is then converted to an equivalent liquid radwaste monitor reading.

CPS	(R/W M	Ionitor)	=	[Net	CPM/ml	(well)	х	Eff	W/RW]	+
				Backg	round C	PS				

Where:

- CPS (R/W Monitor) = liquid radwaste gross activity monitor reading in CPS
- Net CPM/ml (well) = gross gamma activity for the radwaste sample tank [determined by the well counter]
- Eff W/RW = conversion factor between well
 counter and liquid radwaste gross
 activity monitor [determined by
 calibrating both detectors with the
 same liquid radioactive source]
- Background CPS = background reading of the liquid radwaste gross activity monitor in CPS

Exceeding the expected response would indicate that an incorrect sample had been obtained for that release and the release is automatically stopped.

The alarm and trip pot setpoints for the liquid radwaste activity monitor are determined from a calibration curve for the alarm pot and trip pot. The alarm pot setting includes a factor of 1.25 to allow for analysis error, pot setting error, instrument error and calibration error. The trip pot setting includes a factor of 1.35 to allow for analysis error, pot setting error, instrument error and calibration error.

II.B Liquid Radwaste Release Flowrate Setpoint Determination

The trip pot setpoint for the liquid radwaste release flowrate is determined by multiplying the liquid radwaste flowrate (from Section III.A) by 1.2 and using this value on the appropriate calibration curve for the discharge flow meter to be used. The Peach Bottom radwaste system has two flow monitors - high flow (5 to 300 gpm) and low flow (0.8 to 15 gpm). The factor of 1.2 allows for pot setting error and instrument error. The flow rate determination includes a margin of assurance which includes consideration of this error such that the instantaneous release limit of 10 CFR 20 is not exceeded.

II.C <u>Setpoint Determination for Gaseous Radwaste</u>

The high and high-high alarm setpoints for the main stack radiation monitor, Unit 2 roof vent radiation monitor and Unit 3 roof vent radiation monitor are determined as follows:

<u>High Alarm</u> - the high alarm setpoint is set at approximately 3 x the normal monitor reading.

High-High Alarm - the high-high alarm setpoint is set at a release rate from this vent of approximately 30% of the instantaneous release limit of 10 CFR 20 as specified in ODCMS 3.8.C.1.a for the most restrictive case (skin or total body) on an unidentified basis. To determine these setpoints, solve the gaseous effluent dose rate equations in section IV.A of the ODCM to determine what main stack release rate and roof vent release rate will produce a dose rate of 150 mrem/yr to the total body (30% of the limit of 500 mrem/yr) and a dose rate of 900 mrem/yr to the skin (30% of the limit of 3000 mrem/yr) from each release point. Using the smallest (most restrictive) release rate for each release point determine monitor response required to produce this release rate assuming a normal vent flow rate and pressure correction factor. Set the high-high alarm for approximately this monitor response.

II.D. Setpoint Determination for Gaseous Radwaste

Flow Monitors

The alarm setpoint for the main stack flow monitor is as follows:

<u>Low Flow Alarm</u> - 10,000 CFM. - This setting ensures that the main stack minimum dilution flow as specified in ODCMS 3.8.C.4.a is maintained.

The alarm setpoints for the roof vent flow monitors are as follows:

Low Flow Alarm - 1.5×10^5 cfm

High Flow Alarm - 5.4 x 10^5 cfm

III. Liquid Pathway Dose Calculations

III.A Liquid Radwaste Release Flow Rate Determination

Peach Bottom Atomic Power Station Units 2 and 3 have one common discharge point for liquid releases. The following calculation assures that the radwaste release limits are met.

The flow rate of liquid radwaste released from the site to areas at and beyond the SITE BOUNDARY shall be such that the concentration of radioactive material after dilution shall be limited to 10 times the concentration specified in 10 CFR 20, Appendix B, Table 2, Column 2 for radionuclides other than noble gases and $2E-4 \ \mu Ci/ml$ total activity concentration for all noble gases as specified in ODCMS 3.8.B.1. Each tank of radioactive waste is sampled prior to release and is quantitatively analyzed for identifiable gamma emitters as specified in Table 4.8.B.1 of the ODCMS. From this gamma isotopic analysis the maximum permissible release flow rate is determined as follows:

Determine a Dilution Factor by:

Dilution Factor = $\sum_{i} \frac{\mu Ci / ml_{i}}{10 \times ECL_{i}}$

- µCi / ml_i = the activity of each identified gamma emitter in µCi/ml
- ECL_i = The effluent concentration specified in 10 CFR 20, Appendix B, Table 2, Column 2 for radionuclides other than noble gases or $2 \times 10^{-4} \mu$ Ci/ml for noble gases.

III.A (Cont'd)

Determine the Maximum Permissible Release Rate with this Dilution Factor by:

Release Rate
$$(gpm) = \frac{A \times 2.0 \times 10^5}{B \times C \times Dilution Factor}$$

A = The number of circulating water pumps running
which will provide dilution
2.0 x 10⁵ = the flow rate in gpm for each circulating water
pump running
B = margin of assurance which includes
consideration of the maximum error in the
activity setpoint, the maximum error in the
flow setpoint, and possible loss of 5 out of
the 6 possible circulating water pumps during a
release. The value used for B is 10.0.
C = concentration gradient factor. The value used
for C is 5.0 for discharge canal water levels
less than 104' and 3.0 for canal water levels

III.B ODCMS 4.8.B.2.1

Dose contributions from liquid effluents released to areas at and beyond the SITE BOUNDARY shall be calculated using the equation below. This dose calculation uses those appropriate radionuclides listed in Table III.A.1. These radionuclides account for virtually 100 percent of the total body dose and organ dose from liquid effluents.

greater than 104'.

The dose for each age group and each organ should be calculated to determine the maximum total body dose and organ dose for each quarter and the year, as appropriate. Cumulative dose files for quarterly and yearly doses should be maintained separately and the maximum total body and organ dose reported in each case. **CM-1** NRC URI 88-33-01, T00353.

$$D_{\tau} = \sum_{i} \left[A_{i\tau} \sum_{\ell=1}^{m} \Delta t_{\ell} C_{i\ell} F_{\ell} \right]$$

where:

 D_{τ} = The cumulative dose commitment to the total body or any organ, τ , from liquid effluents for the total time period $\sum_{\ell=1}^{m} \Delta t_{\ell}$, in mrem.

 Δt_{ℓ} = The length of the ℓ th time period over which $C_{i\ell}$ and F_{ℓ} are averaged for the liquid release, in hours.

III.B (Cont'd)

- $C_{i'}$ = The average concentration of radionuclide, i, in undiluted liquid effluent during time period $\Delta t_{,i'}$ from any liquid release, (determined by the effluent sampling analysis program, ODCMS Table 4.8.B.1), in μ Ci/ml.
- $A_{i\tau}$ = The site related ingestion dose commitment factor to the total body or organ, τ , for each radionuclide listed in Table III.A.1, in mrem-ml per hr-µCi. See Site Specific Data.**
- F_{ℓ} = The near field average dilution factor for $C_{i\ell}$ during any liquid effluent release. Defined as the ratio of the maximum undiluted liquid waste flow during release to the average flow through the discharge pathway.

III.C ODCMS 4.8.B.4.1

Projected dose contributions from liquid effluents shall be calculated using the methodology described in section III.B.

** See Note 1 in Bases

LIQUID EFFLUENT INGESTION DOSE FACTORS (DECAY CORRECTED) A_{ir} DOSE FACTOR (MREM-ML PER HR-µCi)

TOTAL BODY

RADIO-

NUCLIDE	ADULT	<u>TEEN</u>	CHILD
H-3	2.13E+00	1.53E+00	2.70E+00
NA-24	1.65E+02	1.70E+02	1.98E+02
P-32	5.93E+04	6.49E+04	8.33E+04
MN-54	9.82E+02	1.00E+03	1.08E+03
FE-55	1.31E+02	1.40E+02	1.96E+02
FE-59	1.14E+03	1.17E+03	1.36E+03
CO-58	2.59E+02	2.62E+02	3.17E+02
CO-60	7.40E+02	7.48E+02	9.07E+02
ZN-65	3.87E+04	3.95E+04	4.16E+04
SR-89	8.83E+02	9.45E+02	1.48E+03
SR-90	1.88E+05	1.56E+05	1.72E+05
TE-129M	2.01E+03	2.17E+03	2.79E+03
TE-131M	4.57E+02	4.81E+02	5.74E+02
TE-132	1.40E+03	1.44E+03	1.65E+03
I-131	1.86E+02	1.79E+02	2.36E+02
I-133	1.97E+01	2.03E+01	3.20E+01
CS-134	6.74E+05	3.88E+05	1.49E+05
CS-136	9.79E+04	9.15E+04	7.30E+04
CS-137	3.98E+05	2.20E+05	8.49E+04
BA-140	3.66E+01	3.62E+01	7.42E+01

NOTE: The listed dose factors are for radionuclides that may be detected in liquid effluents and have significant dose consequences. The factors are decayed for one day to account for the time between effluent release and ingestion of fish by the maximum exposed individual.

TABLE III.A.1 LIQUID EFFLUENT INGESTION DOSE FACTORS (DECAY CORRECTED)

 $A_{i\tau}$ DOSE FACTOR (MREM-ML PER HR- μ Ci)

LIVER

RADTO-

NUCLIDE	ADULT	TEEN	CHILD
H-3	2.13E+00	1.53E+00	2.70E+00
NA-24	1.65E+02	1.70E+02	1.98E+02
P-32	9.55E+04	1.04E+05	1.01E+05
MN-54	5.15E+03	5.06E+03	4.03E+03
FE-55	5.62E+02	6.01E+02	6.33E+02
FE-59	2.96E+03	3.02E+03	2.73E+03
CO-58	1.16E+02	1.14E+02	1.04E+02
CO-60	3.35E+02	3.32E+02	3.07E+02
ZN-65	8.55E+04	8.46E+04	6.69E+04
SR-89	no data	no data	no data
SR-90	no data	no data	no data
TE-129M	4.74E+03	5.09E+03	5.02E+03
TE-131M	5.48E+02	5.77E+02	5.40E+02
TE-132	1.48E+03	1.53E+03	1.36E+03
I-131	3.25E+02	3.32E+02	4.16E+02
I-133	6.48E+01	6.66E+01	8.45E+01
CS-134	8.25E+05	8.36E+05	7.06E+05
CS-136	1.36E+05	1.36E+05	1.13E+05
CS-137	6.07E+05	6.32E+05	5.75E+05
BA-140	7.00E-01	6.90E-01	1.11E+00

NOTE: The listed dose factors are for radionuclides that may be detected in liquid effluents and have significant dose consequences. The factors are decayed for one day to account for the time between effluent release and ingestion of fish by the maximum exposed individual.

LIQUID EFFLUENT INGESTION DOSE FACTORS (DECAY CORRECTED) A_{ir} DOSE FACTOR (MREM-ML PER HR- μ Ci)

BONE

RADIO- <u>NUCLIDE</u>	ADULT	TEEN	CHILD
H-3	no data	no data	no data
NA-24	1.65E+02	1.70E+02	1.98E+02
P-32	2.38E+05	2.58E+05	3.35E+05
MN-54	no data	no data	no data
FE-55	8.12E+02	8.47E+02	1.19E+03
FE-59	1.26E+03	1.30E+03	1.68E+03
CO-58	no data	no data	no data
CO-60	no data	no data	no data
ZN-65	2.69E+04	2.43E+04	2.51E+04
SR-89	3.08E+04	3.30E+04	5.19E+04
SR-90	7.67E+05	6.31E+05	6.78E+05
TE-129M	1.27E+04	1.37E+04	1.80E+04
TE-131M	1.12E+03	1.21E+03	1.56E+03
TE-132	2.29E+03	2.42E+03	3.07E+03
I-131	2.28E+02	2.38E+02	4.13E+02
I-133	3.72E+01	3.92 E +01	6.84E+01
CS-134	3.47E+05	3.55E+05	4.30E+05
CS-136	3.45E+04	3.46 E +04	4.10E+04
CS-137	4.44E+05	4.75E+05	6.01E+05
BA-140	5.57E+02	5.63E+02	1.27E+03

NOTE: The listed dose factors are for radionuclides that may be detected in liquid effluents and have significant dose consequences. The factors are decayed for one day to account for the time between effluent release and ingestion of fish by the maximum exposed individual.

LIQUID EFFLUENT INGESTION DOSE FACTORS (DECAY CORRECTED) A_{it} DOSE FACTOR (MREM-ML PER HR- μ Ci)

KIDNEY

RADIO- <u>NUCLIDE</u>	ADULT	TEEN	CHILD
H-3	2.13E+00	1.53E+00	2.70E+00
NA-24	1.65E+02	1.70E+02	1.98E+02
P-32	no data	no data	no data
MN-54	1.53E+03	1.51E+03	1.13E+03
FE-55	no data	no data	no data
FE-59	no data	no data	no data
CO-58	no data	no data	no data
CO-60	no data	no data	no data
ZN-65	5.72E+04	5.41E+04	4.22E+04
SR-89	no data	no data	no data
SR-90	no data	no data	no data
TE-129M	5.31E+04	5.74E+04	5.29E+04
TE-131M	5.55E+03	6.01E+03	5.22E+03
TE-132	1.43E+04	1.47E+04	1.27E+04
I-131	5.57E+02	5.73E+02	6.82E+02
I-133	1.12E+02	1.16E+02	1.41E+02
CS-134	2.67E+05	2.66E+05	2.19E+05
CS-136	7.57E+04	7.42E+04	6.00E+04
CS-137	2.06E+05	2.15E+05	1.87E+05
BA-140	2.38E-01	2.34E-01	3.62E-01

NOTE: The listed dose factors are for radionuclides that may be detected in liquid effluents and have significant dose consequences. The factors are decayed for one day to account for the time between effluent release and ingestion of fish by the maximum exposed individual.

LIQUID EFFLUENT INGESTION DOSE FACTORS (DECAY CORRECTED) $A_{i\tau}$ DOSE FACTOR (MREM-ML PER HR- μ Ci)

GI-LLI

RADIO-

NUCLIDE	ADULT	TEEN	CHILD
H-3	2.13E+00	1.53E+00	2.70E+00
NA-24	1.65E+02	1.70E+02	1.98E+02
P-32	1.73E+05	1.41E+05	5.98E+04
MN-54	1.58E+04	1.04E+04	3.38E+03
FE-55	3.22E+02	2.60E+02	1.17E+02
FE-59	9.90E+03	7.15E+03	2.84E+03
CO-58	2.35E+03	1.56E+03	6.04E+02
CO-60	6.30E+03	4.33E+03	1.70E+03
ZN-65	5.38E+04	3.58E+04	1.18E+04
SR-89	4.94E+03	3.93E+03	2.01E+03
SR-90	2.22E+04	1.77E+04	9.13E+03
TE-129M	6.40E+04	5.15E+04	2.19E+04
TE-131M	5.44E+04	4.63E+04	2.19E+04
TE-132	7.02E+04	4.85E+04	1.37E+04
I-131	8.58E+01	6.57E+01	3.70E+01
I-133	5.82E+01	5.03E+01	3.40E+01
CS-134	1.44E+04	1.04E+04	3.80E+03
CS-136	1.55E+04	1.09E+04	3.96E+03
CS-137	1.18E+04	9.00E+03	3.60E+03
BA-140	1.15E+03	8.69E+02	6.43E+02

NOTE: The listed dose factors are for radionuclides that may be detected in liquid effluents and have significant dose consequences. The factors are decayed for one day to account for the time between effluent release and ingestion of fish by the maximum exposed individual.

IV. <u>Gaseous Pathway Dose Calculations</u>

IV.A. ODCMS 4.8.C.1.1 and 4.8.C.1.2

The dose rate in areas at and beyond the SITE BOUNDARY due to radioactive materials released in gaseous effluents shall be determined by the expressions below:

IV.A.1 Noble Gases:

The dose rate from radioactive noble gas releases shall be determined by either of two methods. Method (a), the Gross Release Method, assumes that all noble gases released are the most limiting nuclide - Kr-88 for total body dose (vent and stack releases) and skin dose (vent releases) and Kr-87 for skin dose (stack releases). Method (b), the Isotopic Analysis Method, utilizes the results of noble gas analyses required by ODCMS 4.8.C.1.1.

a. Gross Release Method

 $D_{TB} = V \dot{Q}_{NS} + K \left(\overline{\chi/Q} \right)_{V} \dot{Q}_{NV}$ $D_{S} = \left[L_{S} \left(\overline{\chi/Q} \right)_{S} + 1.1B \right] \dot{Q}_{NS} + \left[L_{V} + 1.1M \right] \left(\overline{\chi/Q} \right)_{V} \dot{Q}_{NV}$

where:

The location is the site boundary, 1097m SSE from the vents. This location results in the highest calculated dose to an individual from noble gas releases.

 D_{TB} = total body dose rate, in mrem/yr.

- D_{S} = skin dose rate, in mrem/yr.
- $V = 4.72 \times 10^{-4}$ mrem/yr per µCi/sec; the constant for Kr-88 accounting for the gamma radiation from the elevated finite plume. This constant was developed using MARE program with plant specific inputs for PBAPS.

IV.A.1.a (Cont'd)

- $Q_{\rm NS}$ = The gross release rate of noble gases from the stack determined by gross activity stack monitors averaged over one hour, in µCi/sec.
- K = 1.47 X 10^4 mrem/yr per μ Ci/m³; the total body dose factor due to gamma emissions for Kr-88 (Reg. Guide 1.109, Table B-1).
- $(\overline{\chi/Q})_V$ = 5.33 X 10⁻⁷ sec/m³; the highest calculated annual average relative concentration for any area at or beyond the SITE BOUNDARY for all vent releases.
- Q_{NV} = The gross release rate of noble gases in gaseous effluents from vent releases determined by gross activity vent monitors averaged over one hour, in μCi/sec.
- L_V = 2.37 x 10³ mrem/yr per μ Ci/m³; the skin dose factor due to beta emissions for Kr-88. (Reg. Guide 1.109, Table B-1).
- L_S = 9.73 X 10³ mrem/yr per μ Ci/m³; the skin dose factor due to beta emissions for Kr-87. (Reg. Guide 1.109, Table B-1).
- $(\overline{\chi/Q})_{S}$ = 9.97 X 10⁻⁸ sec/m³; the highest calculated annual average relative concentration from the stack releases for any area at or beyond the SITE BOUNDARY.
- B = 1.74×10^{-4} mrad/yr per µCi/sec; the constant for Kr-87 accounting for the gamma radiation from the elevated finite plume. This constant was developed using MARE program with plant specific inputs for PBAPS.
- M = $1.52 \times 10^4 \text{ mrad/yr per } \mu \text{Ci/m}^3$; the air dose factor due to gamma emissions for Kr-88. (Reg. Guide 1.109, Table B-1).
- 1.1 = Unit conversion, converts air dose to skin dose, mrem/mrad.

IV.A.1. b. Isotopic Analysis Method

$$D_{TB} = \sum_{i} \left(V_{i} \dot{Q}_{iS} + K_{i} \left(\overline{\chi/Q} \right)_{V} \dot{Q}_{iV} \right)$$
$$D_{S} = \sum_{i} \left[\left(L_{i} \left(\overline{\chi/Q} \right)_{S} + 1.1B_{i} \right) \dot{Q}_{iS} + \left(L_{i} + 1.1M_{i} \right) \left(\overline{\chi/Q} \right)_{V} \dot{Q}_{iV} \right]$$

where:

The location is the site boundary, 1097m SSE from the vents. This location results in the highest calculated dose to an individual from noble gas releases.

- D_{TB} = total body dose rate, in mrem/yr.
- D_S = skin dose rate, in mrem/yr.
- V_i = The constant for each identified noble gas radionuclide for the gamma radiation from the elevated finite plume. The constants were developed using the MARE program with plant specific inputs for PBAPS. Values are listed on Table IV.A.1, in mrem/yr per μCi/sec.
- K_i = The total body dose factor due to gamma emissions for each identified noble gas radionuclide. Values are listed on Table IV.A.1, in mrem/yr per μCi/m³.
- $(\overline{\chi/Q})_V$ = 5.33 X 10⁻⁷ sec/m³; the highest calculated annual average relative concentration for any area at or beyond the SITE BOUNDARY for all vent releases.
- L_i = The skin dose factor due to beta emissions for each identified noble gas radionuclide. Values are listed on Table IV.A.1, in mrem/yr per $\mu Ci/m^3$.

IV.A.1.b (Cont'd)

- $(\overline{\chi/Q})_{S}$ = 9.97 X 10⁻⁸ sec/m³; the highest calculated annual average relative concentration from the stack releases for any area at or beyond the SITE BOUNDARY.
- B_i = The constant for each identified noble gas radionuclide accounting for the gamma radiation from the elevated finite plume. The constants were developed using MARE program with plant specific inputs for PBAPS. Values are listed on Table IV.A.1, in mrad/yr per μCi/sec.
- M_i = The air dose factor due to gamma emissions for each identified noble gas radionuclide. Values are listed on Table IV.A.1, in mrad/yr per μ Ci/m³.
- 1.1 = Unit conversion, coverts air dose to skin dose, mrem/mrad.
| TABLE | IV.A.1 - Cons | tants | for | Isotopic | Analysis | Method |
|-------|---------------|-------|------|----------|----------|--------|
| | (corrected | for d | ecay | during t | transit) | |

Radionuclide	Plume-Air Dose Factor Bi (mrad/yr per µCi/sec)	Total Body Dose Factor K _i (mrem/yr per µCi/m ³)	Skin Dose Factor L _i (mrem/yr per µCi/m ³)	Gamma Air Dose Factor Mi (mrad/yr per µCi/m ³)	Beta Air Dose Factor Ni (mrad/yr per µCi/m ³)	Plume-Body Dose Factor Vi (mrem/yr per µCi/sec)
Kr-85m	4.02E-05	1.17E+03	1.46E+03	1.23E+03	1.97E+03	3.76E-05
Kr-87	1.74E-04	5.92E+03	9.73E+03	6.17E+03	1.03E+04	1.66E-04
Kr-88	4.90E-04	1.47E+04	2.37E+03	1.52E+04	2.93E+03	4.72E-04
Xe-133	1.19E-05	2.94E+02	3.06E+02	3.53E+02	1.05E+03	1.11E-05
Xe-133m	1.09E-05	2.51E+02	9.94E+02	3.27E+02	1.48E+03	1.01E-05
Xe-135	6.37E-05	1.81E+03	1.86E+03	1.92E+03	2.46E+03	5.95E-05
Xe-135m	6.61E-05	2.53E+03	5.76E+02	2.72E+03	5.99E+02	6.17E-05
Xe-138	1.52E-04	6.98E+03	3.26E+03	7.28E+03	3.75E+03	1.46E-04

The values K_i , L_i , M_i , and N_i are taken from Reg. Guide 1.109, Table B-1. The values B_i and V_i were developed using the MARE program with plant specific inputs for PBAPS.

IV.A.2 <u>Iodine-131, iodine-133, tritium and radioactive materials in</u> <u>particulate form, other than noble gases, with half-lives</u> <u>greater than eight days</u>:

The dose rate shall be determined for either of two critical organs and most restrictive age group. Child thyroid dose is limiting when iodine releases exceed 10 percent of the total release rates. The teenager lung dose is limiting when iodine is either not present or a small fraction of the total release.

When it is not clear which organ dose will be limiting, doses for both restrictive age group organs will be calculated and the limiting organ dose identified.

$$D = \sum_{i} P_{i} \left[W_{S} \dot{Q}_{iS} + W_{V} \dot{Q}_{iV} + W_{V} \dot{q}_{iV} \right]$$

where:

The location is the site boundary, 1097m SSE from the vents.

- D = dose rate to the critical organ most restrictive age group, in mrem/yr.
- P_i = The dose parameter for radionuclides other than noble gases for the inhalation pathway. The dose factors are based on the critical organ, and most restrictive age group. All values are from Reg. Guide 1.109 (Tables E-5, E-8 and E-9). Values are listed on Table IV.A.2, in mrem/yr per μCi/m³
- W_S = 1.03 X 10⁻⁷ sec/m³; the highest calculated annual average relative concentration for any area at or beyond the SITE BOUNDARY from stack releases. (SSE boundary)
- Q_{iS} = The release rate of radionuclides; i, in gaseous effluents from the stack determined by the effluent sampling and analysis program (ODCMS Table 4.8.C.1) in μCi/sec.
- W_V = 4.78 X 10⁻⁷ sec/m³; the highest calculated annual average relative concentration for any area at or beyond the SITE BOUNDARY for all vent releases. (SSE boundary)

IV.A.2. (Cont'd)

- $\dot{Q}_{i\nu}$ = The release rate of radionuclide, i, in gaseous effluents from all vent releases, determined by the effluent sampling and analysis program (ODCMS Table 4.8.C.1) in μ Ci/sec.
- q_{iv} = The release rate of radionuclide, i, in gaseous effluents from the auxiliary boiler stack releases, determined by the oil sampling and analysis program (ODCM Specification Table 4.8.C.1) in μ Ci/sec as calculated below:

$$= \sum_{i} \frac{C_{iV} \times 3785 \times Z}{T}$$

where:

The location is the site boundary, 1097m SSE from the vents.

- $C_{i\nu}$ = activity concentration measured in oil for nuclide, i, in μ Ci/ml.
- 3785 = milliliters per gallon.
- Z = gallons of oil consumed.
- T = number of seconds used for release Method (a) 60 second Method (b) number of seconds used to burn oil for release.

TABLE IV.A.2Pi CONSTANTS FOR CRITICAL ORGAN FOR THEMOST RESTRICTIVE AGE GROUP

(mrem/yr per $\mu \text{Ci/m}^3$)

Radionuclide	Child Thyroid <u>Dose Factor</u>	Teenager Lung <u>Dose Factor</u>
H-3	1.12×10^3	1.27×10^3
Mn-54	0	1.98 x 10 ⁶
Cr-51	8.55 x 10^{1}	2.10×10^4
Co-58	0	1.34×10^{6}
Co-60	0	8.72 x 10 ⁶
Zn-65	0	1.24×10^{6}
Sr-89	0	2.42×10^6
Sr-90	0	1.65×10^7
I-131	1.62×10^7	0
I-133	3.85 x 10 ⁶	0
I-135	7.92 x 10^5	0
Cs-134	0	1.46 x 10 ⁵
Cs-137	0	1.21×10^5
Ba-140	0	2.03×10^{6}
Ce-141	0	6.14 x 10 ⁵

IV.B. <u>ODCMS 4.8.C.2.1</u>

The air dose in areas at and beyond the SITE BOUNDARY due to noble gases released in gaseous effluents shall be determined by the expressions below.

The air dose shall be determined by either of two methods. Method (a), the Gross Release Method, assumes that all noble gases released are the most limiting nuclide - Kr-88 for gamma radiation and Kr-87 for beta radiation. Method (b), the Isotopic Analysis Method, utilizes the results of noble gas analyses required by ODCMS 4.8.C.1.1.

- IV.B.1 for gamma radiation:
 - a. Gross Release Method

$$D_{\gamma} = 3.17 \times 10^{-8} \left[M \left(\overline{\chi/Q} \right)_V \tilde{Q}_V + B \tilde{Q}_S \right]$$

where:

The location is the SITE BOUNDARY 1097m SSE from the vents. This location results in the highest calculated gamma air dose from noble gas releases.

- D_{γ} = gamma air dose, in mrad.
- 3.17×10^{-8} = years per second.
- M = 1.52×10^4 mrad/yr per μ Ci/m³; the air dose factor due to gamma emissions for Kr-88. (Reg. Guide 1.109, Table B-1)
- $(\chi/Q)_{17} = 5.33 \times 10^{-7} \text{ sec/m}^3$; the highest calculated

annual average relative concentration from vent releases for any area at or beyond the SITE BOUNDARY.

Q_V = The gross release of noble gas radionuclides in gaseous effluents from all vents, determined by gross activity vent monitors, in μCi. Releases shall be cumulative over the calendar quarter or year as appropriate. IV.B.1. a (Cont'd)

- B = 4.90×10^{-4} mrad/year per µCi/sec; the constant for Kr-88 accounting for the gamma radiation from the elevated finite plume. The constant was developed using the MARE program with plant specific inputs for PBAPS.
- Q_S = The gross release of noble gas radionuclides in gaseous releases from the stack determined by gross activity stack monitor in µCi. Releases shall be cumulative over the calendar quarter or year as appropriate.
- b. Isotopic Analysis Method

$$D_{\gamma} = 3.17 \times 10^{-8} \sum_{i} \left[M_{i} \left(\overline{\chi/Q} \right)_{V} \tilde{Q}_{iV} + B_{i} \tilde{Q}_{iS} \right]$$

where:

The location is the SITE BOUNDARY, 1097m SSE from the vents. This location results in the highest calculated gamma air dose from noble gas releases.

 D_{γ} = gamma air dose, in mrad.

 3.17×10^{-8} = years per second.

- M_i = The air dose factor due to gamma emissions for each identified noble gas radionuclide. Values are listed on Table IV.A.1, in mrad/yr per $\mu Ci/m^3$.
- $(\chi/Q)_V$ = 5.33 x 10⁻⁷ sec/m³; the highest calculated average relative concentration from vent releases for any area at or beyond the SITE BOUNDARY.
- QiV = The release of noble gas radionuclides, i, in gaseous effluents from all vents as determined by isotopic analysis, in µCi. Releases shall be cumulative over the calendar quarter or year, as appropriate.
- B_i = The constant for each identified noble gas radionuclide accounting for the gamma radiation for the elevated finite plume. The constants were developed using the MARE program with plant specific inputs for PBAPS. Values are listed on Table IV.A.1, in mrad/yr per μCi/sec.

IV.B.1. b. (Cont'd)

а

 Q_{iS} = The release of noble gas radionuclides, i, in gaseous effluents from the stack determined by isotopic analysis, in µCi. Releases shall be cumulative over the calendar quarter or year, as appropriate.

IV.B.2. for beta radiation:

Gross Release Method

$$D_{\beta} = 3.17 \times 10^{-8} N \left[\left(\overline{\chi/Q} \right)_V \tilde{Q}_V + \left(\overline{\chi/Q} \right)_S \tilde{Q}_S \right]$$

where:

The location is the SITE BOUNDARY 1097m SSE from the vents. This location results in the highest calculated gamma air dose from noble gas releases.

- D_{β} = beta air dose, in mrad.
- 3.17×10^{-8} = years per second.
- N = 1.03×10^4 mrad/yr per μ Ci/m³; the air dose factor due to beta emissions for Kr-87. (Reg. Guide 1.109, Table B-1)
- $(\overline{\chi/Q})_V$ = 5.33 x 10⁻⁷ sec/m³; the highest calculated annual average relative concentration from vent releases for any area at or beyond the SITE BOUNDARY.
- Q_V = The gross release of noble gas radionuclides in gaseous effluents from all vents determined by gross activity vent monitors, in µCi. Releases shall be cumulative over the calendar quarter or year, as appropriate.
- $(\overline{\chi/Q})_{S}$ = 9.97 x 10⁻⁸ sec/m³; the highest calculated annual average relative concentration from the stack releases for any area at or beyond the SITE BOUNDARY.
- Q_S = The gross release of noble gas radionuclides in gaseous releases from the stack determined by gross activity stack monitors, in µCi. Releases shall be cumulative over the calendar quarter or year, as appropriate.

IV.B.2. b. Isotopic Analysis Method

$$D_{\beta} = 3.17 \times 10^{-8} \sum_{i} N_{i} \left[\left(\overline{\chi/Q} \right)_{V} \tilde{Q}_{iV} + \left(\overline{\chi/Q} \right)_{S} \tilde{Q}_{iS} \right]$$

 3.17×10^{-8} = years per second.

- N_i = The air dose factor due to beta emissions for each identified noble gas radionuclide. Values are listed on Table IV.A.1, in mrad/yr per $\mu Ci/m^3$.
- $(\overline{\chi/Q})_V$ = 5.33 x 10⁻⁷ sec/m³; the highest calculated annual average relative concentration from vent releases for any area at or beyond the SITE BOUNDARY.
- Q_{iV} = The release of noble gas radionuclide, i, in gaseous effluents from all vents as determined by isotopic analysis, in µCi. Releases shall be cumulative over the calendar quarter or year, as appropriate.
- $(\overline{\chi/Q})_{s}$ = 9.97 x 10⁻⁸ sec/m³; the highest calculated

annual average relative concentration from the stack releases for any area at or beyond the SITE BOUNDARY.

 Q_{iS} = The release of noble gas radionuclide, i, in gaseous effluents from the stack as determined by isotopic analysis, in µCi. Releases shall be cumulative over the calendar quarter or year, as appropriate.

IV.C <u>ODCMS 4.8.C.3.1</u>

The dose to an individual from iodine-131, iodine-133, tritium and radioactive materials in particulate form and radionuclides other than noble gases with half-lives greater than eight days in gaseous effluents released to areas at and beyond the SITE BOUNDARY.

The dose shall be determined for the limiting organ. Infant thyroid doses are dominating any time that either iodine-131 release rates are more than two (2) percent of total release rates or iodine-133 exceeds 25 percent of total release rates. In these cases only iodine-131 and iodine-133 are potentially significant.

For cases where there is no detectable iodine releases, doses shall be determined for infant bone and liver. Both bone and liver doses are calculated because the controlling dose is dependent upon the presence of strontium.

IV.C (Continued)

When it is not clear whether thyroid, bone, or liver doses are controlling, all three shall be calculated and the limiting dose identified.

$$D = 3.17 \times 10^{-8} \sum_{i} F_{e} R_{i} \left[W_{S} \tilde{Q}_{iS} + W_{V} \tilde{Q}_{iV} + W_{V} \tilde{q}_{iV} \right]$$

where:

Location is the critical pathway dairy 1431m WSW from vents.

D = limiting dose to the critical infant organ, from the milk pathway, in mrem.

 3.17×10^{-8} = years per second.

- F_e = Fraction that is elemental (0.5 for iodines and 1.0 for all other elements).
- R_i = The dose factor for each identified radionuclide; i, in m² (mrem/yr) per µCi/sec except tritium, which is in mrem/yr per µCi/m³. The dose factors are for the critical individual organ for the most restrictive age group, infant. Values are listed in Table IV.C.1. See Site Specific Data.**
- W_s = 8.78 x 10⁻¹⁰ meters⁻²; $(\overline{D/Q})$ for the food pathway for stack releases except tritium which uses a (χ/Q) of 8.78 x 10⁻⁸ sec/m³.
- \widetilde{Q}_{is} = The release of radionuclide, i, in gaseous effluents from the stack determined by the effluent sampling and analysis program (ODCMS Table 4.8.C.1), in μ Ci. Releases shall be cumulative over the calendar quarter or year, as appropriate.

$$W_V$$
 = 1.58 x 10⁻⁹ meters⁻²; (D/Q) for the food
pathway for vent releases except tritium
which uses a (χ/Q) of 1.58 x 10⁻⁷ sec/m³.

** See Note 2 and 3 in Bases

IV.C (Continued)

- $\widetilde{Q}_{i\nu}$ = The release of radionuclide, i, in gaseous effluents from the vents determined by the effluent sampling and analysis program (ODCMS Table 4.8.C.1) in μ Ci. Release shall be cumulative over the calendar quarter or year, as appropriate.
- $q_{i\nu}$ = The release of radionuclide, i, in gaseous effluents from the auxiliary boiler stack releases, determined by the oil sampling and analysis program (ODCMS Table 4.8.C.1) in µCi. Release shall be cumulative over the calendar quarter or year, as appropriate.

TABLE IV.C.1 Ri CONSTANTS INGESTION PATHWAY

(m² (mrem/yr) per µCi/sec)*

RADIONUCLIDE	<u>Infant Liver</u>	<u>Infant Thyroid</u>	<u>Infant Bone</u>
H-3	1.30×10^3	1.30 x 10^3	0
Cr-51	0	3.35 X 10 ⁴	0
Mn-54	1.93 x 10 ⁷	0	0
Co-58	9.57 x 10 ⁶	0	0
Co-60	4.69 X 10 ⁷	0	0
Zn-65	9.22 x 10 ⁹	0	2.69 x 10 ⁹
Sr-89	0	0	4.58 x 10 ⁹
Sr-90	0	0	6.55×10^{10}
I-131	9.37 x 10 ⁸	3.08×10^{11}	7.95 x 10 ⁸
I-133	1.56 x 10 ⁷	2.84 x 10 ⁹	1.07×10^{7}
Cs-134	3.54×10^{10}	0	1.90×10^{10}
Cs-137	3.24×10^{10}	0	2.77×10^{10}
Ba-140	7.09 x 10 ⁴	0	7.09×10^7
Ce-141	8.69 x 10 ³	0	1.42×10^4

* Tritium $R_{\rm i}$ values in units of mrem/yr per $\mu \text{Ci}/\text{m}^3$

IV.D <u>ODCMS 4.8.C.5.1</u>

The projected doses from releases of gaseous effluents to areas at and beyond the SITE BOUNDARY shall be calculated in accordance with the following sections of this manual:

- a. gamma air dose IV.B.1
- b. beta air dose IV.B.2
- c. organ dose IV.C

The projected dose calculation shall be based on expected release from plant operation. The normal release pathways result in the maximum releases from the plant. Any alternative release pathways result in lower releases and, therefore, lower doses.

- IV.E <u>Technical Requirements Manual Test Requirement (TR) 3.5.3</u>
- IV.E.1 The recombiner hydrogen analyzers currently used at Peach Bottom are Whittaker Electrochemical type. (Analyzers 4083A and 4083B on Unit 2. Analyzers 5083A and 5083B on Unit 3.)
- IV.E.2 The calibration gas for the Whittaker Analyzers is 2% Hydrogen, Balance Air.
- IV.F <u>ODCMS 4.8.C.7.1 and 4.8.C.7.2</u>
- IV.F.1 The dose rate in areas at and beyond the SITE BOUNDARY due to radioactive materials released in gaseous effluents from the incineration of waste oil from the auxiliary boilers shall be calculated by the equation in IV.A.2.

The dose rate from radioactive particulate release shall be determined by either of two methods. Method (a), total instantaneous release assumes that the total activity contained in the waste oil is released in the first minute of incineration. Method (b) uses the activity release over the entire time of incineration.

For normal operations, it is assumed that Method (a) will be used, since the total activity from the waste oil is expected to contribute an insignificant dose compared to the annual limits. However, in the event that the activity is significantly higher than administrative or regulatory limits, then Method (b) would be used because it is more accurate in calculating the dose rate.

Since the auxiliary boiler stacks are at approximately the same height as the reactor vents and discharge from the auxiliary boilers will also be heated, the use of the reactor vent D/Q value for the calculations is considered conservative.

IV.F.2 The dose to an individual from radioactive materials in particulate form and radionuclides other than noble gases with half-lives greater than eight days in gaseous effluents released to areas at and beyond the SITE BOUNDARY from the incineration of contaminated waste oil from the auxiliary boiler stacks shall be calculated by the equation in IV.C.

V.A. ODCMS 4.8.D.1.1 and 4.8.D.1.2

V.A.1 ODCMS 4.8.D.1.1

The total gaseous and liquid cumulative dose contributions are limited by ODCMS 3.8.D.1 to 3.0 mrem for whole body and critical organ, and 55 mrem for the thyroid to preserve assumptions set forth in the 10CFR72.212 report for the TN-68 spent fuel casks that are stored on the Independent Spent Fuel Storage(IFSI) pad. Exceeding these action levels does not necessarily result in the overall 40CFR190 or 10CFR72.104 requirements not being met. Further calculations are required to determine compliance.

Whole Body

The whole body dose contribution from liquid and gaseous effluents shall be determined by the following method:

$$D_{WB} = D_{\tau} + D_{\gamma}$$

where:

- $D_{\rm WB}$ = whole body dose from liquid and gaseous effluents, in mrem.
- D_r = cumulative dose commitment to the total body from liquid effluents, in mrem (Determined by ODCM Section III.B).
- D_{γ} = gamma air dose, in mrad (Determined by ODCM Section IV.B, with mrad equivalent to mrem).

Critical organ(except thyroid)

The critical organ(except thyroid) dose contribution from liquid and gaseous effluents shall be determined by the following method:

$$D_{co} = D_{\tau} + D_{\gamma} + D$$

where:

 D_{co} = critical organ(except thyroid) dose from liquid and gaseous effluents, in mrem.

V.A.1 (Continued)

- D_r = cumulative dose commitment to any organ from liquid effluents, in mrem (Determined by ODCM Section III.B).
- D_{γ} = gamma air dose, in mrad (Determined by ODCM Section IV.B, with mrad equivalent to mrem).
- D = limiting dose to the critical organ(except thyroid), in mrem (Determined by ODCM Section IV.C).

Thyroid

The thyroid dose contribution from gaseous effluents shall be determined by the following method:

$$D_{Thv} = D_r + D_v + D$$

where:

- D_{Thy} = thyroid dose from gaseous effluents, in mrem.
- D_r = cumulative dose commitment to any organ from liquid effluents, in mrem (Determined by ODCM Section III.B).
- D_{γ} = gamma air dose, in mrad (Determined by ODCM Section IV.B, with mrad equivalent to mrem).
- D = limiting dose to the thyroid, in mrem (Determined by ODCM Section IV.C).

V.A.2 <u>ODCMS 4.8.D.1.2</u>

The cumulative dose from all sources(i.e. gas and liquid effluents and direct radiation) is calculated by summing the individual doses obtained in ODCMS 4.8.D.1.1 for whole body(D_{WB}), critical organ(D_{co}) and thyroid(D_{π_y}) with the TLD measured dose(mrem) minus the background dose.

Whole Body

The cumulative whole body dose from liquid, gas and direct radiation shall be determined by the following method:

$$D_{WB}^{Total} = D_{WB} + D_{n}$$

where:

 D_{WB}^{Total} = whole body dose equivalent from all sources, in mrem.

V.A.2 (continued)

- D_{WB} = whole body dose from liquid and gaseous effluents, in mrem.
- D_D = Dose from direct radiation, in mrem(after subtracting background).

Critical Organ(except thyroid)

The cumulative critical organ(except thyroid) dose from liquid, gas and direct radiation shall be determined by the following method:

$$D_{CO}^{Total} = D_{CO} + D_D$$

where:

- D_{CO}^{Total} = critical organ(except thyroid) dose equivalent from all sources, in mrem.
- D_{co} = critical organ(except thyroid) dose from liquid and gaseous effluents, in mrem.
- D_D = Dose from direct radiation, in mrem(after subtracting background).

<u>Thyroid</u>

The cumulative thyroid dose from gas and direct radiation shall be determined by the following method:

$$D_{Thy}^{Total} = D_{Thy} + D_D$$

where:

 D_{Thv}^{Total} = thyroid dose equivalent from all sources, in mrem.

 D_{Thy} = thyroid dose from gaseous effluents, in mrem.

D_D = Dose from direct radiation, in mrem(after subtracting background).

The dose contribution is calculated at the discharge point for liquids and in the worst sector for gases. If necessary, the dose contribution from liquid and gas may be calculated for a real individual.

VI.A. <u>Unique Reporting Requirement ODCMS 3.10.3</u>, <u>Dose Calculations</u> for the Radiation <u>Dose Assessment Report</u>

The assessment of radiation doses for the radiation dose assessment report shall be performed utilizing the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses To Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I", Revision 1, October 1977. Any deviations from the methodology provided in Regulatory Guide 1.109 shall be documented in the radiation dose assessment report.

The meteorological conditions concurrent with the time of release of radioactive materials (as determined by sampling frequency of measurement) or approximate methods shall be used as input to the dose model.

The Radiation Dose Assessment Report shall be submitted within 120 days after January 1 of each year in order to allow time for the calculation of radiation doses following publication of radioactive releases in the Radioactive Effluent Release Report. There is a very short turnaround time between the determination of all radioactive releases and publication of the Radioactive Effluent Release Report. This would not allow time for calculation of radiation doses in time for publication in the same report.

VII.A ODCMS 4.8.E.1.1 and 4.8.E.1.2

The radiological environment monitoring samples shall be collected pursuant to Table VII.A.1 from the locations shown on Figures VII.A.1, VII.A.2, and VII.A.3, and shall be analyzed pursuant to the requirements of Table VII.A.1.

ODCM - Peach Bottom Atomic Power Station Radiological Environmental Monitoring Program

Pathway	Station Code	Distance and Direction from PBAPS Vents	Collection Method and Discusion	Analyses
I. <u>Dir</u>	rect Radiation	······································		
Site E	Boundary 1L 1A 2 1I 1C 1J	1,256 feet NE of site 1,396 feet SE of site 4,661 feet SE of site 2,851 feet SSE of site 4,513 feet SSE of site 3,755 feet S of site	1 set of four (4) TLDs from each location at least quarterly Gamma dose quarterly	Gamma Dose quarterly
	1F 40 1NN 1H 1G 1B 1E	2,707 feet SSW of site 7,050 feet SW of site 2,547 feet WSW of site 3,104 feet W of site 3,173 feet WNW of site 2,587 feet NW of site 3,136 feet NNW of site	TLD sites were chosen in accordance with Peach Bottom ODCMS Table 4.8.E.1 Item 1. Site Boundary stations all sectors except several along	
Interm Distan	nediate 15 22 44 32 45 14 17 31A 4K 23 27 48 3A 49 50 51 26 6B	19,449 feet N of site 13,230 feet NNE of site 27,480 feet NE of site 15,213 feet ENE of site 18,524 feet ENE of site 10,397 feet E of site 21,966 feet ESE of site 24,105 feet SE of site 45,721 feet SE of site 5,276 feet SSE of site 13,859 feet S of site 25,772 feet SSW of site 20,673 feet WSW of site 20,677 feet W of site 20,511 feet NWW of site 22,093 feet NW of site 30,538 feet NW of site	sectors are monitored by stations on the east side of Conowingo Pond. The 5 mile vicinity stations cover all sectors. The distant and special interest stations provide information in population centers and control locations.	

ODCM - Peach Bottom Atomic Power Station Radiological Environmental Monitoring Program

Pathway	Station Code	Distance and Direction from PBAPS Vents	Collection Method and Discusion	Analyses
Distant	43	26,931 feet NNE of site		
Special	16	67,788 feet E of site		
Interest	24 2B 46 47	58,048 feet ESE of site 3,768 feet SSE of site 23,483 feet SSE of site 22,153 feet S of site		
	18 19 C	51,413 feet W of site 106,354 feet WNW of site		

II. <u>Airborne</u>

Particulates	1Z 1B 1C 3A 5H2 C	1,396 fe 2,587 fe 4,513 fe 19,114 fe 162,565 fe	et SE o et NW o et SSE et SW o et NE o	of site of site of site of site of site	Approximately 1 cfm continuous flow through glass fiber filter which is collected weekly.	Gross beta analysis on each weekly sample. Gamma spectrometry shall be done when gross beta exceeds ten times the
					These stations provide for coverage of the highest annual	yearly mean of control station value.
					average ground level D/Q near the site boundary, the community with the highest annual average D/Q and a control location.	Gross beta analysis done ≥24 hr after sampling to allow for Radon and Thoron daughter decay.
						Gamma Spec on quarterly composite by location.

Page 34 of 48, Rev. 12

ODCM - Peach Bottom Atomic Power Station Radiological Environmental Monitoring Program

Pathway	/	Station Code	Distance and Direction from PBAPS Vents	Collection Method and Discusion	Analyses
	Iodine	1Z 1B 1C 3A 5H2 C	1,396 feet SE of site 2,587 feet NW of site 4,513 feet SSE of site 19,114 feet SW of site 162,565 feet NE of site	A TEDA impregnated flow-through cartridge is connected to air sampler and is collected weekly at site filter change.	Iodine 131 weekly
III.	<u>Waterborne</u>				
	Surface	1LL C 1MM	1,256 feet NE of site 5,470 feet SE of site	Sample collected from a continuous water sampler, monthly. In event sampler is inoperable, grab samples will be collected each calendar day until sampler returned to service.	Gamma isotopic analysis monthly; H-3 on quarterly composite
	Drinking	4L 6I C	45,721 feet SE of site 30,337 feet NW of site	Sample collected from a continuous water sampler monthly. In event sampler is inoperable, weekly grab samples will be collected until sampler returned to service.	Gross beta and gamma isotopic monthly, H-3 on quarterly composite

ODCM - Peach Bottom Atomic Power Station Radiological Environmental Monitoring Program

Pathw	ay	Station Code	Distance and Direction from PBAPS Vents	Collection Method and Discusion	Analyses
	Sediment	4J	7,346 feet SE of site	A sediment sample is taken down stream of discharge semi-annually.	Gamma isotopic analysis each sample
IV.	Ingestion				
	Milk	AC J R O	30,493 feet WSW of site 5,119 feet W of site 4,694 feet WSW of site 12,241 feet SW of site	Sample of fresh milk is collected from each farm biweekly when cows are on pasture (April through October), monthly at other times.	I-131 analyses on each sample Gamma isotopic analysis or Cs-134, -137 by chemical separation quarterly
	Fish	4 6 C	7,162 feet SE of site 57,347 feet NW of site	Two species of recreationally important fish (predator and bottom feeder) sampled in season or semiannually if not seasonal.	Gamma isotopic analyses on edible portions.
F P	ood roducts	Two offs: predicted level D/0 30 km d prevalen determine the most Survey.	ite locations of highest d annual average ground Q and one location (15- istance) in the least t wind direction as ed using the results of recent annual Land use	Samples of three (3) different kinds of broad leaf vegetation monthly when available if milk sampling is not performed	Gamma isotopic and I-131 analysis

Page 37 of 48, Rev. 12



FIGURE VII.A.1 ENVIRONMENTAL SAMPLING STATIONS AT SITE BOUNDARY AREA TO PEACH BOTTOM



FIGURE VII.A.2 ENVIRONMENTAL SAMPLING STATIONS AT INTERMEDIATE DISTANCES FROM PEACH BOTTOM SITE



FIGURE VII.A.3 ENVIRONMENTAL SAMPLING STATIONS AT REMOTE DISTANCES FROM PEACH BOTTOM SITE









VIII. <u>Bases</u>

Site Specific Data

<u>NOTE 1</u>

Liquid dose factors, $A_{i\tau}$, for section III.B were developed using the following site specific data. The liquid pathways involved are drinking water and fish.

 $A_{i\tau} = \left(U_w / D_w + U_F x BF_i\right) k_0 x DF_i x RC$

- U_w = liters per year; maximum age group usage of drinking water (Reg. Guide 1.109, Table E-5)
- D_w = 5.4; average annual dilution at Conowingo intake
- U_F = kg per year; maximum age group usage of fish (Reg. Guide 1.109, Table E-5)
- BF_i = bioaccumulation factor for nuclide, i, in freshwater fish. Reg. Guide 1.109, Table A-1, except P-32 which uses a value of 3.0 x 10³ pCi/kg per pCi/liter.
- $k_0 = 1.14 \times 10^5 = (10^6 \text{ pCi/}\mu\text{Ci} \times 10^3 \text{ ml/}1) / 8760 \text{ hr/yr}$ units conversion factor.
- DF_i = dose conversion factor for nuclide, i, for the age group in total body or organ, as applicable. Reg. Guide 1.109, Table E-11, except P-32 bone which uses a value as indicated below.

 $3.0 \times 10^{-5} \text{ mrem/pCi}$

RC = 1.16; reconcentration from PBAPS discharge back through PBAPS intake.

The data for D_W and RC were derived from data published in Peach Bottom Atomic Power Station Units 2 and 3 (Docket Nos. 50-277 and 50-278) <u>Radioactive Effluent Dose</u> <u>Assessment, Enclosure A</u>, September 30, 1976. All other data except P-32 BF and DF were used as given in Reg. Guide 1.109, Revision 1, October 1977. The P-32 BF and DF were used in accordance with information supplied in Branagan, E.F., Nichols, C.R., and Willis, C.A., "The Importance of P-32 in Nuclear Reactor Liquid Effluents", NRC, 6/82. The teen and child dose factors were derived by the ratio of the adult bone dose factors in Reg. Guide 1.109 and Branagan, et al.

NOTE 2

To develop constant R for section IV.C, the following site specific data were used:

$$R_{i}^{C}\left(D/Q\right) = K'\frac{Q_{F}\left(U_{ap}\right)}{\lambda_{i}+\lambda_{W}}F_{m}(r)\left(DFL_{i}\right)\left[\frac{f_{p}f_{s}}{Y_{p}} + \frac{\left(1-f_{p}f_{s}\right)e^{-\lambda_{i}t_{h}}}{Y_{s}}\right]e^{-\lambda_{i}t_{f}}$$

where:

- $K' = 10^6 \text{ pCi/}\mu\text{Ci}$; unit conversion factor
- Q_F = 50 kg/day; cow's consumption rate
- U_{av} = 330 1/yr; yearly milk consumption by an infant
- λ_i = radioactive decay constant for nuclide of interest, sec⁻¹ (e.g. 9.97 x 10⁻⁷ sec⁻¹ for I-131)
- $\lambda_{w} = 5.73 \times 10^{-7} \text{ sec}^{-1}$; decay constant for removal of activity in leaf and plant surfaces
- F_m = stable element transfer coefficient for nuclide of interest, day/liter (e.g. 6.0 x 10⁻³ day/liter for I-131)
- r = fraction of deposited nuclide retained in cow's
 feed grass, 1.0 for radioiodine; 0.2 for
 particulates
- DFL_i = ingestion dose factor in infant for nuclide of interest, mrem/pCi (e.g. 1.39 x 10⁻² mrem/pCi for I-131)
- f_p = 0.6; the fraction of the year the cow is on pasture (average of all farms)
- f_s = 0.487; the fraction of cow feed that is pasture grass while the cow is on pasture (average of all farms)
- Y_p = 0.7 kg/m²; the agricultural productivity of pasture feed grass
- $Y_s = 2.0 \text{ kg/m}^2$; the agricultural productivity of stored feed

VIII. (Cont'd)

- $t_f = 1.73 \times 10^5$ sec (2 days); the transport time from pasture, to cow, to milk, to receptor
- $t_h = 7.78 \times 10^6$ sec (90 days); the transport time from pasture, to harvest, to cow, to milk, to receptor

NOTE 3

To develop constant R for tritium for section IV.C, the following site specific data were used:

The concentration of tritium in milk is based on the airborne concentration rather than the deposition. The following additional constants and formula are used:

$$R_{H-3}^{C}(\chi/Q) = K'K' "F_{m}Q_{F}U_{ap}(DFL_{i})[0.75(0.5/H)]$$

where:

- $K'' = 10^3 \text{ gm/kg}$; a constant of unit conversion
- $H = 14.61 \text{ gm/m}^3$; absolute humidity of the atmosphere
- 0.75 = the fraction of total feed that is water
- 0.5 = the ratio of the specific activity of the feed grass water to the atmospheric water

The pathway is the grass-cow-milk ingestion pathway. These data were derived from data published in Peach Bottom Atomic Power Station Units 2 and 3 (Docket Nos. 50-277 and 50-278) <u>Radioactive Effluent Dose Assessment,</u> <u>Enclosure A</u>, September 30, 1976. All other data were used as given in Reg. Guide 1.109, Revision 1, October 1977.

ODCMS 4.8.B.2.1, Liquid Pathway Dose Calculations

The equations for calculating the doses due to the actual release rates of radioactive materials in liquid effluents were developed from the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I", Revision 1, October 1977 and NUREG-0133 "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants", October 1978.

ODCMS 4.8.C.1.1 and 4.8.C.1.2

Dose Rate Noble Gases

The equations for calculating the dose rate due to the actual release rates of radioactive noble gases in gaseous effluents were developed from the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I", Revision 1, October 1977, NUREG-0133 "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants", August 1978, and the atmospheric dispersion model presented in Information Requested in Enclosure 2 to letter from George Lear to E. G. Bauer dated February 17, 1976, September 30, 1976. The specified equations provide for determining the dose rates in areas at and beyond the SITE BOUNDARY based upon the historical average atmospheric conditions.

The dose rate due to noble gas release as calculated by the Gross Release Method is much more conservative than the dose calculated by the Isotopic Analysis Method. Assuming the release rates given in <u>Radioactive Effluent</u> <u>Dose Assessment</u>, September 30, 1976, the values calculated by the Gross Release Method for total body dose rate and skin dose rate are 6.0 times and 5.7 times, respectively, the values calculated by the Isotopic Analysis Method.

Dose Rate I-131, I-133, Tritium and Radioactive Material in Particulate Form.

The model Technical Specification LCO of NUREG-0133 for all radionuclides and radioactive materials in particulate form and radionuclides other than noble gases requires that the instantaneous dose rate be less than the equivalent of 1500 mrem per year.

The release data from 1994 to 1996 were evaluated and the critical organs were determined to be the child thyroid or teenager lung. The child thyroid dose rate is limiting when iodine releases exceed 10 percent of the total release rates. The teenager lung dose rate is limiting when iodine is either not present or a small fraction of the total release.

Because of good fuel performance the amount of I-131 released has decreased. The thyroid may not be the critical organ. When it is not clear which organ dose is limiting, doses for the child thyroid and teenage lung are calculated.

ODCMS 4.8.C.2.1

Dose Noble Gases

The equations for calculating the doses due to the actual release rates of radioactive noble gases in gaseous effluents were developed from the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I", Revision 1, October 1977, NUREG-0133 "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants", August 1978, and the atmospheric dispersion model presented in Information Requested in Enclosure 2 to letter from George Lear to E. G. Bauer dated February 17, 1976, September 30, 1976. The specified equations provide for determining the air doses in areas at and beyond the SITE BOUNDARY based upon the historical average atmospheric conditions.

The dose due to noble gas releases as calculated by the Gross Release Method is much more conservative than the dose calculated by the Isotopic Analysis Method. Assuming the releases rates given in <u>Radioactive Effluent</u> <u>Dose Assessment</u>, September 30, 1976, the values calculated by the Gross Release Method for total body dose rate and skin dose rate are 4.3 times and 7.2 times, respectively, the values calculated by the Isotopic Analysis Method.

ODCMS 4.8.C.3.1

Dose, Iodine-131, Iodine-133, Tritium, and Radioactive Material in Particulate Form

The equation for calculating the doses due to the actual release of radioiodines, radioactive material in particulate form, and radionuclides other than noble gases with half-lives greater than 8 days were developed using the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I", Revision 1, October 1977, NUREG-0133, "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants", October 1978, and the atmospheric dispersion model presented in Information Requested in Enclosure 2 to Letter from George Lear to E. G. Bauer dated February 17, 1976, September 30, 1976. These equations provide for determing the actual doses based upon the historical average atmospheric conditions.

VIII. (Cont'd)

Compliance with the 10 CFR 50 limits for radioiodines, radioactive materials in particulate form and radionuclides other than noble gases with half lives greater than eight days is to be determined by calculating the infant thyroid, infant liver and infant bone dose. These organs were determined to be the critical organs based on the release data from 1994 to 1996.

Because of a decrease in the amount of I-131 released, the thyroid may not be the critical organ. The isotopic analysis method is used to calculate dose to the infant thyroid, infant liver and infant bone. APPENDIX A

RADIOACTIVE EFFLUENTS CONTROLS PROGRAM

CONTAINING

OFFSITE DOSE CALCULATION MANUAL SPECIFICATIONS (ODCMS) AND BASES

FOR

PEACH BOTTOM ATOMIC POWER STATION

UNITS 2 AND 3

REVISION 12

RADIOACTIVE EFFLUENTS CONTROLS PROGRAM

TABLE OF CONTENTS

3.8.A	DefinitionsODCM	3.8.A-1
3.8.B	Liquid Radwaste EffluentsODCM	3.8.B-1
3.8.C	Gaseous EffluentsODCM	3.8.C-1
3.8.D	40 CFR 190 and 10 CFR 72.104ODCM	3.8.D-1
3.8.E	Radiological Environmental MonitoringODCM	3.8.E-1
3.9	Major Changes to Radioactive Waste Treatment SystemsODCM	3.9-1
3.10	Reporting RequirementsODCM	3.10-1
B 3.8	ODCM Specifications BasesODCM	B 3.8-1

ODCMS 3.8.A Definitions

The defined terms of this section appear in capitalized type and are applicable throughout these Offsite Dose Calculation Manual Specifications and Bases.

Definition Term

- FUNCTIONAL TESTS A FUNCTIONAL TEST is the manual operation or initiation of a system, subsystem, or component to verify that it functions within design tolerances (e.g., the manual start of a core spray pump to verify that it runs and that it pumps the required volume of water).
- GASEOUS RADWASTE Any system designed and installed to reduce TREATMENT SYSTEM radioactive gaseous effluents by collecting primary coolant system offgases from the primary system and providing for delay or holdup for the purpose of reducing the total radioactivity prior to release to the environment.
- INSTRUMENT CALIBRATION AN INSTRUMENT CALIBRATION means the adjustment of an instrument signal output so that it corresponds, within acceptable range, and accuracy, to a known value(s) of the parameter which the instrument monitors. The known value of the parameter shall be injected into the instrument as close to the primary sensor as practicable.
- INSTRUMENT CHECK An INSTRUMENT CHECK is a qualitative determination of acceptable OPERABILITY by observation of instrument behavior during operation. This determination shall include, where possible, comparison of the instrument with other independent instruments measuring the same variable.
- INSTRUMENT FUNCTIONAL An INSTRUMENT FUNCTIONAL TEST means the TEST injection of a simulated signal into the instrument as close to the primary sensor as practicable to verify the proper instrument response, alarm and/or initiating action.

(continued)

PBAPS Units 2 and 3 ODCM 3.8.A-1

Revision 12

MEMBERS OF THE PUBLIC MEMBERS OF THE PUBLIC shall include all persons who are not occupationally associated with the plant. This category does not include employees of the utility, its contractors, or vendors. Also excluded from this category are persons who enter the site to service equipment or to make deliveries. This category does include persons who use portions of the site for recreational, occupational, or other purposes not associated with the plant.

- OFFSITE DOSE Contains the current methodology and CALCULATION MANUAL parameters used in the calculation of offsite doses due to radioactive gaseous and liquid effluents and describes the radiological environmental monitoring program.
- OPERABLE OPERABILITY A system, subsystem, division, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s) and all necessary attendant instrumentation, controls, normal and emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, division, component, or device to perform its specified safety function(s) are also capable of performing their related support function(s).
- PURGE PURGING PURGE or PURGING is the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is required to purify the confinement.
- SITE BOUNDARY That line beyond which the land is not owned, leased, or otherwise controlled by licensee as defined in Figure 3.8.A.1.
- SOURCE CHECK A SOURCE CHECK shall be the qualitative assessment of channel response when the channel sensor is exposed to a radioactive source.

PBAPS Units 2 and 3 ODCM 3.8.A-2




SITE BOUNDARY (including gaseous and liquid effluent release points)

3.8.B Liquid Radwaste Effluents

ODCMS 3.8.B.1 The concentration of radioactive material released to areas at or beyond the SITE BOUNDARY shall be limited to:

- a. 10 times the concentration specified in 10 CFR 20 Appendix B, Table 2, Column 2 for radionuclides other than noble gases; and
- b. 2 X $10^{-4}\mu$ Ci/ml total activity concentration for all dissolved or entrained noble gases.

APPLICABILITY: At all times.

COMPENSATORY MEASURES

CON	DITION		REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
A. Concentr radioact released or beyon BOUNDARY limits.	ation of tive material to areas at d the SITE c exceeding	A.1 <u>OR</u>	Decrease the release rate of radioactive materials to restore concentration to within limits.	Immediately
		A.2	Increase the dilution flow rate to restore concentration within limits.	Immediately
		OR		
		A.3	Decrease the release rate of radioactive materials and increase the dilution flow rate to restore concentration within limits.	Immediately

ODCMS REQUIREMENTS

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.B.1.1 Take a sample of each batch of liquid effluent and analyze for the concentration of each significant gamma energy peak. Base the release rate on the circulating water flow rate at the time of discharge.	Prior to each release
ODCMS	4.8.B.1.2 Record radioactive concentrations and volume before dilution of each batch of liquid effluent released, the average dilution flow, and length of time over which each discharge occurred. These facility records shall be maintained.	During each release
ODCMS	4.8.B.1.3 Perform radioactive liquid waste sampling and activity analysis.	In accordance with Table 4.8.B.1

Liquid Radwaste Effluents 3.8.B.1

 $1 \times 10^{-6} \mu Ci/ml$

 $1 \times 10^{-6} \mu Ci/ml$

 $1 \times 10^{-5} \mu Ci/ml$

 $1 \times 10^{-7} \mu Ci/ml$

5 X $10^{-8} \mu Ci/ml$

5 X $10^{-8} \mu Ci/ml$

 $1 \times 10^{-5} \mu Ci/ml$

Radioactive Liquid Waste Sampling and Analysis			
SAMPLE TYPE	SAMPLE FREQUENCY	SAMPLE ANALYSIS	SAMPLE LOWER LIMIT OF DETECTION (LLD) (a),(d),(e)
Waste Tank to be released	Each batch (b)	Quantitative Analysis of Identifiable Gamma	5 X 10 ⁻⁷ µCi/ml

Emitters

I-131

Fe-55

Tritium

Gross Alpha

Sr-89

Sr-90

Dissolved noble

gases

Table 4.8.B.1 (Page 1 of 2)

31 days (c)

31 days (c)

31 days

(a)	The Sample Lower Limit of Detection is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement. The values for the lower

- (b) A batch release is the discharge of liquid wastes of a discrete volume. Prior to sampling for analysis, each batch shall be isolated and thoroughly mixed to assure representative sampling.
- A composite sample is one in which the quantity of the sample is (C) proportional to the quantity of liquid waste discharged and in which the method of sampling results in a sample representative of the liquids released.

Proportional

Composite of

Proportional

Composite of

Batches

Batches

One Batch

Table 4.8.B.1 (Page 2 of 2) Radioactive Liquid Waste Sampling and Analysis

- (d) The principal gamma emitters for which the minimum detectable level specification will apply are exclusively the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141, and Ce-144. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the sample detectable limit for the analyses should not be reported as being present at the sample detectable limit level. When unusual circumstances result in sample detectable limits higher than required, the reasons shall be documented in the Radioactive Effluent Release Report. The values listed are believed to be attainable.
- (e) Certain mixtures of radionuclides may cause interference in the measurement of individual radionuclides at their detectable limit especially if other radionuclides are at much higher concentrations. Under these circumstances use of known ratios of radionuclides will be appropriate to calculate the levels of such radionuclides.

Liquid Radwaste Effluents 3.8.B.2

3.8.B Liquid Radwaste Effluents

- ODCMS 3.8.B.2 The dose or dose commitment to a MEMBER OF THE PUBLIC from radioactive material in liquid effluent releases from the two reactors at the site to the areas at or beyond the SITE BOUNDARY shall be limited to:
 - a. \leq 3.0 mrem to the total body and \leq 10.0 mrem to any organ during any calendar quarter; and
 - b. \leq 6.0 mrem to the total body and \leq 20.0 mrem to any organ during any calendar year.

APPLICABILITY: At all times.

COMPENSATORY MEASURES

CONDITION		REQUIRED COMPENSATORY MEASURE		COMPLETION TIME
Α.	Calculated dose from the release of radioactive materials in liquid effluents exceeds required limits.	A.1	Submit a Special Report to the NRC that identifies causes for exceeding limits, actions taken to reduce releases of radioactive materials in liquid effluents, corrective actions taken to assure subsequent releases are within limits, results of radiological analyses of the drinking water source, and the radiological impact on the potentially affected drinking water supplies with regard to 40 CFR 141, Safe Drinking Water Act.	31 days

ODCMS REQUIREMENTS

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.B.2.1 Determine cumulative dose contributions in accordance with the methodology and parameters in the ODCM.	31 days

3.8.B Liquid Radwaste Effluents

ODCMS 3.8.B.3 The following conditions shall be met:

- a. Dilution water flow rates necessary to satisfy requirements of ODCMS 3.8.B.1 shall be maintained;
- b. The gross activity monitor and the flow monitor on the waste effluent line shall be OPERABLE; and
- c. The liquid effluent control monitor shall be set in accordance with methodology and parameters in the ODCM to alarm and automatically close the waste discharge valve prior to exceeding limits in ODCMS 3.8.B.1.

APPLICABILITY: During release of radioactive wastes.

COMPENSATORY MEASURES

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
A. Gross activity monitor on the waste activity line inoperable	A.1 Initiate action to restore monitor to OPERABLE status. <u>AND</u>	Immediately
	A.2 Analyze two independent samples of tank's contents.	Prior to release
	AND	
	A.3 Perform independent verification of the release rate calculations and discharge line valve line-up using at least two technically qualified members of the facility staff.	Prior to release

(continued)

PBAPS Units 2 and 3

Revision 12

Liquid Radwaste Effluents 3.8.B.3

COMPENSATORY MEASURES (Continued)

CONDITION		REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
В.	Flow monitor on the waste effluent line inoperable.	B.1 Initiate action to restore monitor to OPERABLE status. <u>AND</u>	Immediately
		B.2NOTE Pump performance curves may be used to estimate flow.	
		Estimate waste effluent line flow rate.	4 hours
			AND
			Once per 4 hours thereafter
C.	Required Compensatory Measures and associated Completion Time of Condition A or B not met.	C.1 Suspend release of radioactive effluents via this pathway.	Immediately
	OR		
	Dilution water flow rates not satisfying requirements of ODCMS 3.8.B.1.		
D.	Liquid radwaste effluents radiation monitors inoperable for > 30 days.	D.1 Explain the reason the inoperability was not corrected in a timely manner in the Radioactive Effluent Release Report.	Prior to submittal of the next Radioactive Effluent Release Report

ODCMS REQUIREMENTS

		ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.B.3.1	Perform INSTRUMENT CHECK of liquid radwaste effluents radiation monitor.	24 hours during release
ODCMS	4.8.B.3.2	Perform INSTRUMENT CHECK of liquid effluent flow monitor.	24 hours during release
ODCMS	4.8.B.3.3	Perform INSTRUMENT FUNCTIONAL TEST of liquid radwaste effluents radiation monitor, including OPERABILITY demonstration of the radwaste discharge automatic isolation valve and control room annunciation in response to alarm/trip setpoint being exceeded and an instrument INOP failure.	31 days
ODCMS	4.8.B.3.4	Perform SOURCE CHECK of liquid radwaste effluents radiation monitor.	92 days
ODCMS	4.8.B.3.5	Perform INSTRUMENT CALIBRATION of the liquid radwaste effluents radiation monitor with a known radiation source positioned in a reproducible geometry with respect to the sensor.	12 months
ODCMS	4.8.B.3.6	Perform INSTRUMENT CALIBRATION of the liquid effluents flow monitor.	12 months

3.8.B Liquid Radwaste Effluents

- ODCMS 3.8.B.4 Liquid effluent releases shall be processed through one of the radwaste subsystems or combination of subsystems listed below:
 - a. waste collector filter and demineralizer;
 - b. floor drain filter;
 - c. fuel pool filter demineralizer;
 - d. chemical/oily waste cleanup subsystem;
 - e. laundry drain filter
- Prior to all liquid effluent release(s) whenever the APPLICABILITY: release(s) would cause the projected dose, when it is averaged over 31 days to exceed 0.12 mrem to the total body or 0.4 mrem to any organ (combined total from the two reactors at the site).

COMPENSATORY MEASURES

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
A. Liquid waste discharged without required processing.	A.1 Submit a Special Report to the NRC that includes, an explanation of why liquid radwaste was discharged without required processing, identification of any inoperable equipment or subsystems and the reason for the inoperability, the action taken to restore the inoperable equipment to OPERABLE status, and the action taken to prevent recurrence.	31 days

PBAPS Units 2 and 3 ODCM 3.8.B-10

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.B.4.1 Project doses due to liquid effluent releases to areas at and beyond the SITE BOUNDARY in accordance with the methodology and parameters in the ODCM.	31 days
ODCMS	4.8.B.4.2 Demonstrate OPERABILITY of the waste collector filter and demineralizer and the floor drain filter by analyzing the liquid processed through the subsystem and determining it meets the requirements of ODCMS 3.8.B.1.	92 days
ODCMS	4.8.B.4.3 Demonstrate OPERABILITY of the fuel pool filter demineralizer by analyzing the liquid processed through the subsystem and determining it meets the requirements of ODCMS 3.8.B.1.	Prior to release of liquid effluents processed by this subsystem
ODCMS	4.8.B.4.4 Demonstrate OPERABILITY of the chemical/oily waste cleanup subsystem by analyzing the liquid processed through the subsystem and determining it meets the requirements of ODCMS 3.8.B.1.	Prior to release of liquid effluents processed by this subsystem
ODCMS	4.8.B.4.5 Demonstrate OPERABILITY of the laundry drain filter by analyzing the liquid processed through the subsystem and determining it meets the requirements of ODCMS 3.8.B.1.	Prior to release of liquid effluents processed by this subsystem

PBAPS Units 2 and 3 ODCM 3.8.B-11

- ODCMS 3.8.C.1 The dose rate at or beyond the SITE BOUNDARY due to radioactive materials in gaseous effluents released from the two reactors at the site shall be limited to the following:
 - a. For noble gases, ≤ 500 mrem per year to the total body and ≤ 3000 mrem per year to the skin; and
 - b. For iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half lives > 8 days, ≤ 1500 mrem per year to any organ.
- APPLICABILITY: At all times.

COMPENSATORY MEASURES

	CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
Α.	Dose rates at or beyond the SITE BOUNDARY exceed limits due to radioactive material in gaseous effluents.	A.1 Decrease release rates to comply with limits.	Immediately

ODCMS REQUIREMENTS

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.1.1 Verify the dose rate due to noble gases in gaseous effluents is within limits in accordance with methods and procedures of the ODCM.	In accordance with sampling and analysis program specified in Table 4.8.C.1

(continued)

ODCMS	REQUIREMENTS	(Continued)	

		ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.1.2	Obtain representative samples and verify the dose rate due to iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half lives > 8 days in gaseous effluents are within limits in accordance with the methods and procedures of the ODCM.	In accordance with sampling and analysis program specified in Table 4.8.C.1

Table 4.8.C.1 (page 1 of 2) Radioactive Gaseous Waste Sampling and Analysis from Main Stack, Vent Stack, and Auxiliary Boiler Exhaust Stack

SAMPLE TYPE	SAMPLE FREQUENCY	SAMPLE ANALYSIS	SAMPLE LOWER LIMIT OF DETECTION (LLD) (a)(d)
Grab Sample	31 days (b)	Quantitative analysis of identifiable gamma emitters	1 X 10 ⁻⁴ µCi/cc(c)
Grab Sample	92 days	Tritium	1 X 10 ⁻⁶ µCi/cc
Charcoal Filters	7 days (c)	I-131	1 X 10 ⁻¹² µCi/cc(c)
Particulate Filters	7 days (c)	Quantitative analysis of identifiable gamma emitters	1 X 10 ⁻¹⁰ µCi/cc(c)
		I-131	1 X 10 ⁻¹² µCi/cc(c)
Particulate Filters (composite of weekly filters)	31 days	Gross Alpha	1 X 10 ⁻¹¹ µCi/cc
Particulate Filters	31 days	Sr-89	1 X 10 ⁻¹¹ µCi/cc
(composite of weekly filters)		Sr-90	1 X 10 ⁻¹¹ µCi/cc
Noble Gas Monitor (Main Stack)	Continuously	Noble Gas Gross β or γ	1 X 10 ⁻⁶ µCi/cc
Noble Gas Monitor (Roof Vents)	Continuously	Noble Gas Gross β or γ	1 X 10 ⁻⁶ µСі/сс
Auxiliary Boiler Waste Oil Grab Sample	Prior to batch release for burn	Quantitative analysis of identifiable gamma emitters	5 X 10 ⁻⁷ µCi/ml

Table 4.8.C.1 (page 2 of 2) Radioactive Gaseous Waste Sampling and Analysis from Main Stack, Vent Stack, and Auxiliary Boiler Exhaust Stack

- (a) The sample lower limit of detection is defined as an a priori (before the fact) limit representing the capability of measurement system and not as an a posteriori (after the fact) limit for a particular measurement. The values for the lower limit of detection are based on a 95% confidence level.
- Sampling and analysis shall be performed following shutdown, (b) startup or a thermal power change exceeding 15% of rated thermal power within 1 hour from a steady state condition unless (1) analysis shows that the dose equivalent I-131 concentration in the primary coolant has not increased more than a factor of 3, and (2) the noble gas activity monitor shows that effluent activity has not increased by more than a factor of 3.
- (C) Samples shall be changed at least once per 7 days and analyses shall be completed within 48 hours after changing. Sampling shall also be performed at least once per 24 hours for at least 3 days following each shutdown, startup or thermal power change exceeding 15% of rated thermal power in 1 hour and analyses shall be completed within 48 hours of changing. When samples collected for 24 hours are analyzed, the corresponding LLD may be increased by a factor of 10. This requirement does not apply if (1) analysis has shown that the dose equivalent I-131 concentration in the primary coolant has not increased more than a factor of 3. and (2) the noble gas monitor shows that effluent activity has not increased more than a factor of 3.
- (d) Certain mixtures of radionuclides may cause interference in the measurement of individual radionuclides at their detectable limit especially if other radionuclides are at much higher concentrations. Under these circumstances use of known ratios of radionuclides will be appropriate to calculate the levels of such radionuclides. Nuclides which are below the sample detectable limit for the analyses should not be reported as being present at the sample detectable limit level.

3.8.C Gaseous Effluents

- ODCMS 3.8.C.2 The air dose at or beyond the SITE BOUNDARY due to noble gases in gaseous effluents released from the two reactors at the site shall be limited to the following:
 - a. For gamma radiation, \leq 10 mrad during any calendar quarter;
 - b. For beta radiation, ≤ 20 mrad during any calendar quarter;
 - c. For gamma radiation, \leq 20 mrad during any calendar year; and
 - d. For beta radiation, \leq 40 mrad during any calendar year.

APPLICABILITY: At all times.

COMPENSATORY MEASURES

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
A. Calculated air dose at or beyond the SITE BOUNDARY from radioactive noble gases in gaseous effluents exceeds limits.	A.1 Submit a Special Report to the NRC that identifies causes for exceeding limits, corrective actions taken to reduce the releases, and corrective actions to assure that subsequent releases are within limits.	31 days

ODCMS REQUIREMENTS

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.2.1 Determine cumulative dose contributions for noble gases in accordance with the methodology and parameters in the ODCM.	31 days

0

3.8.C Gaseous Effluents

ODCMS 3.8.C.3 The dose to a MEMBER OF THE PUBLIC at or beyond the SITE BOUNDARY from iodine-131, iodine-133, tritium and all radionuclides in particulate form, with half lives > 8 days, in gaseous effluents released from the two reactors at the site shall be limited to:

a. \leq 15 mrem during any calendar quarter; and

b. \leq 30 mrem during any calendar year.

APPLICABILITY: At all times.

COMPENSATORY MEASURES

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
A. Calculated dose from the release of iodine-131, iodine-133, tritium and radionuclides in particulate form, with half-lives > 8 days in gaseous effluents exceeds limits.	A.1 Submit a Special Report to the NRC that identifies causes for exceeding limits, corrective actions taken, and proposed corrective actions to assure that subsequent releases are within limits.	31 days

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.3.1 Determine cumulative dose contributions for iodine-131, iodine-133, tritium, and radionuclides in particulate form with half lives > 8 days in accordance with the methodology and parameters in the ODCM.	31 days

3.8.C Gaseous Effluents

- ODCMS 3.8.C.4 The following conditions shall be met:
 - a. Main stack dilution flow shall be \geq 10,000 cfm;
 - b. One vent stack noble gas monitor and one main stack noble gas monitor shall be OPERABLE and set to alarm in accordance with the methodology and parameters in the ODCM;
 - c. One vent stack iodine filter and one main stack iodine filter and one vent stack particulate filter and one main stack particulate filter with their respective flow rate monitors shall be OPERABLE; and
 - d. One vent stack flow rate monitor and one main stack flow rate monitor shall be OPERABLE and set to alarm in accordance with the methodology and parameters in the ODCM.

APPLICABILITY: During release of radioactive wastes.

COMPENSATORY MEASURES

-----NOTE-----Separate condition entry is allowed for each instrument. ------

	CONDITION	F	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
Α.	One required vent stack noble gas monitor inoperable. OR One required main stack noble gas monitor inoperable.	A.1 <u>AND</u> A.2	Collect two independent grab samples from the affected effluent release pathway. Perform independent verification of the release rate calculations using at least two technically qualified members of the facility staff. Analyze grab samples from the affected release pathway for activity.	<pre>8 hours <u>AND</u> Once per 8 hours thereafter 24 hours from time of collection</pre>

(continued)

COMPENSATORY MEASURES (Continued)

	CONDITION	F	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
В.	One required vent stack iodine filter inoperable. <u>OR</u> One required vent stack particulate filter inoperable. <u>OR</u>	B.1	Collect samples from the affected effluent release pathway continuously with auxiliary sampling equipment such that each sample period duration is approximately 7 days.	Immediately
	One required main stack iodine filter inoperable. <u>OR</u> One required main stack particulate filter inoperable.	B.2	Analyze collected samples.	48 hours after end of each sampling period
C.	One required vent stack flow rate monitor inoperable. <u>OR</u> One required main stack flow rate monitor inoperable.	C.1	Estimate flow rate from the affected effluent release pathway.	4 hours <u>AND</u> Once per 4 hours thereafter
D.	Main off-gas stack dilution flow < 10,000 cfm.	D.1	Initiate action to re- establish main off-gas stack flow ≥ 10,000 cfm.	Immediately

(continued)

PBAPS Units 2 and 3 ODCM 3.8.C-11

COMPENSATORY MEASURES (Continued)

0

CONDITION		REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
E. C r r c i i	One or more required radioactive gaseous effluent monitoring instrumentation channels inoperable for > 30 days.	E.1 Explain the reason inoperability was not corrected in a timely manner in the Radioactive Effluent Release Report.	Prior to submittal of next Radioactive Effluent Release Report

ODCMS REQUIREMENTS

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.4.1 Perform INSTRUMENT CHECK of the vent stack and main stack noble gas radiation monitors.	24 hours
ODCMS	4.8.C.4.2 Perform INSTRUMENT CHECK of the vent stack and the main stack flow rate monitors.	24 hours
ODCMS	4.8.C.4.3 Section Removed	
ODCMS	4.8.C.4.4 Perform INSTRUMENT FUNCTIONAL TEST of the vent stack and main stack noble gas radiation monitors, including control room alarm annunciation in response to alarm setpoint being exceeded and an instrument downscale failure.	92 days
ODCMS	4.8.C.4.5 Section Removed	

(Continued)

ODCMS REQUIREMENTS (Continued)

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.4.6 Perform INSTRUMENT CALIBRATION of the vent stack and main stack noble gas radiation monitors with a known radioactive source positioned in a reproducible geometry with respect to the sensor.	18 months
ODCMS	4.8.C.4.7 Perform INSTRUMENT CALIBRATION of the vent stack and main stack flow rate monitors.	18 months
ODCMS	4.8.C.4.8 Perform INSTRUMENT CALIBRATION of the vent stack and main stack iodine and particulate sample flow rate monitors.	18 months
ODCMS	4.8.C.4.9 Section Removed	

- ODCMS 3.8.C.5 Gaseous effluents shall be processed through the Gaseous Waste Treatment System described below prior to discharge:
 - Steam jet air ejector discharge shall be processed a. through the recombiner, holdup pipe, off-gas filter, and off-gas stack;
 - b. Mechanical vacuum pump and gland steam exhauster discharge shall be processed through the off-gas stack:
 - c. Auxiliary boiler exhaust shall be processed through the auxiliary boiler stack when burning radioactive waste oil;
 - d. Reactor, turbine, radwaste, and recombiner building atmospheres shall be processed through permanently or temporarily installed equipment in the appropriate building ventilation system and the vent stack, with the exception of the following unmonitored exhausts:
 - 1. Recirculation M-G set and reactor building cooling water equipment rooms;
 - 2. Control room utility and toilet rooms;
 - 3. Cable spread room;
 - Emergency switchgear rooms; 4.
 - 125/250 VDC battery rooms and the 250 VDC 5. battery rooms, and
 - 6. Administration building maintenance decontamination area.
- APPLICABILITY: Prior to all gaseous release(s) whenever the release(s) would cause the projected dose, when it is averaged over 31 days to exceed 0.6 mrem to any organ (combined total from the two reactors at the site).

COMPENSATORY MEASURES

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
A. Gaseous waste discharged without required processing.	A.1 Submit a Special Report to the NRC that explains the reasons gaseous radwaste was discharged without processing, identifies inoperable equipment or subsystems and the reasons for the inoperability, identifies actions taken to restore the inoperable equipment to OPERABLE status, and actions taken to prevent a recurrence.	31 days

ODCMS REQUIREMENTS

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.5.1 Project doses due to gaseous effluent releases at and beyond the SITE BOUNDARY in accordance with the methodology and parameters in the ODCM.	31 days
ODCMS	4.8.C.5.2 Collect and analyze air samples from each building area with an unmonitored exhaust.	31 days

(continued)

ODCMS REQUIREMENTS (Continued)

~ ~

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.5.3 Demonstrate OPERABILITY of required gaseous radioactive waste system equipment by analyzing the gaseous waste processed through the required equipment to determine it meets the requirements of ODCMS 3.8.C.1	92 days

3.8.C Gaseous Effluents

ODCMS 3.8.C.6 PURGING of the primary containment shall be:

- Through the Standby Gas Treatment System whenever a. primary containment is required to be OPERABLE; and
- Through the Reactor Building Ventilation Exhaust b. System or the Standby Gas Treatment System whenever primary containment is not required to be OPERABLE.

APPLICABILITY: During PURGING of the primary containment.

COMPENSATORY MEASURES

CONDITION		REQUIRED COMPENSATORY MEASURE		COMPLETION TIME	
Α.	Requirement of ODCMS 3.8.C.6 not met.	A.1	Suspend PURGING.	Immediately	

ODCMS REQUIREMENTS

		ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.6.1	Verify primary containment PURGING is through required effluent release pathway of ODCMS 3.8.C.6.	Prior to PURGING primary containment

3.8.C Gaseous Effluents

ODCMS 3.8.C.7 Burning of radioactive waste oil shall be allowed:

- a. In accordance with the requirements of 10CFR20.2004.
- b. Through the Auxiliary Boilers (Common) with the exhaust stack of the affected auxiliary boiler as a release point for radioactive effluents.
- c. With the radioactive content of the oil determined prior to incineration.
- d. With the radioactive effluents from this pathway summed with other effluents from the site and reported to the Commission in the Radioactive Effluent Release Report.

APPLICABILITY: At all times

COMPENSATORY MEASURES

CONDITION		REQUIRED COMPENSATORY MEASURE		COMPLETION TIME	
Α.	Gaseous effluents discharge without required processing or Gaseous effluents exceed limits specified in 3.8.C.3	A.1	Submit a Special Report to the NRC that explains the reasons gaseous radwaste was discharged without processing, identifies inoperable equipment or subsystems and the reasons for the inoperability, identifies actions taken to restore the inoperable equipment to OPERABLE status, and actions taken to prevent a recurrence.	31	days

ODCMS REQUIREMENTS

		ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.C.7.1	Project doses due to gaseous effluent releases at or beyond the SITE BOUNDARY.	Each Batch Incinerated
ODCMS	4.8.C.7.2	Determine dose and dose rate contributions for radionuclides in particulate form with half lives > 8 days in accordance with the methodology and parameters in ODCM Section IV.F.	Each Batch Incinerated

40 CFR 190 3.8.D.1

3.8.D 40 CFR 190 and 10 CFR 72.104

ODCMS 3.8.D.1 The annual dose equivalent to a real individual who is located beyond the SITE BOUNDARY from all uranium fuel cycle sources within 8 kilometers shall be:

- a. \leq 25 mrem to the total body;
- b. \leq 75 mrem to the thyroid.
- c. \leq 25 mrem to any other critical organ; and
- d. \leq 3.0 mrem contribution from liquid and gaseous effluents for whole body and critical organ doses.
- e. \leq 55 mrem contribution from gaseous effluents for thyroid dose.

APPLICABILITY: At all times.

COMPENSATORY MEASURES

	CONDITION	F	EQUIRED COMPENSATORY MEASURE	COMPLETION TIME
Α.	Annual cumulative liquid and gaseous effluents dose does not meet ODCMS 3.8.D.1 items d or e.	Calcu direc contr units tanks A.1	Initiate actions to determine whether the limits in ODCMS 3.8.D.1 items a, b or c have been exceeded.	Immediately

(continued)

PBAPS Units 2 and 3

COMPENSATORY MEASURES (Continued)

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
B. Dose limits of ODCMS 3.8.D.1 items a, b or c have been exceeded.	B.1 Submit a Special Report to the NRC that includes the corrective actions taken to prevent recurrence, the schedule for achieving conformance with required limits, estimates of radiation exposure to the real individual for the calendar year, descriptions of the levels of radiation and concentrations of radioactive material involved, and the cause of the exposure level or concentrations.	31 days
		(continued)

40 CFR 190 3.8.D.1

COMPENSATORY MEASURES (Continued)

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
B. (continued)	 Only applicable if the release condition resulting in violation of 40 CFR 190 or 10 CFR 72.104 has not been corrected. B.2 Submit a request for a variance in accordance with 40 CFR 190 and a request for an exemption from 10 CFR 72.104. 	31 days

ODCMS REQUIREMENTS

T

		ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.D.1.1	Determine total gas and liquid cumulative dose contributions in accordance with methodology and parameters in the ODCM.	31 days
ODCMS	4.8.D.1.2	Determine the cumulative dose contribution from gas and liquid effluents and the direct radiation from the reactor units and from high and low level radwaste storage in accordance with the methodology and parameters in the ODCM.	92 days

Radiological Environmental Monitoring 3.8.E.1

3.8.E Radiological Environmental Monitoring

Radiological environmental monitoring samples shall be collected at locations and analyzed as specified in Table 4.8.E.1 and the ODCM. ODCMS 3.8.E.1

APPLICABILITY: At all times.

COMPENSATORY MEASURES

	CONDITION	R	EQUIRED COMPENSATORY MEASURE	COMPLETION TIME
Α.	Milk samples permanently unavailable from any of the sample locations listed in the ODCM.	A.1	Identify locations for obtaining replacement samples and add them to radiological environmental monitoring program. Delete locations from which samples are unavailable.	31 days
		AND		
		A.2	Identify in the Radioactive Dose Assessment Report the cause of the unavailability of samples and new locations for obtaining samples and include in the report revised figures and tables for the ODCM reflecting the new locations.	Prior to submittal in next Radioactive Dose Assessment Report

(continued)

COMPENSATORY MEASURES (Continued)

	CONDITION		REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
Β.	Level of radioactivity as a result of plant effluents in an environmental sampling medium at one or more locations specified in the ODCM exceeds the reporting levels of Table 3.8.E.1 when averaged over the calendar quarter. <u>OR</u> Level of radioactivity as a result of plant effluents in an environmental sampling medium at one or more locations specified in the ODCM exceeds the reporting levels of Table 3.8.E.1 when averaged over the calendar quarter and more than one radionuclide from Table 3.8.E.1 is detected and the equation in ODCMS 4.8.E.1.2 is satisfied.	B.1	Submit a Special Report to the NRC which includes an evaluation of any release conditions, environmental factors, or other aspects which caused the reporting level of Table 3.8.E.1 to be exceeded and the corrective actions to be taken to reduce radioactive effluents so that the potential annual dose to a MEMBER OF THE PUBLIC is less than the calendar year reporting level of Table 3.8.E.1.	31 days after end of affected calendar quarter

(continued)

Radiological Environmental Monitoring 3.8.E.1

COMPENSATORY MEASURES (Continued)

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
C. Radionuclides other than those in Table 3.8.E.1 detected and the potential annual dose to a MEMBER OF THE PUBLIC is greater than or equal to the calendar year limits of ODCMS 3.8.B.2, or ODCMS 3.8.C.2, or ODCMS 3.8.C.3, or ODCMS 3.8.D.1.	C.1NOTE Only required if the radionuclides detected are the result of plant effluents. 	31 days after end of affected calendar quarter
		(continued)
COMPENSATORY MEASURES (Continued)

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
C. (continued)	C.2NOTE Only required if the radionuclides detected are not the result of plant effluents. Describe the condition in the Annual Radiological Environmental Operating Report.	Prior to submittal of next Annual Radiological Environmental Operating Report
D. Requirements of ODCMS 3.8.E.1 not met.	D.1 Prepare and submit, in the Annual Radiological Environmental Operating Report, a description of the reasons for not conducting the radiological environmental monitoring program as required and the actions taken to prevent recurrence.	Prior to submittal of next Annual Radiological Environmental Operating Report

ODCMS REQUIREMENTS

ODCMS REQUIREMENT			FREQUENCY
ODCMS	4.8.E.1.1	 NOTES	
		Collect radiological environmental monitoring samples at the locations and analyze as specified in Table 4.8.E.1 and the ODCM.	In accordance with Table 4.8.E.1
ODCMS	4.8.E.1.2	All radionuclides used in this evaluation shall be averaged on a calendar quarterly basis. 	92 days

Table 3.8.E.1 (page 1 of 1) Reporting Levels for Radioactivity Concentration in Environmental Samples

ANALYSIS	WATER (pCi/l)	AIRBORNE PARTICULATE OR GASES (pCi/m ³)	FISH (pCi/kg, wet)	MILK (pCi/l)	FOOD PRODUCTS (pCi/kg, wet)
H-3	20,000*				
Mn-54	1,000		30,000		
Fe-59	400		10,000		
Co-58	1,000		30,000		
Co-60	300		10,000		
Zn-65	300		20,000		
Zr-Nb-95	400				
I-131		0.9		3	100
Cs-134	30	10	1,000	60	1,000
Cs-137	50	20	2,000	70	2,000
Ba-La-140	200			300	

Reporting Levels

*For drinking water samples. This is 40 CFR part 141 value.

Table 4.8.E.1 (page 1 of 3) Radiological Environmental Monitoring Program EXPOSURE PATHWAY NUMBER OF SAMPLES AND SAMPLE LOCATION (a) TYPE AND FREQUENCY SAMPLING AND AND/OR SAMPLE COLLECTION OF ANALYSIS FREOUENCY (b),(c) 1. Direct At least 40 routine monitoring stations either Every 31 days Every 31 days (Gamma Radiation(e) with two or more dosimeters or with one instrument dose) for measuring and recording dose rate continuously or to be placed as follows: 1) an inner ring of or stations in the general area of the SITE BOUNDARY Every 92 days and an outer ring in the 3 to 6 mile range from Every 92 days (Gamma the site. A station is in each sector of each ring dose) except as dictated by local geography. The balance of the stations are in special interest areas such as population centers, nearby residences, schools and in areas to serve as control stations. 2. Airborne Radioiodine Continuous Radioiodine and Samples from 5 locations: sampler canisters: I-131 Particulates operation with analysis every 7 a. 3 samples from close to the SITE BOUNDARY sample davs locations (in different sectors) of the highest collection calculated annual average ground level D/Q. every 7 days Particulate sampler: or required by (f) gross beta b. 1 sample from the vicinity of a community dust loading, radioactivity having the highest calculated annual average analysis following whichever is ground level D/O. filter change; gamma more frequent. isotopic analysis of c. 1 sample from a control location unlikely to be composite (by affected by the plant. location) 92 days 3. Waterborne a. Surface a. 1 sample upstream Composite (b) Gamma isotopic (d) sample over 31 analysis every 31 b. 1 sample downstream day period. days. Composite for tritium analysis at least every 92 days (continued)

Radiological Environmental Monitoring

3.8.E.1

Radiological Environmental Monitoring 3.8.E.1

EXPOSURE PATHWAY	NUMBER OF SAMPLES AND SAMPLE LOCATION	SAMPLING AND	TYPE AND FREQUENCY
AND/OR SAMPLE		COLLECTION FREQUENCY (b), (c)	OF ANALYSIS
3.Waterborne			
(cont'd) b. Drinking	a. 1 sample of each of 1 to 3 of the nearest water supplies that could be affected by its discharge.	Composite (b) sample over 31 day composite period	Composite for gross beta and gamma (d) isotopic
	b. 1 sample from a control location.		analyses every 31 days. Composite for tritium analysis at least every 92 days
c. Sediment from Shoreline	1 sample from downstream area with existing or potential recreational value.	Every 6 months	Gamma isotopic (d) analysis every 6 months
4. Ingestion			
a.Milk	a. Samples from milking animals in 3 locations within 3 miles distance having the highest dose potential.	Every 14 days when	Gamma isotopic (d) analysis or 134
	b. 1 sample from milking animals at a control location (unlikely to be affected by the plant).	pasture, every 31 days at other times.	137 Cs by chemical separation every 92 days. I-131 analysis of each sample.
b. Fish	a. 1 sample of each commercially and recreationally important species in vicinity of discharge point when available.	Sample in season, or every 6 months if they are not	Gamma isotopic (d) analysis on edible portions.
	b. 1 sample of same species in areas not influenced by plant discharge when available.	seasonal.	
c. Food Products	a. Samples of 3 different kinds of broad leaf vegetation grown nearest offsite garden of highest annual average ground level D/Q if milk sampling is not performed.	Every 31 days when available if milk sampling is not performed.	Gamma isotopic (d) and I-131 analysis
	 b. 1 sample of each of the similar broad leaf vegetation grown 15 - 30 km distant in the least prevalent wind direction if milk sampling is not performed. 	Every 31 days when available if milk sampling is not performed	Gamma isotopic (d) and I-131 analysis

Table 4.8.E.1 (page 2 of 3)

Table 4.8.E.1 (page 3 of 3) Radiological Environmental Monitoring Program

NOTES

- (a) Fixed sample locations are shown in the Offsite Dose Calculation Manual, Table VII.A.1 and Figures VII.A.1, VII.A.2, and VII.A.3. At times it may not be possible or practicable to obtain samples of the media of choice at the most desired location or time. In those instances suitable alternative media and locations may be chosen for the particular pathway in question. Such necessary deviations are reported in the Annual Radiological Environmental Operating Report.
- (b) Composite samples shall be collected by collecting an aliquot at intervals not exceeding 2 hours.
- (c) Sample collection frequencies are defined as follows:

7 days	7 calendar days <u>+</u> 2 days
14 days	14 calendar days <u>+</u> 3 days
31 days	31 calendar days <u>+</u> 8 days
92 days	92 calendar days \pm 10 days
6 months	6 calendar months \pm 20 days

- (d) Gamma isotopic analysis means the identification and quantification of gamma-emitting radionuclides that may be attributable to the effluents from the facility.
- (e) Each phosphor is considered one thermoluminescent dosimeter.
- (f) If the gross beta activity in air attributable to plant operation is greater than ten times the yearly mean of control samples, gamma isotopic analysis shall be performed on the individual samples.

Radiological Environmental Monitoring 3.8.E.1

ANALYSIS	WATER (pCi/l)	AIRBORNE PARTICULATE (pCi/m ³)	FISH (pCi/kg, wet)	MILK (pCi/l)	FOOD PRODUCTS (pCi/kg, wet)	SEDIMENT (pCi/kg, dry)
Gross Beta	4	0.01				
H-3	2,000					
Mn-54	15		130			
Fe-59	30		260			
Co-58,60	15		130			
Zn-65	30		260			
Zr-95	30					
Nb-95	15					
I-131	-	0.07		1	60	
Cs-134	15	0.05	130	15	60	150
Cs-137	18	0.06	150	18	80	180
Ba-140	60			60		
La-140	15			15		

Table 4.8.E.2 (page 1 of 2)

PBAPS Units 2 and 3

Table 4.8.E.2 (page 2 of 2)

<u>Notes</u>:

- (a) This list does not mean that only these nuclides are to be considered. Other peaks that are identifiable at 95% confidence level, together with those of the above nuclides, shall also be analyzed and reported in the Annual Radiological Environmental Operating Report.
- (b) The LLD is defined, for purposes of these controls, as the smallest concentration of radioactive material in a sample that will yield a net count (above system background) that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \underbrace{4.66S_{\beta}}_{E \cdot V \cdot 2.22 \cdot Y \cdot exp (-\lambda\Delta t)}$$

Where:

LLD is the <u>a priori</u> lower limit of detection as defined above (as picocuries per unit mass or volume),

 S_β is the standard deviation of the background counting rate or of the counting rate of blank sample as appropriate (as counts per minute),

E is the counting efficiency (as counts per disintegration),

V is the sample size (in units of mass or volume),

2.22 is the number of disintegrations per minute per picocurie,

Y is the fractional radiochemical yield (when applicable)

 λ is the radioactive decay constant for the particular radionuclide, and

 Δt for the environmental samples is the elapsed time between sample collection (or end of the sample collection period) and time of counting.

Typical values of E, V, Y, and Δt should be used in calculation.

It should be recognized that the LLD is defined as an <u>a priori</u> (before the fact) limit representing the capability of a measurement system and not as an after the fact limit for a particular measurement. Analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions. Occasionally background fluctuations, unavoidably small sample sizes, the presence of interfering nuclides, or other uncontrollable circumstances may render these LLDs unachievable. In such cases, the contributing factors shall be identified and described in the Annual Radiological Environmental Operating Report. 3.8.E Radiological Environmental Monitoring

ODCMS 3.8.E.2 A land use census shall be conducted and shall identify the location of the nearest milk animal in each of the 16 meteorological sectors within a distance of five miles.

APPLICABILITY: At all times.

COMPENSATORY MEASURES

CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
A. Land use census identifies a location which yields a calculated dose or dose commitment (via the same exposure pathway) that is at least 20% greater than a location from which samples are currently being obtained in accordance with ODCMS 3.8.E.1.	A.1 Add the new location to the radiological environmental monitoring program. <u>AND</u>	31 days (continued)

Radiological Environmental Monitoring 3.8.E.2

_

COMPENSATORY MEASURES (Continued)

	CONDITION	REQUIRED COMPENSATORY MEASURE	COMPLETION TIME
Α.	(continued)	A.2NOTE The indicator sampling location having the lowest calculated dose or dose commitment (via the same exposure pathway) may be deleted from the radiological environmental monitoring program after October 31 of the year in which land use census was conducted. Identify the new location in the Radioactive Dose Assessment Report and include the revised figures and tables for the ODCM reflecting the new location.	Prior to submittal of the next Radioactive Dose Assessment Report
Β.	Land use census identifies a location which yields a calculated dose or dose commitment that is greater than values currently being calculated in ODCMS 3.8.C.3.	B.1 Identify the new location in the Radioactive Dose Assessment Report.	Prior to submittal of the next Radioactive Dose Assessment Report

Radiological Environmental Monitoring 3.8.E.2

ODCMS REQUIREMENTS

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.E.2.1 Conduct a land use census by a door-to- door survey or by consulting local agriculture authorities or by some other appropriate means.	12 months

3.8.E Radiological Environmental Monitoring

ODCMS 3.8.E.3 Analyses shall be performed on radioactive materials supplied as part of the EPA Environmental Radioactivity Intercomparison Studies Program, or another Interlaboratory Comparison Program traceable to NIST.

APPLICABILITY: At all times.

COMPENSATORY MEASURES

C	ONDITION	REQUIRED COMPENSATORY MEASURE		COMPLETION TIME
A. Requi ODCMS met.	irements of 5 3.8.E.3 not	A.1	Include corrective actions to prevent recurrence in the Annual Radiological Environmental Operating Report.	Prior to submittal of next Annual Radiological Environmental Operating Report

ODCMS REQUIREMENTS

	ODCMS REQUIREMENT	FREQUENCY
ODCMS	4.8.E.3.1 Include a summary of the results of the Interlaboratory Comparison Program in the Annual Radiological Environmental Operating Report.	In accordance with Technical Specification 5.6.2

Major Changes to Radioactive Waste Treatment Systems 3.9

3.9 Major Changes to Radioactive Waste Treatment Systems

- ODCMS 3.9.1 The radioactive waste treatment systems are those systems described in ODCMS 3.8.B.3, 3.8.B.4, 3.8.C.4, and 3.8.C.5, which are used to maintain control over radioactive materials in gaseous and liquid effluents.
- ODCMS 3.9.2 Major changes to the radioactive waste systems shall be made by either of the following methods. For the purpose of this Specification "major changes" is defined in ODCMS 3.9.3.
 - a. Licensee initiated changes:
 - Licensee initiated changes shall be reported to the NRC as part of the Modification Report required by 10 CFR 50.59. The discussion of each change shall contain:
 - a. A summary of the evaluation that led to the determination that the change could be made in accordance with 10 CFR Part 50.59;
 - b. Sufficient detailed information to totally support the reason for the change without benefit of additional or supplemental information;
 - c. A detailed description of the equipment, components, and processes involved and the interfaces with other plant systems;
 - d. A comparison of the predicted releases of radioactive materials, in liquid and gaseous effluents and in solid wastes, to the actual releases for the period prior to when the changes are to be made;
 - e. An estimate of the exposure to plant operating personnel as a result of the change; and
 - f. Documentation of the fact that the change was reviewed and found acceptable by the PORC.
 - 2. The change shall become effective upon review and acceptance by both the PORC and NRB.

(continued)

PBAPS Units 2 and 3

3.9 Major Changes to Radioactive Waste Treatment Systems

ODCMS 3.9.2 (continued)

- b. Commission initiated changes:
 - 1. The applicability of the change to the facility shall be determined by the PORC after consideration of the facility design.
 - 2. The licensee shall provide the Commission with written notification of its determination of applicability including any necessary revisions to reflect facility design.
 - 3. The change shall be reviewed by the NRB at its next regularly scheduled meeting.
 - 4. The change shall become effective on a date proposed by the licensee and confirmed by the Commission.
- ODCMS 3.9.3 "Major Changes" to radioactive waste systems shall include the following:
 - a. Changes in process equipment, components, structures, and effluent monitoring instrumentation from those described in the Final Safety Analysis Report (FSAR) and evaluated in the staff's Safety Evaluation Report (SER);
 - b. Changes in the design of radwaste treatment systems that significantly alter the characteristics and/or quantities of effluents released from those previously considered in the FSAR and SER;
 - c. Changes in system design which invalidate the accident analysis as described in the SER; and
 - d. Changes in system design that result in a significant increase in occupational exposure of operating personnel.

3.10 Reporting Requirements

ODCMS 3.10.1 Annual Radiological Environmental Operating Report

The Annual Radiological Environmental Operating Report shall be submitted in accordance with the requirements of Technical Specification 5.6.2. In addition to the requirements of Technical Specification 5.6.2, the Annual Radiological Environmental Operating Report shall include or reference from previous reports:

- a. A summary description of the radiological environmental monitoring program including sampling methods for each sample type, size, and physical characteristics of each sample type, sample preparation methods, and measuring equipment used;
- b. At least two maps of all sampling locations keyed to a table giving distances and directions from the midpoint between reactor vents;
- c. Results of the land use census required by ODCMS 3.8.E.2; and
- d. Results of the Interlaboratory Comparison Program required by ODCMS 3.8.E.3 and discussion of all analyses in which the LLD required by Table 4.8.E.2 was not achievable.

ODCMS 3.10.2 Radioactive Effluent Release Report

The Radioactive Effluent Release Report shall be submitted in accordance with the requirements of Technical Specification 5.6.3. In addition to the requirements of Technical Specification 5.6.3, the Radioactive Effluent Release Report shall include:

- a. Information for each class of solid waste (as defined by 10 CFR part 61) shipped offsite during the report period:
 - 1. Container volume;
 - 2. Total curie quantity (specify whether determined by measurement or estimate);
 - 3. Principal radionuclides (specify whether determined by measurement or estimate);

(continued)

PBAPS Units 2 and 3 ODCM 3.10-1

ODCMS 3.10.2 Radioactive Effluent Release Report (continued)

- 4. Source of waste and processing employed (e.g., dewatered spent resin, compacted dry waste, evaporator bottoms); and
- 5. Type of container (e.g., LSA, Type A, Type B, Large Quantity).
- b. A list and description of unplanned releases from the site to areas at or beyond the SITE BOUNDARY of radioactive materials in gaseous and liquid effluents made during the reporting period.
- c. Changes made during the reporting period to the Offsite Dose Calculation Manual (ODCM) and a list of new locations for dose calculations and/or environmental monitoring identified by the land use census required by ODCMS 3.8.E.2.
- d. Releases to the environment in liquid or gaseous effluents during the previous 12 months of operation of the Independent Storage of Spent Fuel as required by 10 CFR 72.44(d)(3)

ODCMS 3.10.3 Radiation Dose Assessment Reports

The radiation dose assessment reports shall be submitted within 120 days after January 1 of each year.

The Radiation Dose Assessment Report shall include an annual summary of hourly meteorological data collected over the previous year. This annual summary may be either in the form of an hour-by-hour listing on magnetic tape of wind speed, wind direction, atmospheric stability, and precipitation (if measured), or in the form of joint frequency distributions of wind speed, wind direction, and atmospheric stability. The licensee has the option of retaining this summary of required meteorological data on site in a file that shall be provided to the NRC upon request. This same report shall include an assessment of the radiation doses due to the radioactive liquid and gaseous effluents released from the unit or station during the previous calendar year. This same report shall also include an assessment of the radiation doses from radioactive liquid and gaseous effluent to MEMBERS OF THE PUBLIC due to their activities inside the SITE BOUNDARY during the report period. All assumptions used in making these assessments (i.e., specific activity, exposure time and location) shall be included

PBAPS Units 2 and 3 ODCM 3.10-2

Reporting Requirements 3.10

(continued)

3.10 Reporting Requirements

ODCMS 3.10.3 Radiation Dose Assessment Reports (continued)

in these reports. The meteorological conditions concurrent with the time of release of radioactive materials in gaseous effluents (as determined by sampling frequency and measurement) shall be used for determining the gaseous pathway doses. Approximate methods are acceptable. The assessment of radiation doses shall be performed in accordance with the Offsite Dose Calculation Manual (ODCM).

The Radiation Dose Assessment Report shall also include an assessment of radiation doses to the likely most exposed MEMBER OF THE PUBLIC from reactor releases and other nearby uranium fuel cycle sources (including doses from primary effluent pathways and direct radiation) for the previous calendar year to show conformance with 40 CFR Part 190, Environmental Radiation Protection Standards for Nuclear Power Operation. Guidance for calculating the dose contribution from liquid and gaseous effluents are given in Regulatory Guide 1.109, Revision 1, October 1977.

B 3.8 ODCM SPECIFICATIONS

BASES

General

It is expected that releases of radioactive material in effluents will be kept at small fractions of the limits specified in Section 20.1302 of 10 CFR, Part 20. At the same time, the licensee is permitted the flexibility of operation, compatible with consideration of health and safety, to assure that the public is provided a dependable source of power even under unusual operating conditions which may temporarily result in releases higher than such small fractions, but still within the limits specified in Section 20.1302 of 10 CFR, Part 20. It is expected that in using this operational flexibility under unusual operating conditions the licensee will exert his best efforts to keep levels of radioactive material in effluents as low as practicable.

Liquid Radwaste Effluents

Concentration

This specification is provided to ensure that the concentration of radioactive materials released in liquid waste effluents to areas at and beyond the SITE BOUNDARY will be within 10 times the concentration levels specified in 10 CFR, Part 20, Appendix B, Table 2, Column 2. This instantaneous limitation provides additional assurance that the levels of radioactive materials in bodies of water in areas at or beyond the SITE BOUNDARY will result in exposures within (1) the Section II.A design objectives of Appendix I, 10 CFR, Part 50, to a MEMBER OF THE PUBLIC and (2) the limits of 10 CFR, Part 20.1302 to the population. The concentration limit for noble gases is based upon the assumption that Xe-135 is the controlling radioisotope and its MPC in air (submersion) was converted to an equivalent concentration in water using the International Commission on Radiological Protection (ICRP) Publication 2.

Dose

This specification is provided to implement the requirements of Sections II.A, III.A and IV.A of Appendix I, 10 CFR Part 50. ODCMS 3.8.B.2 implements the guidance set forth in Section II.A of Appendix I and provides the required operating flexibility to implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in liquid effluents will be kept "as low as reasonably achievable." The dose calculations in the ODCM implement the requirements in Section III.A of Appendix I that conformance with the quides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of a MEMBER OF THE PUBLIC through appropriate pathways is unlikely to be substantially underestimated. The equations described in the Offsite Dose Calculation Manual for calculating the doses due to the actual release rates

(continued)

PBAPS Units 2 and 3 ODCM B 3.8-1

Revision 12

Liquid Radwaste Effluents

Dose (continued)

of radioactive materials in liquid effluents are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977 and Regulatory Guide 1.113, "Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I," April 1977. This specification applies to the release of liquid effluents from the site.

Instrumentation

The radioactive liquid effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in liquid effluents during actual or potential release of liquid effluents. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

System Operation

The OPERABILITY of the Liquid Radwaste Treatment System ensures that this system will be available for use whenever liquid effluents require treatment prior to release to the environment. The requirement that the appropriate portions of this system be used when specified provides assurance that the releases of radioactive materials in liquid effluents will be kept "as low as reasonably achievable." This specification implements the requirements of 10 CFR, Part 50.36a, General Design Criterion 60 of Appendix A to 10 CFR, Part 50 and design objective Section II.D of Appendix I to 10 CFR, Part 50. The specified limits governing the use of appropriate portions of the Liquid Radwaste Treatment System were specified as a suitable fraction of the guide set forth in Section II.A of Appendix I, 10 CFR, Part 50, for liquid effluents.

The chemical/oily waste cleanup subsystem may include the portable Epicor oil/water emulsion system (as described in RW-625), an installed chemical/oily waste cleanup subsystem, or equivalent chemical/oil waste system.

The laundry drain filter may be used to process liquid wastes containing detergents or similar cleaning agents. Waste water such as river water that is acceptable for release may be processed through the laundry drain filter.

(continued)

PBAPS Units 2 and 3

Revision 12

Gaseous Effluents

Dose

This specification is provided to ensure that the dose from radioactive materials in gaseous effluents at and beyond the SITE BOUNDARY will be within the annual dose limits of 10 CFR Part 20. The annual dose limits are the doses associated with 10 times the concentrations of 10 CFR Part 20, Appendix B, Table 2, Column 1. These limits provide reasonable assurance that radioactive material discharged in gaseous effluents will not result in the exposure of a MEMBER OF THE PUBLIC, either within or outside the SITE BOUNDARY, to annual average concentrations exceeding the limits specified in Appendix B, Table 2 of 10 CFR part 20.1302. For MEMBERS OF THE PUBLIC who may at times be within the SITE BOUNDARY, the occupancy will usually be sufficiently low to compensate for any increase in the atmospheric diffusion factor above that for the SITE BOUNDARY. Examples of calculations for such MEMBERS OF THE PUBLIC with the appropriate occupancy factors are given in the ODCM. The specified limits restrict, at all times, the gamma and beta dose rates above background to a MEMBER OF THE PUBLIC, at or beyond the SITE BOUNDARY to \leq 500 mrem/year to the total body or to \leq 3000 mrem/year to the skin. These dose rate limits also restrict, at all times, the corresponding thyroid dose rate above background to a child via the inhalation pathway to \leq 1500 mrem/year.

Dose, Noble Gases

This specification is provided to implement the requirements of Sections II.B, III.A and IV.A of Appendix I, 10 CFR Part 50. ODCMS 3.8.C.2 implements the quidance set forth in Section II.B of Appendix I and provides the required operating flexibility to implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in gaseous effluents will be kept "as low as reasonably achievable." ODCMS 4.8.C.2.1 implements the requirements in Section III.A of Appendix I that conformance with the guidance of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of a MEMBER OF THE PUBLIC through the appropriate pathways is unlikely to be substantially underestimated. The dose calculations established in the ODCM for calculating the doses due to the actual release rates of radioactive noble gases in gaseous effluents are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR 50, Appendix I," Revision 1, October 1977 and the atmospheric dispersion model submitted on September 30, 1976, in a report titled: "Information Requested in Enclosure 2 to letter from George Lear to E. G. Bauer dated February 17, 1976." The ODCM equations provided for determining the air doses at and beyond the SITE BOUNDARY are based upon the historical average atmospheric conditions.

(continued)

PBAPS Units 2 and 3 ODCM B 3.8-3

Revision 12

Gaseous Effluents (continued)

Dose - Iodine-131, Tritium and Radionuclides in Particulate Form

This specification is provided to implement the requirements of Sections II.C, III.A and IV.A of Appendix I, 10 CFR Part 50. ODCMS 3.8.C.3 implements the quidance set forth in Section II.C of Appendix I and provides the required operating flexibility to implement the quides set forth in Section IV.A of Appendix I to assure that the releases of radioactive materials in gaseous effluents will be kept "as low as reasonably achievable." The ODCM calculational methods specified in the ODCMS 4.8.C.3.1 implements the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of a MEMBER OF THE PUBLIC through appropriate pathways is unlikely to be substantially underestimated. The ODCM calculational methods for calculating the doses due to the actual release rates of the subject materials are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977 and the Atmospheric Dispersion Model submitted on September 30, 1976 in a report titled: "Information Requested in Enclosure 2 to letter from George Lear to E. G. Bauer dated February 17, 1976." These equations also provide for determining the actual doses based upon the historical average atmospheric conditions. The release rate specifications for iodine-131, tritium, and radionuclides in particulate form with half lives greater than 8 days are dependent on the existing radionuclide pathways to man in the areas at and beyond the SITE BOUNDARY. The pathways that were examined in the development of these calculations 1) individual inhalation of airborne radionuclides, 2) were: deposition of radionuclides onto green leafy vegetation with subsequent consumption by man, 3) deposition onto grassy areas where milk animals and meat producing animals graze with consumption of the milk and meat by man, and 4) deposition on the ground with subsequent exposure of man.

Instrumentation

The radioactive gaseous effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases of gaseous effluents. The OPERABILITY and use of instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR, Part 50.

(continued)

<u>Gaseous Effluents</u> (continued)

System Operation

The OPERABILITY of the Gaseous Radwaste Treatment System ensures that this system will be available for use whenever gaseous effluents require treatment prior to release to the environment. The requirement that appropriate portions of this system be used when specified provides reasonable assurance that the releases of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable." This specification implements the requirements of 10 CFR, Part 50.36a, General Design Criterion 60 of Appendix A to 10 CFR, Part 50 and design objective Section II.D of Appendix I to 10 CFR, Part 50. The specified limits governing the use of appropriate portions of the Gaseous Radwaste Treatment System were specified as a suitable fraction of the guidance set forth in Section II.B and II.C of Appendix I, 10 CFR, Part 50, for gaseous effluents.

To determine if gaseous effluents shall be processed through installed treatment equipment, the average projected dose will be determined. For gaseous effluent pathways other than the specified unmonitored exhausts, treatment and monitoring will only be required for pathways that are significant. Regulatory Guide 1.109, "Calculations of Annual Doses to Man From Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I", states that a pathway is considered significant if a conservative evaluation yields an additional dose increment equal to or more than 10 percent of the total from all pathways. Therefore, the total dose from all release pathways that do not require treatment or monitoring can not exceed 10 percent of the limit specified in Section II.C of Appendix I, 10 CFR Part 50.

Containment PURGE

ODCMS 3.8.C.6 requires that the primary containment atmosphere receive treatment for the removal of gaseous iodine and particulates prior to release to provide reasonable assurance that PURGING operations will not result in exceeding the annual dose limits of 10 CFR Part 20 for areas at or beyond the SITE BOUNDARY.

40 CFR 190 and 10 CFR 72.104

This specification is provided to meet the dose limitations of 40 CFR Part 190 that have been incorporated into 10 CFR 20.1301(d) as well as the dose limitations specific to Independent Spent Fuel Storage Installation (ISFSI) operations in accordance with 10 CFR 72.104.

Over the long term, as more ISFSI casks are placed on the ISFSI pad, it is expected that ISFSI operations will become the prominent contributor to the limits in this section. ISFSI dose contribution is in the form of direct radiation as no liquid or gas releases are expected to occur. The 10 CFR 72.212 report prepared in accordance with ISFSI requirements assumes a certain array of casks exists on the The dose contribution from this array of casks in combination pad. with historical uranium fuel cycle operations (e.q. PBAPS 2 & 3) prior to ISFSI operations was analyzed to be within the 40 CFR 190 and 10 CFR 72.104 limits. The difference between 40 CFR 190/10 CFR 72.104 limits and the analyzed ISFSI cask array contribution are identified in ODCMS 3.8.D.1 items d and e. Therefore, these values are used as assumptions in calculating combined ISFSI and PBAPS 2 & 3 doses. If these PBAPS 2 & 3 liquid and gas radiation values are exceeded, an evaluation is performed to determine if the overall 40 CFR 190 and 10 CFR 72.104 limits have been exceeded.

If the dose limits of 40 CFR 190 or 10 CFR 72.104 are exceeded, a special report to the NRC as well as an appropriate request for exemption/variance is required to be submitted to the NRC.

The requirement that the dose limits of 10CFR 72.104 apply to "any real individual" is controlled for ISFSI activities in the ISFSI 72.212 report. Therefore, for the purposes of analyzing dose in the south end of the site, the member of the public as defined in 40 CFR 190 at this area is the same as the "real individual" identified in the 72.212 report. The location for the real individual identified in the ISFSI 72.212 report is the limiting individual for calculating dose.

Radiological Environmental Monitoring

Monitoring Program

The radiological environmental monitoring program required by this specification provides measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides, which lead to the highest potential radiation exposures of MEMBERS OF THE PUBLIC resulting from the two reactors at the sites. This monitoring program implements Section IV.B.2 of Appendix I to 10 CFR Part 50 and supplements the radiological effluent monitoring program by verifying that the measurable concentrations of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurements and the modeling of the environmental exposure pathways.

The required detection capabilities for environmental sample analyses are tabulated in terms of the Lower Limit of Detection (LLD). The LLD's required by Table 4.8.E.2 of the specifications are considered optimum for routine environmental measurements in industrial laboratories. The monitoring program was developed utilizing the experience of the first seven years of commercial operation. Program changes may be initiated based on the additional operational experience.

Land Use Census

This specification is provided to ensure that significant changes in the use of areas at and beyond the SITE BOUNDARY are identified and that modifications to the radiological environmental monitoring program are made if required by the results of this census. This census satisfies the requirements of Section IV.B.3 of Appendix I to 10 CFR Part 50.

Interlaboratory Comparison Program

The requirement for participation in an Interlaboratory Comparison Program is provided to ensure that independent checks on the precision and accuracy of the measurements of radioactive material in environmental sample matrices, are performed as part of the quality assurance program for environmental monitoring, in order to demonstrate that the results are reasonably valid for the purposes of Section IV.B.2 of Appendix I to 10 CFR Part 50.