



A CMS Energy Company

Palisades Nuclear Plant
27780 Blue Star Memorial Highway
Covert, MI 49643

MI 810-441-1111
Fax 810-441-1110

Nathan L. Haskell
Director, Licensing and
Performance Assessment

May 1, 2001

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

DOCKET 50-255 - LICENSE DPR-20 - PALISADES PLANT
2001 STEAM GENERATOR TUBE SURVEILLANCE REPORT – TUBES PLUGGED

Palisades Technical Specification 5.6.8a requires that the number of tubes plugged in each steam generator shall be reported to the NRC within fifteen days following the completion of an inservice inspection of steam generator tubes. On April 19, 2001, an inservice inspection of the Palisades steam generator tubes was completed.

Fourteen (14) tubes were plugged in Steam Generator E-50A and fifteen (15) tubes were plugged in Steam Generator E-50B. The total number of tubes plugged in Steam Generator E-50A is 340. The total number of tubes plugged in Steam Generator E-50B is 339.

In accordance with Palisades Technical Specification 5.6.8b, a complete steam generator inservice inspection report will be submitted within 12 months.

SUMMARY OF COMMITMENTS

This letter contains no new commitments and no revisions to existing commitments.


Nathan L. Haskell
Director, Licensing & Performance Assessment

CC Administrator, Region III, USNRC
Project Manager, NRR, USNRC
NRC Resident Inspector - Palisades

A008