
Document Update Notification

COPYHOLDER NO: TRM-U2-102

TO: NRC

ADDRESS: OS-DOCUMENT CONTROL,
WASHINGTON, D.C. 20555

DOCUMENT NO: TRM-U2

TITLE: TECHNICAL REQUIREMENTS MANUAL
(UNIT 2)

REVISION NO: 006

CHANGE NO: AP-06

SUBJECT: RE-DISTRIBUTION OF PAGE B 3.1-1

← If this box is checked, please sign, date, and return within 6 days.



ANO-1 Docket 50-313

ANO-2 Docket 50-368

Signature

Date

RETURN TO:

**ATTN: DOCUMENT CONTROL
ARKANSAS NUCLEAR ONE
1448 SR 333
RUSSELLVILLE, AR 72801**

1001

3.1 REACTIVITY CONTROL SYSTEMS

TRM BASES

3/4.1.2 BORATION SYSTEMS

The boron injection system ensures that negative reactivity control is available during each mode of facility operations. The components required to perform this function include 1) borated water sources, 2) charging pumps, 3) separate flow paths, 4) boric acid makeup pumps, 5) an emergency power supply from OPERABLE diesel generators.

With the RCS average temperature above 200°F, a minimum of two separate and redundant boron injection systems are provided to ensure single functional capability in the event an assumed failure renders one of the systems inoperable. Allowable out-of-service periods ensure that minor component repair or corrective action may be completed without undue risk to overall facility safety from injection system failures during the repair period.

The boration capability of either system is sufficient to provide a SHUTDOWN MARGIN from expected operating conditions of that specified in the CORE OPERATING LIMITS REPORT after xenon decay and cooldown to 200°F. The maximum expected boration capability requirement occurs at EOL from full power equilibrium xenon conditions and requires boric acid solution from the boric acid makeup tanks in the allowable concentrations and volumes of TRM Specification 3.1.2.8 and a small fraction of the borated water from the refueling water

The requirement in TRM Specification 3.1.2.8 for a minimum contained volume of borated water 464,900 gallons of 2500-3000 ppm borated water in the refueling water tank ensures the capability for borating the RCS to the desired concentration. The value listed is consistent with the plant ECCS requirements.

With the RCS temperature below 200°F, one injection system is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the additional restrictions prohibiting CORE ALTERATIONS and positive reactivity change in the event the single injection system becomes inoperable.

The boron capability required below 200°F is based upon providing a sufficient SHUTDOWN MARGIN after xenon decay and cooldown from 200°F to 140°F. This condition requires either borated water from the refueling water tank or boric acid solution from the boric acid makeup tank(s) in accordance with the requirements of TRM Specification 3.1.2.7. The contained water volume limits includes allowance for water not available because of discharge line location and other physical characteristics.

The contained water volume limits includes allowances for water not available because of discharge line location and other physical characteristics. The 61,370 gallon limit for the refueling water tank is based upon having an indicated level in the tank of at least 7.5%.

The OPERABILITY of one boron injection system during REFUELING ensures that this system is available for reactivity control while in MODE 6.

The limits on contained water volume and boron concentration of the boric acid sources, when mixed with the trisodium phosphate, ensures a long term pH value of ≥ 7.0 for the solution recirculated within containment after a LOCA. This pH limit minimizes the evolution of iodine and helps to inhibit stress corrosion cracking of austenitic stainless steel components in containment during the recirculation phase following an accident.