INITIAL SUBMITTAL

ROBINSON EXAM 2001-301 MARCH 26 - APRIL 2, 2001

INITIAL SUBMITTAL - RO ONLY WRITTEN EXAMINATION QUESTIONS

Which ONE (1) of the following conditions would be **REQUIRED** to be entered by the Reactor Operator in the Control Operator's Log?

- a. Test data for an unsatisfactory Operations Surveillance Test
- b. Entry into a Technical Specification LCO Action Statement
- c. Name of on-shift person relieving an Auxiliary Operator who went home sick
- d. Change in Secondary Chemistry Action Level

Answer:

d. Change in Secondary Chemistry Action Level

							RO Only	Question Reference
QUESTION N TIER/GROUP	IUMBER: 2:	16	RO	3		SRO		
NA.	2.1.10							
	Ability to mak	e accurate, cle	ar and c	oncise lo	gs, recor	ds, status b	oards, and re	ports.
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b	RO) RO	2.9 10	55.43(b	SRO) SRO		
OBJECTIVE:	OMM-001-11	-02						
	EXPLAIN the 001-11	requirements	for main	taining op	erations	records and	l logs in acco	rdance with OMM-
REFERENCE	ES:	OMM-001-11						
SOURCE:	New	X Signific	antly M	odified		Direc		
USTIFICAT			Бапк	wumper				
a.		Plausible sind required.	ce start a	and comp	letion of	OSTs are re	equired entrie	s, test data is not
b.		Plausible sind entered by C	ce entrie RSS or \$	s into TS SSO to ei	LCOs ac nsure acc	ctions are im curacy.	nportant inform	nation, but only
с.		Plausible sind	ce this e	ffects shit	ft mannin	g requireme	ents, but not a	a required entry.
d.	CORRECT	This is a requ	uired log	entry per	OMM-0	01-11.		
DIFFICULTY Compreher	': nsive/Analysi:	s Kno	owledge	/Recall	X	Rating	2	
	Knowledge of logkeeping requirements for the reactor operator							
REFERENCI	ES SUPPLIED	:						

RNP NRC Written Examination

8.3.4 Control Operator's Logs

1. The CO's Log is maintained by the RO. The narrative log is a vital portion of the shift records and contains notations of plant conditions, operations, and events. It is maintained on a shift basis to record the plant status and events in chronological order. Log entries **SHALL** include, but are not limited to, the following:

NOTE: To ensure accuracy and eliminate redundancy, TECH SPECS LCO Action Statement entries should be recorded only by the SSO or CRSS.

- Plant status.
- Changes in Generator output.
- Changes in Reactor power level.
- Starts/stops/trips of equipment controlled from the RTGB, both automatic and manual, with a brief description of the reason. (NCR 00012657, CR 9902062)
- Example: Started Charging Pump "A" and stopped Charging Pump "C" to allow Maintenance to check packing for leakage.
- Change of auxiliary system and configuration.
- Surveillance tests started and completed. These may include OSTs, ESTs, MSTs, and special tests which are performed from the Control Room Complex, directs or affects Control Room Complex operations or affects plant production (the test data results need not be logged since they are recorded in the specific test).
- Example: Completed partial OST-353 to return SI-844A to service. Test SAT.
- Reactor Trips.

OMM-001-11	Rev. 16	Page 16 of 55

8.3.4.1 (Continued)

- Instrument or equipment malfunctions or failures. The entry should include the time the component is removed from service, a brief description of the problem, any compensatory actions taken, and the number of any Work Request written.
- Example: R-16 removed from service due to frequently spiking high. Notified E&RC to begin collecting grab samples. WR 9X-ABCD1 written.
- Unusual trends or conditions observed.
- Major in-plant electrical switching.
- Starting and stopping of Gaseous or Liquid Waste Releases (list Waste Release Permit Number).
- Setpoint changes which are performed.
- Declaration of and changes to Secondary Chemistry Action Levels.
- Annunciators received that are not the result of operator action or are not expected as a result of evolutions in progress (such as surveillance tests, clearing of equipment or equipment manipulation). It is acceptable to use a rough log for the accumulation of recurring annunciators and to document these annunciators as a single log entry near the end of shift. During plant transients when a large number of annunciators are received in a short period of time, this logging requirement can be waived.
- When annunciators are received and none of the actions specified in the APP are taken in response to the alarm because it is determined that none of the prescribed actions would be effective in eliminating the diagnosed cause, then the basis for not taking the prescribed actions should be logged. This basis should include the plant conditions, diagnosis of the event, conclusions of the diagnosis, and any alternate actions that are taken or justification for taking no actions at all.

OMM-001-11	Rev. 16	Page 17 of 55

Given the following conditions:

- RCS temperature is 362 °F.
- RCS pressure is 900 psig.
- RCP pump bearing temperatures are increasing.
- RCP seal injection and seal leakoff flows are:

RCP	SEAL INJECTION	SEAL LEAKOFF
'A'	5.8 gpm	1.2 gpm
'B'	6.7 gpm	0.9 gpm
'C'	6.5 gpm	1.3 gpm

Which ONE (1) of the following actions must be taken to permit opening CVC-307, PRI SEAL BYP ISO?

- a. Increase RCS pressure more than 100 psig
- b. Lower RCS temperature more than 12 °F
- c. Increase RCP 'A' seal injection more than 0.2 gpm
- d. Increase RCP 'B' seal leakoff more than 0.1 gpm

Answer:

c. Increase RCP 'A' seal injection more than 0.2 gpm

QUESTION N TIER/GROUP K/A:	UMBER: : 003 2.1.32	17	RO	2/1	SRO	0	
	Ability to expla	in and apply a	ll syste	m limits	and precautior	ns (Reactor Coola	nt Pump).
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.4 3	SRO 55.43(b) SR	0	
OBJECTIVE:	RCS-09						
	EXPLAIN the instrumentatio	normal operati n, interlocks, a	on of th annunci	ne React ators, ar	or Coolant System and setpoints.	stem control syste	ms. Include function,
REFERENCE	S:	OP-101					
SOURCE:	New	X Significa	ntly M	odified		Direct	
SOURCE:	New	X Significa	ntly M Bank	odified Numbe	er	Direct	Ŵ
SOURCE: JUSTIFICAT <i>a</i> .	New	X Significat Plausible sind psig, not abov	Bank Bank ce 1000 ve.	odified Numbe	er a trigger press	Direct	W must be below 1000
SOURCE: JUSTIFICAT a. b.	New	X Signification Plausible sind psig, not above Plausible sind operations ar	Bank Bank ce 1000 ve. ce 350 [°] nd Mode	odified Numbe psig is PF is use e change	er a trigger press ed for many ap es, but has no	Direct	W must be below 1000 s RHR system ation of this valve.
SOURCE: JUSTIFICAT a. b. c.	New	X Signification Plausible sind psig, not above Plausible sind operations are Required corr valves open, Only the seal	Bank Bank ce 1000 ve. ce 350 ^o ad Mode aditions any #1 l injectio	odified Numbe psig is PF is use e change are RCS seal lea on flow r	er a trigger press ed for many ap es, but has no S pressure bet koff flow < 1 g equirement is	Direct	W must be below 1000 s RHR system ation of this valve. 00 psig, all seal leakoff on flows > 6 gpm.
SOURCE: JUSTIFICAT a. b. c. d.	New	X Signification Plausible sind psig, not above Plausible sind operations are Required corr valves open, Only the seat Plausible sind be below 1 g	Bank Bank ce 1000 ve. ce 350 ^o ad Mode aditions any #1 l injectio ce 1 gp pm, not	odified Numbe psig is PF is use change are RCS seal lea on flow r m leako	er a trigger press ed for many ap es, but has no S pressure bet akoff flow < 1 g equirement is ff is a trigger va ve.	Direct	W must be below 1000 s RHR system ation of this valve. 00 psig, all seal leakoff on flows > 6 gpm. one leakoff flow must
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Compreheat	New ION: CORRECT 1: nsive/Analysis	X Signification Plausible sind psig, not above Plausible sind operations are Required corr valves open, Only the seat Plausible sind be below 1 g	Bank Bank ce 1000 ve. ce 350 of nd Mode aditions any #1 l injection ce 1 gp pm, not v/edge/	odified Number psig is psig is "F is use change are RCS seal lea on flow r m leako t all abov	a trigger press ed for many ap es, but has no S pressure bet koff flow < 1 g equirement is ff is a trigger va ve.	Direct	W must be below 1000 s RHR system ation of this valve. 00 psig, all seal leakoff on flows > 6 gpm. one leakoff flow must

4.2.1 (Continued)

- 10. The No. 1 Seal Bypass Valve is used when RCS pressure is less than 1000 psig, to prevent the RCP pump bearing temperature and the No. 1 seal leakoff temperature from reaching alarm levels. Prior to opening CVC-307, PRI SEAL BYP ISO, the following conditions shall all be satisfied:
 - a. RCS pressure is between 100 and 1000 psig.
 - b. All three No. 1 Seal Leakoff valves (CVC-303A, B, C) are open.
 - c. Any No. 1 seal leakoff flow rate is less than 1 gpm.
 - d. Seal injection flow rate to each RCP is greater than 6 gpm.
- 11. Any change greater than 10°F on No. 1 and No. 2 seal leak-off for unknown reasons should be investigated.
- 12. Only one RCP is to be started at any one time.
- 13. A Reactor Coolant Pump should not be operated continuously until the RCS has been thoroughly vented.
- 14. If Component Cooling Water flow to the RCP motor is lost, the RCP shall be stopped before either the upper or lower bearing temperature has increased to 200°F IAW AOP-014. (CR 95-02015 and ESR 95-01075)
- 15. Two Containment Fan Coolers are required for normal operation with RCS temperature greater than 140°F. The intent of this requirement is to maintain RCP motor winding temperature less than 248°F.

OR 101	Rev. 42	Page 12 of 70

Given the following conditions:

- A Reactor Trip and SI has occurred from an unisolable main steam line break on SG 'A'.
- Diagnostic actions are in progress.
- SG 'A' has been isolated per EPP-11, "Faulted SG Isolation", and is dry.
- RCS temperature has been stabilized by dumping steam from the intact SGs following the dryout of the SG 'A'.

Which ONE (1) of the following would be the **FIRST** indication to the operators that a 250 gpm tube leak has subsequently developed in SG 'A'?

- a. R-31A, Main Steamline Monitor
- b. R-19A, SG Blowdown Radiation Monitor
- c. Pressurizer level decreasing
- d. SG 'A' level increasing

Answer:

c. Pressurizer level decreasing

QUESTION N TIER/GROUP K/A:	UMBER: : 037AA1.11	18	RO	1/2		SRO		
	Ability to opera PZR level indi	ate and / or mo cator	onitor the	e followi	ng as the	y apply to t	he Steam Gene	erator Tube Leak:
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.4 5	55.43(b)	SRO) SRO		
OBJECTIVE:	PATH-1-03							
	DEMONSTRA explaining the	TE an unders basis of each	tanding	of selec	ted steps	, cautions,	and notes in P/	ATH-1 by
REFERENCE	:S:	PATH-1-BD EPP-16						
SOURCE:	New	Significa	ntly Mc Bank	odified Numbe	D r PAT	и ⁻ ТН-1-03	Direct X	
JUSTIFICAT <i>a.</i>	ION:	Plausible sind a reactor trip	ce this w the N-16	vould pro 6 detect	ovide indic ors on the	cation durir e steam line	ng power opera es would not be	tions, but following effective.
b.		Plausible sind a reactor trip	ce this w and safe	vould pro ety injec	ovide indiction blow	cation durir down woul	ng power opera d be isolated.	tions, but following
с.	CORRECT	Pressurizer le to the plant c would be ava	evel wou ondition iilable.	uld decro s, none	ease rega of the oth	ardless of w er 'normal'	vhich SG had a indications of a	tube rupture. Due a tube rupture
d.		Plausible sind leakage to th would be not	ce this w e faulteo ed.	vould pr d SG wi	ovide indi Il immedia	cation if the ately flash t	e SG were not f o steam so no l	faulted, but any level increase
DIFFICULTY Compreher	′: nsive/Analysis	X Know	vledge/ł	Recall	□ <i>R</i>	ating	3	

Comprehension of the effectiveness of diagnostic indications during abnormal conditions

GRID WOG BASIS/DIFFERENCES

STEP

WOG BASIS

<u>PURPOSE</u>: To identify any faulted SGs (failure in secondary pressure boundary)

BASIS:

An uncontrolled SG pressure decrease or a completely depressurized (i.e., near containment or atmospheric pressure) SG indicates failure of the secondary pressure boundary. Isolation is to be performed using E-2, FAULTED STEAM GENERATOR ISOLATION.

KNOWLEDGE:

"Uncontrolled" means not under the control of the operator, and incapable of being controlled by the operator using available equipment

RNP DIFFERENCES/REASONS

There are essentially no differences.

SSD DETERMINATION

This is not an SSD.

B18 23 RNP STEP

ANY S/G COMPLETELY DEPRESSURIZED

WOG BASIS

See step 23 above.

RNP DIFFERENCES/REASONS

There are essentially no differences.

SSD DETERMINATION

This is not an SSD.

D18 23 RNP STEP

RESET SPDS AND INITIATE MONITORING OF CRITICAL SAFETY FUNCTION STATUS TREES (with transition to EPP-11)

WOG BASIS

See step 23 above.

RNP DIFFERENCES/REASONS

There are essentially no differences.

SSD DETERMINATION

This is not an SSD.

E-4 24 <u>RNP STEP</u>

R-19'S, R-31'S, AND R-15 RAD LEVELS NORMAL

PATH-1-BD	Rev 16	Page 33 of 93

GRID WOG BASIS/DIFFERENCES

STEP

WOG BASIS

<u>PURPOSE</u>: To identify any ruptured SGs (failure in primary to secondary pressure boundary)

BASIS:

Abnormal condenser air ejector radiation, SG blowdown or steamline radiation indicates primary to secondary leakage. Optimal recovery in dealing with a steam generator tube rupture is provided in E-3, STEAM GENERATOR TUBE RUPTURE.

KNOWLEDGE:

"Normal" means the value of a process parameter experienced during routine plant operations.

RNP DIFFERENCES/REASONS

The path eliminates the negative of the ERG high level step. These radiation monitors, when in alarm, are used as indicators of S/G tube leakage. This satisfies RAIL item 91R0043.

Interpretation

Normal also includes instrument behavior observation over time. If levels are increasing or have gone up and then back down due to manual or automatic actions that isolate the RMS sample path, the levels are not considered normal.

SSD DETERMINATION

This is an SSD per criterion 11.

E-4 25 <u>RNP STEP</u>

R-2, R-32A, R32B RAD LEVELS NORMAL

E-5 RNP STEP

CV PRESSURE NORMAL

E-5 RNP STEP

CV SUMP LEVEL NORMAL

WOG BASIS

PURPOSE: To identify any failure in the RCS pressure boundary into the containment

BASIS:

Abnormal containment radiation, pressure, or recirculation sump level is indicative of a high energy line break in containment. Since the SGs have been determined to be non-faulted in an earlier step, then the break must be in the reactor coolant system. For smaller size breaks containment pressure and recirculation sump level may not increase for a period of time; however, containment radiation would be apparent. Guideline E-1, LOSS OF REACTOR OR SECONDARY COOLANT, is used for breaks in the RCS.

KNOWLEDGE:

"Normal" means the value of a process parameter experienced during routine plant operations.

RNP DIFFERENCES/REASONS

There are no significant differences.

SSD DETERMINATION

This is not an SSD.

PATH-1-BD	Rev 16	Page 34 of 93
FAILE PDD		

תתקו	16
EPP.	-10

UNCONTROLLED DEPRESSURIZATION OF ALL STEAM GENERATORS

Rev. 13

Page 4 of 31

_	STEP	INSTRUCTIONS		RESI	PONSE NOT	OBTAINED	 - -]
		Open Foldout D	I				
	֥	Porform The Following.					
	۷.	reitoim ine fortowing.					
		a. Reset SPDS					
		b. Initiate monitoring of Critical Safety Function Status Trees					

While performing OST-012, "Power Range Calorimetric During Power Operation (Manual) Daily," which ONE (1) of the following will result in **ACTUAL** power being **HIGHER THAN INDICATED** power?

- a. SG Blowdown is secured prior to starting the data collection
- b. MDAFW Pump 'A' is operating with flow being delivered to a SG
- c. Indicated feedwater temperature used is lower than actual
- d. Indicated feedwater flow used is higher than actual

Answer:

b. MDAFW Pump 'A' is operating with flow being delivered to a SG

QUESTION N TIER/GROUP K/A:	NUMBER: P: 015K5.04	19	RO	2/1		SRO			
	Knowledge of Factors affecti	the operationation and accuracy a	al implica Ind relial	ations of bility of (f the follo calorimet	wing conc tric calibrat	epts as t ions	hey apply t	o the NIS:
K/A IMPORT 10CFR55 CC	ANCE: DNTENT:	55. 41 (b)	RO RO	2.6 6	55.43(l	SRO b) SRO			
OBJECTIVE	: NI-10								
	EXPLAIN the	operation of th	e Nucle	ar Instru	umentatio	on System.			
REFERENCI	ES:	OST-012							
SOURCE:	New	Significa	antly Mo	dified			Direct	X	
JUSTIFICAT a.	10N:	Plausible sind provided no d	Bank ce blowd changes	<i>Numbe</i> lown is a are ma	r RN a conside de to blo	P-RO-2000 eration in tl wdown dur	0 he calori ring the c	015 metric. Ha data collect	s no effect ion period.
b.	CORRECT	AFW flow is r required to ra calculated po	not acco aise AFV ower (an	unted fo V tempe d indica	or in the o rature to ted after	calorimetric saturation adjustmen	c. The a would b it) to be l	mount of he ignored, ower than a	eat actually thereby causing actual.
с.		Plausible sind feed tempera would require	ce feed f ature was e more h	tempera s lower leat to ra	iture is a than actu aise temj	considerat ual, the cal perature, s	tion in th culation o it woul	e calorimet (and indica d be higher	ric. If indicated ted power) • than actual.
d.		Plausible sin flow was high feed flow to s	ce feed t her than saturatio	flow is a actual, n, so ca	i conside more hea Ilculated	eration in th at would be (indicated)	e calorir e require would b	netric. If in d to raise the higher th	dicated feed he additional an actual.
DIFFICULT Comprehe	(: nsive/Analysis	X Know	vledge/F	Recall	<i>י</i> ت	Rating	4		

Analysis of the effects of various inputs to the calorimetric calibration

- 4.6 Rounding off the readings taken on the PR nuclear instruments shall be IAW the following guidelines (CR 93-15019):
 - 4.6.1 **IF** indicated power is less than 100%, **THEN** round down to the nearest 0.5% increment (EXAMPLES: a reading of 99.7 would be recorded as 99.5, and 99.3 would be recorded as 99.0).
 - 4.6.2 **IF** indicated power is greater than 100%, **THEN** round up to the nearest 0.5% increment (EXAMPLES: a reading of 100.2 would be recorded as 100.5, and 100.6 would be recorded as 101).
- 4.7 This procedure has been screened in accordance with PLP-037 criteria and determined to be a Case Three procedure.
- 4.8 When adjusting an NI Power Range gain with another OOS, extreme care must be utilized. Any electronic spiking has the potential of causing a Reactor Protection System actuation. (CR 97-01677)
- 4.9 Inaccuracies in the calorimetric increase in magnitude when less than 70% power. Reactor Engineering should be notified prior to adjusting any power range channel down when less than 70% to reduce the probability of non-conservative operation. It is allowable to raise indicated power to match calculated power. (CR 98-01362)
- 4.10 Operation of any MDAFW Pump with AFW Flow to a S/G will cause the calorimetric to be non-conservative. Do not perform a calorimetric when a MDAFW Pump is in service and flowing to a S/G. (CR 96-01991)

OST-012	Rev. 7	Page 8 of 27
•••		

ATTACHMENT 8.1 Page 2 of 2

DATA SHEET POWER RANGE CALORIMETRIC DURING POWER OPERATION

ITEM		LOOP		FORMULA/SOURCE
	1	2	3	
AVG STM PRESS (PSIA)				AVG STEAM PRESS (PSIG) + 14.7
ENTHALPY OF STEAM (h _g)				STEAM TABLES (Saturated Steam @ Steam Generator Pressure)
ENTHALPY OF FEED (h _f)				STEAM TABLES (Saturated Liquid @ Feedwater Temperature)
BTU/LB CHANGE IN ENTHALPY FROM FEED TO STEAM (△hg-f)				∆h _{g-f} = [h _g - h _f]
SQ. ROOT OF SPECIFIC WGT (LB/FT ³)1/2 $\sqrt{\Upsilon}$				1/√V _f FROM STEAM TABLES (@ Steam Generator Pressure and Feedwater Temperature)
THERMAL AREA FACTOR (Fa)				From Attachment 8.2
FEED FLOW DELTA P SQ. ROOT (in) ^½ √∆P _f				SQUARE ROOT OF FEEDFLOW DIFFERENTIAL PRESSURE
FLOW CONST	32013	31896	31944	
FEEDWATER MASS FLOW RATE (LB/HR)	X10 ⁶	X10 ⁶	X10 ⁶	m _{f≖} [√Υ] [Fa] [√△P _f] x Flow Constant
GROSS LOOP POWER (BTU/HR)	X10 ⁶	X10 ⁶	X10 ⁶	m _f x_h _{g-f}
	TOTAL		er of len. Netern of energy of the second	
Q TOTAL (BTU/HR)	X10 ⁶			Q(T)=Q(LOOP1) + Q(LOOP2) + Q(LOOP3)
Q NET (MW)		an trainin A na sundor A na sundor		[Q(T) - 30.677 X 10 ⁶]/3.4121 X 10 ⁶
% POWER			at Ministry States States	Q NET / 23
LIMITS AT CALCULAT	ED POWEF	R: HIGH	(CALCULA	ATED + 2%)%

LOW (CALCULATED - 2%)

____%

OST-012	Rev. 7	Page 20 of 27

Given the following conditions:

- Refueling Operations are schedule to commence.
- RCS Boron Concentration is currently 1825 ppm.

Which ONE (1) of the following describes the required RCS boron concentration for refueling operations?

- a. Boron concentration is adequate
- b. Boron concentration must be increased by a minimum of 75 ppm
- c. Boron concentration must be increased by a minimum of 125 ppm
- d. Boron concentration must be increased by a minimum of 175 ppm

Answer:

.

c. Boron concentration must be increased by a minimum of 125 ppm

QUESTION NUMBER: TIER/GROUP: K/A: 2.2.26	20	RO	3	SRO	
Knowledge o	f refueling admin	nistrative	e require	ements.	
K/A IMPORTANCE: 10CFR55 CONTENT:	R 55.41(b) F	20 20	2.5 10	SRO 55.43(b) SRO	
OBJECTIVE: FH-12					
STATE the T	echnical Specific	cation Li	mitation	s and explain the	bases for the FH System.
REFERENCES:	TS 3.9.1				
	COLR 2.8				
SOURCE: New		tiv Moo	lified	Y	Direct
		ling mou	inicu		
		~ /			
JUSTIFICATION:		Bank N	umber	FH-12	003
JUSTIFICATION: a.	Plausible if mis	concept	tion rega	FH-12 arding required bo	003 pron concentration as this is a
JUSTIFICATION: a.	Plausible if mis reasonably higl	Bank N concept h value,	<i>umber</i> tion rega	FH-12 arding required bo ual required conco	003 pron concentration as this is a entration is 1950 ppm.
JUSTIFICATION: a. b.	Plausible if mis reasonably hig Plausible if mis reasonably hig	Bank N concept h value, concept h value,	<i>umber</i> tion rega but actu tion rega but actu	FH-12 arding required bo ual required conce arding required bo ual required conce	003 pron concentration as this is a entration is 1950 ppm. pron concentration as this is a entration is 1950 ppm.
JUSTIFICATION: a. b.	Plausible if mis reasonably high Plausible if mis reasonably high	bank N concept h value, concept h value,	umber tion rega but actu tion rega but actu	FH-12 arding required bo ual required conce arding required bo ual required conce	003 pron concentration as this is a entration is 1950 ppm. pron concentration as this is a entration is 1950 ppm.
JUSTIFICATION: a. b. c. CORRECT	Plausible if mis reasonably high Plausible if mis reasonably high Required boror to raise boron of	concept h value, concept h value, n concer concenti	umber tion rega but actu tion rega but actu ntration ration ar	FH-12 arding required bo ual required conce arding required bo ual required conce for refueling is 19 n additional 125 p	003 pron concentration as this is a entration is 1950 ppm. pron concentration as this is a entration is 1950 ppm. 50 ppm, so a boration is required pm.
JUSTIFICATION: a. b. c. CORRECT	Plausible if mis reasonably high Plausible if mis reasonably high Required boror to raise boron of	concept h value, concept h value, n concert concent	umber tion rega but actu tion rega but actu ntration ration ar	FH-12 arding required bo ual required conce arding required bo ual required conce for refueling is 19 n additional 125 p	003 pron concentration as this is a entration is 1950 ppm. pron concentration as this is a entration is 1950 ppm. 50 ppm, so a boration is required pm.
JUSTIFICATION: a. b. c. CORRECT d.	Plausible if mis reasonably high Plausible if mis reasonably high Required boror to raise boron of Plausible since required is 195	concept h value, concept h value, n concert concent concent this wo 0 ppm.	umber tion rega but actu tion rega but actu ntration ration ar uld mee	FH-12 arding required bo ual required conce arding required bo ual required conce for refueling is 19 n additional 125 p et required boron o	003 pron concentration as this is a entration is 1950 ppm. pron concentration as this is a entration is 1950 ppm. 50 ppm, so a boration is required pm. concentration, but minimum
JUSTIFICATION: a. b. c. CORRECT d.	Plausible if mis reasonably high Plausible if mis reasonably high Required boror to raise boron of Plausible since required is 195	concept h value, concept h value, n concert concentri e this wo 0 ppm.	umber tion rega but actu tion rega but actu ntration ar ration ar uld mee	FH-12 arding required bo ual required conce arding required bo ual required conce for refueling is 19 n additional 125 p et required boron o	003 pron concentration as this is a entration is 1950 ppm. pron concentration as this is a entration is 1950 ppm. 50 ppm, so a boration is required pm. concentration, but minimum
JUSTIFICATION: a. b. c. CORRECT d. DIFFICULTY: Comprehensive/Analysis	Plausible if mis reasonably high Plausible if mis reasonably high Required boror to raise boron of Plausible since required is 195	bank N concept h value, concept h value, n concert concentri this wo 0 ppm.	<i>umber</i> tion rega but actu tion rega but actu ntration ar uld mee	FH-12 arding required bo ual required conce arding required bo ual required conce for refueling is 19 n additional 125 p et required boron of X Rating	003 pron concentration as this is a entration is 1950 ppm. pron concentration as this is a entration is 1950 ppm. 50 ppm, so a boration is required pm. concentration, but minimum

3.9 REFUELING OPERATIONS

- 3.9.1 Boron Concentration
- LCO 3.9.1 Boron concentrations of the Reactor Coolant System, the refueling canal, and the refueling cavity shall be maintained within the limit specified in the COLR.

APPLICABILITY: MODE 6.

ACTIONS

<u>~</u>.

CONDITION		REQUIRED ACTION	COMPLETION TIME
A. Boron concentration not within limit.	A.1	Suspend CORE ALTERATIONS.	Immediately
	AND		
	A.2	Suspend positive reactivity additions.	Immediately
	AND		
	A.3	Initiate action to restore boron concentration to within limit.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.9.1.1	Verify boron concentration is within the limit specified in COLR.	72 hours

ATTACHMENT 7.1 Page 4 of 12 HBRSEP UNIT NO. 2, CYCLE 20 CORE OPERATING LIMITS REPORT REVISION 0

2.7 Shutdown Margin Requirements (SDM) (ITS 3.1.1, 3.4.5, 3.4.6)

- 2.7.1 The Mode 1 and Mode 2 required SDM versus RCS boron concentration is presented in Figure 5.0.
- 2.7.2 The Mode 3 SDM requirements are as follows:
 - a) With at least 2 reactor coolant pumps in operation, the SDM shall be greater than or equal to that specified in Figure 5.0.
 - b) With less than 2 reactor coolant pumps in operation and the rod control system capable of rod withdrawal, the SDM shall be greater than or equal to $4\% \Delta k/k$.
 - c) With less than 2 reactor coolant pumps in operation and with the rod control system not capable of rod withdrawal, the SDM shall be greater than or equal to that specified in Figure 5.0.
- 2.7.3 The Mode 4 SDM requirements are as follows:
 - a) With at least 2 reactor coolant pumps in operation, the SDM shall be greater than or equal to that specified in Figure 5.0.
 - b) With less than 2 reactor coolant pumps in operation and the rod control system capable of rod withdrawal, the SDM shall be greater than or equal to $4\% \Delta k/k$.
 - c) With less than 2 reactor coolant pumps in operation and with the rod control system not capable of rod withdrawal, the SDM shall be greater than or equal to that specified in Figure 5.0.
- 2.7.4 The minimum required SDM for Mode 5 is 1% $\Delta k/k$.
- 2.7.5 The minimum required SDM for Mode 6 is 6% $\Delta k/k$.

2.8 **Refueling Boron Concentration (ITS 3.9.1)**

2.8.1 In Mode 6 the minimum boron concentration shall be 1950 ppm.

	Dav. 44	Dage 12 of 22
FMP-001	Rev. 11	Faye 15 01 22

FH-12 003

Which ONE (1) of the following describes the required RCS boron concentration prior to refueling operations?

- A. 1500 ppm
- B. 1800 ppm
- **√**C. 1950 ppm
 - D. 2050 ppm

Given the following conditions:

- A reactor trip and SI have occurred.
- Containment pressure is 2 psig.
- All RCPs have been secured.
- EPP-007, "SI Termination," is being implemented.
- RVLIS Upper Range is 84%.
- Pressurizer Level is 56%.
- RCS Subcooling is 68 °F.
- SI, Phase A, and Phase B have been reset.
- OP-101 conditions have been met for starting an RCP.

Which ONE (1) of the following describes the conditions for starting an RCP?

- a. All conditions have been met and an RCP may be started
- b. Charging flow must be increased to raise RVLIS Upper Range at least an additional 6% before an RCP can be started
- c. Charging flow must be increased to raise Pressurizer Level at least an additional 18% before an RCP can be started
- d. Pressure must be increased and / or the RCS must be cooled down to raise RCS Subcooling at least an additional 6 °F before an RCP can be started

Answer:

c. Charging flow must be increased to raise Pressurizer Level at least an additional 18% before an RCP can be started

QUESTION N TIER/GROUP K/A:	UMBER: : WE02EK3.2	36	RO	1/2	SRO	
	Knowledge of Normal, abnor	the reasons mal and em	for the fo ergency c	ollowing r operating	esponses as they procedures asso	apply to the (SI Termination) ciated with (SI Termination).
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(1	RO b) RO	3.3 7	SRO 55.43(b) SRO	
OBJECTIVE:	EPP-007-03					
	DEMONSTRA the basis of ea	∖TE an unde ach.	rstanding	of selec	ted steps, caution	is, and notes in EPP-7 by explaining
REFERENCE	ES:	EPP-007				
SOURCE:	New	Signifi		- diffe d		Direct
	nem		canuy w	oairiea		
	1011		Bank	oamea Numbe	r EPP-007-03	011
JUSTIFICAT	ION:	Plausible if neither are	Bank Bank misconce adequate	eption of	r EPP-007-03 required values for P start.	011 or RVLIS or pressurizer level, but
JUSTIFICAT a. b.	ION:	Plausible if neither are Plausible s > 100% or	Bank Bank misconce adequate ince RVL require a	eption of eption of e for RCF IS is add dequate	EPP-007-03 required values for start. Iressed for condition pressurizer level a	ons for starting an RCP, but must be and subcooling.
JUSTIFICAT a. b. c.	ION: CORRECT	Plausible if neither are Plausible s > 100% or Required o Level > 74 must be ra	<i>Bank</i> misconce adequate ince RVL require a conditions % and Su ised.	odified a Numbe eption of e for RCF IS is add dequate for start ibcooling	r EPP-007-03 required values for P start. ressed for condition pressurizer level a ing an RCP are R ¹ > 59 °F. Subcool	011 or RVLIS or pressurizer level, but ons for starting an RCP, but must be and subcooling. VLIS > 100% or both Pressurizer ling is met, but pressurizer level
JUSTIFICAT a. b. c. d.	ION:	Plausible if neither are Plausible s > 100% or Required o Level > 74 must be ra Plausible s subcooling	<i>Bank</i> misconce adequate ince RVL require a conditions % and Su ised. ince subc	odified a Numbe eption of e for RCF IS is add dequate for start ubcooling is cooling is ns are ali	r EPP-007-03 required values for P start. ressed for condition pressurizer level a ing an RCP are R ¹ > 59 °F. Subcool addressed for contract addressed for contract	011 or RVLIS or pressurizer level, but ons for starting an RCP, but must be and subcooling. VLIS > 100% or both Pressurizer ling is met, but pressurizer level onditions for starting an RCP, but
JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	ION: CORRECT (: nsive/Analysis	Plausible if neither are Plausible s > 100% or Required of Level > 74 must be ra Plausible s subcooling	<i>Bank</i> misconce adequate ince RVL require a conditions % and Su ised. ince subo conditior	<i>Recall</i>	r EPP-007-03 required values for P start. ressed for condition pressurizer level a ing an RCP are R ¹ > 59 °F. Subcool addressed for conteady met. Rating	011 or RVLIS or pressurizer level, but ons for starting an RCP, but must be and subcooling. VLIS > 100% or both Pressurizer ling is met, but pressurizer level onditions for starting an RCP, but

.

EPP-7	SI TERM	INATION	Rev. 17 Page 19 of 30
EPP-7	SI TERM INSTRUCTIONS RVLIS Upper Range - TER THAN <u>OR</u> EQUAL TO 100%	INATION RESPONSE NOT OBT IF CV pressure has ret than 4 psig, THEN Perfollowing: Control Charging increase PZR level than 74%. Increase subcooling greater than 59°F Use PZR heaters to PZR Liquid Tempers saturation for RC IF CV pressure has in	Rev. 17 Page 19 of 30 CAINED mained less form the flow to al greater ang to comaintain rature at CS pressure.
		<u>IF</u> CV pressure has in greater than 4 psig, Step 37.	<u>THEN</u> Go To

EPP-007-03 011

Given the following plant conditions:

- A reactor trip and SI have occurred
- Crew has responded IAW the EOP network
- All RCP's have been secured
- EPP-007, SI TERMINATION, is in progress
- SI, Phase A, and Phase B have been reset

Which ONE (1) of the following describes the minimum plant conditions and the basis for starting an RCP?

- A. RVLIS Upper Range > 100% and PZR level > 66%; Collapse void in the reactor vessel head.
- ✓B. RVLIS Upper Range > 100% or PZR level > 66%; Collapse void in the reactor vessel head.
- C. RVLIS Full Range > 100% and RCS subcooling > 59 degrees; Establish saturated conditions in the PZR.
- D. RVLIS Full Range > 100% or RCS subcooling > 59 degrees; Establish saturated conditions in the PZR.

Given the following conditions:

- Unit 2 is in mid loop operation to repair a S/G primary manway leak.
- The RCS is vented by two hot leg vents.
- RCS level is -71" and rising very slowly.
- RHR pump 'A' is in service at 3000 gpm.
- The operator notices that RHR flow and pressure is oscillating.

Which ONE (1) of the following actions would tend to stabilize RHR flow and pressure?

- a. Start the RHR pump 'B' at 3000 gpm
- b. Lower charging flow to stabilize RCS level
- c. Lower RHR pump 'A' flow
- d. Open the RV head vents

Answer:

c. Lower RHR pump 'A' flow

QUESTION N TIER/GROUP K/A:	IUMBER: ?: 005K3.01	37	RO	2/3	SRO			
	Knowledge of	the effect tha	t a loss	or malfur	nction of the RHRS	s will have o	on RCS	
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO) RO	3.9 3	SRO 55.43(b) SRO			
OBJECTIVE:	AOP-020-08							
	Given plant co events as dire	onditions EVA acted in AOP-	LUATE -020.	the appr	opriate actions to r	nitigate cor	sequences of RHR	
REFERENCE	ES:	AOP-020						
SOURCE:	New	Signific	antly M	odified		Direct	X	
			Bank	Numbe	<i>r</i> AOP-020-08	C	105	
a.	ION.	Plausible if r oscillations a	nisconco are due ⁻	eption the to cavitat	at oscillations are o tion.	due to inad	equate heat remova	ıl, but
b.		Plausible sir RHR system	nce RCS n.	level is	increasing, but lev	el tends to	increase as air ente	irs
c.	CORRECT	Cavitation is reduced to 2	s occurri 1500 gpi	ng due to m to elim	o too high a flow ra inate cavitation.	te for the g	iven level. Flow is t	o be:
d.		Plausible if i	misconc are due	eption th to cavita	at oscillations are tion.	due to void	ing in head region,	but
DIFFICULT) Comprehe	ſ: nsive/Analysis	X Kno	wledge	/Recall	Rating	3		
	Analysis of c	onditions to d	etermine	e respon	se to RHR cavitation	on		

	~ ~	~
AOP-	02	υ

LOSS OF RESIDUAL HEAT REMOVAL (SHUTDOWN COOLING)

Rev. 24

Page 62 of 114

TEP INSTRUCTIONS Note of the section of the sectio	
Loss Of RHR Flow Or Temperature Control (Page 3 of 15) NOTE Cavitation will be indicated by oscillations in RHR flow and accompanied by noises from the RHR Pumps.	
Loss Of RHR Flow Or Temperature Control (Page 3 of 15) NOTE Cavitation will be indicated by oscillations in RHR flow and accompanied by noises from the RHR Pumps.	
(Page 3 of 15) NOTE Cavitation will be indicated by oscillations in RHR flow and accompanied by noises from the RHR Pumps.	
NOTE Cavitation will be indicated by oscillations in RHR flow and accompanied by noises from the RHR Pumps.	
Cavitation will be indicated by oscillations in RHR flow and accompanied by noises from the RHR Pumps.	,
Cavitation will be indicated by Oscillations in Mint 110. and accompanied by noises from the RHR Pumps.	pressure,
	- · ·
5 Determine If RHR Pump Cavitation	
Is Occurring As Follows:	
a. Check RCS level - ABOVE a. Perform the follo	owing:
-72 INCHES (69% RVLIS FULL 1) Verify both RE RANGE) STOPPED.	IR Pumps
2) Go To Section RHR While At J Inventory.	A, Loss Of Reduced
b. Check the following RHR b. Go To Step 10. indications - CAVITATION PRESENT	
• FI-605, RHR TOTAL FLOW	
AND	
• Running RHR Pump Discharge Pressure	
• RHR Pump A - PI-602A	
• RHR Pump B - PI-602B	

AOP-020	

Rev. 24

Page 63 of 114

[TNEEDICETONE	L	RESPONSE NOT OBTAINED						
1	STEP									
	<u>Section E</u>									
	Loss Of RHR Flow Or Temperature Control									
	(Page 4 of 15)									
	6.	Perform the following:								
	a. Adjust FC-605 to reduce RHR flow to 1500 gpm.									
		b. Check Cavitation - ELIMINATED		b. Perform the following:						
				1) Verify both RHR Pumps STOPPED.						
				2) Go To Step 7.						
		c. Return to procedure and step in effect								
	7.	Check RCS Level - ABOVE <u>OR</u> EQUAL TO -36 INCHES		Go To Section A, Loss Of RHR While At Reduced Inventory.						
	8.	Check Reactor Vessel Head - OFF		Go To Section D, Loss Of RHR Inventory - Level Stable Or Increasing.						
	9.	Go To Section B, Loss Of RHR Inventory - Vessel Head Off								
	10.	Check APP-001-A7, RHR HX LOW FLOW - ILLUMINATED		Go To Step 16.						
	11.	Adjust FC-605, RHR HX BYPASS FLOW Controller, To Restore Flow Between 3000 GPM And 3750 GPM	7							
	12.	Check RHR Flow - GREATER THAN OF	2	Perform one of the following:						
		EQUAL IO SUUD GPM		• <u>IF</u> RHR flow is less than 500 gpm, <u>THEN</u> Go To Step 14.						
				OR						
				• IF RHR flow is greater than or equal to 500 gpm, <u>THEN</u> observe the <u>NOTE</u> prior to Step 15 and Go To Step 15.						

Given the following conditions:

- The unit is operating at 100% power.
- 'B' EDG is under clearance to repair a leaky oil fitting.
- A tornado touches down in the switchyard.
- The transient resulting from the destruction causes a Phase Differential on the Main Generator.
- The Startup Transformer (SUT) is destroyed by the tornado.
- 'A' EDG is unable to start due to a faulty air lineup.
- After the initial transient, it is noted that **BOTH** of the Reactor Trip breaker indications are RED.

Which ONE (1) of the following describes the required operator action(s)?

- a. Enter FRP-S.1, "Response to Nuclear Power Generation / ATWS," due to the ATWS
- b. Enter PATH-1 due to the turbine trip and then FRP-S.1 due to the ATWS
- c. Enter EPP-001, "Loss of All AC Power," due to the electrical conditions
- d. Enter FRP-S.1 due to the ATWS, then EPP-001 due to the electrical conditions

Answer:

c. Enter EPP-001, "Loss of All AC Power," due to the electrical conditions

QUESTION N TIER/GROUP K/A:	UMBER: : 055 2.4.1 Knowledge of	38 EOP entry cond	RO ditions a	1/1 and imm	nediate a	SRO ction steps	s (Station I	Blackout).	
K/A IMPORT/ 10CFR55 CO OBJECTIVE:	ANCE: NTENT: EPP-001-02	F 55.41(b) F	RO RO	4.3 10	55.43(k	SRO) SRO :PP-001.			
REFERENCE	S:	EPP-001							
SOURCE:	New	Significar	ntly Mo Bank I	dified Numbe	r EPI	P-001-02	Direct	X 105	
JUSTIFICAT <i>a.</i>	ION:	Plausible since but EPP-1 stat exited to imple	e there tes that ement a	is an Al CSFST ny FRP	TWS and s are for s.	Subcritica informatio	lity is the l n only and	nighest order Ca I EPP-1 should	SFST, not be
b.		Plausible since that CSFSTs a any FRPs.	e a read are for i	ctor trip nformat	signal we	ould have t and EPP-1	been gene should no	erated, but EPP- ot be exited to ir	1 states nplement
с.	CORRECT	Loss of all AC only and EPP	power -1 shou	override Id not b	es and E e exited	PP-1 states to impleme	s that CSF ent any FR	FSTs are for info Ps.	ormation
d.		Plausible sinc but EPP-1 sta exited to imple	e there tes that ement a	is an A ⁻ t CSFST any FRP	TWS and Is are fo Ps.	l Subcritica r informatic	ality is the on only and	highest order C d EPP-1 should	SFST, not be
DIFFICULTY Compreher	': nsive/Analysis	Knowl	ledge/F	Recall		Rating	3		

Knowledge of hierarchy between loss of all AC and subcriticality

Purpose and Entry Conditions

(Page 1 of 1)

1. <u>PURPOSE</u>

This procedure provides actions to respond to a loss of all AC power.

2. ENTRY CONDITIONS

- a. Upon any indication that all Main and Emergency AC Busses are de-energized.
- b. PATH-1, upon indication that E-1 and E-2 Busses are de-energized.

- END -

-	m	~		-
Ŀ	۲	Р	-	T

Rev. 28

Page 4 of 51

		RESPONSE NOT OBTAINED								
STEP	INSTRUCTIONS									
	NOTE									
•	Steps 1 AND 2 are Immediate Action steps.									
•	Critical Safety Function Status Trees are monitored for information only. This procedure is not exited to implement any Functional Restoration Procedure.									
•	Foldouts and concurrent AOPs shou procedure to prevent diluting ava	ld not be implemented during this ilable resources.								
1.	Check Reactor Trip:	Trip Reactor.								
	 Check REACTOR TRIP MAIN AND BYP BKRs - OPEN 									
	 Check Neutron flux - DECREASING 									
2.	Check Both Turbine Stop Valves -	Manually trip the Turbine.								
	CTORP	<u>IF</u> the Turbine will <u>NOT</u> trip, <u>THEN</u> close the MSIVs <u>AND</u> MSIV Bypasses.								

Given the following conditions:

- A makeup to the Component Cooling Water (CCW) Surge Tank is being performed.
- CC-832, CC SURGE TANK MAKE-UP VALVE, is stroked full open.
- When tank level is 50%, the operator momentarily places the switch for CC-832 to close.

Assuming **NO** other operator actions are taken, which ONE (1) of the following describes the response of the CCW Surge Tank level?

- a. CCW Surge Tank level will continue to rise to approximately 55% due to the stroke time of the valve
- b. CCW Surge Tank level will stabilize at approximately 50%
- c. CCW Surge Tank level will continue to rise to approximately 55% when the high level alarm will automatically close the valve
- d. CCW Surge Tank level will eventually overflow out the vent valve

Answer:

d. CCW Surge Tank level will eventually overflow out the vent valve

QUESTION N TIER/GROUF K/A:	IUMBER: ?: 026AA1.05	39	RO	1/1	SRC			
	Ability to opera Water: The CO	ate and / or mo CWS surge tar	onitor th nk, inclu	e followi ding leve	ng as they app el control and le	ly to the Loss of Component Cooling evel alarms, and radiation alarm		
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.1 4	SRO 55.43(b) SRO)		
OBJECTIVE:	CCW-08							
EXPLAIN the component operation associated with each switch position for the CCW System switches and controls.								
REFERENCE	ES:	OP-306 SD-013						
SOURCE:	New	Significa	antly Mo	odified	X	Direct		
			Bank	Numbe	r CCW-07	002		
JUSTIFICAT a.	ION:	Plausible sine closed and th	ce level ne tank v	will cont will over	inue to rise, bu low.	t the valve will not continue to stroke		
b.		Plausible sin the valve will	ce it is e not cor	expected ntinue to	that level will s stroke closed a	stabilize when the valve is closed, but and the tank will overflow.		
c.		Plausible sin automatic clo	ce level ose feat	will con ures.	tinue to rise, bu	It the valve does not have any		
d.	CORRECT	The makeup will only thro	valve is ttle it clo	s a thrott osed slig	le valve. Mom htly. Makeup v	entarily placing it in the close position vill continue and the tank will overflow.		
DIFFICULTY: Comprehensive/Analysis Knowledge/Recall X Rating 3								
Comprehe	(: nsive/Analysis	Knov	vledge/	Recall	X Rating	3		
REFERENCE USE

Section 8.4.1 Page 1 of 2

8.4 Infrequent Operation

- 8.4.1 Make-up to the Component Cooling Water System
 - 1. Initial Conditions
 - a. All the prerequisites of Section 4.0 are complete.
 - Primary Make-up Water and Demineralized Water is in service IAW OP-915, Demineralized and Primary Water.
 - 2. Instructions for Making-Up to the Component Cooling Water System Using Primary Make-up Water

NOTE: CC-832, CC SURGE TANK MAKE-UP VALVE is a throttle valve and will remain in position when the OPEN-CLOSE switch is released. Care should be used in opening this valve as the Surge Tank Level will rise rapidly if opened too far.

- a. Verify one Primary Water Pump is RUNNING.
- b. At the RTGB, momentarily place the OPEN-CLOSE Switch for CC-832, MAKEUP in the OPEN position.
- c. Verify a level increase on LI-614B, Comp Cool Surge Tank Level indicator.

OP-306	Rev. 32	Page 27 of 66
0, 000		

Section 8.4.1 Page 2 of 2

8.4.1.2 (Continued)

- d. **WHEN** the desired level has been established (normally 45 to 55%), **THEN** perform the following:
 - 1) Stop the Primary Water pump, **AND** return switch position to AUTO.

NOTE: Holding CC-832 in the CLOSE position for one to two seconds after SHUT indication is received will ensure the valve is properly seated.

- 2) Close CC-832, MAKEUP.
- e. Verify the Surge Tank Level is no longer increasing by observing LI-614B.
- f. Notify E&C of addition of water to CCW Surge Tank (SCR 89-050).
- 3. Instructions for Making-up to the Component Cooling Water System Using Demineralized Water
 - a. Establish Communications between CC-711, DEMIN WTR MAKE-UP TO CC SURGE LINE and the Control Room.
 - b. Open CC-711.
 - c. Verify a level increase on LI-614B, COMP COOL SURGE TANK LEVEL INDICATOR.
 - d. **WHEN** the desired level has been established (normally 45 to 55%), **THEN** close CC-711.
 - e. Verify the Surge Tank Level is no longer increasing by observing LI-614B.
 - f. Notify E&C of addition of water to CCW Surge Tank (SCR 89-050).

OP-306 Rev. 32 Page	28 of 66
---------------------	----------

5.9 CC-735, Thermal Barrier Outlet Isolation - MOV

(CDW-B-190628 Sh00230)

Valve CC-735 is operated from the two position (OPEN/CLOSED), spring return to the center, switch located on the RTGB. The valve is located outside containment downstream of FCV-626 in the Auxiliary Building pipe alley. The motor operator for the valve is powered from MCC-5. Upon receipt of a "P" signal, the valve will close.

5.10 CC-739, Excess Letdown HX. Outlet Isolation Valve, Air Operated Valve

(CWD-B-190628 Sh00229)

Valve CC-739 is operated from the RTGB using a two position (OPEN/CLOSED), spring return to center, switch. This valve is located in the Auxiliary Building pipe alley and provides CV isolation downstream of CV penetration P-22. CC-739 is an Air Operated Valve that receives operating air from the instrument air system through 125V DC solenoid valves. The solenoid valves receive power from the 125V DC Auxiliary Panel GC CKT#29. A safeguards actuation signal, "T" signal, will de-energize the solenoid valves causing CC-739 to close. Valve position indication is provided at the RTGB control switch and at the Containment Phase "A" Isolation indication on the vertical section of the RTGB.

5.11 RCV-609, Component Cooling Surge Tank Vent Isolation Valve, Air Operated Valve

(CWD-B-190628 Sh00204)

RCV-609 is currently gagged open to ensure CCW System does not over pressurize. The control switch for this valve is located on the RTGB. It is a two position (OPEN/CLOSED) spring return to center switch. The solenoid valves that control the air to the valve receive power from 125V Auxiliary DC Panel CKT#4. When Radiation Monitor RE-17 reaches its setpoint, the solenoid valves are deenergized to remove air pressure to RCV-609. When the activity in the CCW surge tank vent line is reduced to below the setpoint of RE-17, the solenoid valves for RCV-609 energize, opening the air supply to the air operator, and RCV-609 then strokes open. (Original design)

5.12 CC-832, CCW Makeup From Primary Water, MOV

(CWD-B-190628 Sh00203)

Valve CC-832 is operated from the RTGB using a two position (OPEN/CLOSED) switch. To open the valve the switch must be held in the OPEN position until the valve

has reached its full stroke. To close the valve the switch must be held in the CLOSED position until the valve has reached the full closed position. It has throttle capability and will allow primary water to be admitted to the tank for makeup purposes. To throttle the valve, the control switch is held in the OPEN or CLOSED position until the valve has reached the desired throttle position. The valve has local position indicating lights. The motor operator for CC-832 is powered from MCC-6

The valve is located near the safeguard racks in the E-1/E-2 room, second level of the Auxiliary Building (outside of the RCA).

5.13 CC-749A/B, CCW From RHR Heat Exchangers A/B, MOVs

(CWD-B-190268 Sh00218/Sh00219)

Valves CC-749A and CC-749B are powered from MCC-5 and MCC-6 respectively and are operated by two position (OPEN/CLOSED), spring return to center, switches located on the RTGB. CC-749A and CC-749B are located in the RHR heat exchanger room, first level, Auxiliary Building. ESR 98-367 modifications added stem sensors to these valves.

6.0 SYSTEM OPERATION

6.1 Normal Operation

6.1.1 Plant Startup/Heat-up

At the beginning of the plant startup procedure, the water chemistry of the component cooling loop is checked and, if required, corrosion inhibitor is added to the loop. The surge tank water level is adjusted with the makeup valves. Normally, primary water is added to the CCW System by opening a motor operated valve from the RTGB. This valve (CC-832) is a throttle valve in that the motor only runs as long as the switch is held in the open or shut position. However, if necessary, demineralized water can be added to the component cooling loop by opening manual valve CC-711.

During plant heatup, while the RHR is in operation, two of the three CCW pumps are in operation. After the RHR System is removed from operation, one of the operating CCW pumps can be stopped.

6.1.2 Normal Plant Operation

Periodically, a sample of the CCW is taken by the plant E&RC technician to determine the solution pH and the concentration of inhibitor in the loop. If the solution is not within the specifications listed for CCW, the appropriate chemicals are added to the

CCW-07 002

Which ONE (1) of the following valves is operated from an RTGB control switch AND receives no other closure signals (no automatic closure signal)?

- A. RCV-609, CCW Surge Tank Vent Isolation Valve
- B. TCV-659A, "A" Charging Pump Oil Cooler Temperature Control Valve
- C. CC-739, Excess Letdown HXer Outlet Isolation Valve
- ✓D. CC-832, CCW Makeup From Primary Water

Given the following conditions:

- RCS pressure is 1805 psig and decreasing.
- RCS temperature is 525 °F and decreasing.
- Tavg is 537°F and decreasing
- Steam Generator pressures and Steam Flows are:

SG	PRESSURE	STEAM FLOW
'A'	626 psig and decreasing	1.7 x 10 ⁶ lbm/hr
'B'	745 psig and stable	0.05 x 10 ⁶ lbm/hr
'C'	740 psig and stable	0.05 x 10 ⁶ lbm/hr

Which ONE (1) of the following Safety Injection signals would be actuated?

- a. High Steamline ΔP
- b. Low Pressurizer Pressure
- c. High Steam Line Flow with Low Tavg
- d. High Steam Line Flow with Low Steam Line Pressure

Answer:

a. High Steamline ΔP

QUESTION N TIER/GROUP K/A:	IUMBER: ?: 013A2.02	40	RO	2/1	SRO	
	Ability to (a) p (b) based Abi consequence	predict the impa lity on those pross s: Excess stear	ets of th edictions m dema	e followi s, use pro nd	ng malfunctions c ocedures to corre	or operations on the ESFAS; and act, control, or mitigate the
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	4.3 8	SRO 55.43(b) SRO	
OBJECTIVE:	ESF-05					
	DESCRIBE th	ne performance	and de	sign attri	butes of the majo	r ESFAS components.
REFERENCE	S:	SD-006				
		AFF-004				
SOURCE:	New	Significa	ntly Mo	dified	x	Direct
			Bank I	Number	ESF-04	006
JUSTIFICATI a.	ON: CORRECT	A single stear	nline pre	essure he	ving 100 poid low	or then the header processre will
		result in a sale	ety injec	tion.	ang 100 psia low	er than the neader pressure win
b.		Plausible sinc pressure safe	ety injec e this is ty injecti	below th	e low pressure re	eactor trip, but is still above the low
b. c.		Plausible sinc pressure safe Plausible sinc injection signa	ety injec e this is ty injecti e high s al, but or	below th on. team flow	e low pressure re w coincident with 2/3 steam lines.	er than the neader pressure will eactor trip, but is still above the low low Tave results in a safety
b. с. d.		Plausible sinc pressure safe Plausible sinc injection signa Plausible sinc low pressure s	ety injec e this is ty injecti e high s al, but or e high s setpoint.	below th on. team flow hly if on 2	e low pressure re w coincident with 2/3 steam lines. w condition exists	eactor trip, but is still above the low low Tave results in a safety s, but steamline pressure is above
b. c. d. DIFFICULTY Comprehen	: sive/Analysis	Plausible sinc pressure safe Plausible sinc injection signa Plausible sinc low pressure	ety injec e this is ty injecti e high s al, but or e high s setpoint.	below th on. team flow ily if on 2 team flow	e low pressure re w coincident with 2/3 steam lines. w condition exists	eactor trip, but is still above the low low Tave results in a safety s, but steamline pressure is above

REFERENCES SUPPLIED:

4.1.2 Reactor Coolant Temperature (ESF-Figure-1)4.1.2 Reactor Coolant Temperature

The RCS Low Tavg signal (2 of 3 channels below 543°F) is used to initiate the Safety Injection signal, when coincident with high steam flow; and close the Main Steam Isolation Valves, when coincident with high steam flow (i.e., generate the Steam Line Isolation Signal).

4.1.3 Steam Flow (ESF-Figure-1)4.1.3 Steam Flow

Hi Steam Flow (37.25% flow at no load to 20% load, increases linearly to 109% at full load) detected by at least one sensor on two of three steam lines, coincident with low Tavg (543°F) or low steam line pressure (614 psig), generates a Safety Injection signal and closes all MSIVs. Two flow controllers on each steam line are used to sense high steam line flow. This circuit is designed to detect steam line breaks downstream of the MSIVs.

4.1.4 Steam Line Pressure (ESF-Figure-1 & 3)4.1.4 Steam Line Pressure

Steam Line Pressure measurement is utilized for steam line break protection. Low steam line pressure (614 psig) in two of three main steam lines or Low Tavg (543°F) in two of three loops, coincident with high steam line flow in two-of-three main steam lines, will initiate the Steam Line Isolation and Safety Injection signals. This is to protect against: a steam line break upstream of the main steam check valves, a feed line break, and/or an inadvertent opening of a SG safety.

In addition, each steam line pressure measurement is compared with a main steam header pressure measurement to determine if a high steam line differential pressure exists. A coincidence of two-of-three steam line differential pressures (100 psid) in any offe steam line, that is, steam line pressure lower than main steam header pressure, will initiate a Safety Injection signal.

The steam header pressure is electronically limited to a minimum value of 585 psig. Therefore, this SI signal must be blocked before a plant cooldown is started to prevent SI actuation when S/G pressures drop below 485 psig(approximately 467°F). The steam line differential pressure circuit detects faults upstream of the MSIVs. Since the steam line check valves prevent reverse flow to the faulted S/G, excessive steam line differential pressure does not close the MSIVs.

4.1.5 Containment Pressure (ESF-Figure-4 & 5)4.1.5 Containment Pressure

Revision 5

ESF

ESF-04 006

Given the following plant conditions:

- A plant cooldown is in progress in accordance with GP-007, Plant Cooldown From Hot Shutdown to Cold Shutdown
- RCS Pressure is 1900 psig and appropriate SI signals have been blocked IAW GP-007
- Tavg is 515°F
- A RCS leak is identified in the CV

Which ONE (1) of the following contains valid signals which could result in a Containment Ventilation Isolation under these conditions?

- A. Hi Steamline Delta-P; an alarm on R-12, Containment Noble Gas Monitor
- B. Low pressurizer pressure Safety Injection; an alarm on R-14C, Plant Effluent Noble Gas Monitor
- ✓C. Manual actuation of Containment Isolation Phase A; an alarm on R-12, Containment Noble Gas Monitor
 - D. Manual actuation of Containment Isolation Phase A; an alarm on R-14C, Plant Effluent Noble Gas Monitor

<u>ALARM</u>

S/G A STM LINE HI ΔP SFGRD/TRIP

AUTOMATIC ACTIONS

1. Safeguards Actuation

CAUSE

- 1. Steam Line Rupture upstream of MSIV and Check Valve
- 2. Failure to block SI with S/G "A" pressure less than 485 psig

OBSERVATIONS

- 1. S/G "A" Steam Flow (FI-474, FI-475)
- 2. Reactor trip breaker position

ACTIONS

- 1. **IF** the Reactor has tripped, **THEN** refer to the EOP Network.
- 2. IF the Reactor is NOT tripped AND a plant transient is in progress, THEN trip the Reactor AND refer to the EOP Network.
- 3. IF the Reactor is NOT tripped AND the plant is stable, THEN perform the following:
 - 1) Scan the RTGB for confirmation that a trip is **NOT** required.
 - 2) Inform the CRSS OR SSO of plant conditions to assist in diagnosis.
 - 3) **IF** no supporting indications show a plant trip is required, **THEN** the plant may remain at power for troubleshooting and repairs.

DEVICE/SETPOINTS

PC-474B (PT-468 - PT-474) / 100 psid

- PC-475 (PT-466 PT-475) / 100 psid
- PC-476 (PT-464 PT-476) / 100 psid
- Differential pressure of greater than or equal to 100 psi between the main steam header and a steam line (2/3 Channels on any steam line).

REFERENCES

- 1. EOP Network
- 2. 5379-2757 and 5379-2758, Logic Diagrams
- 3. CWD B-190628 SH 399 Cable AB
- 4. 5379-3232, Safeguards System

APP-004	Rev. 11	Page 4 of 30

ALARM

HI STM FLO LO TAVG/LO SLP SFGRD/TRIP

AUTOMATIC ACTIONS

- 1. Safeguards Actuation
- 2. Main Steam Line Isolation

CAUSE

1. Steam Line Break downstream of the MSIVs and Check Valves

OBSERVATIONS

1. Reactor trip breaker position

ACTIONS

- 1. IF the Reactor has tripped, THEN refer to the EOP Network.
- 2. IF the Reactor is **NOT** tripped **AND** a plant transient is in progress, **THEN** trip the Reactor **AND** refer to the EOP Network.
- 3. IF the Reactor is NOT tripped AND the plant is stable, THEN perform the following:
 - 1) Scan the RTGB for confirmation that a trip is **NOT** required.
 - 2) Inform the CRSS OR SSO of plant conditions to assist in diagnosis.
 - 3) **IF** no supporting indications show a plant trip is required, **THEN** the plant may remain at power for troubleshooting and repairs.

DEVICE/SETPOINTS

- 1. High Steam Flow (1/2 flows on 2/3 lines)
 - 1) FC-474, FC-475 / 37.25% 109% (Ramped from 20% to 100% Turbine PWR)
 - 2) FC-484, FC-485 / 37.25% 109% (Ramped from 20% to 100% Turbine PWR)
 - 3) FC-494, FC-495 / 37.25% 109% (Ramped from 20% to 100% Turbine PWR)
- 2. Low T_{avg} (2/3 channels)
- 3. TC-412E, TC-422E, TC-432E / 543°F
- 4. Low Steam Line Pressure (2 of 3 Channels)
- 5. PC-474A, PC-485A, PC-496A / 614 psig

REFERENCES

- 1. EOP Network
- 2. 5379-2758, Logic Diagram
- 3. 5379-3435, Block Diagram
- 4. CWD B-190628 SH 399 Cable AE
- 5. Calculation RNP/INST-1045

APP-004	Rev. 11	Page 22 of 30

APP-004-D1

<u>ALARM</u>

PZR LO PRESS SFGRD/TRIP

AUTOMATIC ACTIONS

1. Safeguards Actuation

CAUSE

- 1. LOCA
- 2. Steam Break

OBSERVATIONS

- 1. PZR Pressure (PI-455, PI-456, PI-457)
- 2. Reactor trip breaker position

ACTIONS

- 1. IF the Reactor has tripped, THEN refer to the EOP Network.
- 2. IF the Reactor is **NOT** tripped **AND** a plant transient is in progress, **THEN** trip the Reactor **AND** refer to the EOP Network.
- 3. IF the Reactor is NOT tripped AND the plant is stable, THEN perform the following:
 - 1) Scan the RTGB for confirmation that a trip is **NOT** required.
 - 2) Inform the CRSS **OR** SSO of plant conditions to assist in diagnosis.
 - 3) **IF** no supporting indications show a plant trip is required, **THEN** the plant may remain at power for troubleshooting and repairs.

DEVICE/SETPOINTS

1. PC-456D, PC-457D, PC-455E / 1715 psig (2/3 Channels)

REFERENCES

- 1. EOP Network
- 2. 5379-2757, Logic Diagram
- 3. 5379-3439, Block Diagram
- 4. CWD B-190628 SH 399 Cable A

APP-004	Rev. 11	Page 19 of 30
APP-004	Rev. 11	Page 19 of 30

Given the following conditions:

- The plant is operating at 43% power.
- An electrical transient causes a momentary underfrequency condition on 4 KV Bus 1.
- Moments later, an undervoltage condition is also sensed on 4 KV Bus 1.
- The RCP powered from 4 KV Bus 1 trips.
- The other two RCPs remain running.

Which ONE (1) of the following identifies the signal which **DIRECTLY** generated the reactor trip?

- a. Bus underfrequency
- b. Bus undervoltage
- c. Low flow
- d. Pump breaker trip

Answer:

d. Pump breaker trip

QUESTION N TIER/GROUP K/A:	IUMBER: 2: 012K6.04	56	RO	2/2		SRO		
	Knowledge of block circuits	the effect of a	loss or	malfunc	tion of the	e concepts	s as the apply t	o the RPS: Bypass-
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.9 8	55.43(b	SRO) SRO		
OBJECTIVE:	RPS-11							
	EXPLAIN the	reactor trips a	ssociate	d with th	ne RPS S	System. In	clude purpose	and setpoints.
REFERENCE	S:	SD-011						
SOURCE:	New	X Significa	antly Mc	odified			Direct 🔲	
			Bank	Numbe	r		NEW	
JUSTIFICAT a.	ION:	Plausible sind cause a reac	ce UF or tor trip.	ר 2/3 bu	ses will c	ause all R	CPs to trip, but	does not directly
b.		Plausible sind only cause th	ce UV or ne relate	n 2/3 bu d RCP t	ses will c o trip.	ause a rea	actor trip, but a	single bus UV will
с.		Plausible sine condition wor below P-7 be	ce a low uld trip tl efore the	flow sig he react low flov	inal would or previo v conditic	d be gener us to the lo n was sen	rated in the sin ow flow signal : ised.	gle loop, but the UV so power would be
d.	CORRECT	An undervolt tripping abov	age con re P-8 (4	dition wi 0%) will	II cause f cause a	he pump t reactor tri	preaker to trip. p.	The pump breaker
DIFFICULTY Compreher	·:			- <i>1</i> /	-		2	

Analysis of plant conditions to determine cause of reactor trip as result of electrical perturbation

REFERENCES SUPPLIED:

UNDERVOLTAGE & UNDERFREQUENCY RCP BUS LOGIC RPS-FIGURE-28 (Rev. 0)



UNDER FREQUENCY RCP BUSSES



LOW PRIMARY COOLANT FLOW REACTOR TRIP LOGIC



Given the following conditions:

- An inadvertent reactor trip and safety injection have occurred.
- The SI and Phase A signals have just been reset.

Which ONE (1) of the following describes the expected position of the Normal and Emergency Inlet Dampers for the Containment Air Recirculation Fans (HVH-1 through 4) following resetting of these signals?

	NORMAL INLET DAMPERS	EMERGENCY INLET DAMPERS
a.	Open	Open
b.	Open	Closed
C.	Closed	Open
d.	Closed	Closed

Answer:

C.	Closed	Open
0.		•

QUESTION N TIER/GROUP K/A:	IUMBER: 2: 022A3.01	57	RO	2/1	SRO			
	Ability to moni operation	tor automatic o	operatio	n of the	CCS, including: Ir	iitiation of	safeguards mode	of
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	4.1 9	SRO 55.43(b) SRO			
OBJECTIVE:	CVHVAC-05							
	DESCRIBE th Recombiner S	e performance Systems.	e and de	esign att	ributes of the majo	or CV HVA	C, PACV and Hyd	rogen
REFERENCE	S:	SD-037						
SOURCE:	New	Significa	antly Mo	odified		Direct	X	
			Bank	Numbe	r CVHVAC-07		003	
JUSTIFICAT a.	ION:	Plausible sind opening where	ce until a n SI was	a recent s reset, f	modification to pro these dampers wo	event the r uld open.	normal inlets from	
Ь.		Plausible sind opening when	ce until a n SI was	a recent s reset, †	modification to protection to protection to protect the second seco	event the r ould open.	normal inlets from	
с.	CORRECT	On the SI nor remain open components	rmal inle since th remain i	et dampe ley are f in the po	ers automatically c ailed open. When ost-SI position.	lose and e the signal	emergency inlet da ls are reset these	Impers
d.		Plausible sind dampers will	ce the n remain	ormal in open.	let dampers rema	in closed,	but the emergency	/ inlet
DIFFICULTY Compreher	': nsive/Analysis	Know	/ledge/l	Recall	X Rating	3		
	Knowledge of	f the operation	of the C	Containr	nent Ventilation sy	stems to a	an SI	

REFERENCES SUPPLIED:

The function of the Containment Air Recirculation Cooling system under normal power operating conditions is to remove heat from the containment atmosphere at a rate of 1.75×10^6 Btu/hr and thereby maintain the average dry-bulb temperature of the containment atmosphere below 120° F, except for short durations tolerable for the insulation of the electric motors, wiring, and miscellaneous electrical devices. In order to enhance CV temperature control during the summer, piping needed to inject chilled water has been installed down stream of SW Booster pump "B" (ESR 97-00383).

Condensate from the cooling coils is collected by floor drains and directed to a level column for RCS leakage detection. ESR -98-00314 modified the Condensate Measuring System (CMS). The modification replaced the four level detectors with digital indicators and installed a local annunciator with reflash ability. For example, if a CMS alarm is received on the RTGB, an acknowledge pushbutton on the local panel must be depressed to enable the reflash capability. The alarm on the RTGB will be locked in, however, any new alarms received will cause the RTGB alarm to reflash and a subsequent local alarm. The alarms will clear themselves when the alarm condition no longer exists. APP-002-E2 and OST -901 have been revised to reflect these changes.

The cooling coils of each HVH unit are supplied with 800 gpm of cooling water from the Service Water system.

Each fan is designed to supply at least 65,000 cfm at design basis accident (DBA) conditions at approximately 20 in. static pressure, $263^{\circ}F$, 0.162 lb/ft³ density. The fans are direct-driven centrifugal type. Cooling coils are plate fin-tube type. Each air handling unit is capable of removing 4.0 x 10⁷ Btu/hr from the containment atmosphere under DBA conditions when supplied with 750 gpm of service (cooling) water. The design maximum cooling water inlet temperature is 95°F which results in a maximum outlet temperature of 195°F under DBA conditions.

Each air handling unit has a normal air inlet damper (85,000 cfm) and an emergency air inlet butterfly valve (65,000 cfm).

The emergency air inlet butterfly valve is secured open and supplies air to the unit under all operating conditions. The instrument air tubing for the emergency air inlet butterfly valve solenoids was disconnected and removed during RFO 18 by Engineering Service Request (ESR) 97-00382. The solenoids themselves were abandoned in place.

The operation of the normal air inlet damper was modified during RFO's 17 and 18 by ESRs 97-00382 and 95-00783. A key locked three position selector switch and a new relay were installed for the normal air inlet damper on each unit. The selector switch positions are : LEFT - OPEN, CENTER - CLOSED and RIGHT - RESET. The selector switch maintains position in OPEN or CLOSED but it is spring returned to CENTER - CLOSED from RESET. [These switches are located on the DC Relay Racks in the Computer Room.] The normal air inlet dampers close on a SI SIGNAL and the new relays prevent them from automatically reopening when the SI SIGNAL is reset. These

3.1.4 HVH-9A and HVH-9B (Reactor Concrete Shield Cooling)

Number of units:	2
Fans - per unit:	1
Manufacturer:	Industrial Air
Air flow rate - per fan:	15,450 cfm
Power requirements - per fan:	25 HP
Louisi Isdamente Louis	

The units contain supply ductwork connected to the recirculation cooling unit's distribution header, booster fans, and exhaust ductwork.

3.1.5 HVH-1, HVH-2, HVH-3, and HVH-4 (Containment Air Recirculation Cooling)

Number of units:	4
Fans - per unit:	1
Manufacturer:	Westinghouse
Air flow rate - normal power operation: - with Emergency air inlet butterfly valves open - with Emergency air inlet butterfly	65,000 cfm
valves and normal air inlet dampers open Air flow rate - post-accident operation:	>85,000 cfm 65,000 cfm
Design power requirements - per fan - normal power operation: - post-accident operation: Rated power requirements - per fan Cooling coils - per unit:	117 BHP 244 BHP 350 HP 6
Cooling capacity - per unit - normal power operation: - post-accident operation: Cooling water flow rate - per unit:	1.75 x 10 ⁶ Btu/hr 40 x 10 ⁶ Btu/hr 800 gpm

Each air handling unit includes a space for roughing filters, water supplied cooling coils, and a centrifugal fan enclosed in a sheet metal casing. Supply air is drawn through the space for roughing filters during shutdown operating conditions. During normal power and accident conditions, the space for filters is not used and air is drawn directly through an air operated butterfly valve located on the unit's casing. Air discharges to the recirculation cooling unit's distribution header where it is distributed through ductwork to individual areas in containment.

SD-03/	SD-	037
--------	-----	-----

INFORMATION USE ONLY

Given the following conditions:

- The unit has experienced a loss of off-site power.
- The reactor trip and turbine trip have been verified.
- EPP-1, "Loss of ALL AC Power," was implemented until the inside AO restored power to 480V Bus E-2 per Attachment 6 of EPP-1.
- A transition has been made back to PATH-1.
- SI has NOT occurred and is NOT required.

Which ONE (1) of the following describes how power will be supplied to the Charging Pumps?

	FROM 'B' EDG	FROM DSDG
a.	Charging Pump 'B'	Charging Pump 'A'
b.	Charging Pump 'C'	Charging Pump 'B'
C.	Charging Pump 'B'	Charging Pump 'C'
d.	Charging Pump 'C'	Charging Pump 'A'

Answer:

		······································
d.	Charging Pump	Charging Pump
	'C'	'A'

QUESTION N TIER/GROUP K/A:	IUMBER: 2: 004K2.03	58	RO	2/1	SRO			
	Knowledge of bus power supplies to the Charging pumps							
					•			
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.3 8	SRO 55.43(b) SRO			
OBJECTIVE:	CVCS-06							
	LIST power su	pplies for the	major C	VCS co	mponents as listed	l in the EDPs.		
REFERENCE	ES:	EDP-002						
SOURCE:	New	Significa	antly Mo	odified		Direct X		
			Bank	Numbe	r PATH-1-03	001		
303 HFICAT a.	ION.	Plausible sind listed for 'B' C	ce the po CP.	ower su	pply for 'A' CCP is	correct, but incorrec	t power supply	
b.		Plausible sind listed for 'B' (ce the p CCP.	ower su	pply for 'C' CCP is	correct, but incorrec	t power supply	
c.		Plausible sine power supply	ce powe / listed f	er supply or both.	for both pumps se	eems logically correc	et, but incorrect	
d.	CORRECT	C' CCP will b	e suppli	ied by 'E	B' EDG and 'A' CCI	• will be supplied by	DSDG.	
DIFFICULT Comprehe	Υ: nsive/Analysis	Knov	vledge/l	Recall	X Rating	3		
	Knowledge o	f emergency p	oower su	upplies f	or charging pumps			

.

REFERENCES SUPPLIED:

٦

9.0 **480V-E2**

١

PO	480V-E2 WER SUPPLY: NORMAL - 4160V BUS 3 (52/15)LOCATION:	E-1/E-2 R	ООМ
CMPT NO.	LOAD TITLE EDBS LOAD TAG NO.	CWD NO.	BKR EDBS NO.
23A	CHARGING PUMP C CHG-PMP-C	163B	52/23A
23B	SAFETY INJECTION PUMP C SI-PMP-C	239	52/23B
23C	FEED TO MCC-6 MCC-6	1188	52/23C
24A	SERVICE WATER PUMP C SW-PMP-C	833	52/24A
24B	CV RECIRC FAN, HVH-4 HVH-4	514	52/24B
24C	AUX FEEDWATER PUMP B AFW-PMP-B	655	52/24C
25A	CV RECIRC FAN, HVH-3 HVH-3	513	52/25A
25B	SERVICE WATER PUMP D (NORMAL SUPPLY) SW-PMP-D	834B	52/25B
25C	CV SPRAY PUMP B CV-SPRAY-PMP-B	290	52/25C
26A	FEED TO MCC-18 MCC-18	1189	52/26A
26B	RESIDUAL HEAT REMOVAL PUMP B RHR-PMP-B	216	52/26B
26C	COMPONENT COOLING WATER PUMP C CCW-PMP-C	209	52/26C
27A	PT'S & METERING EQUIPMENT (*) N/A	N/A	N/A
27B	EMERGENCY DIESEL GENERATOR B TO 480V BUS E-2 480V-E2	895	52/27B

Rev. 7	Page 12 of 13

٦

7.0 **480V-DS**

480V-DS POWER SUPPLY: NORMAL - 4160V BUS 3 (52/15)LOCATION: 4160V SWITCHGEAR ROOM				
CMPT NO.	LOAD TITLE EDBS LOAD TAG NO.	CWD NO.	BKR EDBS NO.	
32A	FEED TO 480V BUS DS 480V-DS	1015	52/32A	
32B	DEDICATED SHUTDOWN DIESEL GENERATOR TO 480V BUS DS (ALT POWER) 480V-DS	1016	52/32B	
33A	CONTROL POWER TRANSFORMER (*) CPT/480V-DS	N/A	N/A	
33B	SERVICE WATER PUMP D (ALT POWER) SW-PMP-D	834C	52/33B	
33C	COMPONENT COOLING WATER PUMP A CCW-PMP-A	201	52/33C	
33D	RESIDUAL HEAT REMOVAL PUMPS (ALT POWER) RHR-PMP-A, B	1752	52/33D	
34A	POTENTIAL TRANSFORMER PT/480V-DS	N/A	N/A	
34B	CHARGING PUMP A CHG-PMP-A	161	52/34B	
34C	FEED TO MCC-5 (ALT POWER) MCC-5	N/A	52/34C	
34D	FEED TO PP-51 PP-51	N/A	52/34D	

 Compartment 33A also contains the Charging Pump A total run time meter and the Component Cooling Water Pump A total run time meter.

EDP-002	Rev. 7	Page 10 of 13	

Given the following conditions:

- The unit is experiencing a loss of all feedwater event and FRP-H.1, "Response to Loss of Secondary Heat Sink," has been entered.
- NO AFW flow is available.
- Containment pressure is 0.4 psig.

Which ONE (1) of the following describes when the operator is required to trip the RCPs and immediately initiate feed and bleed?

- a. Five highest core exit TC temperatures are 658 °F, 656 °F, 649 °F, 648 °F, and 645 °F and are all rising
- b. RCS hot leg temperatures are 652 °F, 646 °F, and 648 °F and are all rising
- c. Pressurizer levels are indicating 93%, 97%, and 94% and are all stable
- d. SG wide range levels are 18%, 22%, and 36% and are all stable

Answer:

d. SG wide range levels are 18%, 22%, and 36% and are all stable

QUESTION N TIER/GROUP K/A:	UMBER: : WE05EA2.2	59	RO	1/2	SRO		
	Ability to detern Adherence to a and amendme	mine and inter appropriate pr nts	pret the ocedure	followin is and op	g as they apply to peration within the	o the (Loss o e limitations i	f Secondary Heat Sink n the facility's license
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.7 10	SRO 55.43(b) SRO		
OBJECTIVE:	FRP-H.1-08						
	Given plant co secondary hea	nditions, EVA It sink as direo	LUATE t	the appr steps in	opriate actions to FRP-H.1.	mitigate cor	sequences of a loss o
REFERENCE	S:	FRP-H.1					
SOURCE:	New	Significa	antly Mo	odified		Direct 🚺	3
			Bank	Numbe	r FRP-H.1-03	0	12
JUSTIFICAT <i>a.</i>	ION:	Plausible sind removed fror	ce this w n the RC	vould be CS, but t	an indication tha rigger event is lov	t heat is not l v SG level.	being adequately
b.		Plausible sind removed fror	ce this w n the RC	vould be CS, but t	an indication tha rigger event is lov	t heat is not v SG level.	being adequately
C.		Plausible sin removed fror	ce this v n the R0	would be CS, but t	an indication tha rigger event is lo	t heat is not w SG level.	being adequately
d.	CORRECT	Any 2 SGs b and initiation	elow 26 of feed	% wide and blee	range level requii ed.	es immediat	e tripping of the RCPs
DIFFICULT Comprehe	(: nsive/Analysis	Knov	vledge/l	Recall	X Rating	3	
	Knowledge of	feed and ble	ed initial	tion crite	ria		

REFERENCES SUPPLIED:

1

			Rev. 14				
FRP-H.	.1	RESPONSE TO LOSS OF S			51444 	Page 4 of	E 35
<u></u>		L					
STEP		INSTRUCTIONS		RESP	ONSE NOT OBT	AINED	
		******	****	*****	****	******	**
****		CAUT	<u>ION</u>				
Feed avai:	flow lable.	is not re-established to any	γ fau	ilted S/G	if an intact	S/G is	
****	*****	* * * * * * * * * * * * * * * * * * * *	****	******	* * * * * * * * * * * * *	*******	**
1.	Check THAN ACTIO	Total Feed Flow - LESS 300 GPM DUE TO OPERATOR N		Go To Ste	р3.		
2.	Reset Proce	SPDS And Return To dure And Step In Effect					,
* 3.	Deter Is Re	cermine If Secondary Heat Sink Required As Follows:					
	a. Ch TH PR	neck RCS pressure - GREATER NAN ANY NON-FAULTED S/G RESSURE		a. Reset Entry	SPDS and Go Point C.	To PATH-1	
	b. Ch	neck RCS temperature -		b. Perfor	m the follow	wing:	
	GR	REATER THAN 350°F [310°F]		1) Pla ser	ace RHR Systervice using a	em in Supplement	: I.
				2) WHH RHI res pro ef:	<u>EN</u> adequate is establi set SPDS and pocedure and fect.	cooling wished, <u>THEN</u> return to step in	th 1 5
* 4.	Checl Leve	k Any Two S/G Wide Range ls - LESS THAN 27% [34%]		<u>IF</u> any to decrease <u>THEN</u> Go '	wo S/G Wide to less tha To Step 5.	Range Lev n 27% [34	els %],
				Go To St	ер б.		
5.	Perf	orm The Following:					
	a. S	top all RCPs				····.	-
	b. O S	bserve <u>CAUTION</u> prior to tep 30 and Go To Step 30					
						4,	y

Given the following conditions:

- A unit trip and safety injection have occurred due to a SGTR on 'A' SG.
- EPP-012, "Post-SGTR Cooldown using Backfill," is being implemented.
- RCS pressure is 940 psig.
- It has been determined that the accumulators should be isolated.
- The breakers for the accumulator discharge valves (SI-865A, B, C) have been closed.
- The 'A' accumulator discharge valve (SI-865A) loses light indication after it is given a closed signal.
- 'B' and 'C' accumulator valves stroke closed as expected.

Which ONE (1) of the following actions should be taken regarding 'A' accumulator?

- a. Slow the rate at which the RCS is being depressurized to allow a controlled injection of the accumulator
- b. Drain the accumulator to the Reactor Coolant Drain Tank
- c. Vent the accumulator to Containment atmosphere
- d. Maintain RCS pressure above 800 psig until a Containment entry can be made to locally close the discharge valve

Answer:

c. Vent the accumulator to Containment atmosphere

QUESTION N TIER/GROUP K/A:	IUMBER: : 038EA1.30	60	RO	1/2	SRO	
	Ability to opera containment is	ate and monito	or the fol ns	lowing a	s they apply to a	SGTR: Safety injection and
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	4.0 10	SRO 55.43(b) SRO	
OBJECTIVE:	EPP-012-08					
	Given plant co related to the l	nditions EVA Post-SGTR C	LUATE t	he appro using B	opriate actions to ackfill as directed	mitigate consequences of steps in EPP-12.
REFERENCE	ES:	EPP-12				
SOURCE:	New	Significa	antly Mo	odified	X	Direct
			Bank	Numbe	r EPP-012-08	001
a.	ION.	Plausible sin accident, but	ce the a t vented	ccumula to preve	tors are designed nt nitrogen gas in	to inject into the RCS during an jection into the RCS.
b.		Plausible sin and it does d pressure will	ice this a Irain to tl I still rem	appears t he RCD ⁻ nain in th	to be a method of Γ, but should be v e accumulator du	lowering pressure in accumulator ented, not drained since some e to the nitrogen gas.
с.	CORRECT	Vented to produce to p	event nit ation con	rogen g itinues.	as injection into th	e RCS when the RCS
d.		Plausible sin would delay venting.	the cont	ual isolat inued co	tion would preven poldown and depr	t the accumulator from injecting, but essurization. Procedure directs
DIFFICULTY Comprehe	(: nsive/Analysis	Know	wledge/l	Recall	X Rating	3
	Knowledge o	f actions rega	rding SI	accumu	lators during EPP	implementation

REFERENCES SUPPLIED:

ΈP	Р -	1	2
	*	-	~

POST-SGTR COOLDOWN USING BACKFILL

Rev. 12

Page 6 of 16

٠,

ſ			
-	STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
_	6.	Determine If SI Accumulators Should Be Isolated:	
		a. Check both of the following conditions exist:	a. Go To EPP-17, SGTR With Loss Of Reactor Coolant: Subcooled Recovery.
		 RCS subcooling - GREATER THAN 35°F [55°F] 	
		AND	
		 PZR level - GREATER THAN 10% [32%] 	
	7.	Isolate SI Accumulators As Follows:	
		a. Locally close the breakers for the following valves:	
		 SI-865C, ACCUMULATOR C DISCHARGE (MCC-5, CMPT 9F)
		 SI-865A, ACCUMULATOR A DISCHARGE (MCC-5, CMPT 14F) 	
		 SI-865B, ACCUMULATOR B DISCHARGE (MCC-6, CMPT 10J) 	
		b. Verify all ACCUM DISCHs - CLOSED	b. Vent any unisolated accumulator as follows:
		• SI-865A	 Open the appropriate ACCUM VENT Valves:
		• SI-865B	• SI-853A
		• SI-865C	• SI-853B
			• SI-853C
			2) Open HIC-936, ACC VENT HDR FLOW.

EPP-012-08 001

٠

Given the following plant conditions:

- Plant trip and SI have occurred due to a SGTR on "A" SG
- . EPP-012, "Post-SGTR Cooldown using Backfill" is in progress
- It has been determined that the accumulators should be isolated. The breakers for the accumulator discharge valves (SI-865A, B, C) have been closed.
 - The "A" accumulator discharge valve (SI-865A) loses light indication after it is given a closed signal. "B" and "C" accumulator valves stroke closed as expected.

Which ONE (1) of the following would be the next action?

- A. Continue the RCS Cooldown/Depressurization
- ✓B. Vent the "A" accumulator
 - C. Vent all accumulators
- D. Contact Chemistry to obtain periodic born samples

Given the following plant conditions:

- Following a refueling outage, the unit is being raised to 100% power.
- Reactor Engineering has NOT implemented any power ramp rate limitations other than those stated in GP-005, "Power Operation."

Which ONE (1) of the following power changes would violate the power ramp rate limitations identified in GP-005?

- a. Raising power from 7% to 14% over a 3-minute period
- b. Raising power from 31% to 36.6% over a 1-hour period
- c. Raising power from 62% to 65.8% over a 1-hour period
- d. Raising power from 93% to 96.2% over a 1-hour period

Answer:

c. Raising power from 62% to 65.8% over a 1-hour period

•

QUESTION N TIER/GROUF K/A:	IUMBER: 2: 001A1.06	76	RO	2/1	SRO	
	Ability to predi associated wit	ct and/or mo h operating t	nitor cha he CRD	inges in j S control	parameters (to pre s including: Reacto	vent exceeding design limits) or power
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b	RO) RO	4.1 10	SRO 55.43(b) SRO	
OBJECTIVE:	GP-005-03					
	DEMONSTRA explaining the	TE an under basis of eac	standing h.	of selec	ted steps, caution	s, and notes in GP-005 by
REFERENCE	ES:	GP-005				
SOURCE:	New	Signific	cantly M	odified	X	Direct
			Bank	(Numbe	r GP-005-07	003
JUSTIFICAT a.	ION:	Plausible sir expected ar	Bank nce this i nd accep	t <i>Numbe</i> is the larget table wh	r GP-005-07 gest change, but c ile synchronizing t	003 hanges of this magnitude are he generator to the grid.
JUSTIFICAT a. b.	ION:	Plausible sir expected ar Plausible sir apply above	Bank nce this i nd accep nce this i e 50% pc	is the larget table wh is the larget wer.	r GP-005-07 gest change, but c ile synchronizing t gest non-step char	003 hanges of this magnitude are he generator to the grid. nge (5.6%), but limitations only
JUSTIFICAT a. b. c.	ION: CORRECT	Plausible sir expected ar Plausible sir apply above Power ramp would be a	Bank note this in not accept note this is a 50% po porate lim 3.8% cha	is the larget table wh is the larget ower. hitations a ange over	r GP-005-07 gest change, but c ile synchronizing t gest non-step char are 3.5% per hour er a 1-hour period.	003 hanges of this magnitude are he generator to the grid. nge (5.6%), but limitations only between 50% and 100%. This
JUSTIFICAT a. b. c. d.	ION: CORRECT	Plausible sin expected an Plausible sin apply above Power ramp would be a Plausible sin the highest	Bank nce this i nd accep nce this i 50% po o rate lim 3.8% chi nce this given po	a Numbe is the larget otable wh is the large ower. hitations a ange over exceeds ower level	r GP-005-07 gest change, but c ile synchronizing t gest non-step chan are 3.5% per hour er a 1-hour period. the previous limita I, but the limit is 3.	003 hanges of this magnitude are he generator to the grid. nge (5.6%), but limitations only between 50% and 100%. This ation of 3% per hour (3.2%) and is at 5% per hour.
JUSTIFICAT a. b. c. d. DIFFICULTY Comprehee	ION: CORRECT (: nsive/Analysis	Plausible sin expected ar Plausible sin apply above Power ramp would be a Plausible si the highest	Bank note this in ad accept note this if a 50% point or rate lim 3.8% chi note this given point wiedge/	x Number is the larget otable wh is the larget ower. hitations a ange over exceeds ower levet / Recall	r GP-005-07 gest change, but c ile synchronizing ti gest non-step chan are 3.5% per hour er a 1-hour period. the previous limita al, but the limit is 3.	003 hanges of this magnitude are he generator to the grid. nge (5.6%), but limitations only between 50% and 100%. This ation of 3% per hour (3.2%) and is at 5% per hour.

REFERENCES SUPPLIED:

- 5.8 During start-up and loading of the Turbine, S/G water level is very unstable and has a tendency to swell. S/G levels should be maintained from 40% to 50% on narrow range level indication for better control. The wide range and narrow range tend to disagree slightly when there is a transient level condition. Wide range level indication should be used to observe which direction the level is moving. If the narrow range level approaches the High or LO-LO Level trip point, Turbine loading should be stopped until S/G level recovers. Wide swings in Feedwater Regulating Valve positions, in the open or closed direction, should be avoided, as this can cause water level to shrink or swell out of control. Sustained Turbine operation at less than 5% of rated load should be avoided.
- 5.9 The Feedwater Regulating Valves FCV-478, FCV-488, FCV-498, and Rod Control should be placed in MANUAL when switching Turbine first stage pressure channels. The Feedwater Regulating Valves FCV-478, FCV-488, FCV-498, should be placed in MANUAL when switching steam flow channels, or feedwater flow channels.
- 5.10 For Turbine startups and scheduled load changes the heatup and loading rates specified in Curves 7.8, 7.9, and 7.10 should be adhered to.
- 5.11 Power Ramp Rate Limits are restricted after core fuel movement to 3.5%/hr from 50% to 100% power. During subsequent power increases, this ramp limit may apply depending on the maximum power level achieved and length of operation at that power level. (ESR 98-00395)
- 5.12 The RCS Design Basis Document states that the PZR Spray Valves are designed to prevent PZR pressure from reaching the lift setpoint of the PZR PORVs following a step reduction of 10% of full power under automatic Reactor control during normal plant operations. Normal loading and unloading is 5% of full power per minute. Operability Determination 95-015 Rev 2 identifies that when one PZR Spray Valve is out of service, step changes should be limited to 5% of full power to reduce the potential for challenging the PZR PORVs. (CAPS Project CR 95-02365)
- 5.13 Exhaust hood temperature should not be allowed to exceed 175 °F with exhaust hood spray out of service. If the temperature cannot be reduced to less than 175 °F, the unit should be shutdown and the trouble corrected. The maximum exhaust hood temperature permitted for short periods of time is 250 °F. A Generator Lockout will occur if the exhaust hood temperature is 225 °F for areater for 5 minutes.

GP-005	Rev. 66	Page 9 of 67

GP-005-07 003

Given the following plant conditions:

- Following a refueling outage, the reactor was operated at full power for 118 days
- Then shutdown for 35 days for required maintenance
- A plant startup has been performed to 20% power

What RATE LIMITS, if any, apply to the REACTOR POWER INCREASE from 20% to full power?

- A. 5% per minute
- \checkmark B. 3% per hour
 - C. 3% per minute
 - D. 10% per hour

.

Given the following conditions:

- The reactor has tripped from 100% power due to a feed line break.
- SI has been actuated.
- AFW pumps are supplying feed to the SGs.
- Immediate operator actions are complete.
- Foldout A has been implemented.
- The Outside AO reports a large leak at the CST.

Which ONE (1) of the following describes the available backup sources to the AFW Pump Suction?

	PREFERRED BACKUP	ALTERNATE BACKUP
a.	Service Water	Deepwell Water
b.	Service Water	Fire Water
C.	Deepwell Water	Service Water
d.	Fire Water	Service Water

Answer:

a.	Service Water	Deepwell Water				
						RNP NRC Written Examination RO Only Question Reference
--	---------------------------------	--	--	--	---	---
	IUMBER:	77				
TIER/GROUF	061K1 07		RO	2/1	SRO	
	Knowledge e	f the physical a	onnoofi		lan an in a ffa at wal	-theorem is a second second second
	the following	systems: Emer	gency v	vater so	urce	ationships between the AFVV and
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.6 4	SRO 55.43(b) SRO	
OBJECTIVE:	AFW-05					
	DESCRIBE th	ne performance	and de	esign attr	ibutes of the major	AFW System components.
REFERENCE	S:	EPP-Foldout / OP-402	4			
SOURCE:	New	Significal	ntly Mc	dified	X	Direct
			Bank	Number	AFW-02	002
JUSTIFICATI a.	ON: CORRECT	Both Service V	Bank . Nater a kup sou	<i>Number</i> nd Deep rce.	AFW-02	002 used with Service Water being the
JUSTIFICATI a. b.	ON: CORRECT	Both Service N preferred back Plausible since a backup sour	Bank A Water a kup sou e Servic rce.	<i>Number</i> nd Deep rce. ce Water	AFW-02 well water can be	002 used with Service Water being the ackup source, but Fire Water is not
JUSTIFICATI a. b. c.	ON: CORRECT	Both Service N preferred back Plausible since a backup sour Plausible since Water is the pl	Bank A Water a kup sou e Servic rce. e both S referrec	Number nd Deep rce. ce Water Service \ 5 backup	AFW-02 well water can be is the preferred ba Nater and Deepwe source.	002 used with Service Water being the ackup source, but Fire Water is not Il water can be used, but Service
JUSTIFICATI a. b. c. d.	ON: CORRECT	Both Service V preferred back Plausible since a backup sour Plausible since Water is the pl Plausible since source.	Bank A Water a kup sou e Servic ce. e both S referred	Number nd Deep rce. ce Water Service \ d backup ce Water	AFW-02 well water can be r is the preferred ba Nater and Deepwe source.	002 used with Service Water being the ackup source, but Fire Water is not Il water can be used, but Service e, but Fire Water is not a backup
JUSTIFICATI a. b. c. d. DIFFICULTY: Comprehens	ON: CORRECT sive/Analysis	Both Service V preferred back Plausible since a backup sour Plausible since Water is the pl Plausible since source.	Bank A Water a Kup sou e Servic referrec e Servic	Number nd Deep rce. ce Water Service \ d backup ce Water	AFW-02 well water can be r is the preferred ba Nater and Deepwe source.	002 used with Service Water being the ackup source, but Fire Water is not Il water can be used, but Service e, but Fire Water is not a backup

REFERENCES SUPPLIED:

	CONTINUOUS USE
	FOLDOUT A
	(Page 1 of 6)
1.	RCP TRIP CRITERIA
	IF BOTH conditions below are met, THEN stop all RCPs:
	 SI Pumps - AT LEAST ONE RUNNING AND CAPABLE OF DELIVERING FLOW TO THE CORE
	• RCS Subcooling - LESS THAN 35°F [55°F]
2.	SI ACTUATION CRITERIA
	<u>IF EITHER</u> condition below occurs, <u>THEN</u> Actuate SI and Go To PATH-1, Entry Point A:
	• RCS Subcooling - LESS THAN 35°F [55°F]
	 PZR Level - CAN <u>NOT</u> BE MAINTAINED GREATER THAN 10% [32%]
3.	SPRAY ACTUATION CRITERIA
	<u>IF</u> a valid CV Spray Signal occurs, <u>THEN</u> dispatch an Operator to the Safeguards Racks to block CV Spray as follows: (A screwdriver is available locally for opening the panels)
	a. At the front of Safeguards Relay <u>Rack 51</u> , rotate Test Switch Number 5 (PC-951A) to the PUSH TO TEST position.
	b. At the front of Safeguards Relay <u>Rack 63</u> , rotate Test Switch Number 5 (PC-951A) to the PUSH TO TEST position.
4.	AFW SUPPLY SWITCHOVER CRITERIA
	<u>IF</u> CST level decreases to less than 10%, <u>THEN</u> switch to backup water supply using OP-402, Auxiliary Feedwater System.

- 5.5 Starting an AFW pump to fill S/Gs when the S/Gs are in Wet Layup on Recirculation could result in overpressurization of the S/G Wet Layup System.
- 5.6 **IF** HVH-7A is inoperable, **THEN** MDAFW B will be inoperable. **IF** HVH-7B is inoperable, **THEN** MDAFW A will be inoperable.
- 5.7 Backup water supply valves from both the Service **AND** Deepwell Water are to be normally closed with the telltale valve between each of the two block valves open to insure that no untreated water enters the plant cycle during normal operation. **IF** backup water is required, **THEN** Service Water is the primary backup and Deepwell water a secondary backup.
- 5.8 When using the deepwell pumps as a backup supply to the AFW Pumps, maximum **TOTAL** allowable feed rates for various combinations of AFW Pumps vs. deepwell pumps in operation have been established. The flow rates are based on 200 gpm per deepwell pump **AND** assumes 90 gpm seal leakoff flow, 165 gpm recirc flow for the SDAFW Pump, **AND** 60 gpm recirc flow for each MDAFW Pump. These flow rates are to prevent runout **AND** possible damage to the deepwell pumps.
- 5.9 **IF** the CST level decreases to 10% during AFW operation, **THEN** a backup water supply should be placed in service. Service Water should be used as first backup supply to AFW Pumps. **IF** Service Water is not available, **THEN** Deepwell Water should be used as backup to AFW Pumps.
- 5.10 The proper sequence to follow when securing a MDAFW Pump is, first, stop the pump, allow it to stop rotating, then close the motor operated discharge valves (V2-16A, V2-16B, V2-16C). This sequence will allow proper seating of the check valves **AND** allow the discharge valves to fully seat which prevents back leakage through all these valves.
- 5.11 A possible consequence of check valve or discharge valve backleakage is steam binding of the AFW Pumps. Steam binding of the MDAFW Pumps may be indicated by warm discharge piping between the discharge check valve(s) AND the V2-16(s). Steam binding of the SDAFW Pump may be indicated by a warm pump casing. IF steam binding of any of the AFW Pumps is suspected, THEN refer to the Infrequent Operation section of this procedure.
- 5.12 The Condensate Storage Tank should be maintained full to provide a maximum available water supply.
- 5.13 **IF** the CST level is decreasing , **THEN** prior to reaching 34%, the reliability of the MDAFW Pumps **AND** power supplies shall be evaluated. Starting the SDAFW Pump to ensure its availability should be considered. The SDAFW Pump should be used to feed the S/Gs but can be operated on recirculation.

OP-402	Rev. 52	Page 6 of 62
•••		

AFW-02 002

Given the following plant conditions:

- The reactor has tripped from 100% power due to a feed line break
- SI has been actuated
- AFW pumps are supplying feed to the S/G's
- Immediate operator actions are complete
- Foldout A has been implemented
- The Outside AO reports a large leak at the CST

Which ONE (1) of the following describes the available supply sources to the AFW Pump Suction?

- A. CST, Hotwell
- B. Circulating Water, Service Water
- C. Deepwell Water, Fire Water
- ✓D. Deepwell Water, Service Water

Question: 78

Given the following conditions:

- A turbine runback has occurred from 100% to 70% power.
- RCS Tavg is 567 °F.
- PZR Pressure is 2265 psig.
- PZR Level is 51%.

Which ONE (1) of the following describes the expected condition of the proportional heaters and pressurizer spray valves?

	PROPORTIONAL HEATERS	SPRAY VALVES
a.	On	Open
b.	On	Closed
C.	Off	Open
d.	Off	Closed

Answer:

a.	On	Open

QUESTION N TIER/GROUP K/A:	IUMBER: ?: 027AK2.03	78	RO	1/1	SRO		
	Knowledge of positioners	the interrelation	ons betw	een the	Pressurizer Press	ure Control Controllers and	
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	55.41(b)	RO RO	2.6 7	SRO 55.43(b) SRO		
OBJECTIVE:	PZR-09						
	EXPLAIN the r instrumentatio	normal opera n, interlocks,	tion of the annuncia	e PZR a ators, ar	nd PRT control system of setpoints.	stems. Include function,	
REFERENCE	ES:	SD-059					
SOURCE:	New	Signific	antiy Mc	odified	X	Direct	
			Bank	Numbe	r AOP-019-08	002	
JUSTIFICAT <i>a</i> .	ION: CORRECT	Heaters are open due to	on due to a high de	o level b eviation	eing more than 5% signal of more thar	above program and spray n 25 psid.	s are
b.		Plausible sin sprays shou	nce heate Id be ope	ers are c en due te	n due to being mol o a high deviation s	re than 5% above program, signal of more than 25 psid.	but
с.		Plausible sir psid, but hea	nce spray aters sho	vs are op ould be c	pen due to a high d In due to being mo	leviation signal of more than re than 5% above program.	n 25
d.		Plausible sir pressure co	nce heate ndition, b	ers woul out shou	d normally be expe ld be on due to leve	ected to be off due to the hig el deviation.	зh
DIFFICULTY Comprehei	(: nsive/Analysis	X Kno	wledge/l	Recall	Rating	3	

REFERENCES SUPPLIED:

5.1.6 PZR Level Control Setpoints 1. Level program as function of T_{avg} (TM-459) for T_{avg} 547°F 22.2% for T_{avg} 575.4°F 53.3% (Program is linear from 547°F to 575.4°F) Low limit 22.2% High limit 53.3% 2. Low-Low Level Heater Cutout

(LC-459C, LC-460C)

بهدور ويها المراجعة

3. Level Controller (LC-459F) 10% charging pump Proportional gain speed/% level deviation Reset time constant 430 seconds
4. Letdown Valve Isolation 14.4% of level span

5. Back-up Heaters on

6.0 SYSTEM OPERATION

6.1 Normal Operation

Insurge of RCS Coolant - produced by increase in T_{avg} . An insurge of coolant will reduce volume of the steam bubble causing an increase in the temperature and pressure of the steam. The steam space or bubble becomes superheated and some minor condensation occurs at surface and on walls.

22.2% of level span

53.3% of level span

22.2% of level span

53.3% of level span

14.4.% of level span

+5% of programmed level

The increased pressure causes the spray valve to open which cools and condenses a part of the steam bubble, thereby reducing pressure.

The increase in level will energize backup heaters if the level increases to 5% above program.

Outsurge of RCS Coolant

An outsurge of RCS coolant will increase the volume of the steam bubble, which will cause water to flash to steam, limiting the pressure decrease.

Proportional heaters will be full on to limit pressure decrease. If pressure decrease is

_	
-	
•	Z.R.
-	

Page 21 of 27

Revision 2

INFORMATION USE ONLY

SD-059

 $\frac{2235 - 1700}{800} * 10 = 6.69$ on the 10 turn pot.

The output of PC-444J (setpoint signal) is sent to PC-444A to be compared to the actual pressure. PC-444A has a gain of 2 which effectively cuts in half the range of control of PZR pressure to 400 psi around the setpoint determined by PC-444J. The controller output is then directed to the proportional heaters, spray valves via controllers PC-444C and PC-444D, backup heaters, PZR PORV 456 and PI-458 and is displayed on the meter on PC-444J

The components operated by PC-444A operate at fixed deviation from setpoint or controller output as observed on the meter on PC-444J, no matter what setpoint is dialed in on PC-444J. For example the backup heaters are set to turn on 25 psi below set pressure. If set pressure is 2235 psig, their setpoint would be 2210 psig and the control output when they came on would be as follows:

 $\frac{2210-2035}{400} = .4375 \text{ or } 43.75\% \text{ demand}$

If the pot on PC-444J were then set at 6.25 this would give a set pressure of 2200 psig. When the output of PC-444A was at 43.75% the backup heaters would come on, pressure would be 2175 psig; 25 psi below set pressure. The setpoints normally listed for heater, spray, and PCV-456 setpoints are based on a set pressure of 2235 psig where PC-444J is normally set.

As stated before, PC-444A is a Proportional + Integral controller, therefore controller output may not correspond exactly to the pressure monitored by operator. If pressure is away from setpoint for an extended period of time the controller output may saturate while increasing its output trying to return pressure to setpoint.

5.1.2 PZR Pressure Control Setpoint

(PZR-Figure 10)

1.	PZR Pressure Controller (PC-444A) Proportional gain Reset time constant Rate time constant Pressure set point, Pref	2 12 sec off 2235 psig
2.	Spray Valve Controllers (PC-444C, PC-444D) Proportional gain in % spray valve Lift per psi	2%/psi

PZR

Page 18 of 27

<u>i</u>

Revision 2

INFORMATION USE ONLY

	Set point where spray is initiated on compensated pressure signal from	+25 psi (2260 psig)
	PC-444A Setpoint where spray is full open	+75 (2310 psig)
3.	Variable Heater Controller Proportional gain in % heating power Set point where proportional heating is full on on signal from PC-444A	-3.33%/psi per psi -15 psi (2220 psig)
	Setpoint where proportional heating is full off	+15 psi (2250 psig)
4.	Power Relief Valve, PCV-455C operating on compensated pressure signal from PC-444A to PC-444B	+100 (2335 psig)
5.	Back-up heater turned on, on compensated pressure signal from PC-444A to PC-444F	-25 psi (2210 psig)
	Back-up heaters turned off	-15 psi (2220 psig)
6.	Power Relief Valve (PCV-456) operated on actual pressure (PC-445A)	2335 psig

5.1.3 PZR PORV Control (PZR-Figure 8 & PZR-Figure 13)

The PZR PORVs have two modes of control, Normal and Low Temperature Overpressure Protection (LTOPP). In normal mode the PORVs have a permissive of 2000 psig to open in Automatic. This "permissive" is supplied by the protection channels meeting a 2/3 logic. As stated before PCV-456 receives its signal from PT-445 set at 2335 psig and PCV-455C receives its signal from PC-444A at +100 psi which is nominally 2335 psig also. When the key switch for OVERPRESSURE PROTECTION on the RTGB is place in the LOW PRESSURE position (one switch for each PORV) the input to each PORV is shifted to the LTOPP controller.

5.1.4 Low Temperature Overpressure Protection Control (LTOPP) (PZR-Figure 13)

LTOPP control is required to be activated when the RCS is cooled down below 360°F to minimize Pressurized Thermal Shock (PTS) concerns. The LTOPP controller uses the lowest of TE-410, TE-420 and TE-430 to determine RCS temperature and pressure as sensed by PT-500 and PT-501. The lift setpoint is variable based upon auctioneered low RCS temperature. At an RCS temperature of 350°F, the pressure setpoint is 400 psig. The setpoint of the Comparators PC502 and PC503 are increased as RCS temperature is increased. The setpoint will not decrease below 400 psig.

PZR

Page 19 of 27

Revision 2

INFORMATION USE ONLY

SD-059

1.1.1.

AOP-019-08 002

The unit is at power and a transient occurred. RCS pressure is below normal, the crew has implemented AOP-019, Malfunction Of RCS Pressure Control. They are at the point in the procedure that asks if the master pressure controller PC-444J is operating properly in AUTO. What is the correct response for the master pressure controller PC-444J based on current plant conditions?

- A. heaters off and sprays open
- B. heaters off and sprays shut
- C. heaters on and sprays open
- \checkmark D. heaters on and sprays shut

Question: 79

Following an accident, FRP-C.2, "Response to Degraded Core Cooling," is being implemented.

After the performance of several steps in FRP-C.2, the following Critical Safety Function Status Tree (CSFST) conditions are noted:

- Integrity RED
- Core Cooling RED
- Containment ORANGE
- Heat Sink YELLOW
- Subcriticality YELLOW
- Inventory YELLOW

Which ONE (1) of the following describes which action should be taken by the CRSS?

- a. Remain in FRP-C.2, "Response to Degraded Core Cooling," until completion and then recheck the CSFSTs
- b. Transition to FRP-C.1, "Response to Inadequate Core Cooling" due to the RED condition on Core Cooling
- c. Transition to FRP-P.1, "Response to Imminent Pressurized Thermal Shock," due to the RED condition on Integrity
- d. Transition to FRP-J.1, "Response to High Containment Pressure," due to the ORANGE condition on Containment

Answer:

b. Transition to FRP-C.1, "Response to Inadequate Core Cooling" due to the RED condition on Core Cooling

						RNP NRC Written Examination
		70				
TIER/GROUP	IUMBER: P:	79	RO	3	SRO	
K/A:	2.4.22					
	Knowledge of	the bases for p	orioritizi	ing safe	ty functions during	abnormal/emergency operations.
			PA	3.0	SRO	
10CFR55 CO	NTENT:	55.41(b)	RO	10	55.43(b) SRO	
OBJECTIVE:	OMM-022-09					
	DETERMINE	the different flo	owpaths	s genera	ated by OMM-022.	
DEEEDENOS		OMM 022				
NEF ENERGE		0141141-022				
SOURCE:	New	X Significa	ntly M	odified		Direct
SOURCE:	New	X Significa	ntly Mo Bank	odified Numbe	er 🗌	Direct
SOURCE:	New	X Significa	Bank	odified Numbe	eing performed in	Direct
SOURCE: JUSTIFICAT <i>a.</i>	New	X Signification Signification Plausible since Core Cooling, in response to	Bank Bank E FRP- but FF o the we	odified Numbe -C.2 is b RP-C.1 h orsening	eing performed in has additional action condition.	Direct NEW response to an ORANGE path on ons which will need to be performed
SOURCE: JUSTIFICAT a. b.	New	X Significat Plausible sinc Core Cooling, in response to The highest F	Bank Bank E FRP- but FF bothe wo RED pa	odified Numbe -C.2 is b RP-C.1 h orsening th shoul	eing performed in nas additional action condition. d be addressed fir	Direct NEW response to an ORANGE path on ons which will need to be performed rst and Core Cooling has a higher
SOURCE: JUSTIFICAT a. b.	New	X Significat Plausible sinc Core Cooling, in response to The highest F priority than In	Bank Bank Bank Bank Bank Bank Bank Bank	odified Numbe -C.2 is b RP-C.1 h orsening th shoul	eing performed in nas additional action condition. d be addressed fir	Direct
SOURCE: JUSTIFICAT a. b. c.	New	X Signification Plausible since Core Cooling, in response to The highest F priority than In Plausible since	Bank Bank ce FRP- , but FF o the wo RED pa ntegrity ce Integ	odified Numbe -C.2 is b RP-C.1 h orsening th shoul	eing performed in has additional action condition. d be addressed fir RED path, but Co	Direct
SOURCE: JUSTIFICAT a. b. c.	New	X Signification Plausible since Core Cooling, in response to The highest F priority than In Plausible since	Bank Bank ce FRP- but FF bothe wo RED paintegrity ce Integ	odified Numbe -C.2 is b RP-C.1 h orsening th shoul	er eing performed in has additional action g condition. d be addressed fir RED path, but Co	Direct
SOURCE: JUSTIFICAT a. b. c. d.	New	X Signification Plausible since Core Cooling, in response to The highest F priority than In Plausible since Plausible if a the highest pr	mtly Ma Bank ce FRP, but FF o the wo RED pa ntegrity ce Integ miscon riority a	odified Numbe -C.2 is b RP-C.1 h orsening th shoul grity is a neeption re RED	eing performed in has additional action condition. d be addressed fir RED path, but Co exists that ORANG paths.	Direct NEW response to an ORANGE path on ons which will need to be performed rest and Core Cooling has a higher ore Cooling has a higher priority. GE paths are a higher priority, but
SOURCE: JUSTIFICAT a. b. c. d.	New	X Signification Plausible since Core Cooling, in response to The highest F priority than In Plausible since Plausible if a the highest pr	<i>mtly Me</i> <i>Bank</i> ce FRP, but FF o the wo RED pa ntegrity ce Integ miscon riority a	odified Numbe -C.2 is b RP-C.1 h orsening th shoul th shoul resention re RED	eing performed in has additional action condition. d be addressed fir RED path, but Co exists that ORANG paths.	Direct NEW response to an ORANGE path on ons which will need to be performed rst and Core Cooling has a higher ore Cooling has a higher priority. GE paths are a higher priority, but
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Compreher	New ION: CORRECT	X Signification Plausible since Core Cooling, in response to The highest F priority than In Plausible since Plausible if a the highest priority Know	<i>ntly Me</i> Bank ce FRP, but FF o the wo RED pa ntegrity ce Integ miscon riority a	odified Numbe -C.2 is b RP-C.1 h orsening th shoul th shoul grity is a neeption re RED	eing performed in has additional action g condition. d be addressed fir RED path, but Co exists that ORANG paths. Rating	Direct NEW response to an ORANGE path on ons which will need to be performed rst and Core Cooling has a higher re Cooling has a higher priority. GE paths are a higher priority, but
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	New	X Signification Plausible since Core Cooling, in response to The highest F priority than In Plausible since Plausible if a the highest priority CSFST to dete	<i>ntly Ma</i> <i>Bank</i> ce FRP- b but FF b the wo RED par ntegrity ce Integ miscon riority a <i>dedge/</i> ermine	odified Numbe -C.2 is b RP-C.1 h orsening th shoul : grity is a neeption re RED Recall highest	er eing performed in has additional action g condition. d be addressed fir RED path, but Co exists that ORANG paths. Reting priority	Direct INEW INEW INEW INEX INES INES INES INES INES INES INES INES

.

REFERENCES SUPPLIED:

.

8.2.6 (Continued)

- 3. Monitoring of the Critical Safety Function Status Trees takes place in accordance with its own rules of usage, in parallel with the recovery actions being performed by the Operator. The monitoring may be done directly by one of the Operators in the control room or by some other member of the shift assigned to the control room (normally the STA).
- 4. Monitoring is accomplished by use of the Safety Parameter Display System (SPDS) feature of the ERFIS computer or by use of the manual status boards. The CRSS is the designated primary SPDS user while the Shift Technical Advisor is available to assist the CRSS as the secondary SPDS user.
- 5. Status Trees ask a series of questions about plant conditions, and in general, each question asked depends on the answer to the previous question. This dependency results in a branching pattern, which is referred to as a "tree."
- 6. There are six different trees, each one evaluating a separate safety aspect (Critical Safety Function) of the plant. At any given time, a Critical Safety Function status is represented by a single Path through its tree. Since each Path is unique, it is uniquely labeled at its end point, or terminus. This labeling consists of color-coding of the terminus and possible transition to an appropriate FRP, if required by that safety status. If the status is normal for a particular Critical Safety Function, no transition is specified, and the condition is clarified by the words CSF-SAT.
- 7. Color-coding can be either RED, ORANGE, YELLOW, or GREEN, with GREEN representing a "SAT" safety status. Each non-green color represents an action level that should be addressed according to the Rules of Priority for Status Tree Use.
- 8. Several special conditions also affect the CSFSTs indicated by ERFIS:
 - All CSFSTs are forced to a GREEN-condition when the plant mode is Cold Shutdown.
 - The Heat Sink Tree is forced to a GREEN-condition when the plant is less than 350°F.

		D 47.550
01/11/000	Rov 17	
OMM-022		
•••••	· · · · · · · · · · · · · · · · · · ·	

8.2.6.8 (Continued)

- The Subcriticality Tree is forced to a GREEN-condition when the plant mode is Power Operation or Hot Shutdown except:
 - When in the Power Operation mode, the actual Critical Safety Function Status will be displayed if the Reactor Trip and Bypass Breakers are open.
 - When in any mode, the actual Critical Safety Function Status will be displayed if a trip condition exists (as determined from Reactor Protection System inputs).
- 9. The six Status Trees are always evaluated in the following sequence (order of priority):
 - 1) Subcriticality (S)
 - 2) Core Cooling (C)
 - 3) Heat Sink (H)
 - 4) Integrity (P)
 - 5) Containment (J)
 - 6) Inventory (I)
- 10. If identical color priorities are found on different trees during monitoring, the required action priority is determined by the above sequence. For example, a RED-condition on the Subcriticality Tree takes priority over a RED-condition on Core Cooling Tree.
- 11. The user begins monitoring with the Subcriticality Tree. Questions are answered based on plant conditions at the time, and the appropriate branch line followed to the next question. An individual Status Tree evaluation is complete when the user arrives at a color-coded terminus. With the exceptions noted below, the color and instructions of the terminus are noted and the user continues to the next tree in sequence.
 - a. If any RED terminus is encountered, the operator is required to immediately stop any Path or EPP in progress, and to perform the Function Restoration Procedure (FRP) required by the terminus.

OMM-022	Rev. 17	Page 18 of 50
---------	---------	---------------

8.2.6 (Continued)

- 15. Following FRP implementation, a YELLOW-condition might indicate a residual off-normal condition. The Operator is allowed to decide whether or not to implement any YELLOW-condition FRP.
- 16. When using the SPDS to monitor the CSFSTs, the "SPDS Reset" feature must be used <u>prior to</u> initiating CSFST monitoring. SPDS software "locks in" the highest priority condition occurring during the transient, regardless of whether or not the condition is still present.
- 17. The only requirement of the monitoring function is that the CRSS in charge of recovery actions be immediately informed of RED or ORANGE-conditions, and regularly advised of YELLOW or GREEN-conditions.
- 18. The Path or EPP actions in progress are suspended if either a RED or ORANGE-condition is detected on a Status Tree. Path or EPP actions are not to be performed while a Critical Safety Function is being restored from a RED or ORANGE-condition, unless required by the FRP in effect. Conversely, in a few cases, the FRPs are not performed while certain EPPs are in effect. These cases will be explicitly noted in the EPP.
- 19. After restoration of any Critical Safety Function from a RED or ORANGE-condition, recovery actions may continue when the FRP is complete. Most often, the FRP will return the Operator to the suspended Path or EPP. At times, an FRP will require a transition to a different Path or EPP because of conditions created within the FRP.
- 20. Upon continuation of recovery actions, some judgement is required by the Operator to avoid inadvertent reinstatement of a RED or ORANGE- condition by undoing some critical step in a Function Restoration Procedure. The plant recovery procedures are optimal in assuming that equipment is available when required. The appearance of a RED or ORANGE-condition in most cases implies that some equipment or function required for safety is not available, and some adjustment may be required in the recovery procedures.

OMM 022	Rev 17	Page 20 of 50
0101101-022		<u>_</u>

Question: 80

Given the following conditions:

- A reactor trip has occurred from 100% power.
- All SGs levels indicate 6%.

Upon initiation of AFW, which ONE (1) of the following correctly describes the automatic response of the AFW system to these conditions?

- a. The normally closed MDAFW pump discharge flow control valves (FCV 1424 and 1425) fully open
- b. The normally open SDAFW pump discharge flow control valve (FCV 6416) throttles closed
- c. The normally closed SDAFW pump discharge flow control valve (FCV 6416) throttles open
- d. The normally open MDAFW pump discharge flow control valves (FCV 1424 and 1425) throttle closed

Answer:

b. The normally open SDAFW pump discharge flow control valve (FCV 6416) throttles closed

QUESTION N TIER/GROUP K/A:	UMBER: : 061A3.03	80	RO	2/1	SRO	
	Ability to moni start	tor automatic c	operation	of the <i>i</i>	AFW, including: A	AFW S/G level control on automatic
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.9 4	SRO 55.43(b) SRO	
OBJECTIVE:	AFW-09					
	EXPLAIN the interlocks, anr	normal operation nunciators, and	on of the I setpoin	e AFW c ts.	ontrol systems. I	Include function, instrumentation,
REFERENCE	S:	SD-042				
SOURCE:	New	Significa	ntly Moo	dified		Direct X
	•••		Bank N	lumber	AFW-10	023
JUSTIFICATI a.	ON:	Plausible sinc	e FCV-1	424 & 1	425 are normally	closed, but the valves do not fully
h		and the valves	he pump s throttle	os are si to main	tarted, the discha tain flow rate at t	rge flow control loops are energized he setpoint.
v.	CORRECT	and the valves The normally start.	he pump s throttle open val	os are si to main ve FCV	tarted, the discha tain flow rate at t -6416 will throttle	arge flow control loops are energized he setpoint. to maintain desired flow on a pump
с.	CORRECT	The normally start. Plausible sinc open.	ne pump s throttle open val e FCV-6	os are si to main ve FCV 416 doe	tarted, the discha tain flow rate at t -6416 will throttle	arge flow control loops are energized he setpoint. to maintain desired flow on a pump ntain desired flow, but it is normally
с. d.	CORRECT	 open. When a values and the values The normally start. Plausible sinc open. Plausible sinc the values are 	e FCV-6 e FCV-6 normall	os are si to main ve FCV 416 doe 424 and y closed	tarted, the discha tain flow rate at t -6416 will throttle es throttle to main t FCV-1425 do th	arge flow control loops are energized the setpoint. to maintain desired flow on a pump ntain desired flow, but it is normally nrottle to maintain desired flow, but
c. d. DIFFICULTY: Comprehen	CORRECT sive/Analysis	 The normally start. Plausible sinc open. Plausible sinc the valves are Manual Knowles 	e FCV-6 e FCV-6 normall	os are si to main ve FCV 416 doe 424 and y closed	A FCV-1425 do the train flow rate at the dischange of the term of term	arge flow control loops are energized he setpoint. to maintain desired flow on a pump ntain desired flow, but it is normally nrottle to maintain desired flow, but

REFERENCES SUPPLIED:

~

3.3 Control Valves

The AFW system contains an automatic electrohydraulic flow control valve for each MDAFW pump and the SDAFW pump. Each valve's controller is located in the control room and all other components are located in proximity to their respective pump. These valves and their associated controls are used to set AFW pump discharge flowrate and automatically maintain the rate as S/G pressure varies. These valve provide flow control for the AFW system and NPSH (anti-cavitation) protection for the pumps.

These control valves have electrohydraulic actuators which can be automatically positioned based upon the respective AFW pump discharge flow.

A local manual operator is provided for operating the control valve in the event that the control system fails. The control system can also be operated in manual from the RTGB. If RCS temperature is greater than 350°F, then using manual places the plant in a Tech Specs LCO action statement (3.7.4).

MDAFW pump discharge flow control valves (1424 and 1425) control the flow from each MDAFW pump to the S/Gs. These normally closed valves begin to open when the MDAFW pumps are started. The valves "fail-closed" on loss of electric power or loss of control signal. FCV-1424 is powered from IB#2 and FCV-1425 from IB#3. In modes 1, 2 and 3 each control valve is normally in AUTO and set at 325 gpm. When the RCS temperature is \leq 350°F, these controllers shall be in Auto and set to a flowrate of 100 gpm.

SDAFW pump discharge flow control valve (6416) controls the flow from the SDAFW pump to the S/Gs. This normally open valve begins to adjust when the SDAFW pump is started. This valve will "fail-open" on a loss of electrical power or loss of the control signal. FCV-6416 is powered from LP-26. In modes 1, 2 and 3, FCV-6416 is normally in AUTO and set at 500 gpm.

4.0 **INSTRUMENTATION**

4.1 AFW (AFW) Flow Indication System

There are three dual flow edge meters - 0-500 gpm, one per S/G for the MDAFW pumps and SDAFW pump, located on RTGB.

S/G 1 Aux. Feedwater Flow (Motor Driven)	FI-1425A FI-1426A
S/G 1 Aux. Feedwater Flow (Steam Driven) S/G 2 Aux. Feedwater Flow (Motor Driven)	FI-1425B
S/G 2 Aux. Feedwater Flow (Steam Driven) S/G 3 Aux. Feedwater Flow (Motor Driven)	FI-1426B FI-1425C
S/G 3 Aux. Feedwater Flow (Steam Driven)	FI-1426C

Page 14 of 37

Question: 96

Given the following conditions:

- The unit is operating at 30% power.
- A dropped control rod has just been re-aligned.
- While attempting to reset the Rod Control Urgent Failure alarm, the operator inadvertently pushes the Rod Control STARTUP button.

Which ONE (1) of the following describes the effect of operating the incorrect button?

- a. All Control Bank control rods drop into the core, causing an automatic reactor trip
- b. All rods, including Control Bank and Shutdown Bank rods, drop into the core, causing an automatic reactor trip
- c. All rods remain in their current position and there is **NO** effect on the Rod Control System circuitry
- d. All rods remain in their current position, but the Rod Control System circuitry senses all rods are fully inserted

Answer:

d. All rods remain in their current position, but the Rod Control System circuitry senses all rods are fully inserted

					RNP NRC Written Examinatio RO Only Question Reference	n æ
		96			·	
TIER/GROUF		RO	2/1	SRO		
K/A:	001K6.11					
	Knowledge of detection (trou	the effect of a loss able alarms) and rea	or malfund set system	tion on the Locatior , including rod conti	n and operation of CRDS fault rol annunciator	
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	RO 55.41(b) RO	2.9 6	SRO 55.43(b) SRO		
OBJECTIVE:	RDCNT-07					
	EXPLAIN the	purpose and location	on of the R	od Control System	controls and indications.	
REFERENCE	ES:	SD-007				
SOURCE:	New	Significantly	Modified		Direct X	
JUSTIFICAT	ION:	Da	nik numbe			
a.		Plausible since im into core, but oper	proper oper rated butto	eration of correct bu n only resets startin	tton could result in rods dropping g points for rod control circuitry.	
b.		Plausible since im into core, but oper	proper oper rated butto	eration of correct bu n only resets startin	tton could result in rods dropping g points for rod control circuitry.	
С.		Plausible if miscol is normally only of starting points for	nception th perated pri rod contro	at effect is nothing i or to withdrawing a l circuitry.	f performed at power since button ny rods, but operated button resets	
d.	CORRECT	Operating button a control such that o	at power d circuitry se	oes not affect actua nses rods are at "fu	I rod position, but resets rod Il inserted" position.	
DIFFICULT Comprehe	(: nsive/Analysis	Knowledg	ge/Recall	X Rating	3	
	Knowledge o	f the function of roo	d control sy	stem controls		

REFERENCES SUPPLIED:

SD-007

selected in the manual mode.

CONTROL BANK B

Control Bank B rods can be moved manually using the IN-HOLD-OUT lever. The bank overlap program is overridden. The rod speed signal is the same as that selected in the manual mode.

CONTROL BANK C

Control Bank C rods can be moved manually using the IN-HOLD-OUT lever. The bank overlap program is overridden. The rod speed signal is the same as that selected in the manual mode.

CONTROL BANK D

Control Bank D rods can be moved manually using the IN-HOLD-OUT lever. The bank overlap program is overridden. The rod speed signal is the same as that selected in the manual mode.

5.1.3 Start-Up Pushbutton

This pushbutton, mounted on the control board, is used to reset the following equipment prior to plant start-up:

- All step counters on the RTGB.
- The master cycler reversible counter.
- All slave cycler counters.
- The bank overlap counter.
- All internal memory and alarm circuits.
- The pulse to analog converter in the IRPI System.

5.1.4 Alarm Reset Pushbutton

This pushbutton, mounted on the RTGB, is used to reset Rod Control System urgent alarms. Rod control alarms displayed on the plant annunciator are cleared by the annunciator system reset pushbutton.

5.1.5 Auto Rod Defeat Pushbutton

Prevents auto rod movement when moving ROD BANK SELECTOR SWITCH through the AUTO position.

5.1.6 Lift Coil Disconnect Switches

A lift coil disconnect switch is furnished for each control and shutdown CRDM. These switches, located on a panel at the rear of the RTGB, are used in retrieving a dropped or

RDCNT

Page 30 of 45

Revision 0

INFORMATION USE ONLY

Question: 97

Service Water Pump "D" is capable of being powered from which ONE (1) of the following power sources?

- a. ONLY 480 VAC Bus E-1
- b. ONLY 480 VAC Bus E-2
- c. Either 480 VAC Bus E-1 OR 480 VAC DS Bus
- d. Either 480 VAC Bus E-2 OR 480 VAC DS Bus

Answer:

d. Either 480 VAC Bus E-2 OR 480 VAC DS Bus

QUESTION N TIER/GROUF K/A:	IUMBER: 2: 076K2.01	97	RO	2/3	SRO	
	Knowledge of	bus power sup	oplies to	the follo	owing: Service wa	ter
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.7 4	SRO 55.43(b) SRO	
OBJECTIVE:	SW-06					i
	LIST power su	upplies for the i	major Sl	ERVICE	WATER System	components as listed in the EDPs.
DEFEDENCE						
REFERENCE	.3.	LD1 -002				
	•				_	
NDURLE'	New	L ESignifica	ntiv Mo	odified		Direct IX
SOURCE:	New		ntiy Mo	odified		Direct X
JUSTIFICAT	New	Significa	ntiy Mo Bank	odified Numbe	r SW-06	Direct X
JUSTIFICAT	New	Plausible if mi alternate supp	<i>Bank</i> Bank isconce oly is DS	numbe Numbe ption reg S Bus.	r SW-06 garding power sup	Direct X 005 oply, but normal supply is E-2 and
JUSTIFICAT	New	Plausible if mi alternate supp	ntiy Mo Bank isconce bly is DS	ndified Number ption reg S Bus.	r SW-06 garding power sup	Direct X 005 oply, but normal supply is E-2 and
JUSTIFICAT a. b.	New	Plausible if mi alternate supp Plausible sinc of DS Bus.	ntiy Mo Bank i isconce oly is DS e norma	odified Number ption reg S Bus. al supply	r SW-06 garding power sup y is E-2, but can a	Direct X 005 oply, but normal supply is E-2 and lso be powered by alternate supply
JUSTIFICAT a. b.	New	Plausible if mi alternate supp Plausible sinc of DS Bus. Plausible sinc	<i>ntly Mo</i> <i>Bank</i> isconce bly is DS e norma	ndified Number ption reg B Bus. al supply nate sup	r SW-06 garding power sup y is E-2, but can a ply is DS Bus, but	Direct X 005 oply, but normal supply is E-2 and lso be powered by alternate supply
JUSTIFICAT a. b. c.	New	Plausible if mi alternate supp Plausible sinc of DS Bus. Plausible sinc	<i>ntly Mo</i> <i>Bank</i> isconce oly is DS e norma	ndified Number ption reg S Bus. al supply nate sup	r SW-06 garding power sup y is E-2, but can a ply is DS Bus, but	Direct X 005 oply, but normal supply is E-2 and lso be powered by alternate supply
JUSTIFICAT a. b. c. d.	ION:	Plausible if mi alternate supp Plausible sinc of DS Bus. Plausible sinc Normal suppl	<i>ntly Mo</i> <i>Bank</i> isconce oly is DS e norma ce altern y to SW	ndified Number ption reg S Bus. al supply ate sup	r SW-06 garding power sup y is E-2, but can a ply is DS Bus, but D is E-2 and alterr	Direct X 005 oply, but normal supply is E-2 and lso be powered by alternate supply normal supply is E-2.
JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	ION: CORRECT	Plausible if mi alternate supp Plausible sinc of DS Bus. Plausible sinc Normal suppl Know	<i>ntly Mo</i> <i>Bank</i> isconcep bly is DS ce norma ce altern y to SW	Number Number S Bus. al supply ate sup / Pump I	r SW-06 garding power sup y is E-2, but can a ply is DS Bus, but D is E-2 and alterr X Rating	Direct X 005 oply, but normal supply is E-2 and lso be powered by alternate supply normal supply is E-2.

1

REFERENCES SUPPLIED:

1

9.0 **480V-E2**

PC	480V-E2 POWER SUPPLY: NORMAL - 4160V BUS 3 (52/15)LOCATION: E-1/E-2 ROOM						
CMPT NO.	LOAD TITLE EDBS LOAD TAG NO.	CWD NO.	BKR EDBS NO.				
23A	CHARGING PUMP C CHG-PMP-C	163B	52/23A				
23B	SAFETY INJECTION PUMP C SI-PMP-C	239	52/23B				
23C	FEED TO MCC-6 MCC-6	1188	52/23C				
24A	SERVICE WATER PUMP C SW-PMP-C	833	52/24A				
24B	CV RECIRC FAN, HVH-4 HVH-4	514	52/24B				
24C	AUX FEEDWATER PUMP B AFW-PMP-B	655	52/24C				
25A	CV RECIRC FAN, HVH-3 HVH-3	513	52/25A				
25B	SERVICE WATER PUMP D (NORMAL SUPPLY) SW-PMP-D	834B	52/25B				
25C	CV SPRAY PUMP B CV-SPRAY-PMP-B	290	52/25C				
26A	FEED TO MCC-18 MCC-18	1189	52/26A				
26B	RESIDUAL HEAT REMOVAL PUMP B RHR-PMP-B	216	52/26B				
26C	COMPONENT COOLING WATER PUMP C CCW-PMP-C	209	52/26C				
27A	PT'S & METERING EQUIPMENT (*) N/A	N/A	N/A				
27B	EMERGENCY DIESEL GENERATOR B TO 480V BUS E-2 480V-E2	895	52/27B				

EDP-002	Rev. 7	Page 12 of 13

-

7.0 **480V-DS**

*

480V-DS POWER SUPPLY: NORMAL - 4160V BUS 3 (52/15)LOCATION: 4160V SWITCHGEAR ROOM					
CMPT NO.	LOAD TITLE EDBS LOAD TAG NO.	CWD NO.	BKR EDBS NO.		
32A	FEED TO 480V BUS DS 480V-DS	1015	52/32A		
32B	DEDICATED SHUTDOWN DIESEL GENERATOR TO 480V BUS DS (ALT POWER) 480V-DS	1016	52/32B		
33A	CONTROL POWER TRANSFORMER (*) CPT/480V-DS	N/A	N/A		
33B	SERVICE WATER PUMP D (ALT POWER) SW-PMP-D	834C	52/33B		
33C	COMPONENT COOLING WATER PUMP A CCW-PMP-A	201	52/33C		
33D	RESIDUAL HEAT REMOVAL PUMPS (ALT POWER) RHR-PMP-A, B	1752	52/33D		
34A	POTENTIAL TRANSFORMER PT/480V-DS	N/A	N/A		
34B	CHARGING PUMP A CHG-PMP-A	161	52/34B		
34C	FEED TO MCC-5 (ALT POWER) MCC-5	N/A	52/34C		
34D	FEED TO PP-51 PP-51	N/A	52/34D		

Compartment 33A also contains the Charging Pump A total run time meter and the Component Cooling Water Pump A total run time meter.

EDP-002	Rev. 7	Page 10 of 13
ED : 001		

Question: 98

Given the following conditions:

- A plant cooldown is in progress in accordance with GP-007, "Plant Cooldown From Hot Shutdown to Cold Shutdown."
- RCS Pressure is 1500 psig.
- RCS Tavg is 515°F.
- A RCS leak is identified inside containment.

Which ONE (1) of the following identifies the valid signals that could result in a Containment Ventilation Isolation under these conditions?

- a. Hi Steamline ΔP
 - Alarm on R-12, Containment Noble Gas Monitor
- b. Low Pressurizer Pressure Safety Injection
 - Alarm on R-14C, Plant Effluent Noble Gas Monitor
- c. Manual actuation of Containment Isolation Phase A
 - Alarm on R-12, Containment Noble Gas Monitor
- d.
 Manual actuation of Containment Isolation Phase A
 - Alarm on R-14C, Plant Effluent Noble Gas Monitor

Answer:

- c. Manual actuation of Containment Isolation Phase A
 - Alarm on R-12, Containment Noble Gas Monitor

QUESTION N TIER/GROUP K/A:	I UMBER: : 029K4.03	98	RO	2/2	SRO	
	Knowledge of purge isolation	design featu า	re(s) and	l/or interl	ock(s) which pro	vide for the following: Automatic
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b	RO) RO	3.2 9	SRO 55.43(b) SRO	
OBJECTIVE:	ESF-09					
	EXPLAIN the interlocks, and	normal opera nunciators, ar	ition of th nd setpoi	e ESFAS nts.	S control systems	s. Include function, instrumentation,
REFERENCE	S:	TS Table 3.3 TS Table 3.3 SD-006	3.2-1 3.6-1			
SOURCE:	New	Signific	antly Mo	odified		Direct X
			Bank	Number	ESF-04	006
JUSTIFICATI a.	ION:	Plausible sir but under th	ice these ese cond	would b litions the	oth cause a CVI e steamline differ	if the SI signals were not blocked, ential pressure will not cause a CVI.
b.						
		Plausible sir blocked, but	nce the lo under th	w pressi lese cond	ure would cause ditions the the low	a CVI if the SI signals were not w pressure will not cause a CVI.
с.	CORRECT	Plausible sir blocked, but CVI is cause radiation (ga GP-007 incl	ace the lo under th ed by ma aseous an ude all si	ow pressi lese cond nual actu nd partic gnals ex	ure would cause ditions the the lov uation (same actu ulate), or safety i cept manual and	a CVI if the SI signals were not w pressure will not cause a CVI. uation as Phase A), containment njection. The SI blocks initiated by high containment pressure.
с. d.	CORRECT	Plausible sir blocked, but CVI is cause radiation (ga GP-007 incl Plausible sir waste gas re	ace the lo under th aseous at ude all si ace manu elease.	ow pressi nese cond nual actu nd partic gnals ex ual actua	ure would cause ditions the the low uation (same actu ulate), or safety i cept manual and tion will cause a	a CVI if the SI signals were not w pressure will not cause a CVI. uation as Phase A), containment njection. The SI blocks initiated by high containment pressure. CVI, but R-14C only isolates any
c. d. DIFFICULTY Compreher	CORRECT	Plausible sir blocked, but CVI is cause radiation (ga GP-007 incl Plausible sir waste gas re	nce the lo under th ed by ma aseous a ude all si nce manu elease.	ow pressi nese cond nual actu nd partic gnals ex ual actua Recall	ure would cause ditions the the low uation (same actuulate), or safety i cept manual and tion will cause a Rating	a CVI if the SI signals were not w pressure will not cause a CVI. uation as Phase A), containment njection. The SI blocks initiated by high containment pressure. CVI, but R-14C only isolates any

REFERENCES SUPPLIED:

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS	TRIP SETPOINT
1.	Manual Initiation	1.2.3.4. (a),(b).(c)	2	SR 3.3.6.6	NA
2.	Automatic Actuation Logic and Actuation Relays	1,2,3,4, (a),(b),(c)	2 trains	SR 3.3.6.2 SR 3.3.6.3 SR 3.3.6.5	NA
3.	Containment Radiation				
	a. Gaseous	(a),(b),(c)	1	SR 3.3.6.1 SR 3.3.6.4 SR 3.3.6.7	(d)
	b. Particulate	(a).(b).(c)	1	SR 3.3.6.1 SR 3.3.6.4 SR 3.3.6.7	(d)
4.	Safety Injection	Refer to LCO 3.3.	2, "ESFAS Instru	mentation." Functions	1.a-f, for

Table 3.3.6-1 (page 1 of 1) Containment Ventilation Isolation Instrumentation

all initiation functions and requirements.

During CORE ALTERATIONS. During movement of irradiated fuel assemblies within containment. During Purging. Trip Setpoint shall be in accordance with the methodology in the Offsite Dose Calculation Manual. (a) (b) (c) (d)

HBRSEP Unit No. 2

		FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT (1)
1.	Sat	fety Injection						
	a.	Manual Initiation	1,2,3,4	2	В	SR 3.3.2.6	NA	NA
	b.	Automatic Actuation Logic and Actuation Relays	1.2.3.4	2 trains	С	SR 3.3.2.2 SR 3.3.2.3 SR 3.3.2.5	NA	NA
	c.	Contai nment Pressure – High	1.2.3.4	3	Ε	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≤ 4.45 psig	4 psig
	d.	Pressurizer Pressure – Low	1.2.3 ^(a)	3	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≥ 1709.89 psig	1715 psig
	e.	Steam Line High Differential Pressure Between Steam Header and Steam Lines	1,2.3 ^(a)	3 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≤ 108.95 psig	100 psig
	f.	High Steam Flow in Two Steam Lines	1,2 ^(b) ,3 ^(b)	2 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	(c)	(d)
		Coincident with T _{avg} - Low	1.2 ^(b) .3 ^(b)	1 per loop	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≥ 541.50 °F	543°F
	g.	High Steam Flow in Two Steam Lines	1,2 ^(b) ,3 ^(b)	2 per steam line	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	(c)	(d)
		Coincident with Steam Line Pressure - Low	1,2 ^(b) ,3 ^(b)	1 per loop	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.7	≥ 605.05 psig	614 psig

Table 3.3.2-1 (page 1 of 4) Engineered Safety Feature Actuation System Instrumentation

(continued)

A channel is OPERABLE with an actual Trip Setpoint value found outside its calibration tolerance band provided the Trip Setpoint value is conservative with respect to its associated Allowable Value and the channel is re-adjusted to within the established calibration tolerance band of the Nominal Trip Setpoint.
 (a) Above the Pressurizer Pressure interlock.
 (b) Above the T_{NY}-Low interlock.
 (c) Less than or equal to a function defined as ΔP corresponding to 41.58% full steam flow below 20% load, and ΔP increasing linearly from 41.58% full steam flow at 20% load.
 (d) A function defined as ΔP corresponding to 37.25% full steam flow between 0% and 20% load and then a ΔP increasing linearly from 37.25% steam flow at 20% load to 109% full steam flow at 100% load.

HBRSEP Unit No. 2

NOTE: "A" Component Cooling Pump will start anytime on low pressure if power is available. "A" pump is on the DS Bus.

6.4 Actions That Can Be Initiated By Other Signals 6.4 Actions That Can Be Initiated By Other Signals

6.4.1 Steam Line Isolation6.4.1 Steam Line Isolation

As previously noted, a spray actuation (P-signal) will close all three main steam isolation valves. This action will also occur if there is a high steam line flow coincident with low steam line pressure or low Tavg. (Does not occur on manual spray actuation.)

The main steam isolation valves can be shut individually from the RTGB by their control switch or by the steam line isolation pushbuttons.

Additionally an automatic main steam line isolation actuation will provide a signal to the Safety Injection initiation logic and a safety injection will occur unless it has been blocked.

6.4.2 Feedwater Isolation6.4.2 Feedwater Isolation

As previously noted, an SI actuation will cause a complete feedwater isolation. A reactor trip with median Tavg (TC-408K) less than 554°F will shut the main feedwater regulating valves. A high-high steam generator level (2/3 @ 75%) will shut its respective main feedwater regulating valve, bypass valve, trip both main feedwater pumps, and trip the turbine.

The Feedwater isolation signal must be reset manually if it was caused by an SI signal or steam generator high-high level before normal operation can resume. There is one key operated override/reset switch on the RTGB for each feed line.

6.4.3 Phase "A" Containment isolation and Isolation Valve Seal Water System actuation and Containment Ventilation isolation.6.4.3 Phase A Containment isolation and Isolation Valve Seal Water System actuation and Containment Ventilation isolation

In addition to being actuated by an SI signal, it can be actuated by depressing one of the two manual pushbuttons.

6.4.4 Containment Ventilation Isolation

As previously noted a Containment ventilation isolation will occur upon receipt of an

ESF

Page 26 of 39

Revision 5

INFORMATION USE ONLY

S-signal or P-signal. It will also be initiated if radiation monitor R-11 or R-12 alarms.

6.4.5 Control Room Ventilation Emergency Pressurization Mode6.4.5 Control Room Ventilation Emergency Pressurization Mode

As previously noted this action will occur upon receipt of an SI signal. This action will also be initiated automatically on an alarm of the area monitor for the control room (R-1). The operator has the ability to shift control room ventilation to the emergency pressurization mode with the normal control switch.

6.5 Blocks6.5 Blocks

Some of the SI signals can be blocked manually from the RTGB when the plant is being intentionally cooled down. There are also instances specified in OMM-022 that specify other times when blocking SI is acceptable.

6.5.1 Low pressurizer pressure and high steam line differential pressure6.5.1 Low pressurizer pressure and high steam line differential pressure

Low pressurizer pressure and high steam line differential pressure can be blocked (provided pressurizer pressure is <2000 psig on 2/3 channels) and unblocked using a three position (BLOCK, unmarked (mid position), UNBLOCK) switch located on the RTGB. These SI initiation signals are normally blocked during a plant cooldown when pressurizer pressure is less than 1950 psig. These signals will be automatically unblocked when pressurizer pressure is increased to 2000 psig. These signals can also be unblocked with a switch on the RTGB. Before these signals are manually or automatically unblocked, the operator should check to see if the bistables for these signals are cleared.

6.5.2 High steam line flow coincident with low steam line pressure or low Tavg6.5.2 High steam line flow coincident with low steam line pressure or low Taverage

High steam line flow coincident with low steam line pressure or low T_{avg} and the Hi-Hi CV pressure SI signal can be blocked (provided that Tavg is <543°F on 2/3 channels) and unblocked using a three position (BLOCK, unmarked (mid position), UNBLOCK) switch on the RTGB. This signal is automatically unblocked when T_{avg} reaches 543°F or can be manually unblocked with the switch on the RTGB. Before these signals are manually or automatically unblocked, the operator should check to see if the bistables for these signals are cleared.

7.0 TECHNICAL SPECIFICATIONS7.0 TECHNICAL SPECIFICATIONS

Revision 5

INFORMATION USE ONLY

ESF

Question: 99



Given the following drawing containing an ECCS alignment:

Which ONE (1) of the following describes the ECCS alignment?

- a. Cold leg injection
- b. Cold leg recirculation
- c. Hot leg injection
- d. Long term recirculation

Answer:

d. Long term recirculation

QUESTION N TIER/GROUF K/A:	IUMBER: 2: 006A3.06	99	RO	2/2	SRO		
Ability to monitor automatic operation of the Valve lineups							
	Ability to mon		Speratio		valve meups		
K/A IMPORT, 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.9 8	SRO 55.43(b) SRO		
OBJECTIVE:	RHR-03						
	DESCRIBE th	ie major flow p	ath thro	ough the	RHR Systems.		
DEEEDENCE	· .	SD 002					
REFERENCE		EPP-010					
SOURCE:	New	Significa	ntly Mo	odified	X	Direct	
SOURCE:	New	Significa	ntly Mo Bank	odified Numbei	X r RHR-03	Direct	
SOURCE:	New	Significa	ntly Mo Bank	odified Number	X r RHR-03	Direct 007	
SOURCE: JUSTIFICATI <i>a.</i>	New	Plausible since RWST.	ntly Mo Bank ce flow is	odified Number s going t	r RHR-03 to the cold legs, bu	Direct	umps instead of
SOURCE: JUSTIFICATI <i>a.</i>	New	Plausible since RWST.	ntiy Mo Bank ce flow is	o <i>dified</i> <i>Number</i> s going t	x r RHR-03 to the cold legs, bu	Direct	umps instead of
SOURCE: JUSTIFICAT a. b.	New	Plausible since RWST. Plausible since going to hot le	Bank Bank ce flow is ce flow i egs.	odified Number s going t s going f	x r RHR-03 to the cold legs, but to the cold legs, but	Direct	umps instead of om SI pumps is
SOURCE: JUSTIFICATI a. b.	New	Plausible since RWST. Plausible since going to hot le	Bank Bank ce flow i ce flow i egs.	odified Number s going t s going t	x r RHR-03 to the cold legs, bu to the cold legs, bu	Direct	umps instead of om SI pumps is
SOURCE: JUSTIFICATI a. b. c.	New	Plausible since RWST. Plausible since going to hot le Plausible since RWST.	Bank Bank ce flow i ce flow i egs. ce flow i	bdified Number s going t s going t s going t	x r RHR-03 to the cold legs, but to the cold legs, but to the hot legs, but	Direct	umps instead of om SI pumps is mps instead of
SOURCE: JUSTIFICATI a. b. c.	New	Significat Significat Plausible since going to hot le Plausible since RWST.	ently Mo Bank ce flow i ce flow i egs. ce flow i	odified Number s going t s going t s going t	x r RHR-03 to the cold legs, but to the cold legs, but to the hot legs, but	Direct	umps instead of om SI pumps is mps instead of
SOURCE: JUSTIFICATI a. b. c. d.	New	Signification Plausible since RWST. Plausible since going to hot le Plausible since RWST. RHR pumps a providing a si	Bank Bank For flow i flow i egs. For flow i egs.	Number s going t s going t s going t ng a suc	x RHR-03 to the cold legs, but to the cold legs, but to the hot legs, but tion from sump, play the SL numps whi	Direct	umps instead of om SI pumps is mps instead of cold legs, and ow to the bot legs
SOURCE: JUSTIFICATI a. b. c. d.	New	Signification Plausible since RWST. Plausible since going to hot le Plausible since RWST. RHR pumps a providing a su	<i>Bank</i> <i>Bank</i> ce flow i ce flow i egs. ce flow i are takin uction s	bdified Number s going t s going t s going t ng a suc ource to	x RHR-03 to the cold legs, but to the cold legs, but to the hot legs, but tion from sump, pit the SI pumps whi	Direct	umps instead of om SI pumps is mps instead of cold legs, and ow to the hot legs.
SOURCE: JUSTIFICATI <i>a.</i> <i>b.</i> <i>c.</i> <i>d.</i> DIFFICULTY	New	Signification Plausible since RWST. Plausible since going to hot le Plausible since RWST. RHR pumps a providing a su	<i>Bank</i> <i>Bank</i> ce flow i ce flow i egs. ce flow i are takin uction s	bdified Number s going t s going t s going t ng a suc ource to	x r RHR-03 to the cold legs, but to the cold legs, but to the hot legs, but tion from sump, put the SI pumps whi	Direct	umps instead of om SI pumps is mps instead of cold legs, and ow to the hot legs.
SOURCE: JUSTIFICATI a. b. c. d. DIFFICULTY Comprehent	New	Signification Plausible since RWST. Plausible since going to hot le Plausible since RWST. RHR pumps a providing a su Know	<i>Bank</i> Bank e flow i e flow i egs. e flow i ere takin uction so	bdified Number s going t s going t s going t s going t ng a suc ource to Recall	x RHR-03 to the cold legs, but to the cold legs, but to the hot legs, but tion from sump, ping the SI pumps whi Rating	Direct	umps instead of om SI pumps is mps instead of cold legs, and ow to the hot legs.

1

REFERENCES SUPPLIED:

ï

LONG TERM RECIRCULATION WITH RCS PRESSURE <125 PSIG SI-FIGURE-4 (Rev. 0)



RHR-759B throttled to 2300 gpm INFORMATION USE ONLY --- --

EPP-10			TRANSFER TO LONG TERM	סדר	TECTILATION	Rev. 14		
						Page 5 of 11		
					DECDANCE NOT AD			
	L		INDIROCITONS	L.				
****	***	* * * *	**************************************	***	*****	****		
Open will	Opening SI-866A <u>AND</u> SI-866B, HOT LEG INJs, with only one SI Pump running will cause pump runout.							
****	***	* * * *	*****	***	*****	****		
3.	Al: As	ign Fol	For Hot Leg Recirculation lows:					
	a.	Che RUN	ck SI Pump Status - TWO NING	a.	Stop the running S RHR Pump.	I Pump <u>AND</u>		
	b.	Ver LEG	ify SI-866A, LOOP 3 HOT INJ - OPEN	b.	Open SI-866B, LOOP INJ.	2 HOT LEG		
	c.	Ver CLC	ify BIT OUTLET Valves - SED					
		•	SI-870A					
		•	SI-870B					
	d.	Che	ck SI Valve Status	d.	<u>WHEN</u> the valves h repositioned, <u>THE</u>	ve Go To		
		•	SI-866 - ONE OPEN		Step 3.e.	:		
		•	SI-870A & B - BOTH CLOSED					
	e.	Che	neck Pump Status	e.	Start One RHR Pump Pump on each avail	AND One SI able		
	•	•	One RHR Pump - RUNNING		Emergency Bus.			
		•	Two SI Pumps - RUNNING					
	f.	Go	To Step 8.					

_	_	_		-	-
\mathbf{E}	Р	Р	-	1	0

Page 6 of 11

[]	[]	1					
STEP	INSTRUCTIONS		RESPONSE NOT OBTAINED				
* * * * *	**************************************						
Stone	A through 7 must be performed wi	tho	t delay to minimize the time				
with	but flow through the core.		it delay to minimize the time				
****	* * * * * * * * * * * * * * * * * * * *	****	******				
4.	Perform The Following:						
	a. Verify the RHR PUMPs - ALL STOPPED:						
	b. Verify RHR HX DISCH Valves - CLOSED						
	• RHR-759A						
	• RHR-759B						
	c. Verify RHR LOOP RECIRC Valves- OPEN						
	• SI-863A						
	• SI-863B						
****	***************************************	* * * *	*****				
		<u>. UN</u>					
Openi will	ing SI-866A <u>AND</u> SI-866B, HOT LEG I cause pump runout.	NJs,	with only one SI Pump running				
* * * * *	************	****	*****				
5.	Verify The Following Valves Aligned For Hot Leg Recirculation:						
	a. SI-866A, LOOP 3 HOT LEG INJ - OPEN		a. Open SI-866B, LOOP 2 HOT LEG INJ.				
	b. BIT OUTLET Valves - CLOSED						
	• SI-870A						
	• SI-870B						
FDD-10	TRANSFER TO LONG TERM RECIPCILATION		Rev. 14				
---	---	------	-------------------	-------------------	---------------------		
BFF-10	P			Page 7 of 11			
······							
	INSTRUCTIONS		RESPON	ISE NOT OBT	AINED		
*******	**************************************						
Valves RHR-759A and RHR-759B, RHR HX DISCHs, are closed. The RHR Pumps will run dead-headed and are subject to damage until the SI Pumps are started.							
******	******	****	******	******	* * * * * * * * * *		
6. Estab Flow A	lish Hot Leg Recirculation As Follows:						
a. Ch	eck RHR-759A - CLOSED		a. Perform	the follow	ing:		
			1) Verif	Y CLOSED R	HR-759B.		
			2) Verif stopp	y RHR PUMP ed.	A is		
			3) Open RECIR	SI-863B, R C.	HR LOOP		
			4) Start	RHR PUMP	в.		
			5) Go To	Step 7.			
b. Op	en SI-863A, RHR LOOP RECIRC	•	b. Perform	the follow	ing:		
			1) Verif	y RHR-759B	CLOSED.		
			2) Open RECIR	SI-863B, R C.	HR LOOP		
			3) Close	e SI-863A.			
			4) Start	RHR PUMP	В		
			5) Go Tc	Step 7.			
c. St	art RHR PUMP A		c. Perform	the follow	ing:		
			1) Verif	y RHR-759B	CLOSED.		
			2) Open RECIR	SI-863B, R C.	HR LOOP		
			3) Start	RHR PUMP	В		

EPP-	1	0
------	---	---

Rev. 14

Page 8 of 11

ST	EP -	_	INSTRUCTIONS	RESPONSE NOT OBTAINED
L	7.	Start Avail	One SI Pump On Each able Emergency Bus	J <u>Leun an an</u>
	8.	Check Appro	Indicated Flow On The opriate Flow Meters:	
	PAT	н	FLOW METERS	
	SI-	866B	FI-940, SI HOT LEG HEADER FL FI-933, SI LOOP 2 HOT LEG FL	FLOW FLOW
:	SI-	866A	FI-940, SI HOT LEG HEADER FL FI-932, SI LOOP 3 HOT LEG FL	FLOW FLOW
	9.	Deter Estab Follc a. Ch	mine If Flow Should Be blished To Cold Legs As ws: weck RCS pressure - LESS	a. Go To Step 11.
		TH	IAN 125 PSIG	
		b. Ch co	eck <u>ALL</u> of the below mponents - OPERABLE	b. Go To Step 11.
		•	FI-605, RHR TOTAL FLOW	
		•	RHR-759A & B, RHR HEAT EXCHANGER OUTLETs	
		•	SI-863A & B, RHR LOOP RECIRCs.	
		•	RHR Pumps A & B	

77	D	n		1	\sim
Ŀч	r	۲	-	1	U

Page 9 of 11

GTED	TNETDICTIONS	DECDONCE NOT ODEATNED
		RESPONSE NOT OBTAINED
10.	Align For Cold Leg Injection As Follows:	
	a. Establish communications with operators stationed at the breakers for RHR HEAT EXCHANGER OUTLETs:	
	• RHR-759A (MCC-5, CMPT 14C)	
	• RHR-759B (MCC-6, CMPT 13C)	
	b. Start the second RHR PUMP	b. Go To Step 11.
	c. Verify BOTH RHR LOOP RECIRC Valves - OPEN	
	• SI-863A	
	• SI-863B	
	d. Open RHR-759A, RHR HX A DISCH <u>AND</u> locally open RHR-759A Breaker when RHR flow on FI-605 indicates 1200 gpm	
	e. Open RHR-759B, RHR HX B DISCH <u>AND</u> locally open RHR-759B breaker when RHR flow on FI-605 indicates 2300 gpm	
	f. Go To Step 15	
11.	Check Time Since Hot Leg Flow Established - 16 HOURS	<u>WHEN</u> 16 hours has elapsed, <u>THEN</u> Go To Step 12.

EPE	2-1	0
	-	•••

Rev. 14

Page 10 of 11

			
STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED	
12.	Establish Cold Leg Injection As Follows:		
	a. Check SI Pump Status - TWO RUNNING	a. Stop the running SI Pump <u>AND</u> RHR Pump.	
	b. Verify at least one BIT OUTLET Valve - OPEN		
	• SI-870A		
	OR		
	• SI-870B		
	c. Verify SI-869, SI HOT LEG HDR - CLOSED	c. Verify BOTH SI-866A <u>AND</u> SI-866B are CLOSED.	
	d. Check SI Valve Status	d. <u>WHEN</u> the valves have repositioned, <u>THEN</u> Go To	
	• SI-869 - CLOSED	Step 12.e.	
	• SI-870A <u>OR</u> B - OPEN		
	e. Check Pump Status	e. Start One RHR Pump <u>AND</u> One SI Pump on each available Emergency Bus	
	 One KHK Pump - RONNING Two ST Pumps - RUNNING 	Emergency Dub.	
13.	Check Time Since Cold Leg Flow Established - 16 HOURS	Contact Plant Operations Staff to evaluate long term plant status.	
		When 16 hours has elapsed, <u>THEN</u> Go To Step 14.	

EPP-1	n

Page 11 of 11

] []
STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
14.	Establish Hot Leg Injection As Follows:	
	a. Check SI Pump Status - TWO RUNNING	a. Stop the running SI Pump <u>AND</u> RHR Pump.
	<pre>b. Verify SI-869, SI HOT LEG HDR - OPEN</pre>	
	c. Verify one HOT LEG INJ Valve - OPEN	
	• SI-866A	
·	OR	
	• SI-866B	
	d. Verify BIT OUTLETS - CLOSED	
	• SI-870A	
	• SI-870B	
	e. Check SI Valve Status	e. <u>WHEN</u> the valves have repositioned. THEN Go To
	• SI-866 - ONE OPEN	Step 14.f.
	• SI-870A & B - BOTH CLOSED	
	f. Check Pump Status	f. Start One RHR Pump <u>AND</u> One SI Pump on each available
	• One RHR Pump - RUNNING	Emergency Bus.
	• Two SI Pumps - RUNNING	
	g. Go To Step 11	
15.	Contact Plant Operations Staff To Evaluate Long Term Plant Status	
	- E	END -

4

RHR-03 007

The following valve lineup exists on the RHR system:

- * SI-860A and B closed (CV SUMP TO RHR)
- * SI-861A and B closed (CV SUMP TO RHR)
- * SI-862A and B open (RWST TO RHR)
- * RHR-744A and B open (RHR COLD LEG INJ)
- * RHR-750 and RHR-751 closed (RHR LOOP SUPPLY)
- * RHR-759A and B open (RHR HX DISC)

Which ONE (1) of the following flow paths is the RHR system aligned?

- \checkmark A. Injection from the RWST.
 - B. Cold leg recirculation from the containment sump.
 - C. Long term hot leg recirculation from the containment sump.
 - D. Cooldown lineups for normal plant cooldowns.

Given the following conditions:

- A Large Break LOCA has occurred.
- PATH-1 is being implemented.
- The CRSS directs you to "Verify Supplement D components capable of recirc."

Which ONE (1) of the following describes the actions permitted during performance of Supplement D, "Emergency Recirculation Equipment"?

- a. Restoring flowpath from containment sump to RHR
- b. Aligning flowpath from RHR pumps to the SI pumps
- c. Restoring control power to SI valves controlled from the RTGB
- d. Aligning flowpath from SI pumps to the hot legs

Answer:

c. Restoring control power to SI valves controlled from the RTGB

5.2.5 (Continued)

- 5. Supplement C This supplement contains instructions that align the plant for cold leg recirculation. It is entered from EPP-3, Loss of All AC Power Recovery with SI Required.
- 6. Supplement D This supplement is a listing of valves and components which must be available for Cold Leg Recirculation. Path-1 has a step which asks if Supplement D components are available. This means that Supplement D is to be reviewed to ensure that the valves or components listed are capable of being repositioned when the transition has been made to EPP-9, Transfer to Cold Leg Recirculation. When referenced by Path-1, Supplement D should **NOT** be used as permission to realign the valves included on that Supplement. It is acceptable, however, to restore control power to SI valves on the RTGB. It should be noted that all Supplement D components are not required to be capable of being repositioned. As a minimum the following are required:
 - One flowpath from the CV sump to the RHR Pumps.
 - One flowpath from the RHR Pumps to the SI Pumps.
 - One flowpath from the required pumps to the core.
 - Pumps as specified in the Supplement.
- 7. Supplement E This supplement contains parameters to be monitored to verify that natural circulation flow exists. This allows Operations the option of performing a natural circulation cooldown in accordance with EPP-5 or maintaining current plant conditions while on natural circulation using Supplement E.

OMM-022	Rev. 17	Page 14 of 50
	······	

 QUESTION NUMBER:
 100

 TIER/GROUP:
 RO
 1/2
 SRO

 K/A:
 011 2.4.17
 SRO
 1/2
 SRO

Knowledge of EOP terms and definitions (LBLOCA).

K/A IMPORTANCE:	RO	3.1	SRO
10CFR55 CONTENT:	55.41(b) RO	10	55.43(b) SRO

OBJECTIVE: OMM-022-08

Given plant conditions EVALUATE the appropriate actions to mitigate consequences of early action steps related to OMM-022.

REFERENCES: OMM-022

SOURCE:	New	Significantly Modified	Direct X
JUSTIFICATIO	ON:	Bank Number C	DMM-022-14 004
a.		Plausilbe since this is a flowpath that valves are to be repositioned using	at will be required for recirculation, but no Supplement D.
b.		Plausible since this is a flowpath that valves are to be repositioned using	at will be required for recirculation, but no Supplement D.
с.	CORRECT	Supplement D is not used as permis however, to restore control power to	ssion to realign valves. It is acceptable, o SI valves on the RTGB.
d.		Plausible since this is a flowpath that but no valves are to be repositioned	at will be required for long term recirculation, I using Supplement D.
DIFFICULTY: Comprehens	ive/Analysis	Knowledge/Recall X	Rating 2
	Knowledge of	f procedural requirements for EPP Su	upplements

REFERENCES SUPPLIED:

INITIAL SUBMITTAL

ROBINSON EXAM 2001-301 MARCH 26 - APRIL 2, 2001

INITIAL SUBMITTAL - SRO ONLY WRITTEN EXAMINATION QUESTIONS

Given the following conditions:

- While performing a surveillance on LT-460, I&C personnel discovered at 1200 that the high level trip setpoint for the channel was 87.5%, which is outside the calibration tolerance band.
- The I&C personnel adjusted the LT-460 high level trip setpoint back to 91.0% at 1215 and completed the surveillance satisfactorily.
- They report the "as found" information to the I&C Supervisor who determines that the channel was inoperable in the "as found" condition.
- The I&C Supervisor notifies the SSO at 1230 of the inoperability of the channel in the "as found" condition.

Which ONE (1) of the following statements is correct concerning the operability of the channel in accordance with Technical Specifications?

- a. An operability determination should be conducted to determine the total time the channel was inoperable.
- b. An operability determination is **NOT** required since the channel is now operable
- c. The channel is **NOT** operable and the bistables associated with LT-460 must be placed in a tripped condition no later than 1800.
- d. The channel is **NOT** operable and he bistables associated with LT-460 must be placed in a tripped condition no later than 1830.

Answer:

b. An operability determination is **NOT** required since the channel is now operable

QUESTION N TIER/GROUP K/A:	IUMBER: 2: 2.1.33	16 <i>R</i>	0	SRO	3
	Ability to recog for technical s	nize indications pecifications.	for system operat	ing parameters	which are entry-level conditions
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	RC 55.41(b) RC)) 55.	SRO 43(b) SRO	4.0 2
OBJECTIVE:	PZR-13				
	Given a plant Technical Spe Technical Spe	condition and a c cifications requir cifications and T	opy of Technical ements for the PZ echnical Specifica	Specifications, R and PRT Sy ation Interpreta	DETERMINE the applicable stem IAW H. B. Robinson tions.
REFERENCE	ES:	TS Table 3.3.1-1			
SOURCE:	New	Significan	tly Modified	I	Direct X
		Ε	ank Number	PZR-13	002
JUSTIFICAT <i>a.</i>	ION:	Plausible since the astronomic of the astronomic	the channel is ope s found setpoint w t was more conse	erable and an c vas less conser ervative.	pperability determination would be rvative than allowed value, but the
b.	CORRECT	The channel is of as found setpoir	operable and an o nt was more conse	perability deter ervative than a	rmination is not required since the llowed value.
с.		Plausible since respect to the a respect to the a	t would be inoper lowable value, bu lowable value and	able if the trip s it the trip setpo d was adjusted	setpoint was not conservative with int as found was conservative with I to within calibration tolerance.
d.		Plausible since respect to the a respect to the a	it would be inoper llowable value, bu llowable value and	able if the trip It the trip setpo d was adjusted	setpoint was not conservative with int as found was conservative with I to within calibration tolerance.
DIFFICULTY Comprehei	r: nsive/Analysis	X Know	ledge/Recall	Rating	4

Application of operability determination for an out-of-tolerance instrument

REFERENCES SUPPLIED:

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOIN (1)
1.	Manual Reactor	1.2	2	В	SR 3.3.1.14	NA	NA
	ורוף	3 ^(a) , 4 ^(a) , 5 ^(a)	2	С	SR 3.3.1.14	NA	NA
2.	Power Range Neutron Flux						
	a. High	1.2	4	D	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.11	≤ 110.93% RTP	108 % RTP (2)
	b. Low	1 ^(b) .2	4	E	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 26.93X RTP	24 % RTI
3.	Intermediate Range Neutron Flux	1 ^(b) , 2 ^(c)	2	F,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 37.02% RTP	25% RT
		2 ^(d)	2	н	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 37.02% RTP	25¥ RTI
4.	Source Range Neutron Flux	2 ^(d)	2	I.J	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 1.28 E5 cps	1.0 £5 cps
		3 ^(a) , 4 ^(a) , 5 ^(a)	2	J.K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.11	≤ 1.28 E5 cps	1.0 E5 cps
		3 ^(e) . 4 ^(e) . 5 ^(e)	1	L	SR 3.3.1.1 SR 3.3.1.11	N/A	N/A

Table 3.3.1-1 (page 1 of 7) Reactor Protection System Instrumentation

(continued)

A channel is OPERABLE with an actual Trip Setpoint value found outside its calibration tolerance band provided the Trip Setpoint value is conservative with respect to its associated Allowable Value and the channel is re-adjusted to within the established calibration tolerance band of the Nominal Trip Setpoint.
 The Nominal Trip Setpoint is as stated unless reduced as required by one or more of the following requirements: LCO 3.2.1 Required Action A.2.2; LCO 3.2.2 Required Action A.1.2.2; or LCO 3.7.1 Required Action B.2.
 With Rod Control System capable of rod withdrawal, or one or more rods not fully inserted.
 Below the P-10 (Power Range Neutron Flux) interlock.
 Above the P-6 (Intermediate Range Neutron Flux) interlock.
 Below the P-6 (Intermediate Range Neutron Flux) interlock.
 With the RTBs open. In this condition, source range Function does not provide reactor trip but does provide indication and alarm.

HBRSEP Unit No. 2

٩

_____

Given the following conditions:

- The unit has been shutdown for 30 days for refueling.
- Refueling cavity level is 18" below the flange.
- Initial water temperature is 106 °F.
- RHR cooling is lost.

Given the supplied references, which ONE (1) of the following indicates approximately how much time exists before Containment Closure is required?

- a. 30 minutes
- b. 35 minutes
- c. 12.9 hours
- d. 14.0 hours

Answer:

a. 30 minutes

QUESTION NUMBER:		17			
TIER/GROUP	:		RO	SRO	1/2
K/A:	025 2.1.25				

Ability to obtain and interpret station reference materials such as graphs, monographs, and tables which contain performance data (Loss of RHR).

K/A IMPORTANCE:	RO	SRO	3.1
10CFR55 CONTENT:	55.41(b) RO	55.43(b) SRO	7

OBJECTIVE: AOP-020-08

Given plant conditions EVALUATE the appropriate actions to mitigate consequences of RHR events as directed in AOP-020.

REFERENCES:

Curve 3.5 OMM-033

SOURCE:	New	Significantly Modified X Direct
	Ni	Bank Number GP-008-09 001
a.	CORRECT	Using Curve 3.5, intersection of 30 days and "-10 to -36 Below Flange" curve results in a TIF of 0.32 minutes per degree (going to left from curve). Using formula, T = (200-106) x 0.32 = 30 minutes.
b.		Plausible since this value is determined using the incorrect curve (Refueling Cavity Full) resulting in a TIF of 0.37 minutes per degree. $T = (200-106) \times 0.37 = 35$ minutes.
с.		Plausible since this value is determined using the correct curve (-10 to -36 Below Flange), but uses scale to right, instead of left, resulting in a TIF of 8.2 minutes per degree. $T = (200-106) \times 8.2 = 711$ minutes = 12.9 hours.
d.		Plausible since this value is determined using the incorrect curve (Refueling Cavity Full), but uses scale to right, instead of left, resulting in a TIF of 8.9 minutes per degree. $T = (200-106) \times 8.9 = 837$ minutes = 14.0 hours.
DIFFICULTY: Comprehens	ive/Analysis	X Knowledge/Recall Rating
	Application of	f plant curves to determine time to CV closure

REFERENCES SUPPLIED: Curve 3.5

8.1.2 **IF** the estimated time to close the open penetration exceeds 30 minutes, **THEN** an evaluation should be performed for the open penetration **AND** Operations Manager approval on Attachment 10.1 will be required.

NOTE: <u>Do Not</u> use the curve for "Refueling Cavity Full" on Curve 3.5, Time to CV Closure, <u>Unless</u> Upper Internals are removed.

NOTE: The curve for RCS "Water Level 0 inches to -10 inches Below Flange" will be utilized for RCS water level greater than 0 inches and Refueling Cavity Full with Upper Internals installed.

8.1.3 **IF** <u>ALL</u> the conditions in Section 8.1.1 above do not exist, **THEN** CV Closure Time shall be determined from Plant Curve 3.5, Time to CV Closure, in the Plant Curve Book.

NOTE: When fuel is in the Containment, the crane used for removal and installation of the CV Equipment Hatch will remain available on-site to obtain CV Closure when implementation of Attachment 10.1 is required for the CV Equipment Hatch.

- 8.1.4 CV Equipment Hatch:
 - 1. **IF** the following conditions are satisfied, **THEN** CV Closure is required in 5 hours.(DA 93-0046) (ESR 95-00315)
 - a. Fuel is in the Containment Vessel.
 - b. RCS is intact (Excluding the Pressurizer PORV's).
 - c. RCS temperature is less than 140°F.
 - d. RCS level is greater than -36 inches.
 - e. One SI Pump with flowpath to three RCS Cold Legs is available.
 - f. One Charging Pump with flowpath through CVC-310B, LOOP 2 COLD LEG CHG available.

01414 022	Rev 8	Page 11 of 30
OMM-033		



Based on Calculation RNP-M/MECH-1590 Use Thermal Inertia Factor = 0.00167 x t(hrs) prior to 100 Hours After Shutdown

Rev. 156

INFORMATION USE

8.0 INSTRUCTIONS

8.1 Determining Penetration Closure Times

NOTE: CV Closure time is not applicable with the core fully off loaded to the Spent Fuel Building.

NOTE: AOP-020, Loss of Residual Heat Removal (Shutdown Cooling), will be utilized to provide core cooling if all RHR is lost.

NOTE: When opening the CV Personnel Hatch, at least one of the doors will be capable of being closed. Any equipment impeding the closing of one of the doors shall be located in such a way that it can be immediately removed from the opening through the use of quick disconnects, clamps, etc.

- 8.1.1 **IF** the following conditions are satisfied, **THEN** allowed CV Closure Time is 30 minutes for all penetrations except the CV Equipment Hatch:
 - 1. Two Trains of RHR are OPERABLE AND
 - Reactor Coolant System average temperature is less than or equal to 200°F
 - Reactor Coolant System level is above -36 inches

OR

- One Train of RHR OPERABLE with refueling cavity level between 16 and 29 inches as indicated on the Refueling Cavity Level Indicator AND
 - Reactor Coolant System average temperature is less than or equal to 200°F
 - Reactor Vessel Upper Internals removed

OMM-033	Rev. 8	Page 10 of 30

GP-008-09 001

Given the following plant conditions:

• Plant has been shutdown for 20 days for refueling

1.5.2.25

- Refueling cavity is full
- Initial water temperature is 130 degrees F
- RHR cooling is lost

How much time exists before CV closure is required?

- A. Approximately 8.75 minutes
- B. Approximately 52 minutes
- ✓C. Approximately 8.75 hours
 - D. Approximately 52 hours

Given the following conditions:

- SG Tube Leakage in excess of Technical Specification limits was detected with the unit at power.
- The leaking SG has been identified.
- AOP-035, "SG Tube Leak," is being implemented.
- The leaking SG has been isolated.
- The RCS has been cooled down to 480 °F by core exit thermocouple readings.
- The RCS has been depressurized to less than leaking SG pressure and stabilized.
- All RCPs are running
- Pressurizer level is 85%.

Which ONE (1) of the following describes the actions the operators should take if the affected SG level begins to decrease?

- a. Increase charging flow
- b. Turn on pressurizer heaters
- c. Depressurize using normal sprays
- d. Depressurize using auxiliary spray

Answer:

b. Turn on pressurizer heaters

QUESTION N TIER/GROUP K/A:	IUMBER: : 037AA2.16	18 RO		SRO	1/2			
	Ability to determine and interpret the following as they apply to the Steam Generator Tube Leak: Pressure at which to maintain RCS during S/G cooldown							
K/A IMPORT. 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	55.43(b)	SRO SRO	4.3 4			
OBJECTIVE:	PATH-2-08							
	Given plant co related to SG	onditions EVALUATE	the appropriate ac H-2.	tions to mi	tigate consequences of steps			
REFERENCE	S:	AOP-035						
SOURCE:	New	Significantly M	lodified X	I	Direct			
		Bank	Number AOP	-035-08	003			
JUSTIFICAT a.	ION:	Plausible since this with not used due to the a	vill cause SG level already high press	to increas urizer leve	se, but increased charging flow is I.			
b.	CORRECT	RCS pressure is less pressure will cause b level is already high	s than SG pressure backflow to stop. (in the pressurizer.	e for SG le Charging is	evel to decrease. Raising RCS s not used to raise pressure since			
С.		Plausible since this a is used when SG lev	action is used whe rel is rising to creat	n SG level te backflov	l is changing, but depressurization v from the SG to the RCS.			
d.		Plausible since this a is used when SG lev	action is used whe vel is rising to crea	n SG level te backflov	l is changing, but depressurization v from the SG to the RCS.			
DIFFICULTY Compreher	': nsive/Analysis	X Knowledg	e/Recall 🔲 R	ating	3			

Analysis of plant conditions during SG tube leak to determine proper actions

REFERENCES SUPPLIED:

Rev. 12

Page 28 of 34

CONTINUOUS USE ATTACHMENT 3

S/G LEVEL CONTROL

(Page 1 of 1)

- 1. Monitor affected S/G level during cooldown.
- 2. <u>WHEN</u> required by the table below, <u>THEN</u> use the following in order of priority to depressurize the RCS:

a. Normal spray

- b. Auxiliary spray with letdown in service
- 3. Take the action specified in the table below to maintain stable level in the affected S/G.

PZR LEVEL	L AFFECTED S/G LEVEL					
	INCREASING	DECREASING	OFFSCALE HIGH			
LESS THAN	INCREASE CHARGING FLOW	INCREASE CHARGING FLOW	INCREASE CHARGING FLOW			
24%	DEPRESSURIZE RCS		MAINTAIN RCS <u>AND</u> RUPTURED S/G PRESSURES EQUAL			
BETWEEN 24% <u>AND</u> 50%	DEPRESSURIZE RCS	TURN ON PZR HEATERS	MAINTAIN RCS <u>AND</u> RUPTURED S/G PRESSURES EQUAL			
BETWEEN 50% <u>AND</u> 71%	DECREASE CHARGING FLOW TURN ON PZR MAINTAIN RCS HEATERS RUPTURED S/G PR EQUAL		MAINTAIN RCS <u>AND</u> RUPTURED S/G PRESSURES EQUAL			
GREATER THAN 71%	DECREASE CHARGING FLOW	TURN ON PZR HEATERS	MAINTAIN RCS <u>AND</u> RUPTURED S/G PRESSURES EQUAL			

- END -

.

AOP-035-08 003

Given the following plant conditions:

- · Leakage in excess of tech spec limits was detected with the plant at power
- The leaking S/G has been identified
- AOP-035, S/G Tube Leakage was entered and is still in effect
- The leaking S/G has been isolated
- The RCS was cooled down to 480 F by core exit thermocouple readings
- The RCS was depressurized to less than leaking S/G pressure and stabilized
- All reactor coolant pumps are running
- Pressurizer level is 85%

Which one of the following describes the actions the operators should take if the affected S/G level begins to increase?

- A. Depressurize RCS using normal spray
- B. Decrease charging flow and depressurize RCS using normal spray
- C. Decrease charging flow and turn on heaters
- \checkmark D. Decrease charging flow

Given the following conditions:

- The unit is operating at 40% power.
- An instrument air header break has occurred.
- Instrument air pressure at the receiver is 79 psig.
- Charging Pump 'A' speed has increased to maximum.
- HIC-121, Charging Flow, has failed open.
- VCT level has decreased to 11".

Which ONE (1) of the following actions should be directed to be taken?

- a. Align the Charging Pump suction to the RWST and perform a plant shutdown per GP-006, "Normal Plant Shutdown From Power Operation to Hot Shutdown"
- b. Align the Charging Pump suction to the RWST, trip the reactor, and go to PATH-1
- c. Isolate charging and perform a plant shutdown per GP-006, "Normal Plant Shutdown From Power Operation to Hot Shutdown"
- d. Isolate charging, trip the reactor, and go to PATH-1

Answer:

b. Align the Charging Pump suction to the RWST, trip the reactor, and go to PATH-1

Replacement

				RNP NRC Written Examination SRO Only Question Reference
QUESTION N TIER/GROUP K/A:	UMBER: : 065AA2.06	19 <i>RO</i>	SRO	1/2
	Ability to deter to trip reactor	mine and interpret the follow if instrument air pressure is	wing as they apply to decreasing	the Loss of Instrument Air: When
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	4.2 5
OBJECTIVE:	AOP-017-08			
	Given plant co instrument air	onditions EVALUATE the ap as directed by steps in AOI	propriate actions to r 2-017.	nitigate consequences of a loss of
REFERENCE	S:	AOP-017		
SOURCE:	New	X Significantly Modifie	ed	Direct
		Bank Num	ber NEW	
JUSTIFICAT a.	ION:	Plausible since the chargir reactor trip is required inst	ng pump suction is to ead of a normal shute	be aligned to the RWST, but a lown.
b.	CORRECT	With VCT level low, the ch since the RCS boron conc required.	arging pump suction entration will be rapic	is to be aligned to the RWST, and Ily increased a reactor trip is
с.		Plausible since isolating c charging pump suction is :	harging would stop th aligned to the RWST	e level decrease in the VCT, but and the plant is tripped.
d.		Plausible since a reactor t to the RWST since chargi	rip is required, but the ng cannot be isolated	e charging pump suction is aligned
DIFFICULTY Comprehe	(: nsive/Analysis	X Knowledge/Re	call 🦳 Rating	3
	Analysis of p	lant conditions to determine	e reactor trip requirem	ents in response to a loss of IA

REFERENCES SUPPLIED:

Given the following conditions:

- The unit is operating at 100 % power.
- AOP-017, "Loss of Instrument Air," is being implemented.

Which ONE (1) of the following would require a reactor trip during performance of this procedure?

- a. Instrument Air header pressure at 58 psig
- b. SA Compressor tripped while cross-connected to IA
- c. Trip of **BOTH** Air Compressor 'D' and the Primary Air Compressor
- d. CVCS Letdown isolated due to loss of air

Answer:

a. Instrument Air header pressure at 58 psig

RNP NRC Written Examination
SRO Only Question Reference

QUESTION N TIER/GROUP K/A:	UMBER: : 065AA2.06	19 . <i>R</i>	0	ł	SRO	1/2		
	Ability to deter to trip reactor	mine and interpr if instrument air p	et the following pressure is dec	as they a reasing	apply to t	the Loss	s of Instrur	nent Air: When
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	RC 55.41(b) RC))	55.43(b)	SRO SRO	4.2 5		
OBJECTIVE:	AOP-017-08							
Given plant conditions EVALUATE the appropriate actions to mitigate consequences of a loss of instrument air as directed by steps in AOP-017.								
REFERENCE	:S:	AOP-017						
SOURCE:	New	Significan	tly Modified		0	Direct	X	
JUSTIFICAT	ION:	E	sank Number		19		000	
а.	CORRECT	IA pressure belo	ow 60 psig requ	uires a rea	actor trip			
b.		Plausible since a continues to dec cross-connect, r	attempts will be crease, but a tr not tripping.	e made to ip of the \$	supply SA comp	IA with S ressor v	SA in the e vould requ	event pressure uire isolating the
с.		Plausible since continued action compressor are	these 2 comprons are taken to not available.	essors wi use IA co	ll normal ompress	ly suppl ors 'A' a	y all IA red nd 'B' if 'D	quirements, but ' and the primary
<i>d.</i> Plausible since this is an indication that control functions are beginning to be lost, but a reactor trip is not required until pressure is below 60 psig.								
DIFFICULTY Compreher	': nsive/Analysis	Know	/ledge/Recall	X Ra	ting	2		
	Knowledge of	f reactor trip requ	irements in res	sponse to	a loss o	f IA		

REFERENCES SUPPLIED:

AOP-017	

Rev. 28

Page 4 of 59

ſ		JJ	[]	
[STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED	
	1.	Check Plant Status - AT POWER	Go To Step 4.	
	* 2.	Check IA Header Pressure – LESS THAN 60 PSIG	<u>IF</u> IA pressure decreases to less than 60 psig, <u>THEN</u> Go To Step 3.	
			Go To Step 4.	
	3.	Perform The Following:		
		a. Trip the Reactor		
		b. Go To PATH-1, while continuing with this procedure		
	4.	Verify Instrument Air Compressor D - RUNNING		
	5.	Verify The Primary Air Compressor - RUNNING		
	* 6.	Check IA Header Pressure – LESS THAN 80 PSIG	<u>IF</u> IA pressure decreases to less than 80 psig, <u>THEN</u> observe <u>NOTE</u> prior to Steps 7 and 8 and perform Steps 7 and 8.	
			Observe the <u>NOTE</u> Prior To Step 9 and Go To Step 9.	
L				

Given the following conditions:

- The unit is operating at 100% power.
- All plant systems are available.
- Maintenance is being planned on the following system trains that will make them each unavailable for between 42 and 48 hours:
 - PZR PORV 456
 - MDAFW Pump 'A'
 - SG 'C' PORV
 - RHR Pump 'A'

Given the supplied references, which ONE (1) of the following combinations are permitted to be taken out at the same time based on these planned maintenance times?

- a. PZR PORV 456
 - RHR Pump 'A'
- b. PZR PORV 456
 - MDAFW Pump 'A'
- c. RHR Pump 'A'
 - SG 'C' PORV
- d. MDAFW Pump 'A'
 - SG 'C' PORV

Answer:

- d. MDAFW Pump 'A'
 - SG 'C' PORV

				RNP NRC Written Examination SRO Only Question Reference
QUESTION N TIER/GROUF K/A:	NUMBER: 2.2.18	20 <i>RO</i>	SRO	3
	Knowledge of	the process for managing n	naintenance activities	s during shutdown operations.
K/A IMPORT. 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	3.6 1
OBJECTIVE:	OMM-048-09			
	DEMONSTRA determine pla	TE the ability to evaluate a nt configurations that are no	sample work schedu ot recommended.	le using Table 2 of the Matrix to
REFERENCE	ES:	OMM-048		
SOURCE:	New	Significantly Modifie	ed X	Direct
		Bank Numi	ber PLP-056-09	005
JUSTIFICAT a.	ION:	Plausible since this combir referencing matrix indicate hours only which is less that	nation of components s that this combination an the planned maint	are supplied by same train, but on can be removed for up to 11 enance outage time.
b.		Plausible since this combine referencing matrix indicate hours only which is less that	nation of components s that this combination an the planned mainf	are supplied by same train, but on can be removed for up to 37 enance outage time.
с.		Plausible since this combir referencing matrix indicate hours only which is less th	nation of components s that this combination an the planned maint	are supplied by same train, but on can be removed for up to 22 renance outage time.
d.	CORRECT	Matrix indicates that this co for up to 59 hours, which is	ombination can be re s greater than the ex	moved from service simultaneously pected maintenance period.
DIFFICULTY Compreher	': nsive/Analysis	X Knowledge/Rec	all 🔲 Rating	3
	Application of	PSA assessment of mainte	enance activities	

REFERENCES SUPPLIED: OMM-048, Attachment 10.2

ATTACHMENT 10.2 Page 12 of 14

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 2. Matrix Showing Allowable Hours for Plant Configurations To Remain Non-Risk Significant

(DELTA CDP<1E-06)

								11	alli		<u>nau</u>	<u>IX</u>						·,	·				
Exceeding these allowed hours PGM approval, review of non-qua factors, contingency planning a insights. X - Safety Significant Exceeds M Instantaneous CDF of 1E-3 SHOULD BE AVOIDED	require antifiable and PSA laximum and	RPS CHANNEL A	RCS PZR PORV 456	RHR PUMP A	CVCS CHGP B	SI PUMP A	S/G A PORV RV-1	S/G B PORV RV-2	S/G C PORV RV-3	MFWP A	AFW MDP A	AFW SDP	SW PUMP A	SW PUMP B	CCW PUMP A	CCW PUMP B	EDG A	EMERGENCY BUS E1	DC BAT CHG A/A1	AIR COMP A	AIR COMP PRIM	FIRE PUMP DIESEL	
		1080	2005	2045	2060	2080	3020	3020	3020	3050	3065	3065	4060	4060	4080	4080	100	710	620	0135	775	617	202
RPS CHANNEL A	1080	804	56	136	461	326	117	11/	11/	296	18	/1	_584	584	400_	4/1	122	01	039	004	97	017	70
RCS PZR PORV 456	2005	56	93	$\underline{11}$	85	26	54		54	39	84.1	20	401	161	154	165	106	160	165	91	170	164	1/3
	2045	136	<u>u</u>	174	149	169	22	22	22	116	65	60	101	710	154	070	105	022	004	1060	1042	700	461
	2060	461	85	149	1081	14/	124	124	124	363	95	90	118	118	404	219	100	521	190	576	560	194	327
	2080	326	26	169	14/	5/6	83	83	83	278	78	50	450	400	404	407	00	104	409	126	126	404	117
S/G A PORV RV-1	3020	117	54	22	124	83	136	52	52	109	59	59	120	100	104	104	-00	104	101	100	100	101	117
S/G B PORV RV-2	3020	117	54	22	124	83	52	136	52	109	59	59	128	120	104	124	00	104	101	120	100	101	117
S/G C PORV RV-3	3020	117	54		124	83	-52	52	136	109	(Car)	29.	120	120	200	202	144	506	101	549	541	101	211
MFWP A	3050	296	39	116	363	2/8	109	109	109	548	14	45	438	438	309	393	70	100	400	104	100	100	
	3065	78	31	65	95	/8	59	59	<u>59</u> /	14	104	9	90	98	9/	9/	13	102		104	102	100	93
AFW SDP	3065	/1		60	96	86	59	59	59	45	9	105	92	90	30	90	104	1710	1207	2100	2006	002	551
SW PUMP A	4060	584	86	161	718	456	128	128	128	438	98	92	2190	/3	102	000	104	1710	1007	2190	2000	903	551
SW PUMP B	4060	584	85	161	/18	456	128	128	128	438	98	90	73	2190	1040	000	104	1/10	004	1040	1007	913	506
	4080	466	83	154	506	404	124	124	124	389	97	98	782	834	1340	<u> </u>	170	1150	060	1040	1207	932	500
	4080	4/1	76	155	2/9	407	124	124	124	393	97	98	850	000	<u> </u>	1390	1/2	100	104	1008	1027	101	109
EDG A	5095	122	24	106	165	188	80	08	08	144	/3	14	184	184	101	1150	190	190	184	190	194 5475	0027	706
EMERGENCY BUS E1	5175	718	91	169	932	531	134	134	134	506	102	100	1/18	1/18	995	1153	190	0107	2137	0257	0000	1507	700
DC BAT CHG A/A1	5235	639	90	165	804	489	131	131	131	468		92	1307	1307	834	963	184	2137	3129	0700	2920	1537	93
	6135_	804	91	173	1068	576	136	136	136	548	104	105	2190	2190	1348	1369	196	6257	13129	0760	0760	2920	790
	6135	775	87	172	1043	569	136	136	136	541	102	102	2086	2086	1307	1327	194	0007	12920	0000	0700	2/38	605
	6175	617	92	164	/89	484	131	131	131	463			903	913	932	942	100	2037	1537	2920	700	2920	035
IDEEPWELL PUMP B	6270	303] 79	143	461	337	117	11/	117	311	93	93	551	551	506	1 208	128	706	1 93	004	109	000	_004
			4	456	,	RHI	RA	ł	11	6	~												

Train A Matrix

456 - AFWA 37 hr RHRA-SGPORVC 22. hr AFWA-SGPORVC 59 hr

OMM-048	Rev. 11	Page 43 of 69

PLP-056-09 005

Given the following plant conditions:

- The unit is at 100% power operations
- All plant systems available
- You need to plan maintenance on the following system trains that will make them unavailable for less that 72 hours: SW Pump "C", SI Pump "C", RHR Pump "B', and the Diesel Firewater Pump.

Which ONE (1) of the following combinations are allowed by Table 2 assuming planned maintenance exceeds no Tech. Spec. limits?

- A. Diesel Firewater pump and SW pump "C".
- B. Diesel Firewater pump, RHR pump "B", and SI pump "C".
- ✓C. SW Pump "C" and SI pump "C".
 - D. RHR pump "B" and SW pump "C".

Given the following conditions:

- A reactor trip and safety injection have occurred due to a SGTR.
- A transition was made from PATH-1 to PATH-2.
- During the performance of PATH-2, an improper communication results in the CRSS incorrectly transitioning to EPP-17, "SGTR With Loss of Reactor Coolant: Subcooled Recovery."
- The first four (4) steps of EPP-17 either verify actions previously completed in PATH-1 or check plant indications only (**NO** ACTIONS ARE ACTUALLY PERFORMED).
- After completion of the first four (4) steps of EPP-17, the CRSS recognizes that the wrong procedure is being implemented.

Which ONE (1) of the following describes the actions that the CRSS should take to most quickly mitigate the consequences of the SGTR **WITHOUT** violating any procedures?

- a. Continue on in EPP-17, transitioning to PATH-2, Entry Point J, when directed
- b. Transition back to PATH-1, Entry Point A
- c. Transition back to PATH-2, Entry Point J
- d. Transition back to the point in PATH-2 where the incorrect transition was made

Answer:

d. Transition back to the point in PATH-2 where the incorrect transition was made

				SRO Only Questic	n Reference
QUESTION N TIER/GROUF K/A:	IUMBER: P: WE01EA2.2	36 <i>RO</i>	SRO	1/1	
	Ability to deter Injection Redia in the facility's	mine and interpret the follow agnosis) Adherence to appr license and amendments.	wing as they apply to opriate procedures a	o the (Reactor Trip or Safe and operation within the lin	∍ty nitations
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	3.9 5	
OBJECTIVE:	OMM-022-03				
	DEMONSTRA explaining the	TE an understanding of se basis of each.	lected steps, caution	s, and notes in OMM-022	by
REFERENCE	ES:	OMM-022			
SOURCE:	New	Significantly Modifie	ed X	Direct	
UISTIFICAT		Bank Num	ber OMM-022-03	3 010	
a.		Plausible since EPP-17 wi J, but this will delay the mi	ll provide a transition tigation of the event.	point back to PATH-2, E	ntry Point
b.		Plausible since this is a pe transition, but this will dela	rmissible method of y the mitigation of th	recovering from an incorr e event.	ect
с.		Plausible since this would PATH-1, but this is not an	mitigate the event so acceptable alternativ	ooner than transitioning ba ve.	ack to
d.	CORRECT	If the incorrect transition is mitigation strategy have or where the incorrect transit	immediately recogn ccurred, he may mov ion has occurred.	izable AND no alterations ve back to the point in the	of the Network
DIFFICULTY Comprehe	(: nsive/Analysis	Knowledge/Red	call X Rating	3	
	Knowledge o	f administrative requiremen	ts for incorrect proce	dure transitions	

•

RNP NRC Written Examination

REFERENCES SUPPLIED:

8.3.10 Incorrect EOP Transition

- 1. Should the Operator determine that he is in an incorrect Path or EPP, he has two options:
 - If the incorrect transition is immediately recognizable **AND** no alterations of the WOG mitigative strategy have occurred, he may move back to the point in the Network where the incorrect transition has occurred.
 - If the incorrect transition is not immediately recognizable **OR** alterations in the mitigative strategy have occurred, the Operator should move to Path-1, Entry Point A, and start over.
- 2. During the rediagnosis described above, complete reactuation of the Engineered Safety Features is allowed, but not required. Reactuation of necessary safety features during rediagnosis is guided by the requirements of the applicable Foldout and Operator judgement based on the symptoms present.

8.3.11 Adverse Containment Conditions Usage

- When adverse containment conditions develop, the use of adverse containment condition setpoints shall be initiated.
- 2. The use of adverse containment condition setpoints shall be maintained from that point forward, even when adverse containment conditions no longer exist.
- 3. An adverse containment condition setpoint may or may not be provided. The operator shall use a setpoint with no brackets if no setpoint within brackets is provided, even if adverse containment conditions exist.

8.3.12 Special EPP Priority

1. Certain contingency EPPs take precedence over FRPs because of their treatment of specific initiating events. In all such cases, this precedence is identified in a CAUTION or NOTE at the beginning of the EPP.

22	Rev. 17 Page 3	of 50
22	Rev. 17 Page 5	+

OMM-022-03 010

In regard to incorrect EOP transition, should the Operator determine that he is in an incorrect PATH or EPP, AND IF the incorrect transition is not immediately recognizable OR alterations in the mitigative strategy have occurred, the Operator should do which ONE (1) of the following?

- A. Immediately monitor the CSFSTs and proceed to the highest priority Functional Restoration Procedure
- ✓B. Move to PATH-1, Entry Point A, and start over
 - C. Move back to the point in the network where the incorrect transition was made, hold a crew brief, and proceed on in the applicable PATH or EPP.
 - D. Hold a crew brief including the SSO, perform an evaluation of plant status, continue on in the procedure in effect.
Question: 37

Given the following plant conditions:

- During a plant transient, Control Bank 'D' rods are moved inward.
- After the plant stabilizes, the Reactor Operator recognizes that two (2) Control Bank 'D' rods are misaligned by greater than allowed by Technical Specification limits.

Which ONE (1) of the following actions are to be taken?

- a. Verify Shutdown Margin within 1 hour
 - Realign the misaligned rods or be in Mode 3 within 2 hours
- b. Verify Shutdown Margin within 1 hour
 - Realign the misaligned rods or reduce power to < 70% within 2 hours
- c. Verify Shutdown Margin within 1 hour
 - Shutdown to Mode 3 within 6 hours
- d. Trip the reactor
 - Go to PATH-1

Answer:

- c. Verify Shutdown Margin within 1 hour
 - Shutdown to Mode 3 within 6 hours

QUESTION N TIER/GROUP K/A:	UMBER: : 005AA2.03	37 RO	SRO	1/1	
	Ability to deter Rod: Required	mine and interpret the follo actions if more than one i	owing as they apply rod is stuck or inope	to the Inoperable / S erable	Stuck Control
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	4.4 6	
OBJECTIVE:	AOP-001-07				
	DETERMINE	the action(s) required by T	echnical Specificati	ions associated with	AOP-001
REFERENCE	ES:	TS 3.1.4			
		AOP-001			
SOURCE:	New	Significantly Modif	ied X	Direct	
JUSTIFICAT	ION:	Bank Nun	nber AOP-001-	07 003	
a.		Plausible since these act misaligned or stuck, but r rods.	ions similar to these nore conservative a	e would be taken if o actions are required	nly one rod was with 2 or more
b.		Plausible since these act misaligned or stuck, but r rods.	ions similar to these more conservative a	e would be taken if c actions are required	nly one rod was with 2 or more
с.	CORRECT	With more than one rod r and the plant must be pla	misaligned or stuck, aced in Mode 3 with	SDM must be verifi in 6 hours.	ed within 1 hour
d.		Plausible since a reactor with more than 1 rod mis	trip will be initiated aligned / stuck a cc	if more than one roo ntrolled shutdown is	d is dropped, but performed.
DIFFICULT Comprehe	ſ: nsive/Analysis	Knowledge/R	ecall X Rating	3	
	Knowledge o	f TS and procedural requi	rements for more th	an one misaligned /	stuck rod

REFERENCES SUPPLIED:

	UNS (continued)		DEOUTDED ACTION	COMPLETION TIME
	CONDITION		REQUIRED ACTION	
с.	Required Action and associated Completion Time of Condition B not met.	C.1	Be in MODE 3.	6 hours
D.	More than one rod not within alignment limit.	D.1.1	Verify SDM is within the limits provided in the COLR.	1 hour
		<u>OR</u>		1 6000
		D.1.2	Initiate boration to restore required SDM to within limit.	1 hour
		AND		6 hours
		D.2	Be in MODE 3.	

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.1.4.1 Verify individual rod positions within alignment limit.	12 hours <u>AND</u> Once within 4 hours and every 4 hours thereafter when the rod position deviation monitor is inoperable

HBRSEP Unit No. 2

- ----

Amendment No. 176

				Rev. 15						
AOP-01	U T	MALFONCTION OF REACT	Page 39 of 80							
STEP -	-	INSTRUCTIONS RESPONSE NOT OBTAINED								
	SECTION B									
	IMMOVABLE/MISALIGNED_RODS									
	(Page 4 of 31)									
		NOI	<u>`E</u>							
•	TECH 200 s Step	SPEC limits for bank positi steps are 15 inches (24 step Counter position.	ons greater than <u>OR</u> equal os) alignment with associa	. to ited Group						
•	TECH 7.5 i	SPEC limits for bank positi inches alignment with averag	ons less than 200 steps a ge IRPI position of associ	are ated Bank.						
•	Use I misal	RPI and/or Incore Flux Map ignment.	for determination of Cont	rol Rod						
•	ERFIS	5 display GD ROD LOG may be	used for additional infor	mation.						
*11.	Check GREATE	IRPI Rod Misalignment - ER THAN TECH SPEC LIMIT	 Perform the following a. IF the ROD BANK SF Switch was in Indi Select WHEN the Un Failure condition THEN contact Engir recovery actions to normal rod sequend b. WHEN the urgent fat condition is correct Depress ROD ALARM Button on RTGB ANI APP-005-E2 clears c. WHEN the urgent fat has been cleared, observe the CAUTIO Step 23 and Go To 	Subscription: Subscription: Subscription: Sector Se						
12.	Check Misali	Number Of Rods Indicating ignment - GREATER THAN ONE	Observe the <u>NOTE</u> pric Step 14 and Go To Ste	or to ep 14.						

Rev. 15

Page 40 of 80

I	·····									
	STEP	INSTRUCTIONS RESPONSE NOT OBTAINED								
		<u>SECTION B</u>								
	IMMOVABLE/MISALIGNED RODS									
	(Page 5 of 31)									
	13.	Perform The Following:								
		a. Check SDM - WITHIN THE LIMITS a. Initiate boration to restore SPECIFIED IN THE COLR SDM within 1 hour.								
		b. Within 6 hours Place the unit in Mode 3 using GP-006, Normal Plant Shutdown From Power Operation To Hot Shutdown.								
		c. Go To Step 61								

AOP-001-07 003

During a power escalation it is discovered that 2 Control Bank "D" rods are out of alignment. An unsuccessful attempt was made to realign the rods (rods would not move). The Reactor is currently at 80% power.

Select the appropriate operational restriction that applies for this condition:

- \checkmark A. Place the unit in Hot Shutdown within 8 hours.
 - B. Maintain power < 90% (or 0.9 APL) and determine Hot Channel Factors.
 - C. Borate the RCS an amount equat to the worth of the stuck rods.
 - D. No action required if Bank "D" is < 200 steps.

Question: 38

Using the supplied references, which ONE (1) of the following conditions would require a One-Hour Notification in accordance with AP-030, "NRC Reporting Requirements"?

- a. A manual reactor trip is actuated from 20% power due to a break in the Main Turbine Electro Hydraulic Control system piping
- b. An automatic safety injection is actuated at 100% power due to an I&C Technician lifting an incorrect lead
- c. You receive a report that a previously reported employee's positive FFD test was erroneous and is due to an administrative error at the laboratory
- d. While on your tour, you note that the WCC SRO's speech is slurred and you smell alcohol on his breath

Answer:

c. You receive a report that a previously reported employee's positive FFD test was erroneous and is due to an administrative error at the laboratory

				SRO Only Que	stion Reference
QUESTION N TIER/GROUF K/A:	IUMBER: 2: 2.4.30	38 RO	SRO	3	
	Knowledge of agencies.	which events related to system	n operations/status	s should be reported	to outside
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	3.6 1	
OBJECTIVE:	AP-030-03				
	Given a repor	table event, DETERMINE the i	reporting requirem	ents of AP-030.	
REFERENCE	ES:	AP-030			
SOURCE:	New	Significantly Modified	X	Direct	
		Bank Number	r HNP-SRO-20)00 76	
JUSTIFICAT a.	ION:	Plausible since a TS required trips from power are 4-hour n	l shutdown from M otifications.	ode 1 is a 1-hour noti	ification, but
b.		Plausible since safety injection notifications, but a signal as a actuations.	on actuations due t a result of human e	o valid signals are 4-l error are not consider	hour ed valid
с.	CORRECT	Per Attachment 11.1, false protifications.	ositives of an empl	loyee's FFD are 1-ho	ur
d.		Plausible since this would be	e a 1-hour if this we	ere an NRC employee	9.
DIFFICULT Comprehe	Y: nsive/Analysis	s X Knowledge/Reca	ll 🔲 Rating	3	
	Interpretation	n and application of conditions	to determine repo	rting requirements	
REFERENC	ES SUPPLIED	e: AP-030, Attachments 11	.1 and 11.2		

RNP NRC Written Examination

Question: 38

Given the supplied references, which ONE (1) of the following conditions would require a One-Hour Notification in accordance with AP-030, "NRC Reporting Requirements"?

- a. A manual reactor trip is actuated from 20% power due to a break in the Main Turbine Electro Hydraulic Control system piping
- b. An automatic safety injection is actuated at 100% power due to an I&C Technician lifting an incorrect lead
- c. While at 400 °F during a plant cooldown, a fire destroys the FTS-2000 network in the Technical Support Center
- d. While at 190 °F during a plant heatup, it is discovered that wire leads for **BOTH** Safety Injection pumps in the Sequencer cabinets were inadvertently left lifted

Answer:

c. While at 400 °F during a plant cooldown, a fire destroys the FTS-2000 network in the Technical Support Center

				SRO Onl	y Question Reference
QUESTION N TIER/GROUF K/A:	UMBER: 2: 2.4.30	38 RO	SRO	3	
	Knowledge of agencies.	which events related to sys	stem operations/status	s should be rep	orted to outside
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	3.6 1	
OBJECTIVE:	AP-030-03				
	Given a report	able event, DETERMINE t	he reporting requirem	ents of AP-030.	
REFERENCE	ES:	AP-030			
COURCE.	Now	Significantly Modifi	ad [X]	Direct	
SUURCE:	New				
		Bank Num	ber HNP-SRO-20	000 76	
JUSTIFICAT <i>a.</i>	ION:	Plausible since a TS requi trips from power are 4-hou	red shutdown from M ır notifications.	ode 1 is a 1-ho	ur notification, but
b.		Plausible since safety inje notifications, but a signal a actuations.	ction actuations due t as a result of human e	o valid signals a error are not cor	are 1-hour nsidered valid
с.	CORRECT	Per Attachment 7.1, this wassessment, off-site response	yould be addressed up onse, or communication	nder loss of em on capability an	ergency d would require a 1-
d.		Plausible since this rende shutdown this is a 4-hour	rs both trains of ECC: notification.	S inoperable, bi	ut since the plant is
DIFFICULT Comprehe	(: nsive/Analysis	X Knowledge/Re	call 🔲 Rating	3	
	Interpretation	and application of conditio	ns to determine repor	ting requiremer	nts

RNP NRC Written Examination

REFERENCES SUPPLIED: AP-030, Attachments 7.1 and 7.2

ATTACHMENT 7.1 Page 1 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC						
10 CFR 50.72 states that immediate reports shall be made to the <u>NRC Operations Center</u> of these Emergency Events via the FTS-2000 as specified in the Emergency Plan. 10 CFR 50.72 additionally identifies Non-Emergency Events which are to be reported within One-Hour or Four-Hours to the NRC. FTS -2000 Telephones, which are distinctly labeled, are tan in color and are located in the Control Room, the TSC, and the EOF.						
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES			
NOTE: 10 CFR 50.72 recognizes Emergency.	the Emergency Plar	n and its four Emergency Classes of Unusual Eve	ent, Alert, Site Area Emergency and General			
EMERGENCIES 10 CFR 50.72(a)(i) 10 CFR 30.32(i)(3)(viii) 10 CFR 40.31(i)(3)(viii)	Emergency Unusual Event Alert Site Area Emergency General Emergency	HBRSEP shall notify the NRC of the declaration of any of the Emergency Classes specified in the Emergency Plan.	 Declaration of an Unusual Event, Alert, Site Area Emergency, or General Emergency Discovery of an event that should have resulted in an Emergency Classification, but no emergency was declared Discovery that a declared emergency exceeded the Emergency Action Levels for a higher emergency declaration, but the higher classification was not declared 			
ERDS ACTIVATION 10 CFR 50.72(a)(4)	ERDS Emergency	HBRSEP shall activate the ERDS as soon as possible but not later than one hour after declaring an Alert, Site Area Emergency, or General Emergency.	 An Alert, Site Area Emergency, or General Emergency is declared. 			

AP-030	Rev. 27	Page 19 of 76

ATTACHMENT 7.1 Page 2 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC							
If not reported as a declaration of an Er (FTS-2000) as soon as practical and in	If not reported as a declaration of an Emergency Class under paragraph (a) of 10 CFR 50.72, HBRSEP shall notify the <u>NRC Operations Center via ENS</u> (FTS 2000) as soon as practical and in all cases within one hour of the occurrence of any of the following:						
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES				
SHUTDOWN REQUIRED BY TS	Shutdown TS Shutdown Power Reduction	The <u>initiation</u> of any shutdown required by the TS.	 Unplanned Shutdown initiated due to maximum specific activity of the Reactor Coolant Water (plant shutdown required by TS) Reactor Coolant System Leakage in excess of 10 GPM for greater than 24 hours (plant shutdown required by TS) Component Cooling Water Heat Exchanger inoperable (if not corrected prior to expiration of Required Action Completion Time) 				
DEVIATION FROM TS (10 CFR 50.54(X)) 10 CFR 50.72(b)(1)(i)(B)	Deviation Departure License Condition	Any deviation from the TS authorized pursuant to 10 CFR 50.54(x).	 Intentional deviation from an approved plant procedure in order to preserve plant safety 10 CFR 50.54(x) (See PRO-NGGC-0200) 				

AP-030	Rev. 27	Page 20 of 76

ATTACHMENT 7.1 Page 3 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC				
If not reported as a declaration of an En soon as practical and in all cases within	nergency Class u one hour of the c	nder paragraph (a) of 10 CFR 50.72, HBRSE occurrence of any of the following:	P sha	II notify the <u>NRC Operations Center via FTS-2000</u> as
EVENT	KEY WORDS	REQUIREMENT		EXAMPLES
PRINCIPAL SAFETY BARRIERS SERIOUSLY DEGRADED	Degraded Safety Barriers Fission Product	Any event or condition <u>during operation</u> that results in the condition of the nuclear power plant, including its principal safety barriers, being seriously degraded;	-	Fuel cladding failures in the reactor, or in the storage pool, that exceed expected values, or that are unique or widespread, or that are caused by unexpected factors, and would involve a release of significant quantities of fission products
	Barrier		-	Cracks and breaks in the piping or reactor vessel, or major components in the reactor coolant system, that have safety relevance (steam generators, reactor coolant pumps, valves, etc.)
			-	Significant welding or material defects in the RCS
			-	Serious temperature or pressure transients
			-	Loss of relief and/or safety valve functions during operation – Loss of Containment function or integrity
10 CER 50 72(b)(1)(ii)			_	Complete loss of containment integrity function including (1) containment leakage rate greater than allowed value per SR 3.6.1.1 (i.e., entry into LCO 3.6.1 Condition A), (2) loss of containment penetration isolation functional capability (i.e., both barriers), or loss of containment spray capability
	Safety	for that resulted in the nuclear power	-	OT _△ T changes are declared inoperable due to summator
	UNANALIZED PLANT CONDITION Salety Ion that resulted in the holder points Function plant being:] Unanalyzed In an unanalyzed condition that	plant being:] In an unanalyzed condition that		module lag constants. The channel response time exceeded the value assumed in the accident analysis.
10 CER 50 72(b)(1)(ii)(A)	Condition	significantly compromises plant safety;	-	Accumulation of voids in systems designed to remove heat from the reactor, that could inhibit the ability to adequately remove heat from the core, particularly under natural circulation conditions

	Boy 27	Page 21 of 76
	Rev. 21	
AF-030		

ATTACHMENT 7.1 Page 4 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC				
If not reported as a declaration of an E (FTS-2000) as soon as practical and in	If not reported as a declaration of an Emergency Class under paragraph (a) of 10 CFR 50.72, HBRSEP shall notify the <u>NRC Operations Center via ENS</u> (ETS-2000) as soon as practical and in all cases within one hour of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES	
CONDITION OUTSIDE DESIGN BASIS OF PLANT	Design Bases Loss of Safety Function	[or that resulted in the nuclear power plant being:] In a condition that is outside the design basis of the plant;	 Discovery of design errors that renders a safety system inoperable Discovery that a single train of a safety system has been incapable of performing its design function for an extended time (well beyond surveillance intervals or Required Action Completion Times) Safety related piping found not to be seismically qualified in accordance with design bases requirements 	
10 CFR 50.72(b)(1)(ii)(C)	OP AOP EOP PATH CSFST	[or that resulted in the nuclear power plant being:] In a condition not covered by the operating and emergency procedures.	 An event is occurring having significant implications for the health and safety of the public and no AOP or EOP is applicable to the condition. 	
NATURAL PHENOMENON OR CONDITION THREATENING PLANT SAFETY	Earthquake Hurricane Tornado Weather Explosion Railroad	Any natural phenomenon or other external condition that poses an actual threat to the safety of the nuclear power plant or significantly hampers site personnel in the performance of duties necessary for the safe operation of the plant.	 Natural phenomenon (ice storm that significantly hampers personnel in the conduct of activities necessary for safe operation of the plant). External hazards (railroad tank car explosion that poses an actual threat to Plant safety) 	
ECCS DISCHARGE INTO RCS	ECCS Actuation Safety Injection	Any event that results or should have resulted in ECCS discharge into the reactor coolant system as a result of a valid signal.	 Manual or automatic Safety Injection System actuation in response to a valid signal (Section 4.5 of this procedure) 	

Boy 27	Page 22 of 76 L
Rev. 27	

ATTACHMENT 7.1 Page 5 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

If not reported as a declaration of an E (FTS-2000) as soon as practical and in	nergency Class und all cases within one	er paragraph (a) of 10 CFR 50.72, HBRSEP shall bour of the occurrence of any of the following:	notify the <u>NRC Operations Center via ENS</u>
(1 10 2000) ab coon ac present	······································		
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
LOSS OF EMERGENCY ASSESSMENT, OFF-SITE RESPONSE, OR COMMUNICATIONS CAPABILITY	Selective Signaling System Sirens FTS-2000	Any event that results in a major loss of emergency assessment capability, off-site response capability, or communications capability (e.g., significant portion of control room indication, FTS-2000, or off-site notification system).	 Loss of 23 or more of 45 Public Warning Sirens (≥50%) as indicated on the siren activation system for a period of at least 30 minutes at any one time. Loss of greater than 50% of communications capability (i.e., offsite communications systems which include the Selective Signaling System, the Essex System and the Local Government Radio System). Loss of greater than 50% of the ability of the TSC or EOF to function. Loss of instrumentation indication capability to the extent that an Emergency Action Level cannot be determined to exceed an emergency classification. Loss of FTS-2000 System if identified by the plant (Not reportable if identified by NRC) Loss of commercial telephone system to the extent that required communications could not be made to official offsite locations (e.g., EOCs, Warning Points)
INTERNAL THREAT TO PLANT SAFETY (FIRES, TOXIC GAS, RADIOLOGICAL RELEASE)	Fire Toxic Explosive Release Personnel Safety	Any event that poses an actual threat to the safety of the nuclear power plant or significantly hampers site personnel in the performance of duties necessary for the safe operation of the nuclear power plant including fires, toxic gas releases, or radioactive releases.	 Fire confirmed inside Protected Area (if fire poses an actual threat to plant safety or significantly hampers site personnel in the performance of duties necessary for the safe operation of the plant). Unplanned release of radioactive gases or toxic gas inside Protected Area (if release significantly hampered site personnel in the performance of duties necessary for safe operation of the plant).
		Rev 27	Page 23 g

ATTACHMENT 7.1 Page 6 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC HBRSEP shall immediately notify the NRC Operations Center via FTS-2000 as soon as practical and in all cases within one hour of the occurrence of any of			
the following:		REQUIREMENT	EXAMPLES
EVENT SAFETY LIMIT, LIMITING SAFETY SYSTEM SETTING EXCEEDED	Safety Limit Limiting Safety System Setting	If any safety limit is exceeded, shut down the reactor. HBRSEP shall notify the [NRC within 1 hour via FTS-2000 per 10 CFR 50.72(a)(1), See Emergency Plan Procedures]. Operation must not be resumed until authorized by the NRC.	 Reactor pressure exceeds 2735 psig while at power The limits of TS Table 2.1.1-1 are exceeded Limiting Safety System Settings in TS Table 3.3.1-1 are exceeded
10 CFR 50.36(c)(1)(i)(A) SAFETY SYSTEM DOES NOT FUNCTION AS REQUIRED	ESF RPS Limiting Safety System Setting	HBRSEP shall notify the NRC if the automatic safety system [to correct an abnormal situation before a safety limit is exceeded] has been determined not to function as required.	 A failure mechanism is discovered that indicates that the RPS will not function to trip the reactor under certain required conditions.

		Dogo 24 of 76	
	Rev. 27	Page 24 01 70	
AP-030			

ATTACHMENT 7.1 Page 7 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - SECURITY SAFEGUARDS EVENTS				
HBRSEP shall notify the NRC Operations Center via the FTS-2000 within one hour after discovery of the safeguards events described as follows (10 CFR 73.71(b)(1)):				
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES	
THEFT/UNLAWFUL DIVERSION OF SNM OR SPENT FUEL SHIPMENT 10 CFR 73.71(a)(1)	SNM Spent Fuel Security Safeguards	Any discovery of the loss of any shipment of SNM or spent fuel, and within one hour after recovery of or accounting for such lost shipment	 Shipment Emergency Event (Reference 2.9) 	
THEFT/UNLAWFUL DIVERSION OF SNM 10 CFR 73.71(b)(1) 10 CFR 73, Appendix G, I(a)(1)	Theft of SNM Diversion Security Safeguards	Any event in which there is reason to believe that a person has committed or caused, or attempted to commit or cause, or has made a credible threat to commit or cause: (1) A theft or unlawful diversion of SNM	 Shipment Emergency Event (Reference 2.9) 	
SABOTAGE OF PLANT EQUIPMENT 10 CFR 73.71(b)(1) 10 CFR 73, Appendix G, I(a)(2)	Sabotage Damage to Plant SNM Spent Fuel Security Safeguards	[Any event in which there is reason to believe that a person has committed or caused, or attempted to commit or cause, or has made a credible threat to commit or cause:] (2) Significant physical damage to a power reactoror its equipment or carrier equipment transporting nuclear fuel or spent nuclear fuel, or to the nuclear fuel or spent fuel a facility or carrier possesses.	 Shipment Emergency Event (Reference 2.9) Security Event (Reference 2.11) 	

AP-030	Rev. 27	Page 25 of 76

ATTACHMENT 7.1 Page 8 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - SECURITY SAFEGUARDS EVENTS					
HBRSEP shall notify the <u>NRC Operatio</u> (10 CFR 73.71(b)(1)):	HBRSEP shall notify the <u>NRC Operations Center</u> via the FTS-2000 within one nour after discovery of the saleguards events described as follows (10 CFR 73.71(b)(1)):				
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES		
UNAUTHORIZED TAMPERING WITH PLANT EQUIPMENT	Unauthorized Use Tampering Security System Safeguards	 [Any event in which there is reason to believe that a person has committed or caused, or attempted to commit or cause, or has made a credible threat to commit or cause:] (3) Interruption of normal operation of HBRSEP through the unauthorized use of or tampering with its machinery, components, or controls including the security system. 	 Security Event (Reference 2.11) 		
ENTRY OF UNAUTHORIZED PERSON INTO PROTECTED OR VITAL AREA 10 CER 73, Appendix G, I(b)	Unauthorized Entry Security Safeguards	An actual entry of an unauthorized person into a protected area, material access area, controlled access area, vital area, or transport.	 Security Event (Reference 2.11) 		
FAILURE, DEGRADATION, OR DISCOVERED VULNERABILITY OF SAFEGUARD SYSTEM 10 CFR 73, Appendix G, I(c) Procedure SEC-NGGC-2147	Degradation Vulnerability Safeguards Unauthorized Undetected Access Security	Any failure, degradation, or the discovered vulnerability in a safeguard system that could allow unauthorized or undetected access to a protected area, material access area, controlled access area, vital area or transport for which compensatory measures have not been employed.			
INTRODUCTION OF CONTRABAND INTO VITAL OR PROTECTED AREA 10 CER 73, Appendix G, I(d)	Contraband Unauthorized Security Safeguards	The actual or attempted introduction of contraband into a protected area, material process area, vital area, or transport.			

AP-030 Rev. 27 Page 26 of 76

ATTACHMENT 7.1 Page 9 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - SOURCE, BYPRODUCT AND SNM			
HBRSEP shall immediately notify the <u>NRC Operations Center via FTS-2000</u> , when:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
LOSS OR THEFT OF LICENSED MATERIAL (>1000X 10 CFR 20 LIMITS)	Loss Theft Missing Licensed Radioactive Material	Immediately notify the NRC, after its occurrence becomes known, any lost, stolen, or missing licensed material in an aggregate quantity equal to or greater than 1,000 times the quantity specified in [10 CFR 20] Appendix C under such circumstances that it appears to HBRSEP that an exposure could result to persons in unrestricted areas.	 A radiography source is discovered missing. The source is licensed to the radiography contractor. If the contractor does not make the required notification, HBRSEP should notify the <u>NRC Operations</u> <u>Center via FTS-2000</u>.
EXTERNAL EXPOSURE FROM BYPRODUCT, SOURCE, OR SNM (5X ANNUAL LIMIT)	Byproduct Source SNM Exposure Dose Release Occupational	 Notwithstanding any other requirements for notification, immediately notify the NRC of any event involving byproduct, source, or SNM possessed by HBRSEP that may have caused or threatens to cause any of the following conditions: An individual to receive: A total effective dose equivalent of 25 rems or more; or An eye dose equivalent of 75 rems or more; or (ii) A shallow dose equivalent to the skin or extremities of 250 rads or more; or The release of radioactive material, inside or outside the restricted area, so that, had an individual been present for 24 hours, the individual could have received an intake five times the occupational annual limit on intake. 	

		Page 27 of 76
	Rev. 27	1 490 27 01 70
AF-030		

ATTACHMENT 7.1 Page 10 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - SOURCE, BYPRODUCT AND SNM				
HBRSEP shall immediately notify the 1	NRC Operations Cer	nter via FTS-2000, when:		
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES	
INTERNAL EXPOSURE FROM BYPRODUCT, SOURCE, SNM (>5X OCCUPATIONAL LIMIT) 10 CFR 20.2201(a)(i)	Intake Ingestion Release Source Byproduct SNM	The release of radioactive material, inside or outside the restricted area, so that, had an individual been present for 24 hours, the individual could have received an intake five times the occupational annual limit on intake.		

	Day 97	Page 28 of 76
ΔΡ-030	Rev. 27	1 490 20 01 10
A 000		

ATTACHMENT 7.1 Page 11 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - ISFSI				
HBRSEP shall immediately notify the N	RC Operations Cent	er via FTS-2000, when:		
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES	
ISFSI - ACCIDENTAL CRITICALITY OR LOSS OF SNM 10 CFR 72.74	ISFSI Criticality SNM Loss	The licensee shall notify the NRC Operations Center via FTS-2000 within one hour of discovery of accidental criticality or any loss of SNM.	 Unusually high radiation readings discovered in the vicinity of the ISFSI that could indicate possibility of a criticality event 	
	IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - SNM SHIPMENTS			
HBRSEP shall notify the NRC Operation	ons Center via the F	TS-2000 within one hour of the following:		
LOST OR UNACCOUNTED SHIPMENT OF SNM 10 CFR 70.52(b) 10 CFR 73.71(a)(1)	Shipment Loss SNM Spent Fuel Theft Diversion Safeguards Security	HBRSEP shall notify the <u>NRC Operations</u> <u>Center</u> via the FTS-2000 within one hour after discovery of any loss of any shipment of SNM or spent fuel or any incident in which an attempt has been made, or is believed to have been made, to commit a theft or unlawful diversion of SNM.	 Shipment Emergency Event (Reference 2.9) Security Event (Reference 2.11) 	
LOST OR UNACCOUNTED SHIPMENT OF SNM - RECOVERY 10 CFR 73.71(a)(1)	Recovery Accounting Shipment SNM Security Safeguards	HBRSEP shall notify the <u>NRC Operations</u> <u>Center</u> via the FTS-2000 within one hour after recovery of, or accounting for, any lost shipment of SNM.		

AP-030	Rev. 27	Page 29 of 76
/ 1 000		

ATTACHMENT 7.1 Page 12 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - FOLLOW-UP				
With respect to the telephone notification shall during the course of the event imr	With respect to the telephone notifications made under paragraphs (a) and (b) of 10 CFR 50.72, in addition to making the required initial notification, HBRSEP shall during the course of the event immediately report:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES	
FOLLOW-UP NOTIFICATION	Degradation Emergency Class Change Update Termination	 (i) any further degradation in the level of safety of the plant or other worsening plant conditions, including those that require the declaration of any of the Emergency Classes, if such a declaration has not been previously made, or (ii) any change from one Emergency Class to another, or (iii) a termination of the Emergency Class. 	 Refer to Reference 2.27 	
FOLLOW-UP NOTIFICATION	Result Evaluation Effectiveness Unknown	 (i) the results of ensuing evaluations or assessments of plant conditions, (ii) the effectiveness of response or protective measures taken, and (iii) information related to plant behavior that is not understood. 		
FOLLOW-UP NOTIFICATION	Open Continuous Communication	Maintain an open, continuous communication channel with the <u>NRC</u> <u>Operations Center upon request</u> by the NRC.	- Refer to Reference 2.27	

AP-030	Rev. 27	Page 30 of 76
Ai 000		

ATTACHMENT 7.1 Page 13 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS - NRC REGION II OFFICE			
HBRSEP shall immediately notify the fir	nal delivery carrier ar	nd, by telephone and telegram, mailgram, or fac	simile, the <u>NRC Region II Office</u> when:
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
THEFT/UNLAWFUL DIVERSION OF TRITIUM	Incident Theft Tritium Attempt Security Safeguards	Any incident in which an attempt has been made or is believed to have been made to commit a theft of more than 10 curies of tritium (outside of spent fuel) at any one time or more than 100 curies of tritium in one calendar year.	 10 Curies of tritium discovered missing from the Chemistry Laboratory, and reason exists to suspect that the tritium was stolen
THEFT/UNLAWFUL DIVERSION OF SOURCE MATERIAL	Incident Attempt Theft Diversion Source Security Safeguards	Any incident in which an attempt has been made or is believed to have been made to commit a theft or unlawful diversion of more than 15 pounds of Source Material at any one time or 150 pounds of Source Material in any one calendar year.	 A source assembly is discovered missing from a new fuel shipment.
SHIPPING PACKAGE RADIOACTIVELY CONTAMINATED	Contamination Shipment	Removable radioactive surface contamination exceeds the limits of 10 CFR 71.87;	 New or Spent Fuel Shipment Cask arrives with surface contamination in excess of limits.
SHIPPING PACKAGE EXCEEDING EXTERNAL DOSE RATE LIMITS 10 CFR 20.1906(d)(2)	Radiation Dose Rate Shipment	External radiation levels exceeds of the limits of 10 CFR 71.47.	 New or Spent Fuel Shipment Cask arrives with external radiation levels in excess of limits.

AP-030	Rev. 27	Page 31 of 76

ATTACHMENT 7.1 Page 14 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - FFD					
The NRC Region II Administrator must be notified immediately by telephone of the following:					
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES		
NRC EMPLOYEE NOT FIT FOR DUTY	Alcohol Influence Substance NRC employee FFD Fitness for Duty	If HBRSEP has a reasonable belief that an NRC employee may be under the influence of any substance, or unfit for dutythe Region II Administrator must be notified immediately by telephone. During other than normal working hours, the <u>NRC</u> <u>Operations Center via FTS-2000</u> must be notified.			
10 CFR 26.27(d)					
	IMMEDIATE	(ONE HOUR) NOTIFICATIONS TO THE NRC	- FFD		
The NRC Operations Center via FTS-2	000 must be notified	I immediately by telephone of the following:			
FALSE POSITIVE ERROR ON FFD SPECIMEN 10 CFR 26, Appendix A, Subpart B, 2 8(a)(5)	FFD Fitness for Duty False Positive Specimen Laboratory	Should a false positive error occur on a blind performance test specimen and the error is determined to be an administrative error, HBRSEP shall promptly notify the NRC.			
2.0(8)(3)	2.8(e)(5)				
The NRC Director NRR or Director NMSS must be notified immediately by telephone of the following:					
SURPRISE VISIT OF IAEA OFFICIAL	IAEA International Atomic Energy Agency Credential	HBRSEP shall immediately communicate by telephone, with respect to the credentials of any other person who claims to be an IAEA representative and shall accept telephone confirmation of such credentials by the Commission.	 Person arrives on site bearing IAEA credentials, who is not accompanied by an NRC employee, and has had no prior confirmation in writing of credentials. 		

	D 07	Dage 32 of 76
VD-030	Rev. 21	
AF-030		

ATTACHMENT 7.2 Page 1 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

FOUR HOUR NOTIFICATIONS TO THE NRC If not reported under paragraphs (a) or (b)(1) of 10 CFR 50.72, HBRSEP shall notify the <u>NRC Operations Center via FTS-2000</u> as soon as practical and in all cases, within four hours of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
DEGRADED SAFETY BARRIERS DISCOVERED WHILE SHUT DOWN	Shutdown Safety Barrier Fission Product Barriers Degrade Unanalyzed	Any event, found <u>while the reactor is shut</u> <u>down</u> , that, had it been found while the reactor was in operation, would have resulted in the nuclear power plant, including its principal safety barriers, being seriously degraded or being in an unanalyzed condition that significantly compromises plant safety.	 Corrosion of Reactor Coolant System piping found while shutdown (indicative of a material problem that caused abnormal degradation of the RCS pressure boundary). Significant degradation of Reactor Fuel Rod Cladding identified during testing of fuel assemblies (Reference 2.19).

Rev. 27 Page 33 of /	I
	1761
AI -030	i

ATTACHMENT 7.2 Page 2 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

	FO	UR HOUR NOTIFICATIONS TO THE NRC	
If not reported under paragraphs (a) or	(b)(1) of 10 CFR 50.7	2, HBRSEP shall notify the NRC Operations (Center via FTS-2000 as soon as practical and in all
cases, within four hours of the occurren	nce of any of the follow	ving:	
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
EVENT ESF OR RPS INITIATION (MANUAL/AUTOMATIC)	Manual Automatic Actuation Engineered Safety Feature ESF Valid Clearance Ventilation System Reactor Protection System RPS Reactor Trip	 Any event or condition that results in a manual or automatic actuation of any ESF, including the RPS, except when: (A) The actuation results from and is part of a pre-planned sequence during testing or reactor operation; (B) The actuation is invalid and: (1) Occurs while the system is properly removed from service; (2) Occurs after the safety function has been already completed; or (3) Involves only the following specific ESFs or their equivalent systems: (i) Not Applicable (ii) Control Room emergency ventilation system; (iv) Fuel building ventilation system; (v) Auxiliary building ventilation system. 	 Safety Injection System actuation (also see Emergency Plan Procedures) Reactor Trip (Manual or Automatic). EDG start due to a valid undervoltage trip signal on emergency bus E1 or E2 A single train of Containment Isolation actuates. A valid signal for Containment Ventilation Isolation occurs. All ESF actuations are reportable except the following three categories. 1) An invalid ESF or RPS actuation occurs when the system is already properly removed from service if all requirements of plant procedures for removing equipment from service have been met. This includes required clearance documentation, equipment and control board tagging, and properly positioned valves and power supply breakers. 2) An invalid ESF or RPS actuation occurs after the safety function has already been completed (e.g., an invalid containment isolation signal while the containment isolation signal while the containment isolation of the RPS when all rods are fully inserted). 3) ESF actuations that are caused by non-ESF systems may be excluded because these are not considered ESF actuations of safety significance. (Reference 2.19)
10 CFR 50.72(b)(2)(ii)			systems.

AP-030 Rev. 27 Page 34 of 76

ATTACHMENT 7.2 Page 3 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

FOUR HOUR NOTIFICATIONS TO THE NRC			
If not reported under paragraphs (a) or (b)(1) of 10 CFR 50.72, HBRSEP shall notify the <u>NRC Operations Center via FTS-2000</u> as soon as practical and in all cases, within four hours of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
CONDITION THAT COULD PREVENT FULFILLMENT OF SAFETY FUNCTIONS	Loss of Safety Function Residual Heat Mitigation Shutdown Generic Setpoint Drift Engineering Evaluation Operability Determination Common Mode Failure	 Any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to: (A) Shut down the reactor and maintain it in a safe shutdown condition. (B) Remove residual heat, (C) Control the release of radioactive material, or (D) Mitigate the consequences of an accident. 	 Loss (inoperability) of both Trains, e.g., ECCS, Low Temperature Overpressure Protection System, or Lake Robinson water level below LCO 3.7.8 limit. Overpressurization of the RCS (if Overpressure Protection System fails to perform its intended function) Loss of one Train of required equipment, and the cause of the failure could fail the other train, and there is a reasonable expectation that the other train would not fulfill its safety function if required. Contaminated lubrication fluid degrades SI Pump operation (a single condition could prevent fulfillment of a safety function if both trains could be reasonably expected to be inoperable). EDG Air Start Solenoids (if it demonstrates a design, procedural, or equipment deficiency that could prevent the fulfillment of a safety function, i.e., if both diesels are susceptible to same problem) Multiple equipment inoperability or unavailability. Generic setpoint drift (if indicative of a generic and/or repetitive problem with switches used in safety systems) Oversized breaker wiring lugs (incompatible pigtails and lugs could cause one or more safety systems to fail to perform their intended functions) Control Rod failure (if failure prevented the fulfillment of a safety function) Operator action to inhibit the RPS (actions would prevent fulfillment of a safety function)
10 CFR 50.72(b)(2)(iii)			

AP-030	Rev. 27	Page 35 of 76
Ai -000		

ATTACHMENT 7.2 Page 4 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

	FOUI	R HOUR NOTIFICATIONS TO THE NRC	the state 2000 as soon as practical and in all
If not reported under paragraphs (a) or (b)(1) of 10 CFR 50.72, HBRSEP shall notify the <u>NRC Operations Center via FTS-2000</u> as soon as practical and in all cases, within four hours of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
AIRBORNE RELEASE TO UNRESTRICTED AREA (>20X 10 CFR 20 LIMITS)	Airborne Release Unrestricted Public Radioactive Effluent	Any airborne radioactive release that, when averaged over a time period of 1 hour, results in concentrations in unrestricted area that exceeds 20 times the applicable concentration specified in Appendix B to 10 CFR 20, Table 2, Column 1.	 Unplanned gaseous release (if release exceeded 20 times the applicable concentrations specified in Appendix B, Table 2, Column 1 of 10 CFR 20 averaged over a time period of one hour)
10 CFR 50.72(b)(2)(iv)(A) LIQUID EFFLUENT RELEASE TO UNRESTRICTED AREA (>20X 10 CFR 20 LIMITS)	Liquid Release Unrestricted Public Radioactive Effluent Concentration Discharge	Any liquid effluent release that, when averaged over a time period of 1 hour, exceeds 20 times the applicable concentration specified in Appendix B to 10 CFR 20, Table 2, Column 2, at the point of entry into the receiving waters (i.e., unrestricted area) for all radionuclides except tritium and dissolved noble gases.	 Radioactive release exceeding TS (if release exceeds 20 times the applicable limit of Appendix B, Table 2, Column 2 of 10 CFR 20 when averaged over one hour)
10 CFR 50.72(b)(2)(iv)(B) TRANSPORT OF CONTAMINATED INJURED PATIENT 10 CFR 50 72(b)(2)(v)	Contaminate Injured Person Medical Transport Rescue Hospital	Any event requiring the transport of a radioactively contaminated person to an off-site medical facility for treatment.	 Any event requiring the transport of a radioactively contaminated or potentially contaminated (Reference 2.19) person to an off-site medical facility for treatment

		Dago 36 of 76
	Bey 27	raye so or ro
VD-030	1.67. 21	
AI -050		

ATTACHMENT 7.2 Page 5 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

FOUR HOUR NOTIFICATIONS TO THE NRC				
If not reported under paragraphs (a) or (t cases, within four hours of the occurrenc	If not reported under paragraphs (a) or (b)(1) of 10 CFR 50.72, HBRSEP shall notify the <u>NRC Operations Center via FTS-2000</u> as soon as practical and in all eases, within four bours of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES	
PRESS RELEASES AND GOVERNMENT NOTIFICATIONS	News Release Press Radio Television Fatality Environment Public Health and Safety Release	Any event or situation, related to the health and safety of the public or on-site personnel, or protection of the environment, for which a news release is planned or notification to other government agencies has been or will be made. Such an event may include an on-site fatality or inadvertent release of radioactively contaminated materials.	 Any News release concerning A fatality, Inadvertent release of radioactively contaminated materials to public areas unusual or abnormal releases of radioactive effluents, or Information associated with an Emergency Event except when the ERO is activated (Reference 2.27) Notification to other government agencies concerning A fatality on site, Health and safety of the public or site personnel, Inadvertent release of radioactively contaminated materials to public areas, Discovered endangered species kill. 	

AD 020	Rev. 27	Page 37 of 76
AP-030		

ATTACHMENT 7.2 Page 6 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

FOUR HOUR NOTIFICATIONS TO THE NRC			
HBRSEP shall notify the <u>NRC Operations Center via FTS-2000</u> as soon as possible but not later than 4 hours after the discovery of any of the following events or conditions involving spent fuel.			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
ISFSI - EXPOSURES TO RADIATION OR RADIOACTIVE MATERIALS IN EXCESS OF LIMITS, OR RELEASES IN EXCESS OF LIMITS	ISFSI Release Exposure Fire Explosion Toxic	Any event that prevents immediate actions necessary to avoid exposures to radiation or radioactive materials that could exceed regulatory limits, or releases of radioactive materials that could exceed regulatory limits (e.g., events such as fires, explosions, and toxic gas releases).	 Explosion or fire involves ISFSI resulting in radiological releases
10 CFR 72.75(b)(1)			- A defect discovered in the design or construction
ISFSI - DEFECT IMPORTANT TO SAFETY 10 CFR 50.72(b)(2)(vii)(A) 10 CFR 72 75(b)(2)	ISFSI Defect Safety	system, or component which is important to safety.	of ISFSI units that could result in releases or radiation doses to the public in excess of 10 CFR 20 limits
ISFSI - REDUCTION IN EFFECTIVENESS 10 CFR 50.72(b)(2)(vii)(B) 10 CFR 72 75(b)(3)	ISFSI Confinement Reduction Effectiveness	A significant reduction in the effectiveness of any spent fuel storage cask confinement system during use.	 Wear or degradation of ISFSI units that could result in releases or radiation doses to the public in excess of 10 CFR 20 limits
ISFSI - DEPARTURE FROM LICENSE CONDITION	ISFSI Emergency Departure Deviation Health and Safety License Condition	An action taken in an emergency that departs from a condition or a technical specification contained in a license or certificate of compliance issued under 10 CFR 72 when the action is immediately needed to protect the public health and safety and no action consistent with license conditions or technical specifications that can provide adequate or equivalent protection is immediately apparent.	 Action taken in an emergency that departs from procedure that is deemed necessary to prevent releases or radiation doses to the public in excess of 10 CFR 20 limits (See PRO-NGGC- 0200)

	Boy 27	
AF-030		

ATTACHMENT 7.2 Page 7 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

	FOU	R HOUR NOTIFICATIONS TO THE NRC	
HBRSEP shall notify the NRC Operations Center via FTS-2000 as soon as possible but not later than 4 hours after the discovery of any of the following events			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
ISFSI - TREATMENT OF CONTAMINATED PERSON AT OFFSITE MEDICAL FACILITY	ISFSI Contaminate Injured Person Medical Transport Rescue Hospital	An event that requires unplanned medical treatment at an offsite medical facility of an individual with radioactive contamination on the individual's clothing or body which could cause further radioactive contamination.	 An individual is injured requiring offsite medical treatment and receives contamination from ISFSI(s) that cannot be removed prior to transport
		An unplanned fire or explosion damaging	 ISFSI unit is damaged by an external
10 CFR 72.75(b)(6)	Fire Explosion Damage Integrity	any spent fuel, or any device, container, or equipment containing spent fuel when the damage affects the integrity of the material or its container	explosion and the integrity of the ISFSI unit is potentially affected

	Pov 27	
ΔΡ-030		
/1 000		

Question: 76

Which of the following conditions would require a One-Hour Notification in accordance with AP-617, Reportability Determination and Notification?

- a. A manual reactor trip is actuated from 40% power due to a trip of the running Main Feedwater Pump
- b. An automatic safety injection is actuated at 100% power due to an I&C Technician lifting an incorrect lead
- c. While at 400°F during a plant cooldown, all warning sirens in Lee County are reported to be out-of-service due to severe weather.
- d. While at 400°F during a plant heatup following a refueling outage, the plant is cooled down to Mode 4 to meet a Technical Specification action statement.

Answer:

c. While at 400°F during a plant cooldown, all warning sirens in Lee County are reported to be out-of-service due to severe weather.

SRO BACKUP REPLACEMENT

Question: 39

Given the following conditions:

- The RCS is at 190°F during a plant cooldown.
- A break in the CCW system has resulted in all CCW pumps being tripped.
- All RCPs have been secured. •
- Charging Pump 'B' is running, with Charging Pump 'A' secured.
- Charging Pump 'C' is under clearance.
- AOP-017, Attachment 1, "Emergency Cooling to Charging Pump," has just been started. 014

Which ONE (1) of the following describes how the Charging Pumps should be configured until emergency cooling is available?

- All Charging Pumps should be stopped (LOSS-OF-COOLING TO-PUMPS) a.
- Charging Pumps 'A' and 'B' should be alternately operated every 15 minutes b. -(MINIMIZE HEATING OF PUMPS AND ALLOW COOLDOWN)-
- Charging Pump 'B' should be operated at minimum speed (SEAL INJECTION-C. _REQUIRED-UNTIL-RCS-<-150°F)-
- Charging Pump 'B' should be operated at maximum speed (SEAL INJECTIONd. REQUIRED-UNTIL-RCS-<-150°F-BUT-HIGHER-FLOW-RESULTS-IN-LESS----HEATING OF PUMP)-

Answer:

d. Charging Pump 'B' should be operated at maximum speed

Replacement

Question: 39

Given the following conditions:

- The unit is in a refueling outage.
- GP-010, "Refueling", is being implemented.
- NO core alterations are in progress.
- At 0800, CCW was isolated to the operating RHR pump seal cooler per OP-201, "Residual Heat Removal System."

Which ONE (1) of the following describes when the RHR pump must be secured?

- a. At 0900
- b. When core alterations are resumed
- c. When RCS temperature exceeds 140 °F.
- d. When RHR pump discharge temperature exceeds 135 °F.

Answer:

d. When RHR pump discharge temperature exceeds 135 °F.

				RNP NRC Written Examination SRO Only Question Reference
	IUMBER:	39	680	1/1
K/A:	026AA2.04	RU	370	17.1
	Ability to deter Water: The no CCW	mine and interpret the followin rmal values and upper limits fo	g as they apply to or the temperature:	the Loss of Component Cooling s of the components cooled by
K/A IMPORT, 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	2.9 5
OBJECTIVE:	RHR-05			
	DESCRIBE th	e performance and design attr	butes of the major	RHR System components.
DECEDENCE	-0.	00.201		
REFERENCE	:5:	OP-201		
SOURCE:	New	Significantly Modified		Direct X
		Bank Number	OP-201-06	001
JUSTIFICAT <i>a.</i>	ION:	<i>Bank Number</i> Plausible since TS allows RH time while refueling, but RHR	OP-201-06 R to be removed fi pump seal cooling	001 rom operation for this period of is not based on this limit.
JUSTIFICAT a. b.	ION:	<i>Bank Number</i> Plausible since TS allows RH time while refueling, but RHR Plausible since RHR operabili operability is not affected by 0 temperature increases enoug	OP-201-06 R to be removed fi pump seal cooling ty is required durir CCW flow to the se h to cause RHR p	001 rom operation for this period of is not based on this limit. ng core alterations, but pump eal coolers until seal cooler ump concerns.
JUSTIFICAT a. b. c.	ION:	Bank Number Plausible since TS allows RH time while refueling, but RHR Plausible since RHR operabili operability is not affected by 0 temperature increases enoug Plausible since this is the upp refueling, but RHR pump ope	OP-201-06 R to be removed fi pump seal cooling ty is required durir CCW flow to the se h to cause RHR p er administrative li ration is not based	001 rom operation for this period of is not based on this limit. Ing core alterations, but pump eal coolers until seal cooler ump concerns. imit for RCS temperature during t on this limit.
JUSTIFICAT a. b. c. d.	ION: CORRECT	Bank Number Plausible since TS allows RH time while refueling, but RHR Plausible since RHR operabili operability is not affected by C temperature increases enoug Plausible since this is the upp refueling, but RHR pump ope If CCW is not available to the be operated with pump discha	OP-201-06 R to be removed figump seal cooling ty is required durin CCW flow to the set h to cause RHR piger er administrative light ration is not based RHR pump seal coordinates	001 rom operation for this period of is not based on this limit. Ing core alterations, but pump eal coolers until seal cooler ump concerns. Imit for RCS temperature during on this limit.
JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	ION: CORRECT ': nsive/Analysis	Bank Number Plausible since TS allows RH time while refueling, but RHR Plausible since RHR operabili operability is not affected by O temperature increases enoug Plausible since this is the upp refueling, but RHR pump ope If CCW is not available to the be operated with pump discha	OP-201-06 R to be removed figump seal cooling ty is required durin CCW flow to the set h to cause RHR p er administrative lig ration is not based RHR pump seal c arge temperature s	001 rom operation for this period of a is not based on this limit. Ing core alterations, but pump eal coolers until seal cooler ump concerns. This for RCS temperature during on this limit. Oolers, the RHR pumps shall not greater than 135 °F.

REFERENCES SUPPLIED:

- 5.7 When both RHR-757C and RHR-757D are open, 3750 gpm total per running pump as read from FI-605, FI-608A and FI-608B shall not be exceeded, except as allowed/required by approved test procedures for which total flowrates may be as high as 4200 gpm for one pump or 8400 gpm for two pumps.
- 5.8 When running RHR Pumps with SI-863A and/or SI-863B open, RHR-744A and RHR-744B should be closed to prevent excessive RHR pump runout.
- 5.9 If CCW is not available to the RHR pump seal coolers, the RHR pumps shall not be operated with pump discharge temperature greater than 135 °F. With CCW available to the RHR pump seal coolers there is no time limit for running a single pump with flow only through the heatup recirculation line. It will be necessary to rotate the RHR pumps to avoid exceeding the 50 °F ΔT limit between RHR loops as stated in GP-007.
- 5.10 RHR pump flowrates of less than 2,800 gpm have been shown to increase pressure and flow fluctuations and should be avoided when plant conditions permit. This does not apply during recirculation operation. (ACR 91-078)
- 5.11 With the exception of swapping running pumps, when RHR is aligned for core cooling, both RHR Pumps should not be run simultaneously on recirculation when forward flow is not established to prevent pump over heating from dead heading of the weaker pump. (CR 98-01791)
- 5.12 With no flow in the RHR system, an RHR Pump should not be started with FCV-605 in automatic. This could allow runout of the pump before FCV-605 could respond to control flow.
- 5.13 RHR-750 **AND** RHR-751 shall not be operated (electrically or manually) in a dry condition. Damage to the valve seat may result without water to provide lubrication.
- 5.14 The principles of **ALARA** shall be used in planning and performing work and operations in the Radiation Control Area.
- 5.15 This procedure has been screened IAW PLP-037 criteria and determined not applicable to PLP-037.

OP-201	Rev. 38	Page 7 of 68
Given the following conditions:

- A reactor trip has occurred.
- A transition has been made from PATH-1 to EPP-4, "Post Trip Response."
- APP-004-B2, PZR LO PRESS TRIP, is flashing.
- RCS Pressure is 1825 psig and lowering slowly.
- Pressurizer level is 13% and decreasing at 2% per minute.
- RCS Temperature is 553 °F and lowering slowly.
- 'B' and 'C' Charging Pumps are running.

Which ONE (1) of the following describes the instructions the CRSS should give to the Reactor Operator?

- a. Start **BOTH** Safety Injection Pumps
- b. Verify Letdown isolated and start 'A' Charging Pump
- c. Initiate Safety Injection
- d. Stabilize RCS temperature

Answer:

c. Initiate Safety Injection

QUESTION N TIER/GROUF K/A:	IUMBER: 2: 006A2.12	40	RO	SR	o :	2/2
	Ability to (a) pr based on thos Conditions req	redict the impar e predictions, u juiring actuation	cts of the follow use procedures ns	ing malfunctic to correct, co	ons or c ontrol, c	operations on the ECCS; and (b) or mitigate the consequences:
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	F 55.41(b)	RO RO	SR 55.43(b) SR	0 20	4.8 5
OBJECTIVE:	FOLDOUT A-	80				
	Given plant co directed by ste	onditions EVAL eps in EPP-Fol	UATE the appro douts.	opriate actions	s to mit	tigate consequences of events as
REFERENCE	ES:	EPP-Foldouts				
SOURCE:	New	Significa	antly Modified			Direct X
SOURCE:	New	Significa	antly Modified Bank Number	Foldo	<i>ב</i> 100 UT A	Direct X 3 001
SOURCE: JUSTIFICAT a.	New	Plausible sinc required if una	antly Modified Bank Number this is a requir able to maintain	FOLDO	<i>L</i> UT A-0 Foldout evel.	Direct X 3 001 t B, but in Foldout A SI initiation is
SOURCE: JUSTIFICAT a. b.	New	Plausible sinc required if una Plausible sinc 10%, but PAT capacity requi	antly Modified Bank Number this is a requir able to maintain the starting an ad TH-1 directs star ires SI initiation.	FOLDON red action in F pressurizer le ditional charg ting only 2 ch	L UT A-0 Foldout evel. ging pur harging	Direct X 3 001 t B, but in Foldout A SI initiation is mp may help keep level above pumps and leakage beyond this
SOURCE: JUSTIFICAT a. b. c.	New	Plausible sinc required if una Plausible sinc 10%, but PAT capacity requi In Foldout "A" level greater t	antly Modified Bank Number this is a require able to maintain the starting an ad TH-1 directs star ires SI initiation. I, required to initiation.	FOLDON red action in F pressurizer le ditional charg ting only 2 ch	L UT A-0 Foldout evel. ging pur harging njection	Direct X 3 001 t B, but in Foldout A SI initiation is mp may help keep level above pumps and leakage beyond this if unable to maintain Pressurizer
SOURCE: JUSTIFICAT a. b. c. d.	New	Significat Significat Plausible since required if una Plausible since 10%, but PAT capacity requi In Foldout "A" level greater t Plausible since temperature is after no-load	antly Modified Bank Number the this is a require able to maintain the starting an ad "H-1 directs star ires SI initiation. ", required to init than 10%. The lowering RCS s still above no- temperature acl	FOLDON red action in F pressurizer le ditional charg ting only 2 ch tiate Safety In S temperature load tempera hieved.	L UT A-0 Foldout evel. ging pur harging hjection e will rea	Direct X 3 001 t B, but in Foldout A SI initiation is mp may help keep level above pumps and leakage beyond this if unable to maintain Pressurizer sult in lowering level, but RCS ind level should be maintained
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Comprehea	New ION: CORRECT 1: nsive/Analysis	Signification Plausible since required if unate Plausible since 10%, but PAT capacity required In Foldout "A" level greater to Plausible since temperature is after no-load to Knote	antly Modified Bank Number e this is a require able to maintain the starting an ad TH-1 directs star ires SI initiation. If, required to initiation. If, required to initiation. Than 10%. The lowering RCS is still above no- temperature acl	FOLDOU red action in F pressurizer la ditional charg ting only 2 ch tiate Safety In tiate Safety In	UT A-0 Foldout evel. arging put arging njection e will rea ture an	Direct X 3 001 t B, but in Foldout A SI initiation is mp may help keep level above pumps and leakage beyond this if unable to maintain Pressurizer sult in lowering level, but RCS ind level should be maintained

REFERENCES SUPPLIED:

FOLDOUT A	
(Page 1 of 6)	
1. RCP TRIP CRITERIA	
IF BOTH conditions below are met, THEN stop all RCPs:	
 SI Pumps - AT LEAST ONE RUNNING AND CAPABLE OF DELIVERING FLOW TO THE CORE 	
 RCS Subcooling - LESS THAN 35°F [55°F] 	
2. <u>SI ACTUATION CRITERIA</u>	
<u>IF EITHER</u> condition below occurs, <u>THEN</u> Actuate SI and Go To PATH-1, Entry Point A:	
 RCS Subcooling - LESS THAN 35°F [55°F] 	
 PZR Level - CAN <u>NOT</u> BE MAINTAINED GREATER THAN 10% [32%] 	
3. SPRAY ACTUATION CRITERIA	
IF a valid CV Spray Signal occurs, <u>THEN</u> dispatch an Operator to the Safeguards Racks to block CV Spray as follows: (A screwdriver is available locally for opening the panels)	
a. At the front of Safeguards Relay <u>Rack 51</u> , rotate Test Switch Number 5 (PC-951A) to the PUSH TO TEST position.	
b. At the front of Safeguards Relay <u>Rack 63</u> , rotate Test Switch Number 5 (PC-951A) to the PUSH TO TEST position.	
4. AFW SUPPLY SWITCHOVER CRITERIA	
IF CST level decreases to less than 10%, <u>THEN</u> switch to backup water supply using OP-402, Auxiliary Feedwater System.	

Question: 56

Given the following conditions:

- GP-003, "Normal Plant Startup from Hot Shutdown to Critical," is being performed.
- The reactor is **NOT** critical.
- Two (2) doublings have been performed.
- The ECP extrapolated from the 1/M plot is 44 steps on CBD.
- The minimum calculated critical position for the startup is 62 steps on CBD and the maximum calculated critical position is 174 steps on CBD.

Which ONE (1) of the following choices describes the correct actions to be taken?

- a. Add 250 gallons of boric acid to the RCS
- b. Insert all Control Banks and Shutdown Bank B rods
- c. Continue the reactor startup and perform an additional doubling
- d. Perform a normal reactor shutdown per GP-006

Answer:

c. Continue the reactor startup and perform an additional doubling

۰

QUESTION N TIER/GROUP K/A:	UMBER: : 001A2.12	56	RO	SRO	2/1
	Ability to (a) pr based on thos those malfunct	edict the impace e predictions, u tions or operations	ets of the followi use procedures ons: Erroneous	ng malfunction o to correct, contro ECP calculation	r operations on the CRDS- and (b) I, or mitigate the consequences of
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	F 55.41(b) F	80 80	SRO 55.43(b) SRO	4.2 6
OBJECTIVE:	GP-003-08				
	Given plant co related to ever	nditions EVALI nts as directed	JATE the appro in GP-003.	priate actions to	mitigate consequences of steps
REFERENCE	S:	GP-003			
SOURCE:	New	Significa	ntly Modified Bank Number	X GP-003-03	Direct
JUSTIFICAT	ION:		Dank Number	01-000-00	
а.		Plausible since criticality below should be perf	e this action wor v the minimum o formed.	uld be performed control rod insert	if the reactor actually achieved ion limit, but additional doublings
b.		Plausible since criticality below should be perf	e this action wor v the minimum o formed.	uld be performed control rod insert	if the reactor actually achieved ion limit, but additional doublings
с.	CORRECT	A minimum of unless the pre doubling would	three doublings dicted position i d be performed	are performed b s outside the +/- before achieving	efore actually achieving criticality 500 pcm position, when a fourth criticality.
d.		Plausible since criticality below additional dou	e this action wo w the minimum blings should be	uld be performed rod position for c e performed.	if the reactor actually achieved riticality (-500 pcm position), but
DIFFICULTY Compreher	: nsive/Analysis	Kno	wledge/Recall	X Rating	3

Knowledge of procedural requirements providing guidance for reactor startup activities

REFERENCES SUPPLIED:

5.8.3 Shutdown Bank "A" shall be at the fully withdrawn position whenever reactivity is being changed by Boron or Xenon changes, RCS temperature changes, or Control Rods, other than Shutdown Bank "A". The following exceptions to this rule may be applied:

NOTE: The COLR identifies the required Shutdown Margin (SDM) based on plant conditions. The required Boron Concentration can be determined using Powertrax or the Plant Curve Book using the SDM identified in the COLR.

- 1. The RCS has been borated and confirmed by sampling, to be at least at the Boron Concentration needed to provide the required SDM for MODE 3 and is being maintained at MODE 3. Approval of the Manager Operations, or his designated alternate, shall be given for Shutdown Bank "A" to be inserted.
- 2. The RCS has been borated and confirmed by sampling, to be at least at the Boron Concentration needed to provide the required SDM for MODE 5. Approval of the Manager Operations, or his designated alternate, shall be given for Shutdown Bank "A" to be inserted.
- 5.8.4 **IF** Shutdown Bank "A" cannot be withdrawn, **THEN** the RCS shall be borated as required IAW Step 5.8.3.
- 5.9 Precautions During Approach to Critical:
 - 5.9.1 Startup Rate shall **NOT** be permitted to exceed 1.0 decade/minute as read on the STARTUP RATE METER.
 - 5.9.2 An Inverse Count Rate Ratio Plot (I/M) with a minimum of four data points (including baseline data point which is taken after Shutdown Banks "A" and "B" are fully withdrawn) shall accompany the Reactor startup.
 - 5.9.3 The Reactor Operator may shutdown the Reactor if the predicted critical rod position from the 1/M plot falls outside the +/-500 pcm positions. (Project 97-00161)
- 5.10 Whenever possible, the Steam Dump Valves should be used for temperature control instead of Steam Line PORVs.

	D	Page 9 of 40
00 002	Rev. b1	
GF-003	1.01.01	

8.2.20 Withdraw Shutdown Bank "B" as follows:

- 1. To ensure sufficient time is available to achieve criticality using the current ECP and thereby satisfy ITS SR 3.1.6.1, check that Attachment 10.1 was completed less than 2 hours ago.
- 2. Select SBB on the Rod Bank Selector switch.
- 3. Withdraw Shutdown Bank "B" to 225 steps while performing the checks of Attachment 10.3.
- 4. WHEN Shutdown Bank "B" is greater than 20 steps, AND MODE 2 has not been declared, THEN perform the following:
 - a. Make a plant announcement that MODE 2 has been entered.
 - b. Use the PMODE function to change the ERFIS Mode indication to display MODE 2.
- 5. Verify the Source Range count rate stabilizes **AND** does **NOT** increase in an unexpected manner.

NOTE: A minimum of four inverse count rate ratio (1/M) data points are required on the approach to criticality. The data points should be taken each time the count rate approaches a value that is double the previous stable data point. This is referred to as "doubling". The first data point, Reference Count Rate (CR₀), is obtained after Shutdown Bank "B" has been fully withdrawn.

The Audio Count Rate VOLUME AND AUDIO MULTIPLIER should be adjusted as the count rate increases to maintain a distinguishable audible count rate.

8.2.21 WHEN Shutdown Bank "B" is fully withdrawn AND the count rate is stable, THEN record the time AND Reference Count Rate (CR_0) on Attachment 10.2.

GP-003	Rev. 61	Page 24 of 40
01 000		

8.2.23 (Continued)

3. Transfer NR-45 from the selected Source Range channel to the highest reading intermediate Range **AND** Power Range channels.

IR	N	
PR	N	

NOTE: The approach to criticality should take approximately four doublings of the indicated reference count rate (CR_0) under ideal conditions. The target count rate is intended to serve as a known stable reactivity state suitable for data taking and criticality predictions.

It is **NOT** necessary, **AND** impractical, to attempt to stabilize at exactly double the previous count rate, therefore the use of a "target count rate" (as applied to each doubling of the count rate) is intended to allow the Operator to stabilize the core as close as is practical to the "doubling" count rate without excessive rod motion.

APP-005-F2, ROD BOTTOM ROD DROP, will extinguish when Control Bank "A" is above 20 steps.

- 8.2.24 Withdraw control rods to achieve the target count rate determined in Attachment 10.2 as follows:
 - Select "M" on the Rod Bank Selector switch.
 - 2. Withdraw Control Rods until count rate is approximately equal to the target count rate while performing the checks and verifications of Attachment 10.3.
 - 3. Verify the count rate stabilizes **AND** does **NOT** increase in an unexpected manner.
 - 4. **IF** criticality is indicated, **THEN** Go To Section 8.3.

NOTE: Each successive reactivity addition will require less rod motion **AND** a longer time for the count rate to stabilize. The NR-45 trace should be closely monitored and cross-checked against available instrumentation to determine when count rate has stabilized following each successive rod pull to double counts.

8.2.25 WHEN rod motion has been stopped AND count rate is stable, THEN record the required information on Attachment 10.2.

		D
00.000	Rev 61	Page 20 01 40
GP-003	1164.01	
	and the second	

8.3 Critical Operations

8.3.1	Check that Criticality was achieved above the Minimum Rod Position for Criticality AND below the Maximum Rod Position for Criticality.				
8.3.2	IF criticality occurs AND the Control Rods are BELOW the Minimum Control Rod Insertion Limit, THEN perform the following:				
	1.	Shutdown the Reactor as follows:			
		 Add 250 gallons of Boric Acid to the RCS. 			
		 Insert ALL Control Banks AND Shutdown Bank "B". 			
	2.	Assign a Startup Number.			
	3.	Notify the Reactor Engineer of the reactivity anomaly.	<u></u>		
	4.	N/A the remainder of this GP-003 AND DO NOT continue until the situation is resolved.			
8.3.3	IF the Positi	e Reactor goes Critical below the Minimum Rod ion for Criticality, THEN perform the following:			
	_	Perform a Reactor Shutdown IAW GP-006.			
	-	Assign a Startup Number AND N/A the remainder of this procedure.			
	-	Notify Reactor Engineer of the anomaly.			
8.3.4	IF the Maxi follow	e Reactor does NOT go critical with control rods at the mum Rod Position for Criticality, THEN perform the ving:			
		Insert all Control Banks AND Shutdown Bank "B".			
		N/A the remainder of this procedure.			
		Notify Reactor Engineer of the anomaly.			

		Dama 20 of 40
CD 002	Rev. 61	Page 29 01 40
GP-003	1.011.01	

٦

GP-003-03 020

Given the following plant conditions:

- GP-003, Normal Plant Startup from Hot Shutdown to Critical, is in progress.
- The reactor is sub-critical.
- Three doublings have been performed.
- The ECP extrapolated from the 1/M plot is 182 steps on CBD.
- The minimum calculated critical position for the startup is 62 steps on CBD and the maximum calculated critical position is 174 steps on CBD.

Which ONE (1) of the following choices describes the correct actions to be taken?

- A. Perform a normal reactor shutdown IAW GP-006, assign a startup number and N/A the remainder of GP-003, and notify Reactor Engineering.
- B. Insert all control banks and Shutdown Bank B rods, N/A the remainder of GP-003, and notify Reactor Engineering.
- ✓C. Perform an additional doubling and see if the extrapolated critical position will fall within the minimum and maximum allowable critical positions
 - D. IAW GP-003, Maintain current plant conditions, notify Reactor Engineering for guidance.

1900

1. S. . . .

Given the following conditions:

- A large steam line break occurred while the unit was operating at 100% power.
- After performing the actions of PATH-1, a transition was made to FRP-P.1, "Response to Pressurized Thermal Shock."
- An RCS soak has been initiated.
- RCS temperature has been stable at 360 °F for the past 25 minutes.
- RCS pressure is 450 psig.

Which ONE (1) of the following describes an action that would be permissible during the RCS soak period?

- a. Increase SG level by adjusting the AFW flow controllers
- b. Increase RHR flow by adjusting the RHR HX Bypass Flow controller
- c. Increase subcooling margin by adjusting the Steam Dump controller
- d. Increase subcooling margin by energizing pressurizer heaters

Answer:

b. Increase RHR flow by adjusting the RHR HX Bypass Flow controller

QUESTION NUTIER/GROUP:	JMBER: WE08EA2.2	57 RO	SRO	1/1	
	Ability to detern Adherence to a and amendme	mine and interpret the foll appropriate procedures a nts.	lowing as they apply nd operation within t	to the (Pressurized he limitations in the	Thermal Shock) facility's license
K/A IMPORTA 10CFR55 CON	NCE: ITENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	4.1 5	
OBJECTIVE:	FRP-P.1-03				
	DEMONSTRA explaining the	TE an understanding of s basis of each.	elected steps, cautio	ons, and notes in FF	RP-P.1 by
REFERENCES	S:	FRP-P.1 SD-003			
SOURCE:	New	Significantly Modi	fied	Direct X	
		Bank Nu	mber FRP-P.1-0	3 011	
JUSTIFICATIO a.	ON:	Plausible if misconceptic control band, but this wo	on is that changes ca uld result in an RCS	n be made within n cooldown which is	ormal limits of not permitted.
b.	CORRECT	Increasing RHR bypass temperature will remain cause an increase in pre	flow will not affect flo stable or increase. I essure or a decrease	ow through the RHF During the soak peri in temperature are	HX so RCS iod, operations that not permitted.
с.		Plausible if misconceptic control band, but this wo	on is that changes ca ould result in an RCS	an be made within n cooldown which is	ormal limits of not permitted.
d.		Plausible if misconceptic control band, but this wo permitted.	on is that changes ca buld result in an incre	an be made within r ease in RCS pressu	ormal limits of re which is not
DIFFICULTY: Comprehent	sive/Analysis	X Knowledge/R	ecall 🔲 Rating	3	
	Analysis of op requirements	perations on RCS temper	ature and pressure t	o ensure complianc	e with PTS

REFERENCES SUPPLIED:

RESPONSE TO IMMINENT PRESSURIZED THERMAL SHOCK

Rev. 12

Page 21 of 22

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
44.	Check Cooldown Rate In RCS Cold Legs - GREATER THAN 100°F IN ANY 60 MINUTE PERIOD	Go To Step 47.
45.	Check RCS Temperature - HAS BEEN STABLE FOR ONE HOUR	Perform the following:
		a. Do <u>NOT</u> cooldown the RCS.
		b. Do <u>NOT</u> increase RCS pressure.
		c. Perform actions of any other procedures in effect which do <u>NOT</u> cooldown the RCS <u>OR</u> increase RCS pressure.
		d. <u>WHEN</u> RCS temperature has been stable for one hour, <u>THEN</u> Go To Step 46.
46.	Observe The Following Restrictions:	
	a. Maintain RCS pressure and Cold Leg temperature within the limits of Attachment 1, Post Soak Cooldown Limit Curve, during <u>ALL</u> subsequent actions	
	 b. Maintain cooldown rate in RCS Cold Legs less than 50°F/hr <u>OR</u> administrative limits of GP-007, Plant Cooldown From Hot Shutdown To Cold Shutdown, which ever is more restrictive in any 60 minute period 	
47.	Reset SPDS <u>AND</u> Return To Procedure And Step In Effect	
	- 1	END -

5.3 RHR LOOP ISOL SI-862 A & B, RWST to RHR Pump Suction Isolation

Two motor operated valves are provided to isolate the RHR pump suction from the RWST. When lining up for the injection phase, they will be open. In the recirculation phase, they will be closed prior to taking a suction on the CV floor. They are also closed when the RCS is being cooled by the RHR System. To prevent over pressurization of the RWST and other related low pressure piping and to prevent depressurizing the RCS to RWST, these valves are interlocked so they can't be opened unless the RHR System is less than 210 psig (862A and 863A -PC-601A, 862B and 863B -PC-600B). Keyed switches located behind the RTGB remove the control power from these valves during normal operation.

5.4 RHR-FCV-605, RHR HX Bypass Flow

FCV-605 will automatically maintain a preset flowrate through the operating RHR loop (set by operator). It is an air operated, fail closed valve. If FCV-605 did fail closed, all the flow would be directed through the RHR heat exchanger. This may result in Cooldown rate being higher than desired until valve control was obtained. This problem is addressed in AOP-020, Loss of RHR Cooling.

FCV-605 works in conjunction with hand control valve RHR-HCV-758 and FT-605. HCV-758 is adjusted to increase or decrease flow through the RHR Heat Exchangers to change the Heat up or Cooldown rate. This causes total system flow to be effected and is sensed by FT-605. The flow loop circuitry provides a control signal to FCV-605 which maintains a constant total system flow.

At power, Instrument Air is isolated to FCV-605 (Required by Tech. Specs. when > 1000 psig). A portable skid mounted controller is available for use during Post Fire Repairs if FCV-605 control circuits are damaged or inoperable. These procedures would also line up to use the Nitrogen system for motive force and for valve control.

5.5 RHR-HCV-758, RHR HX Discharge Flow

HCV-758 is throttled from RTGB to control Cooldown or Heat up rate by controlling RHR flow through the heat exchanger. It is an air operated value that fails closed.

At power, Instrument Air is isolated to HCV-758 (Required by Tech. Specs. when > 1000 psig). A portable skid mounted controller is available for use during Post Fire Repairs if HCV-758 control circuits are damaged or inoperable. These procedures also allow the use of Nitrogen as a backup for motive force and for valve control.

INFORMATION USE ONLY

Given the following conditions:

- Following a loss of all AC, EPP-1, "Loss of All AC Power," is being performed.
- Attachment 5, "Removing Control Power From Safeguard Equipment," has been completed.
- The SGs are being depressurized which results in a Safety Injection signal being actuated.
- The Safety Injection signal is reset after being actuated.
- During the SG depressurization, the Dedicated Shutdown Diesel Generator is started.
- Several minutes later, Emergency Diesel Generator 'A' is started.
- SW Pump 'A' automatically starts.
- SG pressures are stabilized by local operator action.

Plant conditions are now:

- EDG 'A' is running.
- SW Pump 'A' is running.
- **NO** other pumps are running.
- All SI valves are aligned in their pre-trip position.
- RCS pressure is 1400 psig.
- RCS temperature is 492 °F.
- RCS subcooling is 96 °F.
- Pressurizer level is 6%.

Which ONE (1) of the following identifies the procedure to be used for recovery from this condition?

- a. EPP-2, "Loss Of All AC Power Recovery Without SI Required"
- b. EPP-3, "Loss Of All AC Power Recovery With SI Required"
- c. EPP-22, "Energizing Plant Equipment Using Dedicated Shutdown Diesel Generator"
- d. EPP-25, "Energizing Supplemental Plant Equipment Using the DSDG"

Answer:

b. EPP-3, "Loss Of All AC Power Recovery With SI Required"

QUESTION N TIER/GROUF K/A:	IUMBER: ?: 055 2.4.16	58 RO	SRO	1/1
	Knowledge or (Station Black	f EOP implementation hie <out).< th=""><th>rarchy and coordinatior</th><th>a with other support procedures</th></out).<>	rarchy and coordinatior	a with other support procedures
K/A IMPORT, 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	4.0 5
OBJECTIVE:	EPP-001-08			
	Given plant complete loss	onditions EVALUATE the of all AC power as direct	appropriate actions to r ted by the steps in EPP	nitigate the consequences of a -1.
REFERENCE	S:	EPP-001		
	Nou			
SOURCE:	New	X Significantly Modi		Direct
		Bank Nu	mber	NEW
JUSTIFICATI a.	ON:	Plausible since no SI equiput EPP-3 is used due to	uipment has actuated a o the low level in the pre	nd no valves have repositioned, essurizer.
b.	CORRECT	Although no SI equipmen used due to the low leve	nt has actuated and no I in the pressurizer.	valves have repositioned, EPP-3 is
с.		Plausible since this proc is not used as a recover	edure is performed dur y procedure.	ing the performance of EPP-1, but
d.		Plausible since this proc during the loss of all AC,	edure may be performe but is not used as a re	ed as a supplemental procedure covery procedure.
DIFFICULTY: Comprehen	sive/Analysis	X Knowledge/R	ecall 🔲 Rating	3

Analysis of plant conditions following AC power restoration to determine recovery flowpath

REFERENCES SUPPLIED:

EPP-1		LOSS OF ALL A			IER	Rev. 28 Page 28 of 51	
		INSTRUCTIONS			RESPONSE NOT OBT	AINED	
57. \$	Select	Recovery Procedure:					
ł	a. RCS 35°	5 subcooling - GREATER TH 'F [55°F]	AN	a.	Go To EPP-3, Loss Power Recovery Wit Required.	Of All AC h SI	
1	b. PZI [32	R level - GREATER THAN 10 2%]	010	b.	b. Go To EPP-3, Loss Of All AC Power Recovery With SI Required.		
	c. Che AC	eck SI Equipment - ANY TUATED ON AC POWER RECOVE	RY	c.	Go To EPP-2, Loss Power Recovery Wit Required.	Of All AC hout SI	
	•	Pumps started					
		OR					
	•	Valves repositioned					
	d. Go Po Re	To EPP-3, Loss Of All AG wer Recovery With SI quired	!				
			- ENI	D -			

Given the following conditions:

- The unit is in Mode 3.
- RCS temperature is at no-load Tavg.
- RCS pressure is 2235 psig.
- RCS gross activity is < 100/E-Bar μCi/gm.
- Dose Equivalent Iodine I-131 is 200 μCi/gm.
- These conditions have existed for the past 48 hours.

Given the supplied references, which ONE (1) of the following describes the requirements for these conditions?

- a. Power may be increased, but **CANNOT** exceed 44%
- b. No-load conditions may be maintained indefinitely, but the unit **CANNOT** be started up
- c. RCS temperature must be reduced to < 500 °F within 6 hours
- d. Mode 4 conditions must be established within 6 hours

Answer:

c. RCS temperature must be reduced to < 500 °F within 6 hours

QUESTION N TIER/GROUP K/A:	UMBER: : 076AA2.02	59 RO		SRO	1/1	
	Ability to detern Corrective acti	mine and interpret the fo ons required for high fis	bllowing as they sion product ac	apply to tivity in R	the High Reactor Coolant Activity: CS	
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	55.43(b)	SRO SRO	3.4 2	
OBJECTIVE:	RCS-12					
	Given a plant o Technical Spe Technical Spe	condition and a copy of cifications requirements cifications and Technica	Technical Spec for the Reactor A Specification I	ifications, ⁻ Coolant interpreta	DETERMINE the applicable System IAW H. B. Robinson tions.	
REFERENCE	S:	TS 3.4.16				
SOURCE:	New	Significantly Mod	dified		Direct X	
		Bank N	umber RCS	S-13	031	
JUSTIFICAT a.	ION:	Plausible since power l 44%, but must have be	imit for accepta een restored bel	ble opera ow 1.0 u0	tion for this value of DEQ I-131 is Ci/gm within 48 hours.	
b.		Plausible since power or restoration within limits hours.	operations woul has expired, bu	d not be j ut must re	permitted since the time period for educe RCS temperature within 6	
<i>c.</i> CORRECT Although DE I-131 is within the limits of TS Figure 3.4.16-1, it is > 1.0 uCi/gm must have been restored within 48 hours. Since this has not been completed					re 3.4.16-1, it is > 1.0 uCi/gm and e this has not been completed, a	
d.		Plausible since Mode a further defined as with	applicability is N Tavg > 500 °F.	lodes 1-3	, but applicability in Mode 3 is	
DIFFICULT Comprehe	(: nsive/Analysis	X Knowledge	Recall 🔲 R	ating	2	
	Application of conditions to Tech Specs to determine required actions					

.

REFERENCES SUPPLIED: TS 3.4.16

- 3.4 REACTOR COOLANT SYSTEM (RCS)
- 3.4.16 RCS Specific Activity
- LCO 3.4.16 The specific activity of the reactor coolant shall be within limits.
- APPLICABILITY: MODES 1 and 2, MODE 3 with RCS average temperature $(T_{avg}) \ge 500^{\circ}F$.

ACTIONS

 \sim

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. DOSE EQUIVALENT I-131 > 1.0 μCi/gm.	A.1 Verify DOSE EQUIVALENT I-131 within the acceptable Figure 3.4.16-1.	Once per 4 hours
	AND A.2 Restore DOSE EQUIVALENT I-131 to within limit.	48 hours
B. Gross specific activity of the reactor coolant not within limit.	B.1 Be in MODE 3 with T _{avg} < 500°F.	6 hours

(continued)

RCS Specific Activity 3.4.16

ACTIONS (continued)

ACTI	UNS (continued)			
	CONDITION		REQUIRED ACTION	COMPLETION TIME
С.	Required Action and associated Completion Time of Condition A not met.	C.1	Be in MODE 3 with T _{avg} < 500°F.	6 hours
	<u>OR</u>			
	DOSE EQUIVALENT I-131 in the unacceptable region of Figure 3.4.16-1.			

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.4.16.1	Verify reactor coolant gross specific activity ≤ 100/E µCi/gm.	7 days
SR 3.4.16.2	NOTE Only required to be performed in MODE 1. Verify reactor coolant DOSE EQUIVALENT I-131 specific activity $\leq 1.0 \ \mu Ci/gm$.	14 days <u>AND</u> Between 2 and 6 hours after a THERMAL POWER change of ≥ 15% RTP within a 1 hour period

(continued)

RCS Specific Activity 3.4.16

		FREQUENCY	
SR	3.4.16.3	Not required to be performed until 31 days after a minimum of 2 effective full power days and 20 days of MODE 1 operation have elapsed since the reactor was last subcritical for ≥ 48 hours. Determine Ē from a sample taken in MODE 1 after a minimum of 2 effective full power	184 days
		days and 20 days of MODE 1 operation have elapsed since the reactor was last subcritical for ≥ 48 hours.	

SURVETILANCE REQUIREMENTS (continued)

HBRSEP Unit No. 2

Amendment No. 176

RCS Specific Activity 3.4.16



Figure 3.4.16-1 Reactor Coolant DOSE EQUIVALENT I-131 Specific Activity Limit Versus Percent of RATED THERMAL POWER

HBRSEP Unit No. 2

Amendment No. 176

Given the following conditions:

- A SGTR has occurred.
- Following the performance of PATH-1 and PATH-2, a transition has been made to EPP-17, "SGTR with Loss of Reactor Coolant: Subcooled Recovery."
- Containment pressure is 0.2 psig.

Given the supplied references, which ONE (1) of the following describes conditions requiring a transition from EPP-17 to EPP-18, "SGTR with Loss of Reactor Coolant: Saturated Recovery"?

- a. RWST level at 63%
 - Containment water level at 6"
- b. RWST level at 46%
 - Containment water level at 124"
- c. Ruptured SG level at 76%
 - RCS Subcooling at 58 °F
- d. Ruptured SG level at 63%
 - RCS Subcooling at 41 °F

Answer:

- b. RWST level at 46%
 - Containment water level at 124"

				SRO Only	/ Question Reference
QUESTION N TIER/GROUP	NUMBER: P:	60 RO	SRO	1/2	
K/A:	038 2.4.4				
	Ability to reco conditions for	gnize abnormal indications for emergency and abnormal ope	system operating rating procedures	parameters whic (SGTR).	ch are entry-level
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	4.3 5	
OBJECTIVE	EPP-018-02				
	RECOGNIZE	the selected entry level condit	ions of EPP-18.		
REFERENCE	ES:	EPP-017			
SOURCE:	New	Significantly Modified	X	Direct	
		Bank Number	F EPP-018-02	003	
JUSTIFICAT	ION:				
а.		Plausible since containment s not required until RWST level	ump level is very l is below 56% with	low, but a transit no increase in s	ion to EPP-18 is sump level.
b.	CORRECT	With RWST level at 46%, mir EPP-17 is 168". A transition	imum required cor to EPP-18 is requi	ntainment water red.	level to continue in
c.		Plausible since ruptured SG I level must be above 84% for implemented.	evel is a condition management to de	for transitioning etermine that EP	to EPP-18, but P-18 should be
d.		Plausible since ruptured SG I level must be above 84% for implemented.	evel is a condition management to de	for transitioning etermine that EP	to EPP-18, but P-18 should be
DIFFICULTY	':				
Compreher	nsive/Analysis	X Knowledge/Recall	Rating	3	
Application of given data to EPP curves to determine required action in response to SGTR					

RNP NRC Written Examination

REFERENCES SUPPLIED: EPP-17, Attachment 1

	EPP	Rev. 12 Page 16 of 35							
-[STEP			INSTRUCTIONS	RESPONSE NOT OBT	AINED			
	*25.		Detern Is App	nine If Subcooled Recovery propriate As Follows:	a Determine expected	CV sump			
			a. Che THI	eck RWST ievei – Greater AN 56%	a. Determine expected to sump level using Attachment 1, Containment Sump Level Vs. RWST Level.				
					<u>IF</u> CV sump level 1 expected, <u>THEN</u> Go SGTR With Loss Of Coolant: Saturated	ess than To EPP-18, Reactor Recovery.			
			b. Cho LE	eck ruptured S/G level - SS THAN 84% [82%]	 b. Contact Plant Operations Staff to determine if recovery should be completed using EPP-18, SGTR With Loss Of Reactor Coolant: Saturated Recovery based upon the following: 				
					 Availability of Capability of to support the water Secondary lique 	of RVLIS steam lines e weight of uid activity			
	26	•	Check THAN	RCS Subcooling - GREATER 35°F [55°F]	Go To Step 40.				
	27	•	Check	SI And RHR Pump Status:	Control charging flom maintain PZR level.	w to			
			• 5	I PUMPS - ANY RUNNING <u>OR</u>	Go To Step 31.				
			• F I	RHR PUMPS - ANY RUNNING IN O HEAD INJECTION MODE					
	*28	•	Check 71%	c PZR Level - GREATER THAN [60%]	Place all PZR Heater IF PZR level increas [60%], <u>THEN</u> energize to maintain steam bu Observe <u>CAUTION</u> pric and Go To Step 30.	s in OFF. es above 71% PZR heaters bble. or to Step 30			

Т

EPP-17

Page 35 of 35



EPP-018-02 003

.

Which ONE (1) of the following correctly describes the conditions requiring a transition from EPP-017, SGTR with Loss of Reactor Coolant: Subcooled Recovery to EPP-018, SGTR with Loss of Reactor Coolant: Saturated Recovery?

- \checkmark A. RWST level is low and there is no corresponding increase in containment sump level.
 - B. The ruptured SG level is high and a Station Blackout has occurred.
 - C. The ruptured SG pressure is high and approaching the safety setpoint.
- D. RCS level is low and there is no corresponding increase in the ruptured SG level.

Given the following conditions:

- A reactor trip and safety injection have occurred due to a large break LOCA.
- A transition has been made from PATH-1 to EPP-15, "Loss of Emergency Coolant Recirculation."
- The minimum required Safety Injection flow has been established in accordance with EPP-15.
- RVLIS is now indicating 78% Full Range and increasing slowly.
- Core Exit Thermocouples (CETs) are now indicating 568 °F and decreasing slowly.

Which ONE (1) of the following actions should be taken regarding Safety Injection flow?

- a. Maintain flow at its current value
- b. Decrease flow until either RVLIS stops increasing OR CETs stop decreasing
- c. Increase flow to increase RVLIS level to \geq 90% Full Range
- d. Increase flow to decrease CETs to \leq 547 °F

Answer:

a. Maintain flow at its current value

RNP NRC	Written Examination
SRO Only	Question Reference

QUESTION N TIER/GROUP K/A:	UMBER: C: WE11EA2.2	76	RO	SRO	1/2	
	Ability to deter Recirculation) facility's licens	mine and inter Adherence to e and amendn	pret the following appropriate proc nents.	as they apply to edures and oper	o the (Loss of Emergency Coolant ation within the limitations in the	
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55. 41 (b)	RO RO	SRO 55.43(b) SRO	4.2 5	
OBJECTIVE:	EPP-015-08					
	Given plant co related to EPF	nditions EVAL P-15.	UATE the appro	priate actions to	mitigate consequences of steps	
REFERENCE	S:	EPP-015				
SOURCE:	New	X Significa	antly Modified		Direct	
			Bank Number		NEW	
JUSTIFICAT	ION:					
а.	CORRECT	Although the remove heat this minimum	minimum flow is from the core and flow must be ma	more than that re d it would conser iintained.	equired to restore RVLIS level or ve RWST inventory to reduce flow,	
b.		Plausible sinc flow establish	e reducing flow ed must be mair	would conserve f tained.	RWST inventory, but the minimum	
c.		Plausible sind level is 69% t	e it would be de o ensure a minin	sirable to raise R num level above	CS level, but the minimum required the fuel to remove heat.	
d.		Plausible sind temperature i	ce it is desirable s decreasing he	to achieve no-loa at is being remov	ad conditions, but as long as red.	
DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3						

Analysis of plant conditions during a loss of recirculation flow to determine required actions

REFERENCES SUPPLIED:

	EPP	2-15 LOSS OF EMERGENCY COOLANT				RI	CIRCULATION	Rev. 13 Page 18 of 31
	STEP		INS	STRUCTIONS][RESPONSE NOT OBI	AINED
	*38.	Eva Make	luate Effe eup Flow <i>F</i>	ectiveness Of RCS As Follows:				
	a. Check RVLIS indication - GREATER THAN REQUIRED FROM TABLE					a.	Increase RCS makeu maintain RVLIS ind necessary.	p flow to ication as
			RCP STATUS	REQUIRED RVLIS INDICATION	-			
			ONE RUNNING	40% DYNAMIC RANGE	-			
1			NONE RUNNING	69% FULL RANGE				
b. Check Core Exit T/Cs - STABLE <u>OR</u> DECREASING					JE I	b.	Increase RCS maken establish T/Cs sta decreasing.	np flow to uble or

Given the following conditions:

- The unit is operating at 60% power.
- Chemistry reports that SG 'A' has exceeded Secondary Action Level (SAL) -2 limits for pH and Conductivity.

Which ONE (1) of the describes the actions that must be taken in response to exceeding the SAL-2 limits?

- a. Return the parameters to within SAL-1 limits within 100 hours of initiating SAL-2 OR initiate a power reduction to less than 30%
- b. Take immediate actions to reduce power to approximately 30% within 8 hours
- c. Return the parameters to within its normal value within 100 hours of initiating SAL-2 OR commence a shutdown and cooldown to less than 250 °F
- d. Take immediate actions to shutdown and cooldown to less than 250 °F as rapidly as plant constraints permit

Answer:

b. Take immediate actions to reduce power to approximately 30% within 8 hours

				RNP NRC Written Examination SRO Only Question Reference		
QUESTION N	IUMBER:	77				
TIER/GROUF):	RO	SRO	3		
K/A:	2.1.34					
	Ability to main	tain primary and secondary pla	ant chemistry within	n allowable limits.		
K/A IMPORT. 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	2.9 5		
OBJECTIVE:	OMM-001-13-	008				
	Given plant co related to plar	onditions EVALUATE the appro at chemistry as directed in OMM	ppriate actions to n Λ-001-13.	nitigate consequences of steps		
REFERENCE	S:	OMM-001-13				
SOURCE:	New	Significantly Modified	X	Direct		
		Bank Number	· OMM-001-13	-03 004		
JUSTIFICAT	ION:		1. L	d within CAL 4 limits within 100		
а.		Plausible since the parameter hours, but if they are not SAL 30% within 8 hours would still	s must be returned -3 entry must be m be required.	nade. A reduction in power to <		
b.	CORRECT	Immediate actions are require lower chemistry within limits.	ed to reduce powe	r to < 30% while attempting to		
С.	c. Plausible since the parameters must be returned within SAL-1 limits within 100 hours, but if they are not SAL-3 entry must be made. A reduction in power to < 30% within 8 hours would still be required.					
d.		Plausible since this is the acti (PAL) -3 condition, but a SAL hours.	on required for en -2 entry requires a	try into a Primary Action Level power reduction to < 30% within 8		
DIFFICULTY Compreher	': nsive/Analysis	Knowledge/Recall	X Rating	3		
	Knowledge o	f required actions for entry into	Chemistry Action	Levels		

REFERENCES SUPPLIED:

- 8.5 Secondary Action Level (SAL) Responses
 - 8.5.1 The chemical Control Parameters and their limits for SALs are listed in CP-001.
 - 8.5.2 Refer to CP-005, Secondary Chemistry Corrective Action Program, for a detailed description of the requirements for the following three SALs:
 - 1. SAL-1 Response (Mode 1)
 - a. Return the parameter to below the SAL-1 Limit within one week of entering SAL-1; **OR**
 - b. **IF** the parameter is **NOT** below the SAL-1 Limit within one week of entering SAL-1, **THEN GO TO** SAL-2 for those parameters having SAL-2 Limits; **OR**
 - c. **IF** the parameter will **NOT** be below the SAL-1 Limit within one week of entering SAL-1, and SAL-2 is **NOT** entered, **THEN** obtain approval for this deviation in advance from the Robinson Plant, General Manager
 - 2. SAL-2 Response (Mode 1)
 - a. Take immediate actions to reduce power **AND** achieve approximately 30% within eight hours of entering SAL-2.
 - b. **IF** the control parameter values can be brought below SAL-2, **THEN** the Power Reduction can be terminated. Full power operation can resume when the control parameter value is below the SAL-1 Limit.
 - c. Return the control parameter to below the SAL-1 Limit within 100 hours of entering SAL-2; **OR**
 - d. **IF** the parameter is **NOT** below the SAL-1 Limit within 100 hours of entering SAL-2, **THEN GO TO** SAL-3 for those parameters having SAL-3 Limits (even if the SAL-3 Limit is not exceeded);**OR**
 - e. **IF** the parameter will **NOT** be below its SAL-1 Limit within 100 hours of entering SAL-2, and SAL-3 is **NOT** entered, **THEN** obtain approval for this deviation in advance from the Robinson Plant General Manager.

OMM-001-13	Rev. 5	Page 9 of 12
	······	

OMM-001-13-03 004

Given the following plant conditions:

- The plant is at 60% power
- Chemistry reports that S/G "A" has exceeded Action Level (AL) -1 limits for pH and Conductivity

Which ONE (1) of the following statements describes the correct actions concerning a secondary chemistry parameter which exceeds its AL-1 specification with the unit on line at 60% power?

- A. Power operations are not restricted until greater than 70% power for secondary AL-1 parameters.
- B. Return the parameter to within its normal value within 12 hours of initiating AL-1 <u>OR</u> initiate a power reduction to less than 30%.
- C. Return the parameter to within its normal value within 12 hours of initiating AL-1 <u>OR</u> commence a shutdown and cooldown to less than 350EF.
- \checkmark D. Return the parameter to within its normal value within one week of initiating AL-1 <u>OR</u> initiate AL-2 for those parameters having AL-2 values.

7

Question: 78

Given the following plant conditions:

- The unit is operating at 100% power.
- A plant transient occurs.
- Pressurizer pressure stabilizes at 1950 psig.

Technical Specification 3.4.1, "RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits," must be entered and pressurizer pressure must be restored above 2205 psig within 2 hours if the transient lowers power to ...

- a. 73% over a 5 minute period.
- b. 88% over a 5 second period.
- c. 90% over a 3 minute period.
- d. 77% over a 3 second period.

Answer:

c. 90% over a 3 minute period.
QUESTION N TIER/GROUP K/A:	IUMBER: 2: 027AA2.04	78 RO	SRO	1/2
	Ability to deter Malfunctions:	mine and interpret the followir Tech-Spec limits for RCS pres	ng as they apply to ssure	the Pressurizer Pressure Control
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	4.3 2
OBJECTIVE:	PZR-13			
	Given a plant Technical Spe Technical Spe	condition and a copy of Techn cifications requirements for th cifications and Technical Spe	ical Specifications, le PZR and PRT S cification Interpreta	, DETERMINE the applicable ystem IAW H. B. Robinson ations.
REFERENCE	S:	TS 3.4.1		
SOURCE:	New	Significantly Modified	X	Direct
SOURCE:	New	Significantly Modified Bank Numbe	x r PZR-13	<i>Direct</i> 008
SOURCE:	New	Significantly Modified Bank Number	r PZR-13	Direct 008
SOURCE: JUSTIFICAT <i>a.</i>	New	Significantly Modified Bank Number Plausible since this power ran applicable, but a common mist transient.	X r PZR-13 mp exceeds 5% pe sconception is that	Direct 008 008 er minute so the TS is not the TS does not apply during any
SOURCE: JUSTIFICAT a. b.	New	Significantly Modified Bank Number Plausible since this power rat applicable, but a common mist transient. Plausible since this step char common misconception is that	x r PZR-13 mp exceeds 5% per- sconception is that nge exceeds 10% s at the TS does not	Direct 008 008 er minute so the TS is not the TS does not apply during any so the TS is not applicable, but a apply during any transient.
SOURCE: JUSTIFICAT a. b. c.	New	Significantly Modified Bank Number Plausible since this power rat applicable, but a common mist transient. Plausible since this step char common misconception is that The TS is applicable and pre does not exceed 5% per min occur.	X r PZR-13 mp exceeds 5% per- sconception is that nge exceeds 10% s at the TS does not ssure must be restricted ute or a step change	Direct 008 over minute so the TS is not the TS does not apply during any so the TS is not applicable, but a apply during any transient. tored within 2 hours if the ramp ge of greater than 10% does not
SOURCE: JUSTIFICAT a. b. c. d.	<i>New</i> ION: CORRECT	Significantly Modified Bank Number Plausible since this power rat applicable, but a common mis transient. Plausible since this step char common misconception is that The TS is applicable and pre does not exceed 5% per min occur. Plausible since this step char common misconception is that	PZR-13 mp exceeds 5% personnception is that nge exceeds 10% s at the TS does not ssure must be rest ute or a step change nge exceeds 10% s	Direct 008 or minute so the TS is not the TS does not apply during any so the TS is not applicable, but a apply during any transient. tored within 2 hours if the ramp ge of greater than 10% does not so the TS is not applicable, but a apply during any transient.
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Compreher	New ION: CORRECT	Significantly Modified Bank Number Plausible since this power rate applicable, but a common mist transient. Plausible since this step char common misconception is that The TS is applicable and pre does not exceed 5% per min occur. Plausible since this step char common misconception is that <i>Knowledge/Recall</i>	X r PZR-13 mp exceeds 5% person state sconception is that nge exceeds 10% state at the TS does not ssure must be rest ute or a step change nge exceeds 10% state nge exceeds 10% state the TS does not state nge exceeds 10% state <t< th=""><th>Direct 008 ar minute so the TS is not the TS does not apply during any so the TS is not applicable, but a apply during any transient. tored within 2 hours if the ramp ge of greater than 10% does not so the TS is not applicable, but a apply during any transient.</th></t<>	Direct 008 ar minute so the TS is not the TS does not apply during any so the TS is not applicable, but a apply during any transient. tored within 2 hours if the ramp ge of greater than 10% does not so the TS is not applicable, but a apply during any transient.

REFERENCES SUPPLIED:

RCS Pressure, Temperature, and Flow DNB Limits 3.4.1

3.4 REACTOR COOLANT SYSTEM (RCS)

- 3.4.1 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits
- LCO 3.4.1 RCS DNB parameters for pressurizer pressure, RCS average temperature, and RCS total flow rate shall be within the limits specified below:
 - a. Pressurizer pressure ≥ 2205 psig;
 - b. RCS average temperature \leq 579.4°F; and
 - c. RCS total flow rate \ge 97.3 x 10⁶ lbm/hr.

APPLICABILITY: MODE 1. Pressurizer pressure limit does not apply during: a. THERMAL POWER ramp > 5% RTP per minute; or b. THERMAL POWER step > 10% RTP.

ACTIONS

	CONDITION	REQUIRED ACTION		COMPLETION TIME
Α.	One or more RCS DNB parameters not within limits.	A.1	Restore RCS DNB parameter(s) to within limit.	2 hours
В.	Required Action and associated Completion Time not met.	B.1	Be in MODE 2.	6 hours

AOP-	025
1101	0.00

Rev. 3

Page 9 of 22

	TNORDITOTTONE	RESPONSE NOT OBTAINED					
STEP	SECTION	C					
	SECTION 2						
	Pressurizer Pressure Tr	ansmitter Failure					
	(Page 1 of	1)					
	NOTE						
	Steps 1 through 4 are Imme	diate Action Steps.					
[
1.	Check Either PZR PORV - OPEN	Go To Step 3.					
2.	Close The Open PORV	Close the associated PORV BLOCK Valve:					
	• PCV-456	• PCV-456 - RC-535					
	• PCV-455C	• PCV-455C - RC-536					
3.	Check PT-444 - FAILED TRANSMITTER	Go To Step 6.					
4.	Control PZR Pressure Controller PC-444J As Follows:						
	a. Place PC-444J in MAN						
	b. Restore PZR Pressure to the desired control band						
5.	Verify PCV-455C in AUTO						
6.	Verify Selector Switch PM-444 - SELECTED TO THE OPERABLE CHANNEL						
	• REC 444						
	• REC 445						
7.	Go To Procedure Main Body, Step 2						
	– ENI	D -					
1							

PZR-13 008

Given the following plant conditions:

- Unit is initially in a normal 100% power lineup
- Pressurizer PI-444 fails high.
- The operators respond per AOP-025 and stabilize the plant pressure at 1950 psig.

e e sea co

Sec. Sec.

. .

• Both PORVs indicate closed

Which ONE (1) of the following describes the appropriate actions to comply with Technical Specifications?

- A. Close and remove power from associated block valve within one hour, restore RCS pressure to > 2000 psig within 1 hours.
- B. Close and maintain power to associated block valve within one hour, restore RCS pressure to
 > 2000 psig within 2 hours.
- C. Close and remove power from associated block valve within one hour, restore RCS pressure to > 2205 psig within 1 hours.
- ✓D. Close and maintain power to associated block valve within one hour, restore RCS pressure to

> 2205 psig within 2 hours.

Given the following conditions:

- A seismic event has occurred.
- A reactor trip and safety injection have occurred following a SGTR.
- A transition is being made from PATH-1 to PATH-2 and the CRSS is conducting a shift brief.
- The following have occurred as a result of the seismic event:
 - A service water header break has occurred.
 - All instrument air compressors have tripped.
 - A fire header break has occurred inside containment.

Which ONE (1) of the following procedures should the CRSS direct an extra operator to perform while PATH-2 is being performed?

- a. AOP-017, "Loss of Instrument Air"
- b. AOP-021, "Seismic Disturbances"
- c. AOP-022, "Loss of Service Water"
- d. AOP-032, "Response to Flooding from the Fire Protection System"

Answer:

a. AOP-017, "Loss of Instrument Air"

Deplacement

				RNP NRC Written Exam SRO Only Question Ref	ination erence
QUESTION I	UMBER:	79			
TIER/GROU	P:	RO	SRO	3	
K/A:	2.4.16				
	Knowledge o	of EOP implementation hiera	rchy and coordinatior	n with other support procedures	, 2 .
K/A IMPORT 10CFR55 CC	ANCE: INTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	4.0 5	
OBJECTIVE	: OMM-022-0	8			
	DEMONSTF explaining th	ATE an understanding of se he basis of each.	elected steps, caution	s, and notes in OMM-022 by	
REFERENCE	ES:	OMM-022			
SOURCE:	New	X Significantly Modifi	ed	Direct	
		Bank Num	ber NEW		
JUSTIFICAT a.	ION: CORRECT	Concurrent AOPs for impl AOP-014, AOP-017, and <i>i</i>	ementation while in th AOP-018.	e EOP network include AOP-0	05,
Ь.		Plausible since it would be the failures, but AOP-021	e desirable to respond is not considered a co	I to the event which caused all poncurrent AOP.	of
<i>c.</i> Plausible since it would be desirable to respond to the loss of service water to ensure availability, but AOP-022 is not considered a concurrent AOP.					
d.	Plausible since it would be desirable to prevent flooding inside containment due to potential for LOCA dilution, but AOP-032 is not considered a concurrent AOP.				
DIFFICULTY Compreher	: nsive/Analysi	s X Knowledge/Re	call 🔲 Rating	3	
	Analysis of p concurrently	plant conditions and knowled with emergency procedures	lge of which AOPs are	e acceptable to perform	

REFERENCES SUPPLIED:

Given the following conditions:

- A reactor trip and safety injection have occurred following a SGTR.
- A transition is being made from PATH-1 to PATH-2 and the CRSS is conducting a shift brief.

Which ONE (1) of the following procedures would be appropriate to perform concurrently with PATH-2 following the crew brief?

- a. AOP-003, "Malfunction of Reactor Makeup Control," due to an inability to establish normal boration flow
- b. AOP-017, "Loss of Instrument Air," due a loss of all instrument air compressors
- c. AOP-031, "Operation with High Switchyard Voltage," due to WEST 115 KV BUS VOLTAGE indicating 120.2 KV
- d. AOP-032, "Response to Flooding from the Fire Protection System," due to a fire header break inside containment.

Answer:

b. AOP-017, "Loss of Instrument Air," due a loss of all instrument air compressors

				RNP NRC Wi SRO Only Qu	ritten Examination Jestion Reference
QUESTION N	UMBER:	79			
TIER/GROUP	?:	RO	SRO	3	
K/A:	2.4.16				
	Knowledge of	EOP implementation hierarc	hy and coordination	with other support	procedures.
	ANCE.	PO	\$20	4.0	
10CER55 CO		RO 55 41(h) RO	55 43(b) SRO	4.0	
		00.47(0) 110	00.40(0) 0/10	Ŭ	
OBJECTIVE:	OMM-022-08				
	DEMONSTR/ explaining the	ATE an understanding of sele basis of each.	cted steps, cautions:	s, and notes in OMM	1-022 by
REFERENCE	ES:	OMM-022			
SOURCE:	New	X Significantly Modified	d 🔲	Direct	
		Bank Numb	er	NEW	
JUSTIFICAT	ION:				
а.		Plausible since it would be of the SGTR recovery actions,	but AOP-003 is not	n normal boration co considered a concu	antrol as part of arrent AOP.
b.	CORRECT	Concurrent AOPs for impler AOP-014, AOP-017, and A	nentation while in the OP-018.	e EOP network inclu	ude AOP-005,
с.		Plausible since it would be of protect equipment from abn concurrent AOP.	desirable to establish ormal voltages, but <i>i</i>	n normal switchyard AOP-031 is not con:	voltage to sidered a
d.		Plausible since it would be optimized potential for LOCA dilution,	desirable to prevent but AOP-032 is not (flooding inside conta considered a concu	ainment due to rrent AOP.
DIFFICULTY Comprehen	: nsive/Analysis	Knowledge/Reca	II X Rating	3	

Knowledge of which AOPs are acceptable to perform concurrently with emergency procedures

REFERENCES SUPPLIED:

- 3. Non SPDS functions of ERFIS do not meet all of the same qualifications as SPDS, therefore these functions should **NOT** be relied on for sole indication during use of the EOP Network.
- 8.3.14 Interface Between EOP Network and AOPs/Concurrent AOPs
 - 1. Events which result in utilization of AOPs may later deteriorate to the point of implementing the procedures of the EOP Network. When this occurs, the potential exists for equipment to be improperly utilized and for resources to be unnecessarily diluted by continuing the subsequent actions of AOPs in effect or implementing AOPs which may become applicable while trying to concurrently proceed through the EOP Network.
 - 2. With the exception of concurrent AOPs, the immediate and subsequent actions of AOPs need not be continued while within the EOP Network since the procedures of the EOP Network have been constructed to address critical safety functions without these AOPs.
 - 3. The following AOPs are considered concurrent AOPs and should be performed while in the EOP Network:
 - AOP-005
 - AOP-014
 - AOP-017
 - AOP-018
 - 4. In the case of the above referenced AOPs, it is expected that the CRSS will continue with the EOPs while another licensed operator implements the AOP after any applicable immediate actions of the EOPs have been completed. The operator performing the AOP will notify the CRSS and RTGB operator of all RTGB controls to be manipulated and/or local actions to be taken which could impact the performance of the EOPs.

OMM-022	Rev. 17	Page 36 of 50

Given the following conditions:

- A Component Cooling Water train was declared inoperable on March 1st, at 0530.
- At 0330 on March 4th, a Technical Specifications required shutdown was commenced.
- It is currently 0400 on March 4th.
- The unit is currently at 62% power.
- System Engineering has just notified the Control Room that a generic issue requires declaring ALL AFW pumps inoperable.
- They estimate that it will be approximately 12 hours before any AFW pump will be capable of being declared operable.

In accordance with Technical Specifications, which ONE (1) of the following describes the actions required?

- a. Be in MODE 3 by 0930
- b. Be in MODE 3 by 1100
- c. Be in MODE 3 by 1130
- d. Maintain MODE 1 until at least one AFW pump is declared operable

Answer:

d. Maintain MODE 1 until at least one AFW pump is declared operable

 QUESTION NUMBER:
 80

 TIER/GROUP:
 RO
 SRO
 2/1

 K/A:
 061 2.1.12
 2/1
 2/1

Ability to apply technical specifications for a system (AFW).

K/A IMPORTANCE:	RO	SRO	4.0
10CFR55 CONTENT:	55.41(b) RO	55.43(b) SRO	2

OBJECTIVE: AFW-13

Given a plant condition and a copy of Technical Specifications, DETERMINE the applicable Technical Specifications requirements for the AFW System IAW H. B. Robinson Technical Specifications and Technical Specification Interpretations.

REFERENCES: TS 3.7.4 TS 3.7.6

SOURCE:	New 🔲 Significantly Modified	Significantly Modified X			
JUSTIFICATION:	Bank Number	AFW-13	009		

а.	Plausible since CCW TS actions require the plant be placed in Mode 3 within 6 hours if the inoperable train cannot be restored to operable within 72 hours. This time is 6 hours after the shutdown started, but the AFW condition suspends the action.
Ь.	Plausible since TS 3.0.3 actions require the plant be placed in Mode 3 within 7

- hours if an LCO and its actions require the plant be placed in Mode 3 within 7 hours if an LCO and its actions cannot be met. This time is 7 hours after receiving the AFW report, but an action does exist for this condition.
- *c.* plausible since CCW TS actions require the plant be placed in Mode 3 within 6 hours if the inoperable train cannot be restored to operable within 72 hours. This time is 6 hours after the 72 hours are completed, but the AFW condition suspends the action.
- *d.* **CORRECT** The unit is in a seriously degraded condition with no safety related means for conducting a cooldown. LCO 3.0.3 and all other LCO required actions requiring Mode changes are suspended until one AFW pump and flow path are restored to operable status.

DIFFICULTY: Comprehensive/Analysis X

Knowledge/Recall Rating

3

Comprehension of Technical Specification requirements when all AFW pumps are inoperable

REFERENCES SUPPLIED: TS 3.7.4 and TS 3.7.6

- 3.7 PLANT SYSTEMS
- 3.7.6 Component Cooling Water (CCW) System
- LCO 3.7.6 Two CCW trains powered from emergency power supplies shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

	CONDITION		REQUIRED ACTION	COMPLETION TIME
Α.	One required CCW train inoperable.	A.1	NOTE	72 hours
В.	Required Action and associated Completion Time of Condition A	B.1 AND	Be in MODE 3.	6 hours
	not met.	B.2	Be in MODE 5.	36 hours

.

3.7 PLANT SYSTEMS

3.7.4 Auxiliary Feedwater (AFW) System

- LCO 3.7.4 Four AFW flow paths and three AFW pumps shall be OPERABLE. Only one AFW flow path with one motor driven pump is required to be OPERABLE in MODE 4.
- APPLICABILITY: MODES 1, 2, and 3, MODE 4 when steam generator is being used for heat removal.

ACTIONS

CONDITION		REQUIRED ACTION		COMPLETION TIME
Α.	One AFW pump inoperable in MODE 1, 2, or 3. <u>OR</u> One or two AFW flow paths inoperable in MODE 1, 2, or 3.	A.1	Restore AFW pump or flow path(s) to OPERABLE status.	7 days <u>AND</u> 8 days from discovery of failure to meet the LCO
Β.	Two motor driven AFW pumps inoperable in MODE 1, 2, or 3. <u>OR</u> Three motor driven AFW flow paths inoperable in MODE 1, 2, or 3.	B.1	Restore one motor driven AFW pump or one flow path to OPERABLE status.	24 hours <u>AND</u> 8 days from discovery of failure to meet the LCO

(continued)

.

<u></u>	CONDITION		REQUIRED ACTION	COMPLETION TIME
с.	Required Action and associated Completion Time for Condition A or B not met.	C.1 <u>AND</u> C.2	Be in MODE 3. Be in MODE 4.	6 hours 18 hours
D.	Steam driven AFW pump or flow path inoperable in MODE 1, 2, or 3. <u>AND</u> One motor driven AFW pump or flow path inoperable in MODE 1, 2, or 3.	D.1 <u>AND</u> D.2	Be in MODE 3. Be in MODE 4.	6 hours 18 hours
Е. <u>OR</u>	Four AFW flow paths inoperable in MODE 1, 2, or 3. Three AFW pumps inoperable in MODE 1, 2, or 3.	E.1	NOTE LCO 3.0.3 and all other LCO Required Actions requiring MODE changes are suspended until one AFW pump and flow path are restored to OPERABLE status. Initiate action to restore one AFW pump and flow path to OPERABLE status.	Immediately
 F.	Required AFW pump and flow path inoperable in MODE 4.	F.1	Initiate action to restore AFW pump and flow path to OPERABLE status.	Immediately

a state

•

AFW-13 009

Given the following plant conditions AND a copy of Tech Specs:

- Reactor Power at 100%
- · SDAFW Pump is out of service for maintenance
- · V2-16A,B and C (MDAFW to S/Gs) have just been declared inoperable due to MOV issues

Which ONE (1) of the following best describes what ACTION(S) is required?

- ✓A. LCO 3.0.3 is not applicable. Initiate action to restore one AFW pump and flowpath to OPERABLE status Immediately.
 - B. Initiate power reduction to MODE 2 immediately. Restore AFW pump or flow path(s) to OPERABLE status within 7 days AND 8 days from discovery of failure to meet LCO.
 - C. Take action immediately to place unit in MODE 4. Restore AFW pump or flow path(s) to OPERABLE status within 24 hours AND 8 days from discovery of failure to meet LCO.
 - D. Enter LCO 3.0.3. Action shall be initiated within 1 hour to place the unit, as applicable, in MODE 3 within 7 hours; MODE 4 within 13 hours.

.

Given the following conditions:

- The unit is in Mode 2 with a reactor startup being performed.
- Shutdown Bank (SDB) 'B' is at 125 steps, being withdrawn.
- APP-005-A1, SR DET LOSS OF DC, alarms.
- N31 indications before alarm 1200 cps; after alarm 1300 cps
- N32 indications before alarm 1300 cps; after alarm 700 cps

Which ONE (1) of the following describes the required action to be taken?

- a. Commence a reactor shutdown
- b. Trip the Reactor and go to PATH-1
- c. Stop rod motion
- d. Drive SDB "B" rods in to <20 steps

Answer:

c. Stop rod motion

				RNP NRC Written Examination SRO Only Question Reference
	IUMBER:	96	0.00	4/0
K/A:	032AA2.01	RO	SRU	1/2
	Ability to dete Instrumentatio	rmine and interpret the follow on: Normal/abnormal power s	ing as they apply to upply operation	the Loss of Source Range Nuclear
K/A IMPORT, 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	2.9 2
OBJECTIVE:	NIS-012			
	STATE the Te the bases.	echnical Specification Limitation	ons for the Nuclear	Instrumentation System. Include
REFERENCE	:S:	GP-003 TS 3.3.1		
SOURCE:	New	Significantly Modified		Direct X
	ION·	Bank Numbe	er ITS	001
a.		Plausible since this is a cons reactivity additions in progre	servative action, but ss for one SR inope	only required to stop any positive erable <p6.< td=""></p6.<>
b.		Plausible since this is a cons are inoperable, but only requ progress for one SR inopera	servative action and uired to stop any po able <p6.< th=""><th>l is required if both SR channels sitive reactivity additions in</th></p6.<>	l is required if both SR channels sitive reactivity additions in
С.	CORRECT	Only required to stop any po inoperable <p6.< th=""><th>ositive reactivity add</th><th>itions in progress for one SR</th></p6.<>	ositive reactivity add	itions in progress for one SR
d.		Plausible since this is a cons reactivity additions in progre	servative action, buins for one SR inope	t only required to stop any positive erable <p6.< th=""></p6.<>
DIFFICULTY Compreher	: nsive/Analysis	Knowledge/Reca	II X Rating	2
		Tool Outon and increases for	OD channels during	a atortun

.

REFERENCES SUPPLIED:

5.0 **PRECAUTIONS AND LIMITATIONS**

- 5.1 Before withdrawing any rod bank from the fully inserted position, the group step counters shall be at zero steps for that bank and each individual rod position indicator should indicate within 7.5 inches of the average of its bank position.
- 5.2 Criticality shall be anticipated at any time when the Shutdown Banks or Control Banks are being withdrawn, or when boron dilution operations are in progress.
- 5.3 If the count rate on either Source Range channel increases by a factor of two or more during any step involving a boron concentration change, the operation shall be stopped immediately and suspended until a satisfactory evaluation of the situation has been made.
- 5.4 When the Reactor is subcritical, positive reactivity shall not be added by more than one method at a time. (Exception: Due to the slow insertion rate contributed by the decay of Xenon, positive reactivity addition by the Operator may be performed during periods of Xenon decay.)
- 5.5 The Reactor will not be made critical until the Hydrogen concentration in the RCS is at least 15 cc/kg of water. (Westinghouse Recommendation, Standard Information Package on Chemistry, Criteria & Specification SIP 5-1, Table 1.5 Note B)
- 5.6 The following requirements apply to the Source Range Nuclear Instruments when in MODE 2 below P-6: (ITS Table 3.3.1-1 item 4)
 - IF one Source Range channel becomes inoperable, THEN immediately suspend operations involving positive reactivity additions.
 - IF two Source Range channels become inoperable, THEN immediately trip the Reactor and Go To PATH-1.

GP-003	Rev. 61	Page 7 of 40

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT (1)
. Manual Reactor	1.2	2	В	SR 3.3.1.14	NA	NA
Trip	$3^{(a)}, 4^{(a)}, 5^{(a)}$	2	С	SR 3.3.1.14	NA	NA
2. Power Range Neutron Flux						
a. High	1.2	4	D	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.11	≤ 110.93% RTP	108# RTP (2)
b. Low	1 ^(b) .2	4	£	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 26.93¥ RTP	24 % RTP
8. Intermediate Range Neutron Flux	1 ^(b) , 2 ^(c)	2	F.G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 37.02% RTP	25% RTP
	2 ^(d)	2	н	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	s 37.02≵ RTP	25% RTP
. Source Range Neutron Flux	2 ^(d)	2	I,J	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 1.28 E5 cps	1.0 E5 cps
	3 ^(a) , 4 ^(a) , 5 ^(a)	2	J,K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.11	≤ 1.28 E5 cps	1.0 E5 cps
	3 ^(e) , 4 ^(e) , 5 ^(e)	1	L	SR 3.3.1.1 SR 3.3.1.11	N/A	N/A

Table 3.3.1-1 (page 1 of 7) Reactor Protection System Instrumentation

(continued)

A channel is OPERABLE with an actual Trip Setpoint value found outside its calibration tolerance band provided the Trip Setpoint value is conservative with respect to its associated Allowable Value and the channel is re-adjusted to within the established calibration tolerance band of the Nominal Trip Setpoint.
 The Nominal Trip Setpoint is as stated unless reduced as required by one or more of the following requirements: LCO 3.2.1 Required Action A.2.2; LCO 3.2.2 Required Action A.1.2.2; or LCO 3.7.1 Required Action B.2.
 With Rod Control System capable of rod withdrawal, or one or more rods not fully inserted.
 Below the P-10 (Power Range Neutron Flux) interlock.
 Above the P-6 (Intermediate Range Neutron Flux) interlock.
 Below the P-6 (Intermediate Range Neutron Flux) interlock.
 With the RTBs open. In this condition, source range Function does not provide reactor trip but does provide indication and alarm.

HBRSEP Unit No. 2

CONDITION		REQUIRED ACTION	COMPLETION TIME
One channel inoperable.	E.1	Place channel in trip.	6 hours
	<u>OR</u> E.2	Be in MODE 3.	12 hours
THERMAL POWER > P-6 and < P-10, one Intermediate Range	F.1	Reduce THERMAL POWER to < P-6.	2 hours
Neutron Flux channel inoperable.	<u>OR</u> F.2	Increase THERMAL POWER to > $P-10$.	2 hours
THERMAL POWER > P-6 and < P-10, two Intermediate Range	G.1	Suspend operations involving positive reactivity additions.	Immediately
inoperable.	<u>AND</u> G.2	Reduce THERMAL POWER to < P-6.	2 hours
THERMAL POWER < P-6, one or two Intermediate Range Neutron Flux channels inoperable.	Н.1	Restore channel(s) to OPERABLE status.	Prior to increasing THERMAL POWER to > P-6
One Source Range Neutron Flux channel inoperable.	I.1	Suspend operations involving positive reactivity additions.	Immediately
	CONDITION One channel inoperable. THERMAL POWER > P-6 and < P-10, one Intermediate Range Neutron Flux channel inoperable. THERMAL POWER > P-6 and < P-10, two Intermediate Range Neutron Flux channels inoperable. THERMAL POWER < P-6, one or two Intermediate Range Neutron Flux channels inoperable. One Source Range Neutron Flux channel inoperable.	CONDITIONOne channel inoperable.E.1OR E.2THERMAL POWER > P-6 and < P-10, one Intermediate Range Neutron Flux channel inoperable.F.1THERMAL POWER > P-6 and < P-10, two Intermediate Range Neutron Flux channels inoperable.G.1THERMAL POWER > P-6 and < P-10, two Intermediate Range Neutron Flux channels inoperable.G.1THERMAL POWER > P-6 and < P-10, two Intermediate Range Neutron Flux channels inoperable.G.1THERMAL POWER < P-6, one or two Intermediate Range Neutron Flux channels inoperable.H.1One Source Range Neutron Flux channel inoperable.I.1	CONDITIONREQUIRED ACTIONOne channel inoperable.E.1Place channel in trip.OR E.2Be in MODE 3.THERMAL POWER > P-6 and < P-10, one Intermediate Range Neutron Flux channel inoperable.F.1Reduce THERMAL POWER to < P-6.

(continued)

HBRSEP Unit No. 2

Given the following conditions:

- An accident has occurred which has resulted in activation of the Emergency Plan.
- A repair team is preparing to enter an area to effect repairs that will protect a piece of valuable company property.
- The dose rate in the area is 15 Rem/hour.

Which ONE (1) of the following identifies the MAXIMUM amount of time that each individual can stay in the area **WITHOUT** exceeding allowable emergency dose limits?

- a. 20 minutes
- b. 40 minutes
- c. 60 minutes
- d. 100 minutes

Answer:

b. 40 minutes

QUESTION N TIER/GROUF K/A:	IUMBER: 2: 2.3.4	97	RO	SRO	3	
	Knowledge of excess of those	radiation expo se authorized.	sure limits and co	ntamination cont	trol, inclu	uding permissible levels in
K/A IMPORT, 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO 5	SRO 55.43(b) SRO	3.1 4	
OBJECTIVE:	OPS-EP-1-01					
	DEMONSTRA	ATE an underst	tanding of the Rob	inson Emergend	y Plan I	AW PLP-007
REFERENCE	S:	PLP-007 EPOSC-04				
SOURCE:	New	Significa	antly Modified	x	Direct	
			Bank Number	HNP-SRO-20	00	97
JUSTIFICAT	ON:					
а.		Plausible sinc allow 12 minu a single expos	e the normal 10Cf tes, but for this typ sure.	-R20 limits are 5 be of emergency	the limit	nnual which would only ts are raised to 10 Rem for
b.	CORRECT	The dose limit rate of 25 Rer	t for protecting val n, an individual ca	uable company r In stay in the are	property a for 0.4	is 10 Rem. With a dose hours, or 24 minutes.
с.		Plausible sinc 15 Rem, but t	e this would be a this would be a this would be a this 10 Rem	valid calculation	if the lim	nit for this condition were
d.		Plausible sinc populations is	e this would be th 25 Rem, but the l	e limit for lifesav	ing or pr lition is 1	otection of large I0 Rem.
DIFFICULTY Comprehen	: sive/Analysis	X Kno	owledge/Recall	Rating	3	

Calculation of stay time in high dose area to determine emergency limits not exceeded

REFERENCES SUPPLIED:

•

5.4.4.3 (Continued)

- <u>50 to 100 Rem in 1 day</u> no impairment likely but some physiological changes, including possible temporary blood changes, may occur. Medical observations would be required after exposure.
- <u>100 to 300 Rem in 1 day</u> some physical impairment possible.
 Some lethal exposures possible.

The following subsections describe the criteria to be considered for life-saving and facility protection actions.

a. Lifesaving Actions

In emergency situations that require personnel to search for and remove injured persons or entry to prevent conditions that would probably injure numbers of people, a <u>planned</u> dose shall not exceed limits as outlined below:

Dose Limit Rem TEDE ¹	Activity	Condition
5	Ali	
10	Protecting valuable property	Lower dose not practicable
25	Lifesaving or protection of large populations	Lower dose not practicable
>25	Lifesaving or protection of large populations	Only on a voluntary basis to persons fully aware of the risks involved

¹Doses to the lens of the eye should be limited to three times the stated TEDE value and doses to any other organ (including skin and body extremities) should be limited to ten times the stated TEDE value.

PLP-007	Rev. 45	Page 103 of 207

Т

8.4.3 (Continued)

- 7. Emergency worker exposure guidelines:
 - a. Although an emergency situation transcends the normal requirements for limiting Total Effective Dose Equivalent (TEDE) to workers, guideline levels are established for doses that may be acceptable in emergencies. The (TEDE) received by any worker should not exceed established regulatory limits, to the extent practical. Every reasonable effort will be used to ensure that an emergency is handled in such a manner that no worker exceeds these limits, including the administering of radioprotective drugs.
 - b. To assure adequate protection of minors and the unborn, the performance of emergency services should be limited to nonpregnant (pregnancy undeclared) adults.
 - c. During emergencies, doses (TEDE) to workers should be limited to 5 Rem.
 - Justification for receiving higher exposures must include the presence of conditions that prevent the rotation of workers or other commonly-used dose reduction methods.
 - Except as noted below, the dose resulting from such emergency exposure should be limited to 10 Rem for protecting valuable property, and to 25 Rem for lifesaving activities and the protection of large populations.
 - In this context, the exposure incurred by workers to protect large populations may be considered justified when the collective dose avoided by the emergency operation is significantly larger than that incurred by the workers involved.

EPOSC-04	Rev. 3	Page 4-12 of 4-29
	· · · · · · · · · · · · · · · · · · ·	

Given the following conditions:

- An accident has occurred which has resulted in activation of the Emergency Plan.
- A repair team is preparing to enter an area to effect repairs that will protect a piece of valuable company property.
- The dose rate in the area is 25 Rem/hour.

Which of the following identifies the **MAXIMUM** amount of time that each individual can stay in the area without exceeding allowable emergency dose limits?

- a. 12 minutes
- b. 24 minutes
- c. 36 minutes
- d. 60 minutes

Answer:

b. 24 minutes

Given the following conditions:

- A reactor trip and safety injection have occurred due to a LOCA on the letdown line and a failure of the letdown line to automatically isolate.
- PATH-1 actions are being performed.
- The following conditions currently exist:
- Containment pressure is 7 psig and slowly decreasing.
- Total AFW flow to the intact SGs is 390 gpm.
- 'A' SG level is 6% and slowly increasing.
- 'B' SG level is 12% and slowly increasing.
- 'C' SG level is 14% and slowly increasing.
- RCS pressure is 1765 psig and rapidly increasing.
- Pressurizer level is 29% and stable.
- Core Exit Thermocouples are 530°F and stable.

Which ONE (1) of the following identifies the parameter that is inadequate to permit terminating SI?

- a. Subcooling
- b. Secondary heat sink
- c. RCS pressure
- d. RCS inventory

Answer:

d. RCS inventory

QUESTION N TIER/GROUF	NUMBER:	98	RO	SRO	1/1
NA.	UTEAZ.II				
	Ability to dete throttling or st	rmine or interpr opping HPI	et the following	as they apply to	a Large Break LOCA: Conditions for
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	l 55.41(b)	RO RO	SRO 55.43(b) SRO	4.3 5
OBJECTIVE:	PATH-1-03				
	DEMONSTRA explaining the	ATE an underst basis of each.	anding of select	ted steps, cautior	ns, and notes in PATH-1 by
REFERENCE	S:	PATH-1			
SOURCE:	New	Significa	ntly Modified	X	Direct
			Bank Number	EPP-008-06	001
JUSTIFICAT	ION:				
а.		Plausible since adverse conta	e subcooling is i inment conditio	required to terminents is 55 °F and si	ubcooling is currently 89 °F.
b.		Plausible since requirement fo (all are current is 390 gpm.	e secondary hea or adverse conta tly below) or tota	at sink is required ainment condition al feed flow of gre	t to terminate SI, but the s is either one SG level above 18% eater than 300 gpm and current flow
с.		Plausible since adverse conta pressure is cu	e pressure is re inment conditio rrently 1765 psi	quired to termina ns is 1750 psig a g and increasing.	te SI, but the requirement for nd stable or increasing and
d.	CORRECT	RCS inventory containment c transition to El	v is not adequate onditions. The PP-007 when S	e since 32% leve crew would be di I flow restores ad	l is required with adverse rected to stabilize pressure and lequate pressurizer level.
DIFFICULTY	:				
Comprehen	sive/Analysis	Kno	wledge/Recall	X Rating	3

REFERENCES SUPPLIED:



EPP-008-06 001

Given the following plant conditions:

- A Reactor Trip and Safety Injection have occurred
- As directed by PATH-1, you have transitioned to EPP-8, "Post LOCA Cooldown and Depressurization"
- Two SI Pumps are running
- Both RHR Pumps have been secured
- The crew has reached the step for SI pump reduction

Which ONE (1) of the following describes two conditions, that if both are met, allow you to secure an SI pump?

- ✓A. RCS Subcooling greater than required and adequate PZR level
 - B. RCS Subcooling greater than required and at least one Charging pump running
 - C. RCS Hot Leg temperatures low enough and adequate PZR level
 - D. RCS Hot Leg temperatures low enough and at least one Charging pump running

Given the following conditions:

- A reactor trip and safety injection have occurred.
- During the performance of PATH-1 a transition has been made to EPP-16, "Uncontrolled Depressurization of All SGs."
- Wide range SG levels are all between 12% and 18% and decreasing slowly.
- SG pressures are all between 180 psig and 200 psig and decreasing slowly.
- Feed flow has been reduced to 80 gpm to each SG per EPP-16 guidance.

Which ONE (1) of the following describes when FRP-H.1, "Loss of Heat Sink," guidance would be implemented to restore SG levels?

- a. Wide range level in 2 SGs is still below 26%
- b. Narrow range level in 1 SG is still below 10%
- c. 2 SGs remain unisolated
- d. Total feed flow is below 300 gpm due to other than operator actions

Answer:

d. Total feed flow is below 300 gpm due to other than operator actions

				RNP NRC Written Examination SRO Only Question Reference
QUESTION N	UMBER:	99		
TIER/GROUP):	RO	SRO	1/2
K/A:	WE05EA2.1			
	Ability to dete Facility condit conditions	rmine and interpret the followin ions and selection of appropria	ng as they apply to ate procedures dur	the (Loss of Secondary Heat Sink) ing abnormal and emergency
		RO	SRO	A A
10CFR55 CO	NTENT:	55.41(b) RO	55.43(b) SRO	5
OBJECTIVE:	FRP-H.1-02			
	RECOGNIZE	the selected entry level condit	tions of FRP-H.1.	
REFERENCE	S:	FRP-H 1		
SOURCE:				
	New	Significantly Modified		Direct X
	New	Significantly Modified		
JUSTIFICATI	New	Significantly Modified Bank Numbe	r FRP-H.1-14	001
JUSTIFICATI <i>a.</i>	New ON:	Significantly Modified Bank Number Plausible since this would rec	r FRP-H.1-14 quire feed and blee	001 d if FRP-H.1 were performed, but it
JUSTIFICATI <i>a.</i>	New ON:	Plausible since this would red is not performed due to flow b	r FRP-H.1-14 quire feed and blee being limited due to	001 d if FRP-H.1 were performed, but it operator action.
JUSTIFICATI a.	New	Plausible since this would red is not performed due to flow b	r FRP-H.1-14 quire feed and blee being limited due to	001 d if FRP-H.1 were performed, but it o operator action.
JUSTIFICATI a. b.	New	Plausible since this would red Bank Number Plausible since this would red is not performed due to flow b Plausible since this is within t	r FRP-H.1-14 quire feed and blee being limited due to he normal control I	001 d if FRP-H.1 were performed, but it o operator action.
JUSTIFICATI a. b.	New	Plausible since this would red is not performed due to flow to Plausible since this is within to plausible since this is within to not performed due to flow be	r FRP-H.1-14 quire feed and blee being limited due to the normal control l	001 d if FRP-H.1 were performed, but it o operator action. Dand for SG level, but FRP-H.1 is perator action.
JUSTIFICATI a. b.	New	Significantly Modified Bank Number Plausible since this would red is not performed due to flow b Plausible since this is within t not performed due to flow bei	r FRP-H.1-14 quire feed and blee being limited due to the normal control l ing limited due to o	001 d if FRP-H.1 were performed, but it o operator action. band for SG level, but FRP-H.1 is perator action.
JUSTIFICATI a. b. c.	New	Plausible since this would red Plausible since this would red is not performed due to flow b Plausible since this is within t not performed due to flow bei	r FRP-H.1-14 quire feed and blee being limited due to the normal control I ing limited due to o	001 d if FRP-H.1 were performed, but it o operator action. band for SG level, but FRP-H.1 is perator action. being below 26%, requiring feed
JUSTIFICATI a. b. c.	New	Plausible since this would read Plausible since this would read is not performed due to flow the Plausible since this is within the not performed due to flow bein Plausible since this would like and bleed if FRP-H.1 were performed	r FRP-H.1-14 quire feed and blee being limited due to the normal control I ing limited due to o ely result in 2 SGs erformed, but it is n	001 d if FRP-H.1 were performed, but it o operator action. band for SG level, but FRP-H.1 is perator action. being below 26%, requiring feed not performed due to flow being
JUSTIFICATI a. b. c.	New	Significantly Modified Bank Number Plausible since this would read is not performed due to flow be Plausible since this is within to not performed due to flow be Plausible since this would like and bleed if FRP-H.1 were performed due to operator action	r FRP-H.1-14 quire feed and blee being limited due to he normal control I ing limited due to o ely result in 2 SGs erformed, but it is n	001 d if FRP-H.1 were performed, but it o operator action. Dand for SG level, but FRP-H.1 is perator action. being below 26%, requiring feed not performed due to flow being
JUSTIFICATI a. b. c. d.	New ON:	Plausible since this would red is not performed due to flow be Plausible since this is within t not performed due to flow be Plausible since this would like and bleed if FRP-H.1 were performed limited due to operator action FRP-H.1 is not implemented	r FRP-H.1-14 quire feed and blee being limited due to the normal control I ing limited due to o ely result in 2 SGs erformed, but it is n	001 d if FRP-H.1 were performed, but it o operator action. band for SG level, but FRP-H.1 is perator action. being below 26%, requiring feed not performed due to flow being below 300 gpm due to operator
JUSTIFICATI a. b. c. d.	New ON:	Significantly Modified Bank Number Plausible since this would rea is not performed due to flow be Plausible since this is within t not performed due to flow be Plausible since this would like and bleed if FRP-H.1 were pe limited due to operator action FRP-H.1 is not implemented actions.	r FRP-H.1-14 quire feed and blee being limited due to the normal control I ing limited due to o ely result in 2 SGs erformed, but it is n if total feed flow is	001 d if FRP-H.1 were performed, but it o operator action. Dand for SG level, but FRP-H.1 is perator action. being below 26%, requiring feed not performed due to flow being below 300 gpm due to operator
JUSTIFICATI a. b. c. d.	New ON:	Significantly Modified Bank Number Plausible since this would rea is not performed due to flow b Plausible since this is within t not performed due to flow bei Plausible since this would like and bleed if FRP-H.1 were pe limited due to operator action FRP-H.1 is not implemented actions.	r FRP-H.1-14 quire feed and blee being limited due to the normal control I ing limited due to o ely result in 2 SGs erformed, but it is n if total feed flow is	001 d if FRP-H.1 were performed, but it o operator action. band for SG level, but FRP-H.1 is perator action. being below 26%, requiring feed not performed due to flow being below 300 gpm due to operator
JUSTIFICATI a. b. c. d. DIFFICULTY:	New ON: CORRECT	Significantly Modified Bank Number Plausible since this would rea is not performed due to flow be Plausible since this is within t not performed due to flow be Plausible since this would like and bleed if FRP-H.1 were per limited due to operator action FRP-H.1 is not implemented actions.	r FRP-H.1-14 quire feed and blee being limited due to the normal control I ing limited due to o ely result in 2 SGs erformed, but it is n if total feed flow is	Direct X 001 d if FRP-H.1 were performed, but it o operator action. Dand for SG level, but FRP-H.1 is perator action. being below 26%, requiring feed not performed due to flow being below 300 gpm due to operator
JUSTIFICATI a. b. c. d. DIFFICULTY: Comprehen	New ON: CORRECT sive/Analysis	Significantly Modified Bank Number Plausible since this would red is not performed due to flow be Plausible since this is within t not performed due to flow be Plausible since this would like and bleed if FRP-H.1 were pe limited due to operator action FRP-H.1 is not implemented actions.	r FRP-H.1-14 quire feed and blee being limited due to the normal control I ing limited due to o ely result in 2 SGs erformed, but it is n if total feed flow is	Direct X 001 d if FRP-H.1 were performed, but it operator action. band for SG level, but FRP-H.1 is perator action. being below 26%, requiring feed tot performed due to flow being below 300 gpm due to operator
JUSTIFICATI a. b. c. d. DIFFICULTY: Comprehent	New ON: CORRECT sive/Analysis Knowledge of	Significantly Modified Bank Number Plausible since this would read is not performed due to flow be Plausible since this is within t not performed due to flow bei Plausible since this would like and bleed if FRP-H.1 were per limited due to operator action FRP-H.1 is not implemented actions. Knowledge/Recall f operator actions which would	r FRP-H.1-14 quire feed and blee being limited due to the normal control I ing limited due to o ely result in 2 SGs erformed, but it is n if total feed flow is	Direct X 001 d if FRP-H.1 were performed, but it o operator action. band for SG level, but FRP-H.1 is perator action. being below 26%, requiring feed not performed due to flow being below 300 gpm due to operator 2 nce of FRP-H.1

REFERENCES SUPPLIED:

	-
	L
PRP-H.	L

Page 4 of 35

						
STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED				

Feed avai	flow is not re-established to any lable.	faulted S/G if an intact S/G is				

1.	Check Total Feed Flow - LESS THAN 300 GPM DUE TO OPERATOR ACTION	Go To Step 3.				
2.	Reset SPDS And Return To Procedure And Step In Effect					
* 3.	Determine If Secondary Heat Sink Is Required As Follows:	·				
	a. Check RCS pressure - GREATER THAN ANY NON-FAULTED S/G PRESSURE	a. Reset SPDS and Go To PATH-1, Entry Point C.				
	b. Check RCS temperature - GREATER THAN 350°F [310°F]	 b. Perform the following: 1) Place RHR System in service using Supplement I. 2) WHEN adequate cooling with RHR is established, THEN reset SPDS and return to procedure and step in effect. 				
* 4.	Check Any Two S/G Wide Range Levels - LESS THAN 27% [34%]	IF any two S/G Wide Range Levels decrease to less than 27% [34%], THEN Go To Step 5. Go To Step 6.				
F	Derform The Following.					
5.	a Stop all PCPs					
	a. Stop all KCPS b. Observe <u>CAUTION</u> prior to Step 30 and Go To Step 30					

Given the following conditions:

- The reactor is defueled.
- Over several days pure water is inadvertently added to the spent fuel pit (SFP).
- The following SFP chemistry exists:
- Boron = 1445 ppm
- Level = 37 ft

Given the supplied references, which ONE (1) of the following is the **MINIMUM** action required to restore key safety functions?

- a. Add 1000 pounds of granulated boric acid to the SFP
- b. Add 5500 pounds of granulated boric acid to the SFP
- c. Drain the SFP a minimum of 8 feet and refill using the RWST
- d. Drain the SFP a minimum of 16 feet and refill using the RWST

Answer:

a. Add 1000 pounds of granulated boric acid to the SFP

ATTACHMENT 10.3 Page 4 of 5 AVAILABLE CONTINGENCY ACTIONS

4.0 Reactivity Control:

- 1) Borated makeup sources, and all components necessary to inject the borated water are required to be operable in accordance with OMP-003 when fuel is in the vessel. Other means of borated makeup when the RCS is intact include the flow path through the RCP seals, however this should only be used as a last resort. Normal letdown if available when fuel is in the vessel, may be used to divert displaced inventory to the CVCS Hold Up Tank (HUT). As an alternate means of increasing the Boron Concentration in the Refueling cavity when the vessel head has been removed, 100 lb. bags of Granulated Boric Acid may be added to the cavity. One 100 lb. bag of Granulated Boric Acid will increase the Cavity Boron Concentration approximately 6 ppm. Contact the Reactor Engineer to provide guidance IAW the Reactivity Management Program. (SOER 94-2)
- 2) When the core is offloaded to the SFP, borated make-up is available from the RWST in accordance with the procedure listed on Attachment 10.2 of this procedure, however if the SFP is at the full level and no more inventory can be added, Boron Concentration may be increased by adding Granulated Boric Acid to SFP locally. One 100 lb. bag of Granulated Boric Acid will increase the Boron Concentration of the SFP approximately 6 ppm. Contact the Reactor Engineer to provide guidance IAW the Reactivity Management Program. (SOER 94-2)

OMM-046	Rev. 6	Page 20 of 23
1 ⁻		

QUESTION N TIER/GROUF K/A:	IUMBER: 2.2.26	100 <i>RO</i>	SRO	3	
	Knowledge of refueling administrative requirements.				
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	RO 55.41(b) RO	SRO 55.43(b) SRO	3.7 6	
OBJECTIVE:	OMM-046-04				
	DEMONSTRA	TE the use of OMM-046 in m	naintaining the Key	Safety Functions.	
REFERENCE	ES:	OMM-046			
		10 0.1.10			
SOURCE					
SOURCE.	New			Direct X	
SOURCE.	New	Bank Numbe	′ ∟ er OMM-046-04	005	
JUSTIFICAT		Bank Numbe	er OMM-046-04	005 0 ppm. Concentration must be	
JUSTIFICAT	New ION: CORRECT	Required boron concentration raised 55 ppm to established granulated boron will raise S	er OMM-046-04 on in the SFP is 150 d required concentra FP level approxima	005 0 ppm. Concentration must be ation. Each 100 pound bag of ately 6 ppm	
JUSTIFICAT a. b.	ION: CORRECT	Required boron concentration raised 55 ppm to established granulated boron will raise S Plausible since with the leve cannot be performed, but it v	er OMM-046-04 on in the SFP is 150 d required concentra SFP level approxima I in the SFP full nor would require 1000	005 0 ppm. Concentration must be ation. Each 100 pound bag of ately 6 ppm mal boration using the RWST pounds at 6 ppm per 100 pounds.	
JUSTIFICAT a. b. c.	New	Required boron concentration raised 55 ppm to established granulated boron will raise S Plausible since with the leve cannot be performed, but it w Plausible since the RWST manual high it cannot be increased at the diluted water is still remo	er OMM-046-04 on in the SFP is 150 d required concentra FP level approxima I in the SFP full nor would require 1000 ormally provides ma and draining the poo oving heat.	005 0 ppm. Concentration must be ation. Each 100 pound bag of ately 6 ppm mal boration using the RWST pounds at 6 ppm per 100 pounds. akeup to the SFP, but with level of would be non-conservative as	
JUSTIFICAT a. b. c. d.	ION: CORRECT	Required boron concentration raised 55 ppm to established granulated boron will raise S Plausible since with the leve cannot be performed, but it w Plausible since the RWST m high it cannot be increased a the diluted water is still remo	er OMM-046-04 on in the SFP is 150 d required concentra SFP level approxima I in the SFP full nor would require 1000 ormally provides ma and draining the poo oving heat.	005 0 ppm. Concentration must be ation. Each 100 pound bag of ately 6 ppm mal boration using the RWST pounds at 6 ppm per 100 pounds. akeup to the SFP, but with level of would be non-conservative as akeup to the SFP, but with level of would be non-conservative as	
JUSTIFICAT a. b. c. d. DIFFICULTY	New ION: CORRECT	Bank Number Bank Number Required boron concentration raised 55 ppm to established granulated boron will raise S Plausible since with the leve cannot be performed, but it w Plausible since the RWST in high it cannot be increased a the diluted water is still remote Plausible since the RWST in high it cannot be increased a the diluted water is still remote the diluted water is still remote the diluted water is still remote	er OMM-046-04 on in the SFP is 150 d required concentra FP level approxima I in the SFP full nor would require 1000 ormally provides ma and draining the poo oving heat. ormally provides ma and draining the poo oving heat.	005 0 ppm. Concentration must be ation. Each 100 pound bag of ately 6 ppm mal boration using the RWST pounds at 6 ppm per 100 pounds. akeup to the SFP, but with level of would be non-conservative as akeup to the SFP, but with level of would be non-conservative as	
JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	ION: CORRECT	Significantly Modified Bank Number Required boron concentration raised 55 ppm to established granulated boron will raise S Plausible since with the leve cannot be performed, but it w Plausible since the RWST no high it cannot be increased at the diluted water is still remote Plausible since the RWST no high it cannot be increased at the diluted water is still remote Migh it cannot be increased at the diluted water is still remote Migh it cannot be increased at the diluted water is still remote	er OMM-046-04 on in the SFP is 150 d required concentra FP level approxima I in the SFP full nor would require 1000 ormally provides ma and draining the poo oving heat. ormally provides ma and draining the poo oving heat.	005 0 ppm. Concentration must be ation. Each 100 pound bag of ately 6 ppm mal boration using the RWST pounds at 6 ppm per 100 pounds. akeup to the SFP, but with level of would be non-conservative as akeup to the SFP, but with level of would be non-conservative as	

REFERENCES SUPPLIED: OMM-046, Attachment 10.3

Fuel Storage Pool Boron Concentration 3.7.13

- 3.3
- 3.7 PLANT SYSTEMS
 - 3.7.13 Fuel Storage Pool Boron Concentration
 - LCO 3.7.13 The fuel storage pool boron concentration shall be \geq 1500 ppm.
 - APPLICABILITY: During new and spent fuel movement activities in the fuel storage pool.

ACTIONS

	CONDITION	REQUIRED ACTION	COMPLETION TIME
Α.	Fuel storage pool boron concentration not within limit.	A.1 Suspend movement of fuel assemblies in the fuel storage pool.	Immediately

SURVEILLANCE REQUIREMENTS

	FREQUENCY	
SR 3.7.13.1	Verify the fuel storage pool boron concentration is within limit.	7 days
INITIAL SUBMITTAL

ROBINSON EXAM 2001-301 MARCH 26 - APRIL 2, 2001

INITIAL SUBMITTAL -RO/SRO COMMON WRITTEN EXAMINATION QUESTIONS

Given the following conditions:

- The unit is operating at 100% power.
- Annunciators APP-008-E7, S. SW HDR STRAINER PIT HI LEVEL, and APP-008-F7, SOUTH SW HDR LO PRESS, come in simultaneously.

Which ONE (1) of the following actions is required as an immediate action?

- a. Stop 'A' and 'B' service water pumps
- b. Close SW supply to south header valve V6-12A
- c. Close SW supply to north header valve V6-12D
- d. Close SW cross-connect valves V6-12B and V6-12C

Answer:

d. Close SW cross-connect valves V6-12B and V6-12C

ć

QUESTION N TIER/GROUP K/A:	UMBER: : 062 2.4.24	1	RO	1/1	SRO	1/1		
	Knowledge of	loss of cooli	ng water p	orocedu	res (Service Water).		
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(k	RO b) RO	3.3 10	SRO 55.43(b) SRO	3.7		
OBJECTIVE:	AOP-022-05							
	STATE the im	mediate acti	on steps o	of AOP-	022			
REFERENCE	S:	APP-008 AOP-022						
SOURCE:	New	Signific	cantly Mo	odified		Direct	X	
			Bank	Numbe	r AOP-022-05		002	
JUSTIFICATI a.	ION:	Plausible si but this is n	nce a sev ot an imm	ere unis iediate c	olated rupture cou operator action.	ld result i	in flooding in cr	itical areas,
b.		Plausible si immediate d	nce the all operator a	nnunciat action.	tors address the so	outh head	ler, but this is r	not an
C.		Plausible si header, but	nce this a this is no	iction wo t an imn	ould isolate the nor nediate operator ac	-ruptured	d header from t	he ruptured
d.	CORRECT	Immediate headers.	action to c	close the	e cross-connect va	lves to pi	revent a loss o	f both
DIFFICULTY Compreher	: nsive/Analysis	К	nowledg	e/Recal	IX Rating	2		
	Recall of AO	P immediate	actions					

APP-008-E7

ALARM

S SW HDR STRAINER PIT HI LEVEL

AUTOMATIC ACTIONS

1. None Applicable

CAUSE

- 1. Failure of sump pump in south service water strainer pit
- 2. System leakage in excess of sump pump capacity

OBSERVATIONS

1. Other SW pit Annunciators (D7, D8, & E8)

ACTIONS

1. Refer to AOP-022.

DEVICE/SETPOINTS

1. LS-1652B / 1 foot above floor

POSSIBLE PLANT EFFECTS

- 1. Continued flooding could jeopardize operability of valves V6-12A, V6-12B, V6-12C, & V6-12D
- 2. Potential to enter TECH SPEC LCO condition

REFERENCES

- 1. ITS LCO 3.7.7
- 2. AOP-022, Loss of Service Water
- 3. HBR2-11098, SH. 11
- 4. CWD B-190628, Sh. 832

APP-008	Rev. 27	Page 42 of 51

ALARM SOUTH SW HDR LO PRESS

AUTOMATIC ACTIONS

1. None Applicable

<u>CAUSE</u>

- 1. Loss of SW Pump(s)
- 2. CCW Heat exchanger Outlet Valves open too far
- 3. Rupture of Service Water Piping

OBSERVATIONS

- 1. Service Water Pressure (PI-1684, PI-1616)
- 2. Service Water Pump Breaker(s) Indicating Lights

ACTIONS

- 1. IF an operating SW Pump has tripped, THEN perform the following:
 - 1) START a Standby Pump.
 - 2) Dispatch operator to check breaker(s)
 - SW Pump A 480V Bus E1 (CMP 20B)
 - SW Pump B 480V Bus E1 (CMP 19C)
 - SW Pump C 480V Bus E2 (CMP 24A)
 - SW Pump D 480V Bus E2 (CMP 25B)
 - 3) Throttle CCW Heat Exchanger Return Valves, as necessary, to maintain 40 to 50 psig in the SW Headers.
- 2. IF a rupture in a SW Header has occurred, THEN refer to AOP-022.

DEVICE/SETPOINTS

1. PSL-1684 / 40 psig

POSSIBLE PLANT EFFECTS

- 1. Loss of Service Water
- 2. Overheat of CCW
- 3. Possible entry into TECH SPEC LCO

REFERENCES

- 1. ITS LCO 3.7.7
- 2. AOP-022, Loss of Service Water
- 3. CWD B-190628, Sheet 840, cable M
- 4. Flow Diagram G-190199

•••	\sim	1		

RAV 27	
100, 27	1 490 00 01 01 1

20	D_	n	2	2
AO	Р-	υ	4	4

Rev. 20

Page 4 of 69

EP INSTRUCTIONS	RESPONSE NOT OBTAINED
<u>NOTE</u> Step 1 is an immediat	e action step.
 Check The Following Alarms - EXTINGUISHED: APP-008-E7, S SW HDR STRAINER PIT HI LEVEL APP-008-E8, N SW HDR STRAINER PIT HI LEVEL 	 Perform the following: a. Close the following SW X-CON Valves: V6-12B V6-12C b. Go To Section F.
NOTE A SW Header leak may be identified by SW Header low pressure alarms are rece	observing the sequence in which ived, and evaluating SW Header
NOTE A SW Header leak may be identified by SW Header low pressure alarms are rece pressure indications. 2. Check Leak Location - IDENTIFIED	observing the sequence in which ived, and evaluating SW Header Perform local inspections as necessary to determine leak location.
NOTE A SW Header leak may be identified by SW Header low pressure alarms are rece pressure indications. 2. Check Leak Location - IDENTIFIED	observing the sequence in which lived, and evaluating SW Header Perform local inspections as necessary to determine leak location. WHEN the leak location is identified, THEN Go To Step 3.
NOTE A SW Header leak may be identified by SW Header low pressure alarms are rece pressure indications. 2. Check Leak Location - IDENTIFIED	observing the sequence in which lived, and evaluating SW Header Perform local inspections as necessary to determine leak location. WHEN the leak location is identified, THEN Go To Step 3.
NOTE A SW Header leak may be identified by SW Header low pressure alarms are rece pressure indications. 2. Check Leak Location - IDENTIFIED	observing the sequence in which ived, and evaluating SW Header Perform local inspections as necessary to determine leak location. WHEN the leak location is identified, THEN Go To Step 3.
NOTE A SW Header leak may be identified by SW Header low pressure alarms are rece pressure indications. 2. Check Leak Location - IDENTIFIED	observing the sequence in which ived, and evaluating SW Header Perform local inspections as necessary to determine leak location. WHEN the leak location is identified, THEN Go To Step 3.
NOTE A SW Header leak may be identified by SW Header low pressure alarms are rece pressure indications. 2. Check Leak Location - IDENTIFIED	observing the sequence in which ived, and evaluating SW Header Perform local inspections as necessary to determine leak location. WHEN the leak location is identified, THEN Go To Step 3.

Four Operators worked the following schedule at the RTGB position over the past six days:

HOURS WORKED (Shift turnover time not included. Do **NOT** assume any hours worked before or after this period.)

OPERATOR	DAY 1	DAY 2	DAY 3	DAY 4	DAY 5	DAY 6
1	10	14	off	12	12	12
2	14	12	14	10	off	11
3	off	off	off	13	11	14
4	11	13	14	off	11	12

Which ONE (1) of the operators would be permitted to work a 12 hour shift on Day 7 **WITHOUT** requiring permission to exceed normal overtime limits?

- a. 1
- b. 2
- c. 3
- d. 4

Answer:

r

a. 1

١

QUESTION N TIER/GROUP K/A:	IUMBER: 2.1.1	2	RO	3	SRO	3	
	Knowledge of	conduct of op	erations	requirer	ments.		
			PO	37	SRO	3.8	
10CFR55 CO	NTENT:	55.41(b)	RO	10	55.43(b) SRO	0.0	
OBJECTIVE:	PLP-015-03						
	DEMONSTRA explaining the	TE an unders	standing (of select	ted steps, cautio	ns, and not	es in PLP-015 by
REFERENCE	S:	PLP-015					
SOURCE:	New	Significa	antly Mo	dified	X	Direct	
SOURCE:	New	Significa	antly Mo Bank I	dified Number	X PLP-015-03	Direct	002
SOURCE: JUSTIFICATI a.	New ION: CORRECT	Working a 12 of 48, and 72	antly Mo Bank I 2 hour sh 2 hours in	dified Number ift on Da 17 days,	PLP-015-03 ay 7 would result both of which a	Direct	002 rator working 24 hours out ble.
SOURCE: JUSTIFICATI <i>a.</i> <i>b.</i>	New	Significa Working a 12 of 48, and 72 Plausible sind had a recent	Bank I Bank I hour sh hours in ce this of day off, I	dified Number ift on Da 17 days, perator v but woul	PLP-015-03 ay 7 would result both of which a would not exceed d work 73 hours	Direct	002 rator working 24 hours out ble. urs out of 48 limit and has which exceeds limit.
SOURCE: JUSTIFICATI a. b. c.	New	Signification Si	Bank I Bank I hour sh hours in ce this op day off, I ce this op nt days o	Number Number ift on Da 7 days, perator v but woul perator v	PLP-015-03 ay 7 would result both of which a would not exceed d work 73 hours would not exceed ould not exceed	Direct B in this oper re permissi d the 24 ho in 7 days w d the 72 ho than 24 hor	002 rator working 24 hours out ble. urs out of 48 limit and has which exceeds limit. urs in 7 day limit and has urs in 48 which exceeds
SOURCE: JUSTIFICATI a. b. c. d.	New	Signification Si	Bank I Bank I hour sh hours in ce this of day off, I ce this of nt days o ce this of day off,	Number Number ift on Da 7 days, perator v but woul perator v off, but w perator v but wou	PLP-015-03 ay 7 would result both of which a would not exceed d work 73 hours would not exceed ould work more would not exceed would not exceed would not exceed a would not exceed	Direct Direct in this oper re permissi d the 24 ho in 7 days w d the 72 ho than 24 ho d the 24 ho s in 7 days w	002 rator working 24 hours out ble. urs out of 48 limit and has which exceeds limit. urs in 7 day limit and has urs in 48 which exceeds urs out of 48 limit and has which exceeds limit.
SOURCE: JUSTIFICATI a. b. c. d. DIFFICULTY Comprehent	New	Signification Working a 12 of 48, and 72 Plausible sind had a recent Plausible sind several recent limit. Plausible sind had a recent	antly Mo Bank I hour sh hours in ce this of day off, I ce this of day off, day off,	dified Number ift on Da 7 days, perator w but woul perator w off, but w perator w but wou	PLP-015-03 ay 7 would result both of which a would not exceed would not exceed would not exceed would not exceed would not exceed would not exceed a work 73 hours	Direct Direct in this oper re permissi d the 24 ho in 7 days v d the 72 ho than 24 ho d the 24 ho in 7 days v 3	002 rator working 24 hours out ble. urs out of 48 limit and has which exceeds limit. urs in 7 day limit and has urs in 48 which exceeds urs out of 48 limit and has which exceeds limit.

Compare given data to administrative limits to determine which selection would remain within limits

8.2 Improved Technical Specifications

Improved Technical Specifications requirements set forth in detail in Section 5.2.2.e state that administrative procedures shall be developed and implemented to limit the working hours of Plant Staff who perform safety related functions. This procedure applies to the following job categories for individuals on-shift, performing safety-related work activities: all licensed Operators, Auxiliary Operators, RC Technicians, EC Technicians, I&C Technicians, Electricians, Mechanics, and their First Line Supervisors. First Line Supervisors are defined as those individuals who direct safety-related work activities of the above personnel. All other job categories are exempt. This information is intended to clarify and expand upon the requirements defined within definitions 4.1.1.1 and 4.1.1.2, and represents Robinson's interpretation and application of the available regulatory guidance. (ACR 93-211)

8.3 Requirements

Enough plant operating personnel should be employed to maintain adequate shift coverage without routine heavy use of overtime. The objective is to have operating personnel work a normal shift, based on their work schedule, while the plant is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shutdown for refueling, major maintenance, or major plant modifications, on a temporary basis, the following guidelines shall be followed (Reference Improved Technical Specifications 5.2.2.e):

- 8.3.1 An individual should not be permitted to work more than 16 hours straight, excluding shift turnover time.
- 8.3.2 An individual should not be permitted to work more than 16 hours in any 24-hour period, nor more than 24 hours in any 48-hour period, nor more than 72 hours in any seven day period, all excluding shift turnover time.
- 8.3.3 A break of at least eight hours should be allowed between work periods, including shift turnover time.

PLP-015	Rev. 4	Page 9 of 17

File No.: 10076A

ATTACHMENT 10.1 Page 1 of 1 EXTENDED OVERTIME REQUEST FORM

CONTINUOUS USE

Applicable overtime limits which are being exceeded are one or more of the following: Α.

- Fewer than eight hours between work periods 1.
- More than 24 hours in a 48 hour period 2.
- More than 16 hours in one day 3.
- More than 72 hours in seven days 4.
- The following person(s) are authorized to exceed the guidelines of Technical Specification 6.2.3.b for the В. applicable overtime limits (all limits being exceeded shall be indicated by appropriate number under "Limit"):

E

<u>Name</u>	<u>Limit(s)</u>	<u>Name</u> 7	<u>Limit(s)</u>
2.		8.	
3.		9.	
4.		10.	
5.		11.	
6.		12.	

Effective Date:

Reason(s) why overtime guidelines are exceeded and length of time exceeded: C.

Recommended by (Supervisor):	Date
Reviewed by (Unit Manager):	Date
Telephonic Concurrence:	Date
Approved by Plant General Manager, his designee or highe	r levels of management: Date
Telephonic Concurrence:	Date

A declared emergency is in progress. All affected personnel reporting for emergency response duties are D. authorized to exceed the technical specifications limits for extended overtime for the duration of the emergency.

Approved by: Site Emergency Coordinator or Emergency Response Manager	Date	
--	------	--

Telephonic Concurrence: _____ Date _____

PLP-015	Rev. 4	Page 14 of 17

PLP-015-03 002

Given the following plant conditions:

• Operators #1, #2, and #3 worked the below schedule at the RTGB position (Do not assume any hours worked before or after the seven day schedule shown)

Hours worked (shift turnover time not included)

Operator	Day 1	Day 2	Day 3	Day 4	Day 5	Day 6	Day 7
1	11	13	off	12	12	12	12
2	14	off	13	10	12	11	13
3	off	off	12	13	11	12	12

Which operator(s) exceeded the number of hours a licensed operator may work at the RTGB position?

- A. 2 only
- B. 3 only
- ✓C. 2 and 3
- D. 1, 2 and 3

Given the following conditions:

- The unit was operating at 100% power when a pipe break occurred inside containment.
- Containment pressure is rising.
- RCS temperature is lowering.

Which ONE (1) of the following differentiates between a non-isolable main feed line break inside containment and a non-isolable main steam line break inside the containment of the same size?

- a. RCS heat removal would be greater for the steam line break
- b. Containment pressure would be greater for the feed line break
- c. Containment radiation levels would be greater for the steam line break
- d. RCS depressurization would be greater for the feed line break

Answer:

a. RCS heat removal would be greater for the steam line break

								RNP NRC Written Examination Common Question Reference
QUESTION N	UMBER:	3						
TIER/GROUF K/A:	9: 054AK1.01		RO	1/2		SRO	1/2	
	Knowledge of Feedwater (M	the operation FW): MFW lin	al implic le break	ations of depress	[:] the foll urizes t	owing conc he S/G (sin	epts a nilar to	as they apply to Loss of Main o a steam line break)
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	55.41(b)	RO RO	4.1 5	55.43	SRO (b) SRO	4.3	
OBJECTIVE:	MCD-09-02							
	DESCRIBE th	e limiting ana	lysis for	the Cont	tainmer	nt Critical Sa	afety f	unction
REFERENCE	ES:	FSAR Accide Steam Table	ent Analy s	/sis				
SOURCE:	New	Significa	antly Mo	odified			Direc	ct X
			Bank	Numbe	r M	CD		001
JUSTIFICAT	ION:				inction	would be re	move	d from the RCS as feed
a.	CORRECT	water is boile	ent neat ed to stea	am, a gr	eater a	mount of he	at is r	emoved from the RCS.
b.		Plausible sin steam break	ce feed would p	water wo rovide n	ould flas	sh to steam ergy and a l	as it e higher	entered containment, but the ⁻ pressure.
с.		Plausible sin steam break feed break o	ce in the earlier, nce the	e event c but woul break is	of a con d event uncove	current SG tually escap ered.	TR ga be to tl	ses would escape out the he containment through a
d.		Plausible sin the latent he greater depr	ice large at of vap essuriza	amount porization ition.	s of col n remov	d feed wate ves more er	er wou nergy 1	ld be exiting the break, but from the RCS and results in a
DIFFICULTY Compreher	′: nsive/Analysis	X Kn	owledg	e/Recal		Rating	3	

Comparison of different plant responses to different initiating accidents

standby condition have been analyzed.

Main Feedwater System Design

The rapid depressurization that occurs following a rupture may result in large amounts of water being added to the steam generators through the Main Feedwater System. Rapid-closing isolation valves are provided in the main feedwater lines to limit this effect. Also, the piping layout downstream of the isolation valves affects the volume in the feedwater lines that cannot be isolated from the steam generators. As the steam generator pressure decreases, some of the fluid in this volume will flash into the steam generator, providing additional secondary fluid that may exit out the rupture.

The feedwater addition that occurs before closing of the feedwater line isolation valves influences the steam generator blowdown in several ways. First, the rapid addition of feedwater increases the amount of entrained water in large-break cases by lowering the bulk quality of the steam generator inventory. This tends to reduce the amount of energy released to containment because of the lower energy content of water relative to that of steam.

Second, because the water entering the steam generator is subcooled, it lowers the steam pressure, thereby reducing the flow rate out of the break because of a reduced differential pressure. Finally, the increased flow rate causes an increase in the heat transfer rate from the primary to the secondary system because of the increase in delta-T (Δ T) across the steam generator tubes. This results in greater energy being released out the break.

Since these are competing effects on the total mass and energy release, no worst-case feedwater transient can be defined for all plant conditions. In the results presented in the FSAR, the worst effects of each variable have been used. For example, moisture entrainment for each break is calculated, assuming conservatively small feedwater additions so that the entrained water is minimized.

Determination of total steam generator inventory, however, is based on conservatively large feedwater additions. Table 10-5 contains plant-specific design input for the main steam line break analysis. In Table 10-5, the value given for mass added by feedwater pumping assumes that no reduction in feedwater pump turbine speed occurs following a main steam line break and before main feedwater isolation.

The unisolated feedwater line volumes between the steam generators and the isolation valves

Because this lesson is limited to a discussion of the Containment Critical Safety Function, only the bounding containment pressure transient analysis will be considered. The limiting containment pressure transient for the reference plant is a main steam line break inside containment. Table 10-3 lists the spectrum of secondary system pipe ruptures analyzed in the FSAR. Detailed information concerning other analyzed containment pressure transients appears in the facility FSAR.

Table 10-4 lists the initial conditions used in the FSAR containment analysis. The initial containment conditions were selected based on the range of the normal expected conditions within the containment, with consideration given to maximizing the calculated peak containment pressure.

A detailed study of the initial accident conditions was conducted to determine the effects of varying these initial conditions. The results of this study showed that varying the initial containment conditions over a wide range of values changes the calculated peak pressure by less than 1 percent. So the initial containment conditions are relatively unimportant parameters for the containment pressure and temperature analysis.

Steam line ruptures occurring inside a reactor containment structure may result in a significant release of high-energy fluid to the containment environment, possibly resulting in high containment temperatures and pressures. The quantitative nature of the releases following a steam line rupture is dependent upon the many possible configurations of the plant steam system and containment design, as well as the plant operating conditions and the size of the rupture. These variations make difficult a reasonable determination of the single, absolute "worst case" for both containment pressure and temperature evaluations following a steam line break.

As stated, the FSAR analysis of the main steam line break (MSLB) considers 16 different accident scenarios. Refer to table 10-3. For each of the accident scenarios considered, the analysis is sensitive to four major factors that influence the release of mass and energy following a steam line break:

- Steam generator fluid inventory
- Primary-to-secondary heat transfer
- Protective system operation
- State of the secondary fluid blowdown

Given the following plant conditions:

- The RCP Seal Injection filter has just been changed out.
- HP placed the filter in a lead container.
- Prior to placement of the container, R-4, Charging Pump Room Monitor, read 2 mr/hr.
- The container is on a pallet outside of the Charging Pump Room.
- The activity source in the filter is primarily Cobalt-60.
- The container is 5 feet away from R-4 detector, and R-4 reads 10 mr/hr.

If the container is moved to 10 feet away from the R-4 detector, R-4 will indicate ...

- a. 4.0 mR/hr.
- b. 4.5 mR/hr.
- c. 6.0 mR/hr.
- d. 7.0 mR/hr.

Answer:

a. 4.0 mR/hr.

QUESTION N TIER/GROUF K/A:	IUMBER: 2: 072K5.02	4	RO	2/1		SRO	2/1	
	Knowledge of system: Radia	the operationa tion intensity c	I implica hanges	tions of t with sour	he follov ce dista	wing conce Ince	epts as t	they apply to the ARM
K/A IMPORT, 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.5 12	55.43(b)	SRO) SRO	3.2	
OBJECTIVE:	AOP-005-03							
	EXPLAIN the	basis of select	ed steps	, caution	s, and n	otes in AC	OP-005	
REFERENCE	S:	GET						
SOURCE:	New	Significa	ntly Mo Bank I	dified [Number	X AOP	P-005-03	Direct	012
JUSTIFICAT a.	ION: CORRECT	Container cor factor of 1/r so Background is	ntributes quared, o s still pre	8 mr/hr te or 4. Thu esent (2 n	o readin us. final nr/hr) foi	ig. If dout container r a total of	ble the d contribu f 4 mr/hr	istance, then rate falls by ition is 2 mr/hr.
b.		Plausible if ap double the dis 2.5 mr/hr. Ba	oplies the stance, t ckgroun	e inverse hen rate l d is still p	-square- falls by f present (-ratio to th factor of 4 (2 mr/hr) f	e entire . Final c or a tota	reading of 10 mr/hr. If container contribution is all of 4.5 mr/hr.
с.		Plausible if ap container con mr/hr) for a to	oplies a l tribution stal of 6.0	inear rati calculate 0 mr/hr.	o to the ed to be	container 4.0 mr/hr	contribu . Backg	ution of 8 mr/hr. Final round is still present (2
d.		Plausible if ap calculated to mr/hr.	oplies a l be 5.0 m	linear rati hr/hr. Ba	o to the ckgroun	entire rea d is still p	iding of resent (2	10 mr/hr. Final reading 2 mr/hr) for a total of 7.0
DIFFICULTY Compreher	: sive/Analysis	X Kno	owledge	Recall	Ra	ating	4	

Calculation based on inverse square ratio using a point source

AOP-005-03 012

Given the following plant conditions:

- Mode 5
- The RCP Seal Injection filter has just been changed out
- HP placed the filter in a one inch thick lead container
- Prior to placement of the container, R-4 read 1 mr/hr
- The container is on a pallet outside of the Charging Pump Room
- There is effectively 2 inches of steel between the container and the R-4 (CHARGING PUMP ROOM MONITOR) detector
- The activity source in the filter is primarily Cobalt-60
- The container is 8 feet away from R-4 detector, and R-4 reads 5 mr/hr

Which ONE (1) of the following identifies the correct R-4 reading if the container is moved to 16 feet away from R-4 detector?

- A. 1.25 mr/hr
- **√**B. 2.0 mr/hr
 - C. 2.5 mr/hr
 - D. 3.0 mr/hr

Given the following conditions:

- At 0110, a Reactor Trip and Safety Injection occurred following an accident.
- At 0112, an Alert was declared due to RCS leakage.
- At 0116, a Site Area Emergency was declared.
- At 0120, a General Emergency was declared.

Which ONE (1) of the following identifies the **LATEST** time that the **INITIAL** notification to State/County officials and the NRC must be completed?

1

	STATE / COUNTY	NRC
a.	0125	0210
b.	0127	0212
C.	0131	0216
d.	0135	0220

Answer:

h	0127	0212
∼.		

QUESTION N TIER/GROUF K/A:	NUMBER: 2.4.43	5	RO	3	SRO	3	
	Knowledge of	emergency c	communic	ations s	systems and tech	niques.	
K/A IMPORT 10CFR55 CC	ANCE: INTENT:	55.41(b	RO) RO	2.8 10	SRO 55.43(b) SRO	3.5	
OBJECTIVE:	: EPSPA01-03						
	DEMONSTRA	ATE an under	standing	of the C	R/EOF Emergen	cy Comm	unicator
REFERENCE	ES:	EPLCA-01					
couper.	Maur		onthe Ma	dified		Direct	
SOURCE:	New	Signific	antly Mo	dified	X	Direct	
SOURCE:	New	Signific	antly Mc Bank	odified Numbe	X r EPSPA01-0	Direct	001
SOURCE: JUSTIFICAT <i>a.</i>	New	Plausible sir	<i>Bank</i> Bank	odified Number times a	EPSPA01-C re consistent with	Direct 3 a the even	001 ot initiation, but times are
SOURCE: JUSTIFICAT a.	New	Plausible sir based on the	Bank Bank . Bank . nce these e declara	odified Numbe times a tion time	X r EPSPA01-0 re consistent with e.	<i>Direct</i> 3 a the even	001 at initiation, but times are
SOURCE: JUSTIFICAT a. b.	New	Plausible sir based on the Notifications state/county	Bank Bank nce these e declara are requ	<i>dified</i> <i>Number</i> times a tion time ired with our to the	X r EPSPA01-0 re consistent with a. bin 15 minutes of a NRC.	<i>Direct</i> 3 a the even the initial	001 at initiation, but times are declaration to the
SOURCE: JUSTIFICAT a. b.	New	Plausible sir based on the Notifications state/county	Bank Bank nce these e declara are requ	<i>Number</i> times a tion time ired with our to the	EPSPA01-0 re consistent with e. nin 15 minutes of e NRC.	<i>Direct</i> 3 a the even the initial	001 nt initiation, but times are declaration to the
SOURCE: JUSTIFICAT a. b. c.	New	Plausible sir based on the Notifications state/county Plausible sir Emergency,	Bank Bank Bank Bank Bank Bank Bank Bank	<i>Number</i> times a tion time ired with bur to the times a s are ba	EPSPA01-0 re consistent with a. hin 15 minutes of e NRC. re consistent with sed on the initial	<i>Direct</i> 3 a the even the initial a the decla declaratio	001 ot initiation, but times are declaration to the aration of the Site Area on time.
SOURCE: JUSTIFICAT a. b. c.	New	Signific Plausible sir based on the Notifications state/county Plausible sir Emergency,	Bank Bank ace these e declara are requ and 1 ho but times	<i>dified</i> <i>Number</i> times a tion time ired with our to the times a s are ba	EPSPA01-0 re consistent with . nin 15 minutes of e NRC. re consistent with sed on the initial	<i>Direct</i> 3 a the even the initial a the decla declaratio	001 ot initiation, but times are declaration to the aration of the Site Area on time.
SOURCE: JUSTIFICAT a. b. c. d.	New	Signific Plausible sir based on the Notifications state/county Plausible sir Emergency, Plausible sir Emergency,	Bank Control Bank	<i>dified</i> <i>Number</i> times a tion time ired with our to the times a s are ba	EPSPA01-C re consistent with a. nin 15 minutes of a NRC. re consistent with sed on the initial re consistent with sed on the initial	<i>Direct</i> 3 a the even the initial a the decla declaration a the decla	001 ot initiation, but times are declaration to the aration of the Site Area on time.
SOURCE: JUSTIFICAT a. b. c. d.	New	Signific Plausible sir based on the Notifications state/county Plausible sir Emergency, Plausible sir Emergency,	antly Mo Bank ace these e declara a are requ a and 1 ho but times hoce these but times	<i>Number</i> times a tion time ired with our to the times a s are ba s are ba	EPSPA01-0 re consistent with a. nin 15 minutes of e NRC. re consistent with sed on the initial are consistent with sed on the initial	<i>Direct</i> 3 a the even the initial the initial declaratio	001 ot initiation, but times are declaration to the aration of the Site Area on time. aration of the General on time.
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	New	Signific Plausible sir based on the Notifications state/county Plausible sir Emergency, Plausible sir Emergency, Kr	antly Mo Bank ace these e declara a are requir and 1 ho but times but times but times	<i>Number</i> times a tion time ired with our to the times a s are ba s are ba	X r EPSPA01-0 re consistent with a. hin 15 minutes of be NRC. re consistent with sed on the initial are consistent with	<i>Direct</i> 3 a the even the initial the initial declaratio the decla declaratio	001 at initiation, but times are declaration to the aration of the Site Area on time. aration of the General on time.

8.1.3 (Continued)

- 12. If a General Emergency has been declared, formulate a protective Action Recommendation (PAR).
 - a. Use guidance in Attachments 8.1.5.1, Initial Protective Action Recommendation Flowchart and Attachment 8.1.5.3, PAR Affected Zones Based on Wind Direction to formulate the initial recommendation and zones to be evacuated based on wind direction.
 - b. Subsequent PARs are made by comparing dose projections and environmental monitoring results to Attachment 8.1.5.2, Protective Action Guidelines (PAG) and upgrading the initial recommendations as necessary.
- 13. Develop and transmit an initial Emergency Notification Form to at least one State and County agency within 15 minutes of emergency declaration.
 - a. Follow up notifications are required at least every 30-60 minutes.
- 14. Within one hour of an Alert (or above) declaration, activate the Emergency Response Data System (ERDS) as noted below:
 - a. If the ERDS is not currently operational (ERDS = NORMAL is not displayed at the bottom of an ERFIS terminal), the SEC will ensure that ERDS is activated. Any problems should be reported to Information Technology personnel.
 - b. Display the ERDS activation screen by:
 - Depressing the ERDS key on the ERFIS keyboard, or
 - Typing the Turn-On-Code "ERDS" at the input field, or
 - Selecting ERDS from the EP Menu.

EPSPA01-03 001

Given the following plant conditions:

- At 0608 a Reactor Trip and Safety Injection occurred
- At 0610 an Alert was declared due to RCS leakage
- At 0617 a Site Area Emergency was declared
- It is now 0622

Which ONE (1) of the following determines the amount of time remaining to complete the initial notification to State/County officials and the NRC?

- ✓A. 3 minutes for State/County, 48 minutes for NRC
 - B. 1 minute for State/County, 46 minutes for NRC
 - C. 1 minute for NRC, 46 minutes for State/County
 - D. 3 minutes for NRC, 48 minutes for State/County

Given the following plant conditions:

- An emergency boration is in progress through MOV-350, BA to Charging Pmp Suct, per FRP-S.1, "Response to Nuclear Power Generation / ATWS."
- FI-110, Boric Acid Bypass Flow, indicates 33 gpm.
- FI-122, Charging Line Flow, indicates 75 gpm.
- VCT level is 23 inches.
- VCT Makeup is aligned for automatic operation.
- Normal letdown has been isolated.

VCT level will ...

- a. remain essentially unaffected.
- b. decrease to the auto makeup setpoint and stabilize.
- c. decrease to the low-level setpoint and cause the charging pump suction to switch to the RWST.
- d. decrease to the auto makeup setpoint and cycle between the makeup start and stop setpoints.

Answer:

d. decrease to the auto makeup setpoint and cycle between the makeup start and stop setpoints.

6	RO	1/1	SRC	1/1		
rate and / or m	onitor th	na fallowi	na as thou ann	ly to the Em	argancy Boration	
of letdown sys	stem dur	ing emer	gency boratior		ergency boration.	
55.41(b)	R0) R0	3.1 6	SRO 55.43(b) SRO	3.2)		
normal opera nunciators, ar	ition of th nd setpoi	ne CVCS ints.	control systen	ns. Include f	unction, instrume	ntation,
SD-021						
1111-0.1						
Signific	antly M	odified	X	Direct		
	Bank	Number	CVCS-09		008	
Plausible if n during emer	nisconce gency bo	eption is t pration, b	hat VCT is iso ut remains alig	ated from ch ned.	narging pump suc	tion
Plausible sin lower, but m difference be	nce charg akeup ca etween c	ging exce apability charging	eeds emergend even with eme and boration.	y boration fl rgency borat	ow and VCT leve tion flow is greate	l will r than the
Plausible sir lower, but m	nce charg akeup c	ging exce apability	eeds emergeno is still available	boration fl	ow and VCT leve	l will
Since charg Automatic m	ing exce nakeup w	eds eme vill occur	rgency boratio to cause VCT	n flow, VCT level to rise.	level will decreas	e.
	6 rate and / or more of letdown systems 55.41(b) remore a contract of the systems 55.41(b) remore a contract of the systems SD-021 FRP-S.1 SD-021 FRP-S.1 Signific Plausible if more of the systems Since charge of the systems Contract of the systems Since charge of the systems Contract of the	6 RO ate and / or monitor the of letdown system during for the determinant of the determi	6 RO 1/1 rate and / or monitor the followin of letdown system during emeret RO 3.1 55.41(b) RO 6 normal operation of the CVCS nunciators, and setpoints. SD-021 FRP-S.1 Significantly Modified Bank Number Plausible if misconception is the during emergency boration, b Plausible since charging exceet lower, but makeup capability of difference between charging exceet lower, but makeup capability of difference between charging exceet lower, but makeup capability of difference between charging exceet lower, but makeup capability of difference between charging exceet lower, but makeup capability of difference between charging exceets emerging exceeds emerging excee	6 RO 1/1 SRO rate and / or monitor the following as they app of letdown system during emergency boration RO 3.1 SRO RO 3.1 SRO SRO SSO $S5.41(b)$ RO 6 $55.43(b)$ SRO SRO normal operation of the CVCS control system nunciators, and setpoints. SD-021 SD-021 SD-021 FRP-S.1 Significantly Modified X Bank Number CVCS-09 Plausible if misconception is that VCT is isol during emergency boration, but remains aligned for the company of the since charging exceeds emergency lower, but makeup capability even with emerging exceeds emergency lower, but makeup capability is still available for the company of the since charging exceeds emergency lower, but makeup capability is still available since charging exceeds emergency lower, but makeup capability is still available for the company of the since charging exceeds emergency lower, but makeup capability is still available since charging exceeds emergency lower, but makeup capability is still available since charging exceeds emergency boration. Since charging exceeds emergency boration for the cause VCT Since charging exceeds emergency boration for the cause VCT	6 RO 1/1 SRO 1/1 rate and / or monitor the following as they apply to the Emitod letdown system during emergency boration Image: Constraint of the CMCS control systems 3.2 S5.41(b) RO 6 55.43(b) SRO 3.2 mormal operation of the CVCS control systems. Include for inunciators, and setpoints. Include for inunciators, and setpoints. SD-021 FRP-S.1 Direct Bank Number CVCS-09 Plausible if misconception is that VCT is isolated from charmon during emergency boration, but remains aligned. Plausible since charging exceeds emergency boration for lower, but makeup capability even with emergency boration for lower, but makeup capability is still available. Since charging exceeds emergency boration for lower, but makeup capability is still available. Since charging exceeds emergency boration for lower, but makeup capability is still available. Since charging exceeds emergency boration for lower, but makeup capability is still available.	6 R0 1/1 SR0 1/1 rate and / or monitor the following as they apply to the Emergency Boration: of letdown system during emergency boration Monomial operation of the CVCS control systems. Include function, instrume inunciators, and setpoints. SD-021 FRP-S.1 Direct

Comprehension of the effect of performing an emergency boration on the remainder of CVCS

FRP-	S.	1
T. T/T	υ.	- -

.

RESPONSE TO NUCLEAR POWER GENERATION/ATWS

Rev. 12

Page 6 of 18

	TNOTDICTIONS]		RESPO	NSE NOT OBTAINED]
STEP						J
4.	Initiate Emergency Boration Of RCS As Follows:					
	a. Verify Charging flowpath established as follows:					
	1) CVC-310B, LOOP 2 COLD LEG CHG - OPEN			1) Open LEG	CVC-310A, LOOP 1 HOT CHG.	
	2) HIC-121, CHARGING FLOW Controller - DEMAND SIGNAL AT 0%	Ľ.				
	b. Verify Two Charging Pumps - RUNNING AT FULL SPEED					
	c. Verify Boric Acid Pump		c.	Perform	the following:	
	aligned for biend - Ronning			1) Open valv	n one of the following ves:	
				•	LCV-115B, EMERG MU TO CHG SUCT	
					OR	
				•	CVC-358, RWST TO CHARGING PUMP SUCTION (locally)	
				2) Clos	se LCV-115C, VCT OUTLE	Ť.
				3) Go 1	To Step 4.f.	
	(CONTINU	ed ne	SXT P	PAGE)		

FRP-S.1	RESPONSE TO NUCLEAR PO	OWER GENERATION/ATWS	Rev. 12
			Page / OI 18
STEP	INSTRUCTIONS	RESPONSE NOT OBT	AINED
4. (CONT d. Ve: CHi	INUED) rify MOV-350, BA TO ARGING PMP SUCT - OPEN	 d. Perform the follow 1) Open one of the valves: LCV-115B, E CHG SUCT OR CVC-358, RW CHARGING PU (locally) C) Clear LCV 115C 	ing: following MERG MU TO ST TO MP SUCTION
e. Ch AC IN	eck flow on FI-110, BORIC ID BYPASS FLOW - FLOW DICATED	 2) Close LCV-115C, 3) Go To Step 4.f. e. Perform the follow 1) Open one of the valves: LCV-115B, F CHG SUCT QR CVC-358, RV CHARGING PU (locally) 2) Close LCV-115C, 	VCT OUTLET. ving: following MERG MU TO MST TO MP SUCTION VCT OUTLET.
f. Ve on 5. Verif	rify Charging Flow to RCS FI-122A Y CONTAINMENT VENTILATION		
* 6. Check	SI - INITIATED	IF An SI Signal occu: verify auto start of equipment using Supp while continuing with procedure. Go To Step 8	rs, <u>THEN</u> all SI lement L, h this

6.4.1 Emergency Boration

Emergency Boration is required when an uncontrolled cooldown is in progress while shut down, an unexplained or uncontrolled reactivity increase is occurring, or an Anticipated Transient Without Scram (ATWS) event has occurred.

Five supply paths to charging pump suction exist: through FCV-113A and 113B; through LCV-115B or CVC-358 and close LCV-115C; through FCV-113A and 114B; through MOV-350, or through FCV-113A and CVC-356. The path through MOV-350 shall only be used if intent is to shut down the reactor and maintain it shut down.

Operator actions required to initiate emergency boration include aligning the preferred path, shutting LCV-115C if the RWST is being used and verifying boric acid flow to the RCS through normal or alternate charging, auxiliary spray line or RCP seal injection.

6.4.2 Malfunction of Reactor Makeup Control

Emergency low-low level in VCT causes automatic actions - shifts charging pump suction to RWST.

Low level in VCT requires operator to verify automatic operation or initiate manual operations to restore level.

Manual system lineup will be required if the entire makeup system is inoperative.

Operator actions are directed by AOP-003, Malfunction of Reactor Makeup Control

6.4.3 Loss of Instrument Air to CVCS

Letdown isolated due to orifice valves and letdown valves failing closed

Charging isolations to both loops fail open as does charging flow control valve (HCV-121).

All air operated valves in makeup control system close, except for boric acid to blender valve CVC-113A which fails open.

Automatic switchover to the RWST on VCT low-low level is defeated because LCV-115B fails closed.

Any operating charging pump will go to maximum speed. The Foxboro is an AUTO/MANUAL station and not a controller. The Foxboro allows an I/P signal to

system controls.

- NOTE: The following starting duty limitations apply to the Primary Water pump motor:
 - 1. Maximum number of starts per hour is 20.
 - 2. Minimum time between starts is 2 minutes.

YIC-113, BORIC ACID TOTALIZER, provides a means of setting the amount (in gallons) of boric acid to be added from the RTGB and displays the amount of boric acid actually added. When using the makeup controls in the BORATE mode, it closes FCV-113A and stops the boric acid transfer pump after the desired volume is added.

YIC-114, PRIMARY WATER TOTALIZER, provides a means of setting the amount of Primary Water to be added (in gallons) for a dilution or alternate dilution and provides a display of the amount of primary water actually added. When using the makeup controls in AUTO, DILUTE, and ALTERNATE DILUTE modes, it closes FCV-114A and stops the Primary Water Pump after the desired volume is added.

The RCS Makeup System START/STOP Switch starts and stops makeup when the mode selector switch is not is AUTO and enables/disables auto makeup when the mode selector switch is in AUTO. This switch spring returns to neutral.

The RCS Makeup Mode Selector Switch is a four position (BORATE, AUTO, DILUTE, ALT DILUTE) RTGB switch which controls the mode of makeup to the VCT.

5.2.6 Automatic Makeup (Figure 6, 18 & 19)

The Automatic Makeup mode of operation of the reactor makeup control system provides dilute boric acid solution preset to match the boron concentration in the RCS. The automatic makeup compensates for minor leakage of reactor coolant without causing significant changes in the coolant boron concentration. It operates on VCT level, starting at 20.2 inches and stopping at 24.4 inches.

Under normal plant operating conditions, the mode selector switch and makeup stop valves (FCV-113A and B, and FCV-114A) are set in the AUTOMATIC MAKEUP position. A preset low level signal from the VCT level controller causes the automatic makeup control action to start a boric acid transfer pump, start a primary water makeup pump, open the makeup stop valve (FCV-113B) to the charging pump suctions, open the concentrated boric acid control valve (FCV-113A) and the primary water makeup control valve (FCV-114A). The flow controllers then blend the makeup stream according to the present concentration in the RCS. Makeup addition to the charging pump suction header causes the water level in the volume control tank to rise. At the preset high level point,

the makeup is stopped by the following actions:

- Primary makeup water control valve (FCV-114A) closes
- Boric acid transfer pump is stopped
- Primary water transfer pump is stopped
- Concentrated boric acid control valve (FCV-113A) closes
- Makeup stop valve (FCV-113B) to charging pump suction closes

This operation may be stopped manually by actuating the makeup stop. The blend composition desired in the Automatic Makeup mode of control is established by the plant operator. The primary makeup water flow is controlled at a selectable preset rate when the Automatic Makeup mode is functioning. The boric acid flow is controlled to the rate determined by the plant operator and manually set on the boric acid flow controller. The control of valve FCV-114A for primary makeup water flow is dependent upon the RCS makeup switch position. With the RCS makeup switch and the FCV-114A control station in automatic, valve position is controlled by the HFC-114 setting which is normally set at 100 gpm. With the RCS makeup switch in dilute or alternate dilute and the FCV-114A control station in automatic valve position is controlled by the FCV-114A setting. When the FCV-114A control station is set in manual, regardless of RCS makeup mode switch position, the arrow buttons on the controller are used to set valve position.

The desired boron concentration in the blend is determined on the basis of the present RCS boron concentration. A chart showing the ratio of concentrated boric acid flow to primary makeup water flow vs. boron concentration in the blend stream is used by the operator to determine the boric acid flow and primary makeup water flow control setpoints. The Automatic Makeup blending control functions on demand signals from the VCT level controller.

5.2.7 Dilute (Figure 20 & 21)

The Dilute mode of operation permits the addition of a pre-selected quantity of primary water makeup at a pre-selected flow rate to the RCS. The amount of dilution required to change RCS boron concentration can be estimated using the nomographs in the Station Curve Book. The operator sets the mode selector switch to DILUTE, the primary water makeup flow controller (FC-114) setpoint to the desired flow rate, and the primary water makeup batch integrator (YIC-114) to the desired quantity. Turning the makeup control switch to start opens the primary water makeup control valve (FCV-114A), the VCT makeup stop valve to the VCT (FCV-114B), and starts a primary water makeup pump. Primary water is added to the VCT and thus to the charging pump suction header. Excessive rise of the VCT water level is prevented by automatic actuation of a three-way diversion valve (LCV-115A), which routes the reactor coolant letdown flow to the CVCS holdup tanks. When the preset quantity of primary water has been added, the batch integrator causes the primary water makeup pump to stop and FCV-114A and FCV-114B to close. This operation may be stopped manually by actuating the makeup stop switch.

CVCS-09 008

Given the following plant conditions:

- An emergency boration is in progress
- FI-110, Rapid Boration Flow, indicates 63 gpm
- FI-122, Charging Line Flow, indicates 90 gpm
- VCT level is 35%
- Normal letdown is in service

Which ONE (1) of the following describes the effect emergency boration will have on VCT level?

VCT level will:

- A. remain essentially unaffected
- B. decrease to the auto makeup setpoint and stabilize
- \checkmark C. increase then stabilize after the divert valve is full open
 - D. decrease to the auto makeup setpoint and cycle between makeup start and stop setpoints

Given the following conditions:

- The unit is operating at 100% power.
- APP-003-C3, PRT HI PRESS and APP-003-D3, PRT HI/LO LVL have alarmed.
- PRT level and pressure are slowly increasing, but there is **NO** appreciable increase in PRT temperature.
- NO other annuciators are in alarm.

The PRT response is likely being caused by leakage past ...

- a. PCV-455C, PZR PORV.
- b. RC-551A, PZR Safety.
- c. CVC-203A, High Pressure Letdown Line Relief.
- d. CVC-382, Seal Water Return Line Relief.

Answer:

d. CVC-382, Seal Water Return Line Relief.

TIER/GROUF	UMBER: ?: 007A3.01	7	RO	2/3	SRO	2/3		
	Ability to moni PRT	tor automatic c	peratior	n of the I	PRTS, includin	g: Compone	ents which discharge to the	;
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.7 3	SRO 55.43(b) SRC	2.9)		
OBJECTIVE:	PZR-14							
	EXPLAIN the	effect on the P	ZR and	PRT Sy	stem due to se	lected failur	es	
REFERENCE	ES:	APP-003						
SOURCE:	New	Significa	ntly Mo	dified		Direct	X	
			Bank l	Number	PZR-03		003	
JUSTIFICAT <i>a.</i>	ION:	Plausible sinc	<i>Bank I</i> e this is g tempe	Number a discha rature a	PZR-03 PZR-03 arge source to larms / change	the PRT, bu s have occu	003 ut incorrect since no urred.	
JUSTIFICAT a. b.	ION:	Plausible sinc accompanying Plausible sinc accompanying	Bank I e this is g tempe e this is g tempe	Number a disch rature a a disch rature a	PZR-03 arge source to larms / change arge source to larms / change	the PRT, bu s have occu the PRT, bu s have occu	003 ut incorrect since no urred. ut incorrect since no urred.	
JUSTIFICAT a. b. c.	ION:	Plausible sinc accompanying Plausible sinc accompanying Plausible sinc accompanying	Bank I e this is g tempe e this is g tempe e this is g tempe	Number a disch rature a a disch rature a a disch rature a	PZR-03 arge source to larms / change arge source to larms / change arge source to larms / change	the PRT, but s have occu the PRT, but s have occu the PRT, but s have occu	003 ut incorrect since no urred. ut incorrect since no urred. ut incorrect since no urred.	
JUSTIFICAT a. b. c. d.	ION: CORRECT	Plausible sinc accompanying Plausible sinc accompanying Plausible sinc accompanying Discharges to PRT tempera	Bank I e this is g tempe e this is g tempe e this is g tempe o the PR ture.	A disch rature a a disch rature a a disch rature a T and te	PZR-03 arge source to larms / change arge source to larms / change arge source to larms / change	the PRT, but s have occu the PRT, but s have occu the PRT, but s have occu	003 ut incorrect since no urred. ut incorrect since no urred. ut incorrect since no urred. ly the same as the normal	
JUSTIFICAT a. b. c. d. DIFFICULTY Compreher	ION: CORRECT 7: nsive/Analysis	Plausible since accompanying Plausible since accompanying Plausible since accompanying Discharges to PRT tempera	Bank I e this is g tempe e this is g tempe e this is g tempe o the PR ture.	Number a disch rature a a disch rature a a disch rature a T and te	PZR-03 PZ	the PRT, bu s have occu the PRT, bu s have occu the PRT, bu s have occu upproximatel	003 ut incorrect since no urred. ut incorrect since no urred. ut incorrect since no urred. ly the same as the normal	

ALARM

PRT HI PRESS

AUTOMATIC ACTIONS

1. Not Applicable

<u>CAUSE</u>

- 1. In leakage from Makeup Water, Pressurizer Relief Valves, Pressurizer Safety Valves, RHR Loop Relief Valves, Letdown Relief Valves, Seal Water Return Relief Valve, SI Test Line Relief Valve, or SI Cold Leg Injection Header Relief Valve
- 2. Failure of N₂ Supply to PRT
- 3. Opening of Pressurizer Safety or PORV

OBSERVATIONS

- 1. PRT Level (LI-470)
- 2. PRT Pressure (PI-472)
- 3. PRT Temperature (TI-471)
- 4. Pressurizer Safety Valve Line Temperatures (TI-465, TI-467, TI-469)
- 5. PORV Discharge Line Temperature (TI-463)

ACTIONS

- 1. IF a PZR PORV or Safety fails open while greater than 350°F, THEN Refer To Path-1.
- 2. IF pressure is high, THEN vent the PRT as follows:
 - 1) Open RC-549, PRT VENT
 - 2) IF required, THEN verify a Waste Gas Compressor starts.
 - 3) WHEN pressure is less than 3 psig, THEN close RC-549.
- 3. IF necessary, THEN adjust Nitrogen Regulator to PRT.
- 4. IF necessary, THEN drain the PRT using OP-103.

DEVICE/SETPOINTS

1. PC-472 / 5 psig

POSSIBLE PLANT EFFECTS

1. PRT Rupture Disk failure at 100 psig

REFERENCES

- 1. Path-1, EOP Network
- 2. CWD B-190628, Sheet 461, Cable P
- 3. OP-103, Pressurizer Relief Tank Control System

ADD 002		Page 25 of 52
APP-003	1(04.20	- 9

<u>ALARM</u>

PRT HI/LO LVL *** WILL REFLASH ***

AUTOMATIC ACTIONS

1. Not Applicable

CAUSE

High

- 1. Excessive makeup water added
- In leakage from Makeup Water, Pressurizer Relief Valves, Pressurizer Safety Valves, RHR Loop Relief Valves, Letdown Relief Valves, Seal Water Return Relief Valve, SI Test Line Relief Valve, or SI Cold Leg Injection Header Relief Valve
- 3. Opening of Pressurizer Safety or PORV

Low

- 1. Leakage from PRT to the Reactor Coolant Drain Tank or other area.
- 2. Excessive draining.

OBSERVATIONS

- 1. PRT Level (LI-470), Pressure (PI-472), and Temperature (TI-471)
- 2. Pressurizer Safety Valve Line Temperatures (TI-465, TI-467, TI-469)
- 3. PORV Discharge Line Temperature (TI-463)

ACTIONS

- 1. IF a PZR PORV or Safety fails open while greater than 350°F, THEN Refer To Path-1.
- 2. IF level is high, THEN drain the PRT using OP-103.
- 3. IF level is low, THEN add Primary Water to the PRT using OP-103.

DEVICE/SETPOINTS

- 1. LC-470 / 83%
- 2. LC-470 / 68%

POSSIBLE PLANT EFFECTS

1. None Applicable

REFERENCES

- 1. Path-1, EOP Network
- 2. OP-103, Pressurizer Relief Tank Control System
- 3. CWD B-190628, Sheet 461, Cable M, N

APP-003	Rev. 29	Page 33 of 52

Which ONE (1) of the following conditions would result in a reactor trip?

- a. PT-447, First Stage Turbine Pressure, fails low with power level at 22%
- b. NI-43, PR Channel N43, fails low with power level at 49%
- c. PT-446, First Stage Turbine Pressure, fails high with power level at 1×10^{-8} amps
- d. NI-44, PR Channel N44, fails high with power level at at 1×10^{-8} amps

Answer:

c. PT-446, First Stage Turbine Pressure, fails high with power level at 1×10^{-8} amps

					Co	ommon Question Reference	Э
QUESTION N TIER/GROUP K/A:	IUMBER: : 045K1.18	8 R	O 2/3	SRO	2/3		
	Knowledge of system and th	the physical conr le RPS	nections and	/or cause-effect	relationships	between the MT/G	
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	RC 55.41(b) RC	3 .6 7	SRO 55.43(b) SRO	3.7		
OBJECTIVE:	MT-11						
	EXPLAIN the	reactor trips asso	ciated with t	ne MT System.	Include purp	ose and setpoints.	
REFERENCE	S:	SD-011					
SOURCE:	New	X Significantl	y Modified		Direct		
		В	ank Numbe	r		NEW	
JUSTIFICATI <i>a.</i>	ON:	Plausible since P-7 blocks are changed at 10% equivalent power, but 1/2 above 10% enables turbine trip to reactor trip.					
b.		Plausible since P-7 blocks are changed at 10% power and P-10 provides an input to P-7, but 2/4 above 10% enables turbine trip to reactor trip.					
с.	CORRECT	At this power level the turbine stop valves are closed. With 1/2 First Stage Pressure transmitters failing high, P-7 automatically unblocks the turbine trip to reactor trip signal.					
d.		Plausible since i turbine stop valv power.	ndicated pov es closed, b	ver above P-7 w ut coincidence f	ould cause a or P-10 input	a reactor trip with the to P-7 is 2/4 above 10%	
DIFFICULTY Comprehen	: sive/Analysis	X Know	ledge/Recal	Rating	3		

RNP NRC Written Examination

Analysis of the effect of instrument failures on turbine trip to reactor trip circuits
ATTACHMENT 10.1 Page 2 of 3

REACTOR PROTECTION SYSTEM PERMISSIVES

PERMISSIVE NUMBER	DERIVATION	FUNCTION
P-7	 2/4 Power Ranges above setpoint (10% from P-10) OR 1/2 Turbine First Stage Pressure above setpoint (10%) 	 Enables the following trips: 1. RCS Low Flow 2. RCP Breakers Open 3. UV 4. Turbine Trip 5. PZR low Pressure 6. PZR High Level
	 3/4 Power Ranges below setpoint (10%) from P-10 AND 2/2 Turbine First Stage Pressure below setpoint (10%) 	 Blocks the following reactor trips: 1. RCS Low Flow 2. RCP Breakers Open 3. UV 4. Turbine Trip 5.PZR Low Pressure 6.PZR High Level
Р-8	2/4 Power Ranges above setpoint (40%)3/4 Power Ranges below	Enables Reactor Trip on low flow in a single loop Blocks Reactor Trip on low
	setpoint (40%)	flow in a single loop

Revision 3



RPS-FIGURE-34 (Rev. 0)

TURBINE TRIP/REACTOR TRIP LOGIC



Which ONE (1) of the following describes the reason for RCP restart in FRP-P.1, "Response To Imminent Pressurized Thermal Shock", if the SI termination criteria **CANNOT** be satisfied?

- a. Restores PZR spray to allow RCS depressurization in subsequent steps
- b. Equalizes S/G pressures to allow simultaneous cooldown of all three loops in subsequent steps
- c. Mixes Safety Injection water and RCS water to raise the fluid temperature entering the Reactor Vessel downcomer
- d. Transfer core cooling to forced flow allowing the operators to terminate Safety Injection when the criteria are **NOT** satisfied

Answer:

;

c. Mixes Safety Injection water and RCS water to raise the fluid temperature entering the Reactor Vessel downcomer

							RNP NRC Written Examination Common Question Reference
QUESTION N TIER/GROUP K/A:	UMBER: : WE08EK3.3	9	RO	1/1	SRC) 1/1	
	Knowledge of Shock) Manip emergency si	the reasons fulation of con tuations.	or the fo trols req	ollowing r uired to	esponses as th obtain desired o	ney apply operating	to the (Pressurized Thermal results during abnormal, and
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.7 3	SRO 55.43(b) SRO	3.8)	
OBJECTIVE:	FRP-P.1-03						
	DEMONSTRA explaining the	ATE an unders basis of each	standing 1.) of selec	ted steps, caut	ions, and	notes in FRP-P.1 by
REFERENCE	S:	FRP-P.1					
SOURCE:	New	Signific	antly M	odified		Dire	ct X
	0.11		Bank	Numbe	r FRP-P.1-(03	004
a.	UN:	Plausible sin sprays, but t	ce starti he RCP	ing an R0 is started	CP does restore d to provide mix	e pressur king for th	e control using normal ne SI water.
b.		Plausible sin steaming rat procedure.	ce durin es, but c	ig natural cooldown	l circ the SG pr s are not perfo	essures r rmed dur	may vary due to different ing the implementation of this
с.	CORRECT	Cold SI wate to create mix downcomber	r flows t king. Th ⁻ wall.	through t is could i	he cold leg to th result in radical	ne downc drops in	omber with no RCPs running temperature along the
d.		Plausible sin conditions ar	ce cooli e met.	ng will be	e by forced flow	/, but SI is	s not terminated unless all
DIFFICULTY: Comprehen	sive/Analysis	Kn Kn	owledg	e/Recall	X Rating	3	
	Knowledge of	background	nformat	ion in FR	P-P.1		

REFERENCES SUPPLIED:

FRP-P.1

RESPONSE TO IMMINENT PRESSURIZED THERMAL SHOCK

Rev. 12

Page 9 of 22

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
16.	Determine If An RCP Can Be Started As Follows:	
	a. Check RCS subcooling - GREATER THAN 35°F [55°F]	a. Go To Step 44.
	 b. Establish support conditions for running an RCP using OP-101, Reactor Coolant System and Reactor Coolant Pump Startup and Operation 	b. Go To Step 44.
	c. Start one RCP using OP-101, Reactor Coolant System and Reactor Coolant Pump Startup and Operation	c. Go To Step 44.
	d. Go To Step 44	
****	******	**********
	<u>CAUT:</u>	ION
If o rest	ffsite power is lost after SI rese art safeguards equipment.	et, manual action may be required to
****	***************************************	**************
17.	Reset The Following Signals:	
	• SAFETY INJECTION	
	• CONTAINMENT SPRAY	
18.	Reset The Following Containment Isolations:	
	• PHASE A	
	• PHASE B	

RNP WOG BASIS/DIFFERENCES

STEP STEP

12 4 <u>WOG BASIS</u>

PURPOSE: To specifically note if PRZR PORVs are properly positioned

BASIS:

Depending upon the implementation of the Cold Overpressure Protection System (COPS), the pressure criterion used for checking PORV operations is either PRZR pressure less than the PORV setpoint (if COPS not in service) or RCS pressure less than cold overpressure limit (if COPS in service). If the appropriate pressure criterion is met, the PRZR PORVs should be closed.

RNP DIFFERENCES/REASONS

The step has been formatted as a continuous actions step (see C4 above).

SSD DETERMINATION

This is an SSD per criterion 11.

13 5 WOG BASIS

PURPOSE: To determine if any high-head SI pump is running

BASIS:

If SI is in service, then the SI termination sequence in Steps 6 through 12, which includes stopping SI pumps and establishing charging flow, is appropriate. If SI is not in service, these steps are bypassed.

RNP DIFFERENCES/REASONS

There are no significant differences.

SSD DETERMINATION

This is not an SSD.

14-16 6 <u>WOG BASIS</u>

PURPOSE: To determine if conditions have been established which indicate that full SI flow is no longer required

BASIS:

Following SI actuation, RCS conditions may be restored to within acceptable limits for SI termination to be allowed. The combination of a minimum subcooling and sufficient liquid level in the vessel to cover the core represents less restrictive SI termination criteria in this guideline than those present in the ORGs since, for an imminent PTS condition, SI flow may have contributed to the RCS cooldown or may prevent a subsequent reduction in RCS pressure.

FRP-P.1	Rev 12	Page 16 of 31

RNP WOG BASIS/DIFFERENCES

STEP STEP

14-16 6 BASIS (Continued)

The subcooling criterion will ensure subcooled conditions and the RVLIS indication ensures the existence of an adequate vessel inventory such that core cooling is ensured. Refer to document SI TERMINATION/REINITIATION in the Generic Issues section of the Executive Volume.

If either of the termination criteria are not satisfied, then SI is required to ensure core cooling and should not be terminated. Most likely the cold leg/downcomer low temperature condition is due to SI water mixing effects and an RCP restart is attempted. Of the transients considered in PTS, the SBLOCA transient may result in a condition whereby Safety Injection (SI) flow cannot be terminated. In Westinghouse Owners Group (WOG) reports 0G-110 and 0G-117 titled "Evaluation of Alternate RCP Trip Criteria" and "Justification of Manual RCP Trip for Small Break LOCA Events" respectively, a range of SBLOCAs were identified where continued RCP operation or conversely untimely RCP restart could result in increased RCS inventory loss. The loss of additional inventory could ultimately result in deeper core uncovery transients which could in turn result in fuel cladding temperatures in excess of the plant's design basis FSAR analysis result. Therefore, from a SBLOCA standpoint, RCP restart at an inopportune time could result in a degraded core cooling scenario. In WCAP-10319 titled "A Generic Assessment of Significant Flaw Extension, Including Stagnant Loop Conditions, from Pressurized Thermal Shock of Reactor Vessels on Westinghouse Nuclear Power Plants", numerous transient analyses including those of SBLOCA have been analyzed without RCP restart. The results of the stagnant loop evaluation demonstrate that the total expected frequency of significant flaw extension in a typical W PWR reactor vessel due to PTS, including the contributions from stagnant loop SBLOCA transients, does not exceed the NRC required RTPTS screening value of 270°Ffor axial flaws. Therefore, based on analyses results, RCP restart is not required to meet the NRC PTS risk goal for a typical W plant.

Therefore, an additional support condition, RCS subcooling, in addition to plant specific minimum support conditions is recommended to assure that no potential RCS inventory aggravation will occur due to RCP restart.

An analysis of the effect of an RCP restart has been made to ensure the safety of this action relative to vessel integrity. For conservatism in the analysis the assumption was made that a small preexisting flaw had grown and arrested at 75 percent of wall thickness before RCP start. Starting an RCP was shown not to result in any further flaw propagation and loss of vessel integrity. For a case where a flaw has not grown prior to RCP start, the subsequent heat-up of the downcomer region will decrease the possibility of flaw initiation.

Therefore, in order to mix the cold incoming SI water and the warm reactor coolant water and thereby decrease the likelihood of a PTS condition, an RCP restart is attempted. Whether an RCP is started or not, the next step performed (Step 24), if SI is still required, provides guidance on subsequent cooldown restrictions.

FRP-P.1	Rev 12	Page 17 of 31

Given the following conditions:

- The plant has experienced a reactor trip.
- The CRSS directs the RO to manually initiate Safety Injection.
- The RO inadvertently depresses BOTH Containment Spray pushbuttons.

In addition to Containment Spray, which ONE (1) of the following are **ALL** expected to automatically occur?

- a. Phase A
 - Phase B
- b. Phase A
 - Containment Ventilation Isolation
- c. Phase B
 - Containment Ventilation Isolation
- d. Phase A
 - Phase B
 - Containment Ventilation Isolation

Answer:

- c. Phase B
 - Containment Ventilation Isolation

Common Question Reference QUESTION NUMBER: 10 **TIER/GROUP:** RO 2/3 SRO 2/2 103K4.06 K/A: Knowledge of containment system design feature(s) and/or interlock(s) which provide for the Containment isolation system SRO 3.7 3.1 **K/A IMPORTANCE:** RO 55.43(b) SRO 10CFR55 CONTENT: 55.41(b) RO 9 **OBJECTIVE: CSS-08** EXPLAIN the component operation associated with each switch position for the CSS switches and controls. SD-024 **REFERENCES:** SD-006 Significantly Modified Direct X SOURCE: New **CSS-08** 003 **Bank Number JUSTIFICATION:** Plausible since Phase B occurring is correct, but Phase A does not occur. a. Plausible since CVI occurring is correct, but Phase A does not occur. b. CORRECT Manual actuation of Containment Spray results in Phase B and CVI occurring. C. Plausible since Phase B and CVI occurring is correct, but Phase A does not occur. d. **DIFFICULTY:** 3 Knowledge/Recall X Rating Comprehensive/Analysis Knowledge of system actuations in response to manual actuation

RNP NRC Written Examination

REFERENCES SUPPLIED:

5.0 CONTROLS AND PROTECTION

- 5.1 Containment Spray Actuation
- 5.1.1 Automatic

Containment Spray Actuation will automatically occur when a Containment Hi-Hi Pressure signal is sensed at 20 psig. This will cause the following:

NOTE: In the year 2000, it is planned to reduce this setpoint to 10 psig to allow the Service Water temperature to be increased without challenging CV pressure. (ESR 99-00153).

- 1) Steam Line Isolation actuation (closes all three MSIVs)
- 2) Spray actuation
- 3) Safety Injection actuation
- NOTE: Containment pressure bistables for spray actuation are energize-to-actuate. This differs from other ESF actuations. The purpose is to minimize the possibility for an inadvertent spray signal due to power interruption.
- Phase "B" Containment Isolation, The following values close: CC-716A & B, RCP Clg Wtr Inlet Isols
 FCV-626, RCP Thermal Barrier Flow Control
 CC-735, RCP Thermal Barrier Outlet Isol
 CC-381, RCP Seal Wtr Rtrn Isol
 CVC-730, RCP Oil Coolers Outlet Isol

5.1.2 Manual

Containment Spray Actuation can be manually actuated when both Spray pushbuttons are simultaneously depressed. There are Containment Spray Defeat pushbuttons on the RTGB that are not used (abandoned in place). Spray actuation will cause the following:

- 1) Spray actuation
- 2) Containment Phase "B"
- 3) Containment Ventilation Isolation The following valves will close:
 - Purge Valves
 - Pressure Relief Valves
 - Vacuum Relief Valves

Revision 4

SD-024

CSS

- 3. Low Pressurizer Pressure
- 4. Containment High Pressure
- 5. Manual
- 6. Containment Hi-Hi Pressure

4.2.2 Safety Injection (SI or S) Signal Actions4.2.2 Safety Injection (SI or S) Signal Actions

The actions caused by a SI signal are listed below:

- 1. Reactor Trip
- 2. Emergency diesel generator startup
- 3. Feedwater isolation
- 4. Safeguard sequence actuation
- 5. Phase "A" Containment isolation and IVSW actuation
- 6. Containment Ventilation isolation
- 7. Control Room Ventilation shifts to the Emergency Pressurization Mode
- 8. Close normal dampers for HVH 1-4
- 9. Align various valves within the SI and RHR systems
- 4.3 Containment Spray4.3 Containment Spray
- 4.3.1 Containment Spray (P) Signal4.3.1 Containment Spray (P) Signal

The Containment Spray ("P") signal is initiated by a Hi-Hi containment pressure(10 psig) or manual actuation.

4.3.2 Containment Spray Automatic Signal Actions4.3.2 Containment Spray Automatic Signal Actions

The actions caused by a Containment Spray Automatic signal are listed below:

- 1. Spray actuation
- 2. Phase "B" containment isolation
- 3. Steam line isolation

4.3.3 Containment Spray Manual Signal Actions4.3.3 Containment Spray Manual Signal Actions

The actions caused by a Containment Spray Manual Signal are listed below:

- 1. Spray actuation
- 2. Phase "B" containment isolation
- 3. C.V. ventilation isolation

Page 14 of 39

Revision 5

INFORMATION USE ONLY

ESF

Given the following conditions:

- The unit is operating at 17% power.
- Condenser backpressure is 5.7 inches Hg Absolute and degrading slowly.
- A power reduction is in progress in an attempt to stabilize backpressure.
- NO cause has yet been identified.

Which ONE (1) of the following actions should be taken in accordance with AOP-012, "Partial Loss of Condenser Vacuum or Circulating Water Pump Trip"?

- a. Trip the reactor and go to PATH-1
- b. Trip the turbine and verify the plant stabilizes on the steam dumps at the point of adding heat
- c. Trip the turbine and verify the plant stabilizes on the steam dumps at approximately the current power level
- d. Continue the power reduction

Answer:

d. Continue the power reduction

AOP-012-03 010

Given the following plant conditions:

- Vacuum in the main condenser is decreasing
- No cause has yet been identified
- A power reduction has commenced IAW directions in AOP-012, "Loss of Condenser Vacuum"
- Power is presently at 7.0%

Which ONE (1) of the following describes the proper course of action for the above conditions?

- A. If condenser backpressure reaches 7 inches Hg, trip the reactor and go to Path-1
- B. If condenser backpressure reaches 7 inches Hg, trip the turbine and go to AOP-007, "Turbine Trip Below P-7"
- C. If condenser backpressure reaches 10 inches Hg, trip the reactor and go to Path-1
- ✓D. If condenser backpressure reaches 10 inches Hg, trip the turbine and go to AOP-007, "Turbine Trip Below P-7"

								Common Question Reference
QUESTION N TIER/GROUP K/A:	IUMBER: ?: 051AA2.02	11	RO	1/1		SRO	1/1	
	Ability to deter Conditions rec	mine and inte quiring reactor	erpret the and/or t	e followin urbine tr	g as the ip	y apply to	the Lo	ss of Condenser Vacuum:
K/A IMPORT, 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.9 7	55.43(k	SRO) SRO	4.1	
OBJECTIVE:	AOP-012-08							
	Given plant co loss of conder	onditions EVA nser vacuum o	LUATE t or a Circi	he appro ulating V	opriate a Vater Pui	ctions to r mp trip as	nitigate directe	e consequences of a partial ed by AOP-012.
REFERENCE	ES:	AOP-012						
SOURCE:	New	Signific	antly Mo	odified	X		Direc	
			Bank	Numbei	r AO	P-012-03		010
JUSTIFICAT a.	ION:	Plausible sin was required	ce at this I, but a tr	s power ip is not	level a re required	eactor trip until vaci	would uum lov	be required if a turbine trip wers to 10'' Hg Abs.
b.		Plausible if n vacuum calls Abs.	nisconce s for turbi	ption tha	at reactor but trip is	trip is no not requi	t requir ired un	ed at this power level and til vacuum lowers to 10'' Hg
C.		Plausible if n vacuum calls Abs.	nisconce s for turbi	ption tha ine trip, l	at reactor but trip is	r trip is no s not requi	t requir ired un	ed at this power level and til vacuum lowers to 10" Hg
d.	CORRECT	With vacuun and determin	n better th ne the ca	han 10" iuse of tl	Hg Abs, ne loss o	efforts are f vacuum	e contir . A trip	nued to lower turbine load is not yet required.
DIFFICULTY Compreher	: nsive/Analysis	Kr.	owledge	e/Recall	X F	Rating	3	
	Knowledge o	f required acti	ons in re	sponse	to loss o	f vacuum		

RNP NRC Written Examination

REFERENCES SUPPLIED:

Page 8 of 24

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
<u>_</u>		
	NOTE	
	NS-115 is located at the Steam I	Dump Nitrogen Accumulator.
	,,,,,,,,_	
17.	Dispatch An Operator Perform The Following:	
	a. Close NS-115, STEAM GENERATOR NITROGEN BLANKET ISOLATION	
	b. Close each of the four TURBINE PERFORMANCE TEST CONNECTION VALVEs used for Nitrogen addition	
	 HP Turbine Enclosure two valves between the LP and HP Turbines (North & South sides) 	
	• LP Turbine 2 Enclosure two valves between the LP Turbine and Generator (North & South sides)	
18.	Verify Standby Vacuum Pump - RUNNING	
19.	Verify All Available Circulating Water Pumps - RUNNING	
20.	Check Turbine Status - ON LINE	Go To Step 25.
*21.	Check Condenser Back Pressure On PI-1312 <u>AND</u> PI-1313 - GREATER THAN 10 INCHES HG ABS	Go To Step 24.
22.	Check REACTOR TRIP FROM TURB	Perform the following:
	ILLUMINATED	a. Trip the Reactor.
		b. Go To Path-1.

AOP-0	12	PARTIAL LOSS OF CONDENSER V WATER PUMP	ACUUM OR CIRCULATING TRIP	Rev. 11 Page 9 of 24
<u>,</u>				1490 5 01 51
STEP	-	INSTRUCTIONS	RESPONSE NOT OB	TAINED
23.	Perfo Follow	rm Turbine Trip Actions As ws:		
	a. Mar	nually trip the Turbine		
	b. Go Wit	To AOP-007, Turbine Trip thout Reactor Trip Below P-7		
*24.	Check	Condenser Back Pressure On	Perform the following	g:
	5.5 II	NCHES HG ABS	a. Reduce Turbine loa necessary to main Condenser back pro than 5.5 inches He	ad as tain essure less g abs.
			b. Notify Load Dispation.	tcher of the
			c. <u>IF</u> Condenser back <u>NOT</u> be maintained 5.5 inches Hg abs plant shutdown us Normal Plant Shut Power Operations Shutdown, while c with this procedu	pressure can less than , <u>THEN</u> begin ing GP-006, down From To Hot ontinuing re.
25.	Verif BREAK	y The Following VACUUM ER Valves - CLOSED		
	• M	S-70A		
	• M	IS-70B		
26.	Check Opera RUNNI	: Circulating Water Pump tion – LESS THAN TWO PUMPS NG	Go To Step 29.	

Given the following conditions:

- The plant is shutdown following a reactor trip.
- RCPs are all secured.
- The Inadequate Core Cooling Monitor is **NOT** capable of providing subcooling margin.
- Primary Plant parameters indicate the following:

INSTRUMENT	PARAMETER	VALUE
PT-455	PZR Press	1485 psig
PT-456	PZR Press	1465 psig
PT-457	PZR Press	1515 psig
PT-402	RCS Press	1500 psig
PT-405	RCS Press	1525 psig
TI-453	PZR Temp (Surge Line)	524 °F
TI-454	PZR Temp (Vapor)	630 °F
TI-413	RCS Hot Leg WR Temp	538 °F
TI-423	RCS Hot Leg WR Temp	536 °F
TI-433	RCS Hot Leg WR Temp	534 °F
	Highest Five (5) CETs	548 °F
		544 °F
		542 °F
		542 °F
		541 °F

The margin to saturation is ...

- a. 46 °F.
- b. 51 °F.
- c. 56 °F.
- d. 58 °F.

Answer:

a. 46 °F.

QUESTION N TIER/GROUP K/A:	UMBER: 2: 017K4.01	12	RO	2/1		SRO	2/1		
	Knowledge of Input to subco	TITM system d	esign fe	eature(s) a	and/or into	erlock(s)	which pro	ovide for the	following:
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.4 3	S 55.43(b)	RO SRO	3.7		
OBJECTIVE:	ICCM-10								
	EXPLAIN the	operation of th	e ICCN	1.					
REFERENCE	:S:	OP-307							
SOURCE:	New	X Significa	ntly Mo	odified			Direct		
			Bank	Number				NEW	
JUSTIFICAT	ION:								-
a.	CORRECT	Using lowest temperature f	valid pr or this p	essure (1 pressure i	465 psig) is 594 °F,	and hig resulting	nest valid g in a man	gin to satura	r), saturation ation of 46 °F.
b.		Plausible sind but highest C	e this is ET, not	s calculate average,	ed value u is used.	using lov	vest press	ure and ave	erage CET,
с.		Plausible sind highest CET,	e this is not Tho	s calculat ot, is usec	ed value (I.	using lov	vest press	ure and hig	hest Thot, but
d.		Plausible sind but highest C	e this is ET sho	s calculat uld be us	ed value i ed.	using lov	vest press	sure and ave	erage Thot,
DIFFICULTY Compreher	: sive/Analysis	X Kno	owledg	e/Recall	Ra	ting	3		

REFERENCES SUPPLIED:

3.0 **PREREQUISITES**

- 3.1 The Electrical System has been lined up to supply power to the Instrument Buses in accordance with OP-603, Electrical Distribution System, and OP-001, Reactor Coolant and Protection System.
- 3.2 The Reactor Vessel Level Instrumentation System (RVLIS) sensors and sensing lines have been filled and vented in accordance with MRP-008.
- 3.3 The RVLIS system has been calibrated in accordance with LP-042.

4.0 **PRECAUTIONS AND LIMITATIONS**

- 4.1 Operating personnel should refer to Section 8.1 for determining Saturation Margin if the Inadequate Core Cooling System becomes inoperative.
- 4.2 Under normal conditions, the pressurizer temperature is the saturation temperature corresponding to pressurizer pressure; therefore, the difference between pressurizer temperature and hot leg temperature is approximately the margin to saturation in °F. This may be used as a rapid backup method for determining saturation margin. However, this method will not be valid in the event that the hottest spot in the RCS should shift to another point in the system, such as formation of a void in the reactor vessel head.
- 4.3 When manually determining saturation margin, each temperature and pressure indication must be carefully evaluated for its validity. The highest valid temperature indication and lowest valid pressure indication should be used for a conservative determination of saturation margin.

OP-307	Rev. 11	Page 5 of 17
01 001		

CONTINUOUS USE

8.0 INFREQUENT OPERATIONS

- 8.1 Manual Calculation of Margin to Saturation
 - 8.1.1 Initial Conditions
 - 1. This revision has been verified to be the latest revision available.

N	lame (P	rint)	Initial	Signature		Date	
8.1.2	Instruc	tions for Ma	anual Calculati	ion of Margin to Saturati	on		
	1.	Determine indication.	primary press	ure using the lowest vali	d pressure _ psig	•	
	2.	Convert pre determined	essure to abso I in Step 8.1.2.	lute by adding 14.7 psi 1	to value ₋ psia		
	3.	Enter, from temperatur Step 8.1.2. temperatur	the Saturated e correspondir 2 to determine e.	I Steam Tables, the satung to the pressure show the corresponding	uration n in °F		
	4.	Determine primary temperature using the highest valid core exit thermocouple temperature indication.					
	5.	Subtract th temperatur to saturatic	e temperature re of Step 8.1.2 on in °F.	of Step 8.1.2.4 from the 2.3 to determine the ma	e rgin °F		
		<u>Initials</u>	Name	(Print)	<u>Dat</u>	e	
Performed By	y: _						
Approved By	: -	Unit 2	- Superintend	dent Shift Operations	 Da	te	

OP-307	Rev. 11	Page 14 of 17

Given the following conditions:

- A 25 year old male started working for the Operations department at H.B. Robinson on March 3rd of this year.
- He previously worked this year at Shearon Harris as part of the Maintenance department.
- His exposure for this year at the Harris plant was 1200 mRem.
- He has received NO CP&L management exposure extensions and NO emergencies exist.

Which ONE (1) of the following is the **TOTAL ADDITIONAL** effective dose equivalent that the individual can receive **WITHOUT** management concurrence at Robinson this year?

- a. 300 mRem
- b. 800 mRem
- c. 2000 mRem
- d. 2800 mRem

Answer:

b. 800 mRem

				Commor	Question Reference
QUESTION NUMBER: TIER/GROUP: K/A: 2.3.1	13	RO 3	SRO	3	
Knowledge	e of 10 CFR:20 an	d related facil	ity radiation contro	l requirements.	
-					
K/A IMPORTANCE: 10CFR55 CONTENT:	55.41(b)	RO 2.6 RO 12	SRO 55.43(b) SRO	3.0	
OBJECTIVE: 10CFR20-	03				
Identify the Dose Limits for adults including: a. Occupational Dose Limits b. Public Dose Limits					
REFERENCES:	NGGM-PM-00	02			
SOURCE: Ne	w 🔲 Significa	ntly Modified	I X	Direct	
		Bank Numb	er 10CFR20	008	
JUSTIFICATION: a.	Plausible if m 2000 mRem.	isconception i	s that administrativ	ve limit is 1500 mR	Rem, but limit is
b. CORREC	CT Total exposur Harris is a CF	Total exposure for the year for all work performed at CP&L plants is 2000 mRem. Harris is a CP&L plant.			
с.	Plausible since this would be correct exposure at Robinson if previous exposure was at a utility other than a CP&L plant, but Harris exposure counts toward CP&L limit.				
d.	Plausible sinc a CP&L plant limit of 2000 r	Plausible since limit is 4000 mRem if previous exposure was at a utility other than a CP&L plant, but Harris exposure counts toward CP&L limit and additional CP&L limit of 2000 mRem would be imposed.			
DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3					

RNP NRC Written Examination

Calculation of exposure limits based on previous exposure

REFERENCES SUPPLIED:

- 6.7.3 The prior dose history shall be documented on NRC Form 4 or equivalent. The record shall show each period in which the individual received occupational dose and shall be signed by the individual.
- 6.7.4 As a record of current year dose, a written, signed statement from the individual or the most recent employer may be accepted.
- 6.7.5 As documentation of cumulative lifetime dose, a written estimate signed by the individual or an up-to-date NRC Form 4 or equivalent signed by the individual or the most recent employer may be accepted.
- 6.7.6 Prior dose reports may be obtained by letter or electronic means (e.g. fax). However, if the authenticity of the data cannot be ascertained or the reliability is questionable, written verification shall be requested. Orally transmitted dose reports shall not be accepted.
- 6.7.7 Any period for which the prior dose is not obtained must be noted on the NRC Form 4 or equivalent. In establishing the allowable dose for the current year, assume that the individual received 1.25 rem (TEDE) in each quarter for which records are missing, but do not record the assumed dose values on the NRC Form 4 or equivalent.
- 6.8 Annual Administrative Dose Limits
 - 6.8.1 The Company goal is that no individual shall exceed the following annual administrative limits for total effective dose equivalent:
 - 1. 0.5 rem CP&L dose if non-CP&L dose for the current year has not been determined (no dose extension permitted).
 - 2. 2 rem CP&L dose and 4 rem total dose if non-CP&L dose for the current year has been determined.
 - 6.8.2 Administrative Dose Limit Extensions
 - 1. The individual's supervisor must provide written justification for the need to extend the individual's dose limit.
 - 2. Site Vice President approval is required to authorize an individual to receive more than 2 rem CP&L dose in a year. This responsibility will not be delegated except during a |

10CFR20 008

Given the following conditions:

- A 25 year old male recently started working for the maintenance department at Robinson
- His lifetime dose is currently 31.5 REM total effective dose equivalent
- He has received no radiation exposure for the last 2 years
- No extensions have been approved and no emergencies exists

Which ONE (1) of the following is the TOTAL additional effective dose equivalent that the individual can receive without management concurrence at CP&L this year?

- A. 1.5 REM
- **√**B. 2 REM
 - C. 3.5 REM
 - D. 4.5 REM

Given the following conditions:

- A clearance is in effect with two (2) Maintenance department clearance holders (Clearance Holders A and B).
- Clearance Holder A has requested a temporary lift of a portion of the clearance to test equipment for one of the tasks.
- Clearance Holder B is NOT available on site and is NOT expected back for two (2) days.

Given the provided references, which ONE (1) of the following describes the process to temporarily lift the required portion of the clearance?

- a. Obtain permission of Clearance Holder A and the Control Room Shift Supervisor, remove the tags as necessary, and reinstall the tags when complete
- b. Obtain permission of Clearance Holder A and Clearance Holder B's supervisor, remove the tags as necessary, and reinstall the tags when complete
- c. Obtain permission of Clearance Holder A and the Control Room Shift Supervisor, remove and cancel the entire clearance, and reissue a new clearance with different boundaries
- d. Obtain permission of Clearance Holder A and Clearance Holder B's supervisor, remove and cancel the entire clearance, and reissue a new clearance with the same boundaries when complete

Answer:

b. Obtain permission of Clearance Holder A and Clearance Holder B's supervisor, remove the tags as necessary, and reinstall the tags when complete

QUESTION NUMBER: 14 TIER/GROUP: SRO 3 RO 3 K/A: 2.2.13 Knowledge of tagging and clearance procedures. **K/A IMPORTANCE:** SRO 3.8 RO 3.6 55.41(b) RO 10 55.43(b) SRO 10CFR55 CONTENT: **OBJECTIVE: OMM-005-03** DEMONSTRATE an understanding of selected steps, cautions, and notes in OMM-005 by explaining the basis of each. **REFERENCES:** OPS-NGGC-1301 SOURCE: New Significantly Modified X Direct Bank Number OMM-005-03 006 JUSTIFICATION: Plausible since 1/2 clearance holders is available and the CRSS is a licensed а. SRO, but the CRSS is not authorized to approve removal of this clearance. CORRECT If the original clearance holder is not available, the removal of tags requires the b. approval of the Alternate Clearance Holder or the clearance holder's supervisor. A temporary lift should reinstall the same clearance. Plausible since 1/2 clearance holders is available and the CRSS is a licensed C. SRO, but the CRSS is not authorized to approve removal of this clearance. If the original clearance holder is not available, the removal of tags requires the d. approval of the Alternate Clearance Holder or the clearance holder's supervisor, however a temporary lift should reinstall the same clearance. **DIFFICULTY:** Knowledge/Recall X Rating 3 Comprehensive/Analysis Knowledge of administrative requirements regarding clearance removals

REFERENCES SUPPLIED:

9.5 Boundary Changes

9.5.1 Administrative - Boundary Changes

- 1. Should plant needs dictate the removal of any tags, and the Clearance Holder is not available on site, the removal of the tags require the approval of the designated Alternate Clearance Holder or the individual's supervisor. The original Clearance Holder shall be notified by the individual releasing the clearance as soon as practical.
- 2. For boundary changes that involve removing clearance tags, the Affected Holders shall be notified of and agree with the boundary change. Once the new clearance boundary has been established, the Affected Holders shall be notified of the new clearance boundary.
- 3. For boundary changes that involve either temporarily lifting or permanently removing grounds, the Clearance Holders relying on those grounds for protection shall be notified of and agree with the lifting or removal of the grounds.
- 4. When it is necessary to temporarily lift a clearance tag, the Affected Holders shall be notified of and agree with the lifting of the clearance tag. Once the tag has been reinstalled, the Affected Holders shall be notified of the restoration of the clearance boundary.
- 5. Temporary Tag Lifts are intended to be for short duration jobs. Temporary Tag Lifts should not exceed the current Operations shift. S-SO concurrence is required to allow a Temporary Tag Lift to extend past the Operations shift.
- 6. When a boundary change involves only adding tags to a clearance, notification of Clearance Holders is not required.
- 7. Work activities that will be placed in an unsafe condition during a boundary change shall be suspended until such time that the boundary change is completed.

OPS-NGGC-1301 Rev. 4	Page 41 of 73
----------------------	---------------

OMM-005-03 006

Given the following conditions:

- A clearance is in effect with 2 clearance holders (Clearance Holder A and B)
- \cdot A partial removal of the clearance is required to test equipment for one of the tasks

Which ONE (1) of the following describes the process the clearance holder will follow?

- A. Obtain clearance holders A and B permission, cancel the entire LCTR and assign a new one to be issued.
- B. Obtain permission from requesting clearance holder A, sign the clearance as canceled, but tags will not be pulled from the other components until the clearance holder B gives his approval.
- \checkmark C. Before tags can be removed, holders A and B shall be notified and agree with the boundary change.
 - D. Obtain permission from requesting clearance holder B, sign for and remove the tag, give it to the SRO when the rest of the clearance is to be cancelled.

Given the following conditions:

- Fuel is in the vessel.
- RCS temperature is 120°F.
- It is 10 days after the shutdown.
- RCS Level is 8" below the vessel flange.
- RHR cooling is lost.

Given the supplied references, which ONE (1) of the following identifies how much time remains before boiling begins occurring in the RCS?

- a. 15.5 minutes
- b. 22 minutes
- c. 19 minutes
- d. 40.5 minutes

Answer:

b. 22 minutes

						Co	ommon Quest	ion Reference
QUESTION N TIER/GROUP K/A:	IUMBER: 2: 025AK1.01	15	RO 1/2		SRO	1/2		
	Knowledge of Residual Hea	the operational t Removal Syste	implications em: Loss of F	of the follo RHRS durir	wing conce ng all mode	epts as tl es of ope	ney apply to L ration	oss of
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	F 55.41(b) F	RO 3.9 RO 10	55.43(I	SRO b) SRO	4.3		
OBJECTIVE:	OMM-046-04							
	DEMONSTRA	TE the use of (OMM-046 in	maintaining	g the Key S	Safety Fu	nctions.	
REFERENCE	ES:	OMM-046 Plant Curve 7.	19					
SOURCE:	New	Significar	ntly Modified			Direct		
JUSTIFICAT	ION:		Bank Numi	ber UM	111-046-04		009	
a.		Plausible since 10 day shutdo	e correct curv wn.	ve is used,	but uses 1	00 hour :	shutdown line	instead of
b.	CORRECT	Using Curve 7 time to boiling	. 19, the inter is 22 minute	section of t s.	the 10 day	shutdow	n line and 120	°F, the
с.		Plausible since correct curve is used, but uses 20 day shutdown line instead of 10 day shutdown.						
d.		Plausible since day shutdown	e correct cur	ve is used,	but uses 4	10 day sh	utdown line in	stead of 10
DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3								
Application of given data to plant curves to determine time to boiling								
REFERENCI	ES SUPPLIED	: Plant Curv	es 7.19, 7.20), 7.21				

RNP NRC Written Examination

NOTE: The value listed in the following step is also listed on "Plant Status and Shutdown Safety Function Status" sheet which is located on the LAN. This sheet will be updated by the WCC or Outage Management as plant conditions change.

- 8.1.5 Verify by the "Time To Boiling" curves in the Plant Curve Book (curves 7.19, 7.20, 7.21, and 7.22 for the RCS; curves 7.23 and 7.24 for the SFP) that the current values listed on "Plant Status and Shutdown Safety Function Status" sheet are correct <u>AND</u> have the values updated as necessary once per 12 hours, <u>OR</u> any time a greater than 10% change in RCS level, or temperature is made.
- 8.1.6 Evaluate, in conjunction with the outage management, the impact of any work request not previously scheduled, on the shutdown safety functions:
 - DECAY HEAT REMOVAL
 - ELECTRICAL POWER
 - INVENTORY CONTROL
 - REACTIVITY CONTROL
 - RCS PRESSURE CONTROL (with fuel in Containment)
 - CONTAINMENT VESSEL STATUS(with fuel in Containment)
- 8.1.7 Once each shift, verify the minimum Structures, Systems, and Components are in the required status IAW OMP-003, Attachment 10.2, <u>AND</u> initial the correct line on Attachment 10.1.
- 8.1.8 <u>WHEN</u> all the Shutdown Safety Functions are available, <u>THEN</u> completion of Attachment 10.1 may be suspended.

OMM-046	Rev. 6	Page 13 of 23

Curve 7.19 - Loss of Residual Heat Removal Cooling Water Level Between 0" to -10" Below Vessel Flange



. .

A 20 Days After Shutdown

* 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153



Curve 7.20 - Loss of Residual Feat Removal Cooling Water Level Between -10" to -36" Below Vessel Flange

⊟ 100 Hours After Shutdown → 10 Days After Shutdown

÷...

* 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153



Curve 7.21 - Loss of Residual Heat Removal Cooling Water Level Between -36" to -72" Below Vessel Flange

⊟ 100 Hours After Shutdown 🛛 🕁 10 Days After Shutdown

A 20 Days After Shutdown

* 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153

OMM-046-04 009

The following plant conditions exist:

- Fuel is in the vessel
- Initial RCS temperature is 150 F
- 40 days after shutdown
- RCS Level is 20" below the vessel flange
- RHR cooling is lost

How long before a steam release occurs?

- A. Approximately 20 minutes
- ✓B. Approximately 23 minutes
- C. Approximately 34 minutes
- D. Approximately 39 minutes
Given the following conditions:

- A reactor shutdown is in progress.
- APP-005-B2, N-35 LOSS OF COMP VOLT, is received.
- N-35 indicates 6.0x10E-10 amps.
- N-36 indicates 7.0x10E-11 amps.
- N-51 indicates 80 counts.
- N-52 indicates 90 counts.

Which ONE (1) of the following describes the **MINIMUM** action(s) required to obtain Source Range N-31 and N-32 indication?

- a. Push **ONLY** the "Train A Source Range Logic Trip Defeat" button
- b. Push **ONLY** the "Train A Permissive P-6 Defeat" button
- c. Push **BOTH** the "Train A Source Range Logic Trip Defeat" AND the "Train B Source Range Logic Trip Defeat" buttons
- d. Push **BOTH** the "Train A Permissive P-6 Defeat" AND the "Train B Permissive P-6 Defeat" buttons

Answer:

d. Push **BOTH** the "Train A Permissive P-6 Defeat" AND the "Train B Permissive P-6 Defeat" buttons

						Common	
QUESTION N TIER/GROUF K/A:	IUMBER: 2: 033AA2.11	21	RO	1/2	SRO	1/2	
	Ability to dete Nuclear Instru	rmine and inte umentation: Le	erpret th oss of co	e following ompensati	g as they apply ng voltage	to the Loss of Inte	rmediate Range
K/A IMPORT. 10CFR55 CO	ANCE: NTENT:	55.41(b	RO) RO	3.1 7	SRO 55.43(b) SRO	3.4	
OBJECTIVE:	NI-08						
	EXPLAIN the Instrumentation	component c on System sw	peration ritches a	associate nd contro	ed with each sw ls.	ritch position for th	e Nuclear
REFERENCE	:S:	APP-005 GP-006					
SOURCE:	New	Signific	antly M	odified		Direct X	
			Bank	Number	NI-08	003	
JUSTIFICAT a.	ION:						
		Plausible sir be pushed.	nce faileo	d IR chani	nel is related to	Train A, but both o	defeat buttons must
b.		Plausible sir be pushed. Plausible sir be pushed.	nce faileo nce faileo	d IR chani d IR chani	nel is related to nel is related to	Train A, but both o	defeat buttons must defeat buttons must
b. c.		Plausible sir be pushed. Plausible sir be pushed. Plausible sir defeat not tr	nce failed nce failed nce both ip logic d	d IR chann d IR chann buttons n defeat.	nel is related to nel is related to nust be pushed	Train A, but both o Train A, but both o , but buttons to be	defeat buttons must defeat buttons must pushed are P-6
Ь. с. d.	CORRECT	 Plausible sir be pushed. Plausible sir be pushed. Plausible sir defeat not tr Even though defeat butto 	nce failed nce failed nce both ip logic d n only or ns be pu	d IR chann d IR chann buttons n defeat. ne IR is ur ushed to e	nel is related to nel is related to nust be pushed ndercompensate energize the SR	Train A, but both o Train A, but both o , but buttons to be ed, the circuitry red instruments.	defeat buttons must defeat buttons must pushed are P-6 quires that both
b. c. d. DIFFICULTY Compreher	CORRECT	Plausible sir be pushed. Plausible sir be pushed. Plausible sir defeat not tr Even though defeat butto	nce failed nce failed nce both ip logic d n only or ns be pu	d IR chann d IR chann buttons n defeat. ne IR is ur ushed to e ge/Recall	nel is related to nel is related to nust be pushed indercompensate energize the SR	Train A, but both o Train A, but both o , but buttons to be ed, the circuitry red instruments.	defeat buttons must defeat buttons must pushed are P-6 quires that both

RNP NRC Written Examination

- 5.5 Following a significant (10 ppm or more) change in RCS Boron concentration, additional PZR heaters should be energized. This will permit opening of the PZR spray valves and allow the Boron concentration between the PZR and the RCS loops to equalize.
- 5.6 Normal spray flow is unlikely or will not occur at all when RCP "C" is stopped and PZR level is less than 30%. Therefore, PZR pressure response may not be as expected. (SCR 90-031)
- 5.7 Impurities which may be present in the Intermediate Range detectors can prevent the Intermediate Range currents from decreasing to the P-6 reset (10⁻¹⁰ amps) in a normal manner. This situation can be identified by observing NI-35, NI-36, NI-51A and NI-52A. If NI-51A and NI-52A are indicating less than 10² cps, and NI-35 **OR** NI-36 is not less than 10⁻¹⁰ amps, the PERMISSIVE P-6 DEFEAT pushbuttons should be depressed to energize the Source Range detectors. (ACR 92-071)
- 5.8 When opening disconnect switches, open the blades SLOWLY for the first inch or so, when possible, to make sure there is no power load on it. If there is no load, there will be only a small static discharge, and then the switch may be fully opened. If there is a heavy power arc, the switch should be reclosed to minimize the hazard to the person doing the switching and damage to the equipment. (CP&L Safety Manual)
- 5.9 ITS SR 3.4.16.2 requires that RCS dose equivalent I-131 specific activity be verified \leq 1.0 μ Ci/gm within 2 to 6 hours after every thermal power change of >15% in any one hour period.
 - Every time the power level of the Reactor is changed 15% or more in any one hour, E&C shall be notified of the power change, including the time started and the expected duration of the transient. Sample results shall be compared with ITS limits and logged according to Chemistry Procedures. Additionally, E&C shall be notified when the transient is completed.
 - A power level change shall be defined for sampling purposes as an absolute value of 15%/hr. in one direction only, (i.e. 95% to 80% = 15%, or 95% to 85% to 90% = 10%). This includes controlled changes, runbacks, transients, and trips that result in changes greater than 15% in any one hour period.
 - E&C shall be notified after every 15% power change that is completed in less than one hour. Do not wait until after an hour of changing power before notifying E&C.

GP-006	Rev. 37	Page 7 of 60

<u>ALARM</u>

N-35 LOSS OF COMP VOLT

AUTOMATIC ACTIONS

1. None Applicable

<u>CAUSE</u>

1. Loss of Compensating Voltage on NI-35

OBSERVATIONS

1. Intermediate Range NI

ACTIONS

- 1. IF NI-35 has failed, THEN remove NI-35 from service in accordance with OWP-011.
- 2. IF a unit shutdown occurs, THEN Source Range NIS will require manual activation.

DEVICE/SETPOINTS

1. None Applicable

POSSIBLE PLANT EFFECTS

1. NI-35 will read higher than actual causing failure of automatic Source Range activation.

REFERENCES

- 1. ITS Table 3.3.1-1, Item 3
- 2. CWD B-190628, Sh 441, Cable AL
- 3. OWP-011, Nuclear Instrumentation (NI)

APP-005	Rev. 19	Page 10 of 40
APP-005	Rev. 19	Page 10 01 40

Given the following conditions:

- The unit is operating at 100% power.
- NO scheduled releases are in progress.
- A small leak develops from the bottom of Waste Condensate Tank "A".
- All ventilation systems are in a normal configuration.

An indication that would alert the operators of the accidental liquid release in progress is an increase in the level of monitor ...

- a. R-3, PASS Panel Area Monitor.
- b. R-4, Charging Pump Room Area Monitor.
- c. R-9, Letdown Line Area Monitor.
- d. R-14C, Plant Effluent Noble Gas, Low Range Monitor.

Answer:

d. R-14C, Plant Effluent Noble Gas, Low Range Monitor.

QUESTION N TIER/GROUF K/A:	IUMBER: ?: 059AK2.02	22	RO	1/2	S	RO	1/1
	Knowledge of monitors	the interrelation	ons betw	veen the	Accidental I	Liquid	Radwaste and Radioactive-gas
K/A IMPORT 10CFR55 CC	ANCE: NTENT:	55.41(b)	RO RO	2.7 11	SR 55.43(b) S	RO RO	2.7
OBJECTIVE:	RM-14						
	EXPLAIN the	effect on the R	RM Syste	em due	to selected f	ailures	Э.
REFERENCE	25:	AOP-005 SD-019					
SOURCE:	New	Significa	ntly Mo	odified			Direct X
SOURCE:	New	Significa	ntly Mo Bank	odified Numbe	r RM-01		Direct X 003
SOURCE: JUSTIFICAT <i>a.</i>	New	Plausible sinc from the leak area.	Bank Bank : Bank : ce the Pr will be c	odified Number ASS Par collected	r RM-01 nel is in the d in a sump a	genera and wil	Direct X 003 al vicinity of WCT "A". The liquid I not spill out to the PASS Panel
SOURCE: JUSTIFICAT a. b.	New	Plausible sind from the leak area. Plausible sind liquid from the Line area.	Bank Bank Bank Bank Bank Bank Bank Bank	Number ASS Par collected etdown I	r RM-01 nel is in the d in a sump a Line Area is llected in a s	genera and wil in the sump a	Direct X 003 al vicinity of WCT "A". The liquid I not spill out to the PASS Panel general vicinity of WCT "A". The and will not spill out to the Letdown
SOURCE: JUSTIFICAT a. b. c.	New	Plausible sind from the leak area. Plausible sind liquid from the Line area. Plausible sind The liquid from Charging Pur	Bank Bank Bank Bank Bank Bank Bank Bank	odified Number ASS Par collected etdown I ill be co harging ak will b n.	RM-01 r RM-01 nel is in the d in a sump a Line Area is llected in a s pump room be collected i	genera and wil in the sump a is in th n a sur	Direct X 003 al vicinity of WCT "A". The liquid I not spill out to the PASS Panel general vicinity of WCT "A". The and will not spill out to the Letdown the general vicinity of WCT "A". mp and will not spill out to the
SOURCE: JUSTIFICAT a. b. c. d.	New	Signification Plausible since from the leak area. Plausible since liquid from the Line area. Plausible since The liquid from Charging Pur The liquid for solution will b	Bank Bank Bank Bank Bank Bank Bank Bank	odified Number ASS Par collected etdown I ill be co harging ak will b n. ak will b n.	RM-01 r RM-01 nel is in the d in a sump a Line Area is llected in a s pump room pe collected i pe collected i st R-14C by	genera and wil in the sump a is in th n a su in a su the Au	Direct X 003 al vicinity of WCT "A". The liquid I not spill out to the PASS Panel general vicinity of WCT "A". The and will not spill out to the Letdown he general vicinity of WCT "A". mp and will not spill out to the mp but the gas that comes out of uxiliary building exhaust.
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	New ION: CORRECT	Signification Plausible since from the leak area. Plausible since liquid from the Line area. Plausible since The liquid from Charging Pur The liquid for solution will b	<i>Bank</i> Bank ce the Pr will be c ce the Le ce the Le ce the C m the le mp roor m the le ce exhau	<i>odified</i> <i>Number</i> ASS Par collected etdown I ill be co harging ak will b n. ak will b usted pa <i>e/Recal</i>	r RM-01 nel is in the d in a sump a Line Area is llected in a s pump room pe collected i pe collected i ast R-14C by I X Rational	genera and wil in the sump a is in th n a su in a su the Au	Direct X 003 al vicinity of WCT "A". The liquid I not spill out to the PASS Panel general vicinity of WCT "A". The and will not spill out to the Letdown he general vicinity of WCT "A". mp and will not spill out to the mp but the gas that comes out of uxiliary building exhaust.

- c. MD-12(series) Beta/Gamma (GM tube) Detector (R-15) These detectors use a halogen quenched geiger tube to absorb both beta and gamma particles. The signal is then processed through the preamplifier circuit to the ratemeter. The Overload P.C. Board provides a positive upscale indication of high range instead of the downscale indication normally associated with G.M. Tubes after saturation.
- d. MD-51 Gamma Scintillation Detector (R-18) Similar to MD-5D. This detector uses a sodium iodide (NaI) crystal.
- 3. Process channels R-30, R-31A, R-31B, and R-31C utilize a model DRM-200A (V15) microprocessor base ratemeter; manufactured by NRC. They use <u>Area</u> monitoring equipment housed in a shielded assembly to measure a specific radiation source.
- 3.2.2 Nuclear Measurements Corporation (NMC) Monitors (channels R-14A, R-14B, R-14C, R-14D, R-14E, R-22A, R-22B, R-22C, R-23A, R-23B, R-23C, R-38A, R-38B, and R-38C)
- 3.2.2.1 NMC Channels R-14A, R-14B, R-14C, R-14D, R-14E

Channels R-14A, R-14B, R-14C, R-14D and R-14E. Each channel has a detector which measures the radiation levels and provides a signal to the Programmable Input Output Processor System (PIOPS). In the Low Range Flow Path (normal operation) this monitor will collect and monitor airborne particulate, iodine, and noble gases. In the High Range Flow Path this monitor will collect airborne particulate and iodine prior to the monitoring of Nobles Gases by the intermediate (mid) and high range channels. The major components for the R-14 Skid monitoring system are (FIGURE 9):

- 1. SKID (Components common to both the Low and High Range Flow Paths)
 - a. Sample Inlet

The inlet and outlet lines to the monitor are 1 inch diameter stainless steel tubing. A "Y" is provided to allow diversion of the sample to the normal range channels or to the high range channels. Each leg of the outlet of the "Y" will have a remote actuated full port valve. The sample is drawn from the plant stack via eight sampling nozzles.

b. Shield Assembly

Each detector and its associated collector/sample chamber or prefilter is housed in a lead shield.

- c. Heat Tracing
 - Sample lines from the Plant Stack to the Skid.
 - Sample lines within the Skid.

Accident Channels.

Accident Channels are defined as detector/drawer arrangements, either area or process, that are designed to provide indication during and after an accident when radiation levels and/or environmental specifications of the other area and process channels may be exceeded. (The other Area and Process channels will however, continue to provide indication during and after an accident until the above mentioned limitations are exceeded.)

- The area RMS (system # 7005). 1. Defined as a detector/drawer arrangement in which the detector is exposed or subject to general area radiation.
- The process RMS (system # 7005). 2. Defined as a detector/drawer arrangement in which the detector is housed in a shielded assembly where only a specific radiation source is monitored.

2.3.1 Area RMS (FIGURE 2)

This system consists of twelve channels which monitor radiation levels in various areas of the plant. Two of these channels (R-32A and R-32B) are designated as accident channels.

Channel	Area Monitored
R-1	Control Room
R-2	CV Low Range Monitor
R-3	PASS Panel Area
R-4	Charging Pump Room
R-5	Spent Fuel Building
R-6	Sampling Room
R-7	CV In-core Instrumentation Room
R-8	Drumming Station
R-9	Letdown Line Area
Channel	Area Monitored
R-32A	CV High Range
R-32B	CV High Range
R-33	Monitor Building Area

A typical area channel consists of a detector and a ratemeter. This monitoring system utilizes fixed-position, gamma-sensitive G-M tube detectors (except R-32A and R-32B which use Ion Chambers). The radiation level is indicated locally near the detector (except R-32A and R-32B) and in the Control Room on the ratemeter digital display (R-32A and R-32B have an analog display). Radiation levels are recorded by a multi-point recorder. High-radiation levels and Trouble alarms are annunciated on the RTGB and

Revision 1

AOP-005	AOP-	005
---------	------	-----

. ...

Rev. 19

Page 11 of 56

Г	J		DEGEONGE NOT OPENINED	
	STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED	
		ATTACHMEN	<u>T 3</u>	
		<u>AREA MONITOR R-3 - HEALT</u>	H PHYSICS WORK AREA	
		(Page 2 of	2)	
	9.	Check Reason For Alarm - KNOWN	With assistance from RC personnel, visually inspect the PASS Panel area for radioactive spills.	
	10.	Check Radioactive Spill - DETECTED	Go To the main body, Step 1, of this procedure.	
	11.	Start One Of The Following AUX BUILDING CHARCOAL EXH FANs:		
		• HVE-5A		
		• HVE-5B		
	12.	Coordinate With RC Personnel To Control The Spill And Limit Spread Of Contamination		
	13.	Go To The Main Body, Step 1, Of This Procedure		
		- ENI) -	
	·			

AOP-005

Rev. 19

Page 12 of 56

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
	ATTACHM	ENT_4
	AREA MONITOR R-4 -	CHARGING PUMP ROOM
	(Dage 1 d	of 2)
1.	Place VLC Switch To EMERG Position	
2.	Place And Hold EVACUATION ALARM Switch To LOCAL Position For 15 SECONDS	
3.	Announce The Following Over Plant PA System:	
	"ATTENTION ALL PERSONNEL. ATTENTION ALL PERSONNEL. A HIGH RADIATION ALARM HAS BEEN RECEIVED ON CHARGING PUMP ROOM AREA MONITOR, R-4. ALL NON-ESSENTIAL PERSONNEL EVACUATE THE CHARGING PUMP ROOM UNTIL FURTHER NOTICE"	
4.	Repeat PA Announcement	
5.	Place VLC Switch To NORM Position	
6.	Contact RC Personnel To Perform A Survey, As Necessary, To Determine Magnitude Of Radiation Source	
7.	Check Reason For Alarm - KNOWN	With assistance from RC personnel, visually inspect Charging Pump Room for radioactive leaks.
8.	Check Charging Pump Room - LEAK IDENTIFIED	Go To the main body, Step 1, of this procedure.
9.	Start One Of The Following AUX BUILDING CHARCOAL EXH FANs:	
	• HVE-5A	
	• HVE-5B	

AOP-005

Rev. 19

Page 22 of 56

CTED	TNSTRICTIONS		RESPONSE NOT OBTAINED	
SIEF	ATTACH	 MENT 9		J
	AREA MONITOR R-9 -	LETDOWN	LINE AREA	
	(Page 1	of 2)		
1.	Place VLC Switch To EMERG Position			
2.	Place And Hold EVACUATION ALARM Switch To LOCAL Position For 15 SECONDS			
3.	Announce The Following Over Plant PA System:			
	"ATTENTION ALL PERSONNEL. ATTENTION ALL PERSONNEL. A HIGH RADIATION ALARM HAS BEEN RECEIVED ON LETDOWN LINE AREA MONITOR R-9. ALL NON-ESSENTIAL PERSONNEL EVACUATE AUXILIARY BUILDING UNTIL FURTHER NOTICE"			
4.	Repeat PA Announcement			
5.	Place VLC Switch To NORM Position	n		
6.	Contact RC Personnel To Perform A Survey In The Following Areas To Determine Magnitude Of Radiation Source:			
	• Lower level Aux Building			
	• VCT area			
7.	Verify LTDN ORIFICE Valve(s) - LESS THAN <u>OR</u> EQUAL TO ONE OPEN			
8.	Control Charging Flow To Maintain PZR Level			

Given the following conditions:

- The Control Room has filled with dense smoke from a fire on Unit 1.
- The reactor has been tripped manually by operators.
- The Control Room has been evacuated due to the dense smoke.

Which ONE (1) of the following identifies the procedure(s) that will be **INITIALLY** used to stabilize the plant?

- a. EOP Path-1 and EPP-004, Reactor Trip Reponse
- b. DSP-002, Hot Shutdown Using the Dedicated/Alternate Shutdown System
- c. AOP-004, Control Room Inaccessibility
- d. GP-006, Normal Plant Shutdown from Power Operation to Hot Shutdown

Answer:

c. AOP-004, Control Room Inaccessibility

QUESTION N TIER/GROUF K/A:	UMBER: ?: 068 2.4.11	23	RO	1/1	SRO	o 1/1	
	Knowledge of	abnormal con	dition pr	ocedure	es (Cont Room	Evac).	
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.4 10	SRO 55.43(b) SR(3.6 0	
OBJECTIVE:	AOP-004-02						
	RECOGNIZE	the selected e	ntry leve	el condit	ions of AOP-0	04.	
REFERENCE	S:	AOP-004					
SOURCE:	New	Significa	ntly Mo	dified		Dire	ct X
					L		
			Bank I	Numbe	r AOP-004	-02	001
JUSTIFICAT <i>a.</i>	ION:	Plausible sinc EOP network	Bank I ce a read is not in	Numbe ctor trip	AOP-004 is performed in ited in the eve	-02 n accorda nt of a co	001 nce with AOP-004, but the ntrol room evacuation.
JUSTIFICATI a. b.	ION:	Plausible sinc EOP network Plausible sinc initially.	Bank I ce a read is not in ce entry i	Numbel ctor trip nplemer may be	AOP-004 is performed ir nted in the eve directed to DS	-02 n accorda nt of a co SP-002 by	001 nce with AOP-004, but the ntrol room evacuation. AOP-004, but not used
JUSTIFICATI a. b. c.	ION: CORRECT	Plausible sinc EOP network Plausible sinc initially. Entry conditio threatening de	Bank I be a read is not in be entry i ons to AC ense sm	Number otor trip nplemer may be DP-004 noke.	AOP-004 is performed ir nted in the eve directed to DS are met due to	-02 n accorda nt of a co P-002 by requiring	001 nce with AOP-004, but the ntrol room evacuation. AOP-004, but not used
JUSTIFICATI a. b. c. d.	ION: CORRECT	Plausible since EOP network Plausible since initially. Entry condition threatening de Plausible since the control root	Bank I ce a read is not in ce entry i ons to AC ense sm ce GP-00 om are o	Number of the second se	AOP-004 is performed in the eve directed to DS are met due to ed for normal s the scope of G	-02 n accorda nt of a co P-002 by requiring shutdown: P-006.	001 nce with AOP-004, but the ntrol room evacuation. AOP-004, but not used g evacuation due to life-
JUSTIFICATI a. b. c. d. DIFFICULTY Compreher	ION: CORRECT : sive/Analysis	Plausible since EOP network Plausible since initially. Entry condition threatening de Plausible since the control root	Bank I ce a reac is not in ce entry i ons to AC ense sm ce GP-00 om are o	Number otor trip nplemer may be DP-004 ooke. D6 is us butside t	AOP-004 is performed in the d in the even directed to DS are met due to ed for normal s the scope of G	-02 n accorda nt of a co P-002 by p requiring shutdown: P-006.	001 nce with AOP-004, but the ntrol room evacuation. AOP-004, but not used e evacuation due to life-

Purpose and Entry Conditions (Page 1 of 1) 1. <u>PURPOSE</u>: This procedure provides instructions in the event conditions in the Control Room require evacuation as deemed necessary by the SSO. The following assumptions apply to this procedure: Offsite power is available. All RTGB controls are operational and no failures are expected to occur to the RTGB which preclude safe operation of equipment from outside the Control Room. No other accident condition exists within the primary plant requiring the Emergency Operating Procedures OR any other AOP. The plant is <u>NOT</u> in Cold Shutdown. ENTRY CONDITIONS: 2. DSP-001, Alternate Shutdown Diagnostic. Toxic gas in the Control Room. Confirmed bomb threat in or adjacent to the Control Room. Other life threatening conditions, as determined by the SSO or his designee, that cause the Control Room to be uninhabitable. - END -

Given the following conditions:

- The unit is operating at 40% power.
- OST-011, "Rod Cluster Control Exercise & Rod Position Indication Monthly Interval," is being performed.
- Annunciator APP-005-E2, ROD CONT SYSTEM URGENT FAILURE, alarms just as Control Bank 'C' rods are being withdrawn.

Which ONE (1) of the following describes this condition and / or the actions that should be taken?

- a. This is an expected alarm.
 - Continue withdrawing Control Bank 'C' rods.
- b. This makes more than one rod inoperable.
 - Trip the reactor and go to PATH-1.
- c. Place the ROD BANK SELECTOR switch in Manual.
 - Restore Tavg to Tref by raising turbine load.
- d. Place the ROD BANK SELECTOR switch in Manual.
 - Restore Tavg to Tref by dilution.

Answer:

- d. Place the ROD BANK SELECTOR switch in Manual.
 - Restore Tavg to Tref by dilution.

								Common Question Reference
	UMBER:	24						
TIER/GROUF K/A:	°: 001K3.01		RO	2/1		SRO	2/1	
	Knowledge of	the effect that	at a loss	or malfun	iction c	of the CRDS	S will h	ave on the CVCS
K/A IMPORT. 10CFR55 CO	ANCE: INTENT:	55.41(b	RO) RO	2.9 10	55.43	SRO (b) SRO	3.0	
OBJECTIVE:	AOP-001-08							
	Given plant co related to drop	onditions EVA pped rod, mis	LUATE	the appro rod, immo	opriate ovable	actions to r rod, IRPI fa	mitigate ailure a	e consequences of steps s directed in AOP-001
REFERENCE	ES:	AOP-001						
SOURCE:	New	X Signific	antly M	odified			Direc	t 🔲
			Bank	Number	•			NEW
JUSTIFICATI a.	IUN:	Plausible sir being perfor rods will not	nce this is med due move.	s an actic to this be	on that eing ar	would be ta	aken if alarm,	a dropped rod recovery were but it is not expected and
b.		Plausible sir but an urger	nce this is nt failure	s an actic does not	on that indica	would be ta te that any	aken if rods ar	multiple rods were dropped, e dropped.
с.		Plausible sir turbine load	nce turbir should b	ne load a be lowere	djustm d, not i	ents to rest raised.	tore Ta	vg are permissible, but
d.	CORRECT	Rod bank se concentratio	elector is on (dilutic	to be pla on) or turb	iced in Dine loa	Manual an ad (load rec	d Tavg duction)	restored by adjusting boron).
DIFFICULTY Comprehen	: isive/Analysis	ХК	nowledg	e/Recall		Rating	3	

RNP NRC Written Examination

Rev. 15

Page 36 of 80

┛	STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
L	0121	SECTIO	<u> </u>
		TMMOVABLE/MISA	ALTGNED RODS
		(Dense 1	
		(Page 1	
	1.	Check Current Plant Status - MODE 1	Observe the <u>NOTE</u> prior to Step 49 and Go To Step 49.
	2.	Verify ROD BANK SELECTOR Switch Position - M (Manual)	
	3.	Check Tavg - WITHIN +0.5 TO -2.5°F OF TREF	Adjust Turbine load <u>QR</u> RCS boron concentration to maintain Tavg to within +0.5 to -2.5°F of Tref prior to continuing.
	4.	Stop Any Evolutions That Change Reactor Power Except As Called For By This procedure	
		• Turbine load changes	
		• Boron concentration changes	
	5.	Check APP-005-E2, ROD CONT SYSTEM URGENT FAILURE - ILLUMINATED	 Perform one of the following: IF an entire bank of rods will <u>NOT</u> move, <u>THEN</u> Go To Step 64.
			OR
			 <u>IF</u> individual rod(s) indicate misalignment <u>OR</u> will <u>NOT</u> move, <u>THEN</u> Go To Step 18.
	б.	Dispatch An Operator To The Rod Control Room To Check Indications And Alarms At The Following:	
		• Each Rod Control Power Cabinet	
		• Rod Control Logic Cabinet	

Given the following conditions:

- A turbine runback is in progress.
- Power is currently at 93% and lowering as the turbine runback occurs.
- APP-005-D5, OTAT/OPAT TURBINE RUNBACK ROD STOP, is illuminated.
- APP-004-E3, OVERTEMP Δ T TRIP, is illuminated.
- All loop ΔT 's indicate less than the OT ΔT and OP ΔT setpoints.
- All OTAT and OPAT bistables are extinguished.

Which ONE (1) of the following describes the actions to be taken?

- a. Verify the turbine runback stops when power lowers to 90%
- b. Verify the turbine runback stops when power lowers to 70%
- c. Place the turbine in MANUAL due to a runback circuitry failure
- d. Trip the reactor and go to PATH-1

Answer:

d. Trip the reactor and go to PATH-1

					RNP NRC Written Examinatio Common Question Referenc
QUESTION NUMBER: TIER/GROUP: K/A: 2.4.45	25 RO	3	SRO	3	
Ability to pri	ioritize and interpret the	e significan	ce of each annu	nciator	or alarm.
K/A IMPORTANCE: 10CFR55 CONTENT:	RO 55.41(b) RO	3.3 10	SRO 55.43(b) SRO	3.6	
OBJECTIVE: OMM-001-1	15-02				
DISCUSS th	he major sections of OI	MM-001-15	j		
REFERENCES:	OMM-001-15				
SOURCE: New	/ X Significantly M	lodified		Direc	
JUSTIFICATION:	Bank	k Number			NEW
а.	Plausible since a tur condition and a ΔT r first out alarm during	bine runba unback wil g a transier	ck is designed to I only occur until It requires a read	o reduce the cor ctor trip.	e any excessive ∆T ndition is cleared, but the
b.	Plausible since a tur condition and some during a transient re	bine runba turbine rur quires a re	ck is designed to backs lower pov actor trip.	o reduce ver to 7	e any excessive ΔT 0%, but the first out alarm
С.	Plausible since no ir the first out alarm du	ndications s uring a tran	support the requi	irement reactor	for a turbine runback, but trip.
d. CORRECT	F With the plant in a tr reactor trip.	ansient, ar	y Reactor Trip F	irst Oul	t annunciator requires a
d. CORRECT DIFFICULTY: Comprehensive/Analysi	T With the plant in a tr reactor trip. is X Knowledg	ansient, ar ge/Recall	y Reactor Trip F	First Out	t annunciator requires a

8.4.2 (Continued)

- 2. RTGB Annunciators
 - a. APP-004, First-Out Reactor Trips, annunciators are an indication that a condition exists that has resulted, or should have resulted, in a signal to effect a Reactor Trip or Safeguards actuation. First-Out annunciator alarms require the highest priority and the following immediate response:
 - 1) Announce the alarm.
 - 2) Scan the RTGB for confirmation of a Reactor Trip.
 - IF the plant is in a transient condition, THEN immediately trip the Reactor and actuate Safeguards as required.
 - 4) **IF** the plant is at steady state conditions, **THEN** perform the following:
 - .a) IF a Reactor Trip has NOT occurred, THEN scan the RTGB for confirmation that the First-Out annunciator is valid. The scan should include bistable status lights, other annunciators, and process and control indications such as levels and pressures that input to the Reactor protection system.
 - .b) **IF** the scan supports the need for a Reactor Trip or Safeguards actuation, **THEN** the operator should immediately trip the Reactor and actuate Safeguards as required.
 - .c) **IF** the scan does **NOT** support a Reactor Trip or Safeguards actuation, **THEN** the operator should clearly and quickly communicate the condition to the SSO/CRSS, who is expected to assist in the diagnosis. Any indication that supports the diagnosis that a trip is required should result in an immediate Reactor Trip. Only if **NO** supporting indication is present is it acceptable to remain at power while troubleshooting and repairs are made.

OMM-001-15	Rev. 16	Page 14 of 36

A "Blue Dot" adjacent to a RTGB instrument indicates the instrument is \ldots

- a. out-of-service for calibration.
- b. environmentally qualified.
- c. a Technical Specification indication.
- d. out of tolerance from a channel deviation check.

Answer:

d. out of tolerance from a channel deviation check.

								Common Question Refere	ence
QUESTION N TIER/GROUF K/A:	NUMBER: 2.4.45	25	RO	3		SRO	3		
	Ability to priori	tize and interpr	ret the s	significan	ice of e	ach annun	iciator o	er alarm.	
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	F 55.41(b)	RO RO	3.3 10	55.43(SRO (b) SRO	3.6		
OBJECTIVE:	: OMM-001-11-	02							
	EXPLAIN the 001-11	requirements fo	or maint	taining o	peratio	ns records	and log	gs in accordance with OM	M-
REFERENCE	ES:	OMM-001-11							
SOURCE:	New	Significal	ntly Mo	odified			Direct		
			Bank	Number	0	MM-001-?7	?-04	001	
JUSTIFICAT <i>a.</i>	ION:	Plausible since reserved for ir	e the instrume	strumen ents with	t is in a an ider	n unusual htified unac	configui ceptabl	ration, but blue stickers ar le deviation.	e
b.		Plausible sinc blue stickers a deviation.	e identif are rese	fying the erved for	ese instr instrun	ruments is nents with	vital to an ident	post-accident response, b tified unacceptable	out
с.		Plausible sinc blue stickers a deviation.	e identii are rese	fying the erved for	se inst instrun	ruments is nents with	vital to an iden	post-accident response, b tified unacceptable	out
d.	CORRECT	The blue stick deviation iden	er is us tified.	ed to de	signate	e an instrur	nent wh	iich has an unacceptable	
DIFFICULTY Comprehe	(: nsive/Analysis	Knc	owledge	e/Recall	X	Rating	2		
	Knowledge o	f administrative	e require	ements f	or ident	tifying out o	of servic	ce indicators	

•

RNP NRC Written Examination

- 8.2.4 Corrective Action
 - 1. Once an unacceptable deviation is identified, corrective action consistent with the Plant TECH SPECS, QA requirements, and OWP should be initiated. For instrumentation which also provides an input to an automatic safety function, "Operator Actions" described in TECH SPECS shall be met until proper operation of the safety circuit can be verified.
 - 2. A blue sticker will be placed adjacent to the respective RTGB instrument as a visual reminder to the operator that an unacceptable deviation has been identified.
 - 3. One or more of the following options should be used as a guide in initiating a Work Request (WR).
 - a. Declare the channel inoperable, perform applicable "Operator Actions" described in TECH SPECS, and initiate Work Request.
 - b. Declare the channel out of tolerance but still available as a trend indicator, perform applicable "Operator Actions" described in TECH SPECS, and initiate Work Request.
 - c. Declare the channel deviating by a known constant amount. If the deviation is in a conservative direction, the "Operator Actions described in TECH SPECS need not be inserted; if the deviation is in a nonconservative direction, perform applicable "Operator Actions" described in TECH SPECS, and initiate Work Request.

NOTE: Any trips inserted may be reset after the protection portion of the channel is verified to be operating properly.

4. When maintenance on the instrument has been completed, the blue sticker adjacent to it is removed from the RTGB and discarded and the instrument is no longer carried in the applicable section of the RO/BOP Operators Turnover Checklist.

Page 12 of 55
26

Given the following conditions:

- A valid alarm has been acknowledged for R-1, Control Room Area Monitor.
- The CRSS has entered AOP-005, Radiation Monitoring System.
- Step 3 of Attachment 1 has the operator stop the HVS-1 Auxiliary Building Supply Fan by opening the supply breaker on MCC-5.

Which ONE (1) of the following is the basis for this step?

- a. Ensures that any air-flow will be from the Control Room to the Auxiliary Building
- b. Ensures that the air-borne contaminants in the Control Room will be exhausted to the Auxiliary Building for cleanup
- c. Ensures that personnel in the Auxiliary Building will **NOT** be exposed to high airborne activity for a prolonged period
- d. Ensures that personnel in the Control Room will **NOT** be exposed to high radiation condition for a prolonged period of time

Answer:

a. Ensures that any air-flow will be from the Control Room to the Auxiliary Building

QUESTION N TIER/GROUP	IUMBER:	26	RO	1/2		SRO	1/2	
K/A:	061AK3.02							,
	Knowledge of Monitoring (Al	the reasons fo RM) System Al	or the foll larms: G	lowing re uidance	esponse contain	s as they ed in alar	apply to m respor	the Area Radiation use for ARM system
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	55.41(b)	RO RO	3.4 8	55. 4 3(b	SRO)) SRO	3.6	
OBJECTIVE:	AOP-005-03							
	EXPLAIN the	basis of select	ed steps	s, cautio	ns, and i	notes in A	OP-005.	
REFERENCE	-9.	AOP-005						
							D!	
SOURCE:	New		ntiy Mo	dified			Direct	
SOURCE:	New		Bank l	dified Numbei	r AOI	P-005-03	Direct	005
JUSTIFICAT	ION: CORRECT	Ensures CR p CR and into th	Bank I Bank I pressure he AB.	dified Numbei is highe	r AOI er than A	P-005-03 .B pressu	Direct	005 ure air flow is out of the
JUSTIFICAT a. b.	New	Ensures CR p CR and into the Plausible since contaminants	Bank I Bank I pressure he AB. ce it wou are pre	dified Number is highe Id be de vented f	AOI er than A esirable to from ente	P-005-03 B pressu o clean up ering the (prect p airborn CR due to	005 ure air flow is out of the e contaminants, but o the high pressure.
JUSTIFICAT a. b. c.	New	Ensures CR p CR and into th Plausible sind contaminants Plausible if m maintained at	Bank I Bank I bressure he AB. ce it wou are prev isconcept t higher p	dified Number is highe ld be de vented f ption that pressure	AOI er than A esirable to from ente at AB is r e than Al	P-005-03 B pressu o clean up ering the (maintaine 3.	pairborn CR due to d at high	005 ure air flow is out of the e contaminants, but o the high pressure. er pressure, but CR is
JUSTIFICAT a. b. c. d.	New	Ensures CR p CR and into the Plausible since contaminants Plausible if m maintained at Plausible since the CR, but co pressure.	Bank I Bank I pressure he AB. ce it wou are pre- isconce thigher p ce it wou ontamin	<i>dified</i> Number is higher ld be de vented f pressure nd be de ants are	AOI er than A esirable to from ente at AB is r e than AI esirable t e prevent	P-005-03 B pressu o clean up ering the (maintaine 3. o maintai ed from e	p airborn CR due to d at high n low lev entering t	005 ure air flow is out of the e contaminants, but o the high pressure. er pressure, but CR is els of airborne radiation in he CR due to the high
JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	New ION: CORRECT	Ensures CR p CR and into the Plausible sind contaminants Plausible if m maintained at Plausible sind the CR, but c pressure.	Bank I Bank I Dressure he AB. ce it wou are prev isconcept higher p ce it wou ontamin	<i>dified</i> Number is highe Id be de vented f ption the pressure ants are <i>p</i> / <i>Recall</i>	AOI er than A esirable to from enter at AB is r e than Af esirable to prevent	P-005-03 B pressu o clean up ering the (maintained 3. o maintai ed from e	p airborn CR due to d at high n low lev entering t	005 ure air flow is out of the e contaminants, but o the high pressure. er pressure, but CR is els of airborne radiation in he CR due to the high

BASIS DOCUMENT, RADIATION MONITORING SYSTEM

ATTACHMENT 1, AREA MONITOR R-1 - CONTROL ROOM

Step Description

- 1 Upon high radiation alarm on Area Monitor R-1, Control Room ventilation automatically shifts to emergency pressurization mode. This step verifies that the automatic shift has occurred. The discharge dampers are verified closed by observing the pink and blue status lights (when power available) or by locally observing the damper positions (when power is unavailable to status lights).
- 2 Radiation Control personnel are contacted in response to all abnormal radiation conditions at the Plant. This step provides instruction to contact RC personnel and provides instruction on minimum radiological surveys to be performed.
- 3 This step opens Breaker AUX BUILDING SUPPLY FAN HVS-1 (MCC-5, CMPT-7J). This breaker must be opened to ensure that Control Room pressure is higher than Aux Building pressure, thereby ensuring that any air flow will be out of the Control Room and into the Auxiliary Building. (This is an NRC commitment per CP&L memo RNP/94-1689.)
- 4 This standard step provides transition back to the procedure body to address other Radiation Monitor alarms or to exit the procedure.

ATTACHMENT 2, AREA MONITOR R-2 - CV AREA

Step Description

1 If personnel are not in CV, then performing a CV evacuation is not necessary. This step checks if personnel are in CV and RNO 1 provides transition around steps performing CV evacuation if not required.

AOP-005-BD	Rev. 19	Page 4 of 38

Given the following conditions:

- A large break (DBA) LOCA has occurred.
- EPP-15, Loss of Emergency Coolant Recirculation, is being implemented.
- One SI Pump and one RHR pump are running.
- Time after trip and SI is 20 minutes.
- SI CANNOT be terminated due to insufficient subcooling.

Given the supplied references, which ONE (1) of the following states the **MINIMUM** SI flow for these conditions?

- a. One RHR pump injecting, with flow manually throttled to approximately 260 gpm
- b. One RHR pump injecting, with flow manually throttled to approximately 130 gpm
- c. One SI pump injecting, with flow manually throttled to approximately 260 gpm
- d. One SI pump injecting, with flow manually throttled to approximately 130 gpm

Answer:

c. One SI pump injecting, with flow manually throttled to approximately 260 gpm

							RNP NRC Written Examination Common Question Reference
QUESTION N	UMBER:	27					
TIER/GROUP			RO	1/2	SRO	1/2	
K/A:	WE11EK2.2						
	Knowledge of facility's heat i removal syste	the interrelation removal system ms, and relation	ns bet ns, incl ons bet	ween the uding prin ween the	(Loss of Emerg mary coolant, er systems.	ency Co nergenc	olant Recirculation) and the y coolant, the decay heat
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.9 8	SRO 55.43(b) SRO	4.3	
OBJECTIVE:	EPP-015-08						
	Given plant co related to EPF	onditions EVAL P-15.	UATE	the appro	opriate actions to	o mitigat	e consequences of steps
REFERENCE	S:	EPP-15					
SOURCE:	New	Significa	ntiy M	odified	X	Direc	ct
						•	004
			Bank	Number	EPP-015-0	8	001
JUSTIFICATI a.	ON:	Plausible sinc pump, not RH	<i>Bank</i> e detei IR pum	rmined flo	EPP-015-0	8 t flow sh	001 ould be established with SI
JUSTIFICATI a. b.	ON:	Plausible sinc pump, not RH Plausible if 20 maintained at	Bank e deter IR pum 00 minu pove 26	rmined flo np. ute line is 50 gpm.	F EPP-015-0	8 t flow sh I, but ac	001 rould be established with SI tual flow should be
JUSTIFICATI a. b. c.	ON: CORRECT	Plausible since pump, not RH Plausible if 20 maintained at Using EPP-15 minimum requ these condition	Bank e deter IR pum 00 minu bove 26 5, Attac uired flo ons.	rmined flo np. ute line is 50 gpm. chment 1, ow as 260	EPP-015-0 w is correct, bu incorrectly used intersection of 2) gpm. The RH	8 t flow sh I, but ac 20 minut R pump:	001 hould be established with SI tual flow should be te line with curve identifies s are both stopped under
JUSTIFICATI a. b. c. d.	ON: CORRECT	Plausible since pump, not RH Plausible if 20 maintained at Using EPP-18 minimum requ these condition Plausible if 20 maintained at	Bank e deter IR pum 00 minu pove 26 5, Attac uired flo ons. 00 minu pove 26	rmined flo ip. ute line is 50 gpm. chment 1, ow as 260 ute line is 50 gpm.	EPP-015-0 w is correct, bu incorrectly used intersection of 2 gpm. The RH incorrectly used	8 t flow sh I, but ac 20 minut R pumps d, but ac	001 nould be established with SI tual flow should be te line with curve identifies s are both stopped under tual flow should be
JUSTIFICATI a. b. c. d. DIFFICULTY Compreher	ON: CORRECT	Plausible since pump, not RH Plausible if 20 maintained at Using EPP-18 minimum requ these condition Plausible if 20 maintained at X <i>Kno</i>	Bank e deter IR pum 00 minu bove 26 5, Attac uired flo ons. 00 minu bove 26 powledg plant c	rmined flo ip. ute line is 50 gpm. chment 1, ow as 26 ute line is 50 gpm. ge/Recall urves to 0	EPP-015-0 bw is correct, bu incorrectly used intersection of 2 0 gpm. The RH incorrectly used Rating determine SI flow	8 t flow sh I, but ac 20 minut R pumps d, but ac 3 w require	001 nould be established with SI tual flow should be te line with curve identifies s are both stopped under tual flow should be

REFERENCES SUPPLIED: EPP-15, Attachment 1

Page 15 of 31

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
33.	Check If SI Can Be Terminated A: Follows:	s Establish minimum SI flow to remove decay heat as follows:
	 a. Check RCS subcooling - GREATER THAN 85°F [105°F] b. Check RVLIS indication - GREATER THAN REQUIRED FROM TABLE 	 Determine required SI flow from Attachment 1, Required Flow Rate Versus Time After Reactor Trip. Verify BOTH RHR pumps are stopped.
	RCP REQUIRED STATUS RVLIS INDICATION	3) Check SI flow rate on FI-943, COLD LEG HEADER FLOW.
	ONE 40% RUNNING DYNAMIC RANGE	4) Start an additional SI Pump as necessary.
	NONE 69% RUNNING FULL RANGE	5) Establish communications with operators stationed at the breakers for the BIT OUTLET COLD LEG INJECTION Valves
		• SI-870A - MCC-5 (CMPT 10M)
		 SI-870B - MCC-6 (CMPT 13J) 6) Coordinate with local personnel to OPEN the appropriate breaker <u>WHEN</u> flow reaches the required value.
		7) As necessary, individually CLOSE BIT OUTLET Valves, SI-870A <u>AND</u> SI-870B.
		8) <u>IF</u> necessary, <u>THEN</u> locally throttle SI-870A <u>OR</u> SI-870B.
		9) Go To Step 38.
34.	Reset CONTAINMENT ISOLATION PHASE A <u>AND</u> PHASE B	

Rev. 13

Page 31 of 31



EPP-015-08 001

The following plant conditions exist for a large break (DBA) LOCA when the operators begin to implement EPP-15 Loss of Emergency Coolant Recirculation.

the second state of the se

•

- * One SI and One RHR pumps are running
- * Time after trip and SI is 30 minutes
- * SI cannot be terminated due to insufficient subcooling

Which ONE (1) of the following states the minimum SI flow for these conditions?

- A. Only one SI pump and one RHR pump injuecting at full flow.
- B. Only one SI pump injecting at full flow.
- ✓C. Only one SI pump injecting with flow manually throttled to approximately 230 gpm.
- D. Only one SI pump inujecting with flow manually throttled to approximately 120 gpm.

Given the following conditions:

- The unit is operating at 24% power during a plant startup.
- Rods are being withdrawn to raise RCS temperature.
- When the IN-HOLD-OUT lever is released, rods continue to step outward.

Which ONE (1) of the following actions should be taken?

- a. Place the ROD BANK SELECTOR switch in Automatic and verify rod motion stops
- b. Place the ROD BANK SELECTOR switch in Manual and verify rod motion stops
- c. Manually trip the reactor in anticipation of an Intermediate Range High Flux Trip and go to PATH-1
- d. Manually trip the reactor in anticipation of a Power Range High Flux (Low Setpoint) Trip and go to PATH-1

Answer:

a. Place the ROD BANK SELECTOR switch in Automatic and verify rod motion stops

. MON ____

								Common Question Refere	nce
QUESTION N TIER/GROUP	IUMBER: ':	28	RO	1/2		SRO	1/1		
K/A:	001AA2.03								
	Ability to deter Proper actions	rmine and inte s to be taken if	rpret the automa	followir itic safet	ig as they y functior	r apply to ns have n	the Co ot taker	ntinuous Rod Withdrawal: n place	
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	4.5 6	55.43(b)	SRO) SRO	4.8		
OBJECTIVE:	AOP-001-05								
	STATE the im	mediate actior	n steps o	of AOP-(001				
REFERENCE	S:	AOP-001							
SOURCE:	New	X Significa	ntly Mo Bank	dified			Direct		
USTIFICAT			Dank	Number					
a.	CORRECT	Automatic roo should stop a	d withdra II rod wit	awal is p thdrawa	hysically I.	disabled,	so plac	cing the switch in Automati	C
b.		Plausible sind automatic roc	ce auton I insertio	natic rod on as au	control is tomatic ro	s capable od withdra	above awal is j	15% power, but only for physically disabled.	
с.		Plausible sind actions failed	ce a read to stop	ctor trip rod mot	would be ion, but IF	required R trip wou	if below Ild have	v 15% or if the correct been blocked by this poin	t.
d.		Plausible sind actions failed point.	ce a read to stop	ctor trip rod mot	would be ion, but P	required R trip wo	if below uld hav	v 15% or if the correct re been blocked by this	
DIFFICULTY Comprehen	: nsive/Analysis	Knu	owledge	e/Recall	X R	ating	3		

RNP NRC Written Examination

Knowledge of immediate operator actions for continuous rod motion

Rev. 15

Page 4 of 80

a.

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
	NOTE	
		immediate actions
	Steps 1 through 4 are	Timiediate actions.
1.	Check Unwarranted Rod Motion - IN PROGRESS	Go To Step 6.
2.	Check Reactor Power - GREATER THAN 15%	Trip the Reactor and Go To Path 1.
3.	Attempt To Stop Rod Motion As Follows:	
	a. Check ROD BANK SELECTOR Switch position - A (AUTO)	a. Place the ROD BANK SELECTOR Switch in A (Auto).
		Go To Step 4.
	b. Place ROD BANK SELECTOR Switch in M (Manual)	
4.	Check Unwarranted Rod Motion - STOPPED	Trip the Reactor and Go To Path 1.
5.	Go To Section C, Continuous Rod Motion	
6.	Determine If Multiple Rods Have Dropped As Follows:	
	a. Analyze Indications For Multiple Rod Drop	
	• Prompt Drop - PRESENT	
	 More than 1 Rod Bottom Light - ILLUMINATED 	
	 More Than 1 IRPI - INDICATES ON BOTTOM 	
	b. Check Multiple Dropped Rods - PRESENT	b. Go To Step 9.
7.	Check Reactor Status - MODE 1 <u>OR</u> 2	Go To Section A, Dropped Rod

DISCUSSION (Continued)

The following are possible indications that a bank has failed to move:

- No change in IRPI or Group Step Counter readings when motion is demanded
- With rods in auto, following a Turbine load or boron concentration decrease, any of the following:
 - Increasing Tavg, RCS pressure and pressurizer level
 - Tavg/Tref deviation indication and alarm

In the case of an individual rod that indicates misalignment or lack of motion, it may or may not be fully known by the Operator the exact nature of the failure. The problem could be a stuck rod, IRPI failure, or misaligned rod. Depending on core location, core flux patterns may not be sufficiently abnormal to indicate a rod alignment problem on the ex-core detectors. Incore flux maps and thermocouple readings would be necessary to confirm a misaligned rod. In the case of a stuck rod, it may not be confirmed until actions have been taken to validate the IRPI and attempts to realign the rod prove unsuccessful.

The procedure has arrange the sections in the main Body to assist the operator in diagnosing an IRPI failure vs a Misaligned or Stuck Rod. The operator should always keep in mind that if not sure that a problem is an IRPI problem, then it should be treated as a misaligned rod.

Section C - Continuous Rod Motion

This section of the procedure is intended to provide the direction necessary to diagnose the cause of unwarranted rod motion and comply with ITS requirements if the rod movement occurred while in Individual bank Select Mode. This section also assures plant power is maintained below 100%. Possible causes of unwarranted rod motion are:

- Out motion Failure of IN/OUT manual station
- In motion Failure of IN/OUT manual station
 - Failure of the Automatic Control System

In most cases of unwarranted rod motion, the cause would be accompanied by alarms and indications of the failure. The alarms that would occur and the rate of rod motion are proportional to the cause and extent of the failure. it is not possible to experience a failure in the Automatic Control System causing continuous rod withdrawal. The leads for automatic rod withdrawal have been physically lifted.

AOP-001-BD Rev. 15

INDIVIDUAL STEP DESCRIPTION:

Main Body

Step Description

- N1 This note reminds the operator that the first four steps are immediate actions.
- 1 This step provides transition for actions in the event of uncontrolled rod movement. The step is noted as "unwarranted" rod movement. It is expected that the operator is familiar with the setup of the rod control system so that he may observe plant conditions and determine that rod motion should not be called for.
- 2 This step checks plant power for applicability of actions for unwarranted rod movement. If <u>NOT</u> greater than 15% the reactor will be tripped.

If less than 15% a startup (or shutdown) is in progress with rods in manual. Uncontrolled rod movement could result in an uncontrolled criticality. Rods can not be placed in automatic when below 15% power, therefore the reactor is tripped.

If in Mode 3 the rods are in manual with rod movement, most likely, not in progress (this would be classified as spontaneous uncontrolled manual rod movement). Once again, rods can not be placed in automatic below 15%.

- 3 This step attempts to stop rod motion. If rods are in manual initially and rod movement begins, the failure is most likely in the in or out selector switches. Note that this includes having the switch in the manual "bank select" position. Placing the rods in automatic will remove those switches from the circuit. If the rods are in automatic when movement occurs placing the switch in manual will remove the automatic circuitry from service.
- 4 If after moving the switch to a different position, the uncontrolled rod movement continues, a reactor trip is required. Rods movement without control of the operator is a serious condition which could lead to flux anomalies and fuel damage if left unattended.

AOP-001-BD	Rev. 15	Page 7 of 39
------------	---------	--------------
Question: 29

A Containment Purge is in progress.

Which ONE (1) of the following will automatically terminate the purge on a high radiation signal?

- a. R-11, Containment Air and Plant Vent Particulate
- b. R-14A, Plant Effluent Particulate
- c. R-14C, Plant Effluent Noble Gas Low Range
- d. R-16, Containment HVH Cooling Water Radioactive Liquid

Answer:

a. R-11, Containment Air and Plant Vent Particulate

								RNP NRC Written Exa Common Question F	amination Reference
	UMBER:	29							
TIER/GROUF K/A:	073A4.01		RO	2/2		SRO	2/2		
	Ability to man	ually operate	and/or n	nonitor ir	the co	ontrol room:	Effluer	nt release	
	,								
K/A IMPORT	ANCE:	55 A1 (h	RO	3.9	55 A.	SRO	3.9		
		55.41(b	,	9	55.40	10/ 310			
OBJECTIVE:	RM-09								
	EXPLAIN the	normal opera	ation of the	he RM co	ontrol s	ystems. Inc	clude fu	unction, instrumentatio	on,
	menocks, an	nunciators, ai	iu seipo						
REFERENCE	ES:	AOP-005							
		SD-019							
SOURCE:	New	Signific	antly M	odified	X		Direc		
			Bank	Numbe	r R	M-09		003	
JUSTIFICAT	ION: CORRECT	On high radi	ation lev	el autor	natically	/ closes CV	purae	supply and exhaust, a	as well
ц.	o o ra izo r	as the press	ure and	vacuum	relief v	alves.	1		
									*r 1
b.		Plausible sir by this rad n	nce R-14 nonitor, t	A monito	ors ven ito acti	t exhaust ar ons are ass	nd CV ociated	purge exnaust is mon I with R-14A.	itorea
		,							
с.		Plausible sir	ice R-14	A monito	ors ven	t exhaust ar	nd CV	purge exhaust is mon	itored
		gas tank rel	nonitor, i ease.	out auto	actions	associated	WILLE IN		3510
d.		Plausible sir	nce this v	would de	tect a d	containment	t high r	adiation condition, but	t only if
		leakage into	the coo	ling wate	er also	existed and	there a	are no automatic actic	ons for
	·.								
Compreher	nsive/Analysis	К	nowledg	e/Recal		Rating	3		
-	-								

Knowledge of automatic actions associated with radiation monitors

REFERENCES SUPPLIED:

AOP-	n	٥	5
AUP-	υ	v	Э

Rev. 19

Page 28 of 56

CTED -	INSTRUCTIONS	RESPONSE NOT OBTAINED						
SIEF	ATTACHMEN	۲ 12						
	PROCESS MONITOR R-11/R-12 -	- CV AIR & PLANT VENT						
	(Page 2 of	E 3)						
8.	Check CONTAINMENT VENTILATION	Perform the following:						
	ISOLATION Valves - CLOSED	a. Depress H.V. OFF on R-11 <u>OR</u> R-12 to initiate Containment Ventilation Isolation.						
		b. IF any CONTAINMENT VENTILATION ISOLATION Valve fails to close, <u>THEN</u> locally verify penetration is isolated from outside CV.						
9.	Place The Following CV IODINE REMOVAL FAN Control Switches To PREPURGE Position:							
	• HVE-3							
	• HVE-4							
10.	Check RCS Temperature - GREATER THAN 200°F	Initiate CV closure using OMM-033, Implementation Of CV Closure.						
11.	Request RC To Perform A Background Radiation Check At Radiation Monitors R-11 <u>AND</u> R-12							
		· · ·						

.

ATTACHMENT 10.2 Page 1 of 2

RMS INSTRUMENT CONTROL FUNCTIONS

MONITOR	MEDIUM MONITORED	FUNCTION		
R-1	Control Room Air	Switches Control Room ventilation into the emergency pressurization operating mode.		
R-11	CV Air or Stack Particulate	Closes C.V. purge supply and exhaust; pressure and vacuum relief valves.		
R-12	CV Air or Stack Gas	Same function as R-11		
R-14C	Stack Gas (Low Range)	Closes waste gas decay tank release valve (RCV-014); swaps R-14 Skid over to high range (two different setpoints).		
R-14D	Stack Gas (Mid Range)	Swaps R-14 Skid over to low range.		
R-18	Liquid Waste Disposal	Closes waste disposal system liquid release valve (RCV-018)		
NOTE The blowdown tank release isolation valve (V1-31) will close if all three SG monitors (R-19A, R-19B and R-19C) are in alarm.				
R-19A	SG "A" Blowdown	Closes; blowdown isolation valves FCV-1930A & FCV-1930B, sample isolation valves FCV-1933A & FCV-1933B, rate flow control valve FCV-4204A.		

,

RM-09 003

Which ONE (1) of the following describes process radiation monitor channels that initiate automatic actions?

The following titles are associated with the channel numbers:

	R-11: R-12: R-14C R-17:	Containn Containn Plant Ve CCW M	Containment Air Particulate Containment Air Gas Plant Vent Gas CCW Monitor		
	R-11	R-12	R-14C	R-17	
A.	Yes	No	No	Yes	
B.	No	Yes	Yes	Yes	
√ C.	Yes	Yes	Yes	No	
D.	No	No	No	No	

Question: 30

Given the following conditions:

- Reactor power is 35%.
- All control systems are in automatic.
- Pressurizer level transmitter LT-459 is selected for control.
- A small leak develops across the differential pressure bellows for LT-459, resulting in pressure equalizing across the bellows.

Assuming **NO** operator actions, which ONE (1) of the following describes the instrumentation and plant response to this leak?

	LI-459 PZR LVL	LI-460 PZR LVL
a.	Increases	Increases
b.	Increases	Decreases
C.	Decreases	Increases
d.	Decreases	Decreases

Answer:

b.	Increases	Decreases

QUESTION N TIER/GROUP	IUMBER:	30	RO	1/3	SRO	1/3	
K/A:	028AK1.01						
	Knowledge of Level Control	the operationa Malfunctions: F	l implica PZR refe	itions of t erence le	he following con ak abnormalities	cepts as they apply to Pressurize	r
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.8 7	SRO 55.43(b) SRO	3.1	
OBJECTIVE:	CVCS-09						
	EXPLAIN the	effect on the C	VCS du	e to sele	cted failures.		
REFERENCE	:S:	SD-059 Pressurizer I	D				
SOURCE							
OUDINOL.							
HISTICICAT			Bank I	Number	CVCS-09	019	
a.		Plausible sinc pressurizer le	e indica vel will lo	ted level ower.	on the failed insi	trument will increase, but actual	
b.	CORRECT	T Pressure equalizing across the cell would indicate that water level in the pressurizer is equal to the height of the reference leg. Since this would indicate a high level, charging pump speed would lower, and actual level would lower.					
		pressurizer is high level, cha	equal to arging p	the heig ump spe	ht of the referen would lower, a	ce leg. Since this would indicate and actual level would lower.	а
с.		pressurizer is high level, cha Plausible if mi decrease, but	equal to arging pr sconcep indicate	o the heig ump spe otion is the	a cell would indic ght of the referen ed would lower, a nat indicated leve vill increase.	ce leg. Since this would indicate and actual level would lower. I decreases as differential pressu	a re
с. d.		pressurizer is high level, cha Plausible if mi decrease, but Plausible if mi decrease, but	equal to arging pr sconcep indicate sconcep indicate	o the heig ump spe otion is the ed level v	a cell would indic ght of the referen ed would lower, a nat indicated leve vill increase. nat indicated leve vill increase.	ce leg. Since this would indicate and actual level would lower. I decreases as differential pressu	a re re
c. d. DIFFICULTY Compreher	: nsive/Analysis	Plausible if mi decrease, but Plausible if mi decrease, but	equal to arging pr sconcep indicate sconcep indicate	the heigump spe otion is the otion is the otion is the otion is the otion is the otion is the otion is the otion is the otion is the otion is the otion is the otion is the ot	t of the referenced would lower, a mat indicated level will increase.	ce leg. Since this would indicate and actual level would lower. I decreases as differential pressu	a re

REFERENCES SUPPLIED:

There is one alarm associated with each channel of LTOPP. It actuates for 3 reasons: (1) RCS temperature is <360°F and LTOPP is not selected on the key switch for OVERPRESSURE PROTECTION, (2) The PORV has received an actuation signal based upon current pressure and temperature or (3) the associated Block valve is shut.

5.1.5 PZR Level Control (PZR-Figure 12)

PZR level is controlled by controlling charging pump speed. The level is programmed to ramp up as Tavg increases by LC-459G. This maintains approximately constant mass in the RCS as Tavg is increased and the coolant in the RCS expands. Level program is 22.2% at Tavg of 547°F and 53.3% at Tavg of 575.4°F.

There are 3 PZR level channels LT-459, LT-460 and LT-461. LC-459G the PZR level controller is normally fed by level channel LT-459 but can be replaced by LT-461 with a selector switch on the RTGB. The output of LC-459G is then fed to the charging pump speed controllers to control speed of the charging pump if their controllers are selected to Auto.

If PZR level increases 5% above program LC-459D will turn on the backup heaters and sound an annunciator for High Level Heaters on.

On PZR low level of 14.4%, proportional and backup heaters are deenergized and letdown is isolated by shutting LCV-460A & B if respective control switches are in auto. LC-459 and the LC-460, the low level bistables, are normally supplied by LT-459 and LT-460 respectively but either can be replaced by LT-461 with a selector switch on the RTGB.

LC-459 will only turn off the backup heaters that are selected to Automatic where LC-460 will turn off the backup heaters in Automatic or Manual. The only time this would have any bearing would be in the event of an instrument failure. If the channel feeding LC-459, usually LT-459, were to fail low the proportional heaters and any backup heaters in Automatic would deenergize and any backup heater in manual would remain energized.

PZR

		(1) Exam	ples:	
		(a)	Break in reference leg - reference pressure decreases - indicated level increases	
		(b)	High temperature in CV - reference pressure decreases - indicated level increases	
		(c)	D/P cell rupture - reference pressure decreases - indicated level increases	
	c)	Cold cal. remains co decreases	level at NOP/NOT - reference pressure onstant - variable leg density/pressure - cold cal. level indicates lower	
5.	AV RC	AILABILI P COMBIN	TY OF SPRAY FLOW FOR VARIOUS NATIONS	PZR-FIGURE-14
	a)	Spray valv	ve 455B off of "C" loop	
	b)	Spray valv	ve 455A taps off of "B" loop	
	c)	Spray per combinati Normal s all when I than 30%	formance may be improved with any on of pumps by raising PZR water level. spray flow is unlikely or will not occur at RCP "C" is stopped and PZR level is less	
	d)	When ope spray value left shut t the idle lo	erating only one RCP in a loop with a we, the idle loop spray valve should be o prevent "short-cycling" of flow back to pop	
	e)	RCP/Spra	ay combinations shown in Figure-14	
6.	PR	ESSURE C	CHANNEL FAILURE	OBJ. #14
	a)	Automatic change	c systems will act same as any pressure	
	b)	Channel f PORV fai	failing high will result in full spray and iling open	
	c)	Must man low press	nually shut PORV to prevent trip on sure	
				1

1 1 - 1 - 1		a) Vent if hydrogen or oxygen >4% by	
		b) Gaseous Waste Vent Header	
		c) RC-549	
C.	AB	NORMAL OPERATIONS	
	1.	PZR automatically responds to all abnormal conditions	
		a) Automatic controls	
		b) Safety valves	
	2.	CONTROLLING CHANNEL FOR PZR LEVEL FAILS HIGH (NO OPERATOR ACTION)	OBJ. #14
		a) Charging pump speed \downarrow causing PZR level \downarrow	
		 b) Letdown isolates and all PZR heaters trip @ 14.4% 	
		c) Letdown will reinitiate as level \uparrow , heaters will not	
Q A	WI Bro	by will heaters not automatically re-energize ?	hen back to AUTO or on
		 d) PZR level oscillates and pressure ↓ (no heaters), reactor trip on low pressure, OT∆T runback may be experienced 	
	3.	PZR LEVEL AND PRESSURE RESPONSE FOLLOWING A 15 % LOAD REDUCTION	
		a) Level and pressure increase	
		b) Pressure increase stops before level increase stops	
	4.	PZR LEVEL INDICATION CHANGES DUE TO ABNORMAL TRANSMITTER CONDITIONS	Draw a picture of a vessel variable and reference legs
		a) Transmitter works on differential pressure	
		 Anything that causes reference leg pressure to decrease/increase relative to variable leg causes indicated level to go up/down 	
			-

÷

CVCS-09 019

Given the following plant conditions:

- VCT level is at 20 inches and automatic makeup is in progress
- The level transmitter associated with the automatic level controller (LT-115) fails HIGH
- The Hagan rack switch is in the NORMAL position
- Which ONE (1) of the following describes the CVCS system response?
- A. LT-112 will override the input from LT-115 for LCV-115A; therefore actual VCT level will remain constant.
- B. Actual VCT level will increase once an auto markup signal is established due to input from LT-112.
- C. LCV-115C, VCT Outlet valve, will CLOSE and LCV-115B EMERG MU TO CHG SUCT valve will open.
- \checkmark D. The operating charging pump(s) will become air bound due to gas intrusion from the VCT.

. . .

Question: 31

Given the following conditions:

The plant is being shutdown because of high vibrations on Condensate Pump "A".

- The plant is currently at 65% power.
- Two Main Feedwater Pumps, two Condensate Pumps and a Heater Drain Tank Pump are in service.
- Condensate Pump "A" trips.

Which ONE (1) of the following actions should be taken?

- a. Attempt to stabilize the plant at the current power level
- b. Attempt to lower turbine load at a rate between 1% minute and 5% per minute and stablize the plant at or below 60% power
- c. Attempt to lower turbine load at a rate between 1% minute and 5% per minute and stablize the plant at or below 50% power
- d. Trip the reactor and go to PATH-1

Answer:

c. Attempt to lower turbine load at a rate between 1% minute and 5% per minute and stablize the plant at or below 50% power

							(Common (Question Re	eference
QUESTION N TIER/GROUP K/A:	UMBER: : 056K1.03	31	RO	2/1		SRO	2/1			
	Knowledge of Condensate S	the physical System and th	connectione following	ons and/ ng syste	or caus ms: MF	e-effect rela W	ationshi	ps betwee	n the	
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b	RO) RO	2.6 4	55.43(SRO Љ) SRO	2.6			
OBJECTIVE:	AOP-010-03									
	DEMONSTRA explaining the	TE an under basis of eac	standing h.	of selec	ted step	os, cautions	s, and no	otes in AO	P-010 by	
REFERENCE	S:	SD-027 APP-007 AOP-010								
SOURCE:	New	Signific	cantly Mo	odified	X		Direct			
			Bank	Numbei	- AC	0P-010-03		002		
JUSTIFICATI a.	ON:	Plausible sir and one fee	nce this p d pump, l	ower lev but powe	el is be er is to t	low the trip be reduced	require to less	ment for o than 50%.	ne condens	sate
b.		Plausible si power is to trip.	nce this w be reduce	vould be ed to less	the cor s than 5	rect action 0% with bo	if only o oth a cor	ne feed pu ndensate a	ump tripped and feed pu	, but mp
С.	CORRECT	Under these pump. Max 50%. A trip	e condition imum allo is not rec	ns, a trip owable p quired si	of one ower le nce pov	condensat vel for one ver is belov	e pump conden v 70%.	will cause sate and c	a trip of on one feed pu	e FW mp is
d.		Plausible si trip is not re	nce this a quired at	this leve	uld be i I.	equired if	oower le	vel was al	oove 70%, I	but a
DIFFICULTY Comprehen	: sive/Analysis	ХК	nowledg	e/Recall		Rating	3			
	Application of limitations	f given condit	ions to de	etermine	respon	se required	d to rem	ain within	condensate)

RNP NRC Written Examination

REFERENCES SUPPLIED:

• High-High steam generator level (2/3 ≥75%), the bypass valve associated with the high-high level closes

4.0 **INSTRUMENTATION**

4.1 Main Feedwater Pumps

The control switches and indicating lights for the main feedwater pumps are located on the RTGB. The following requirements must be met before a pump will start under normal plant conditions: A condensate pump running, sufficient suction pressure, and sufficient lube oil pressure (8 psig). In addition, if no feedwater pumps are running, then all three block valves must be closed prior to the first feedwater pump start. To start a feedwater pump following a feedwater isolation, all of the above must be met plus the Reactor Trip breakers must be closed and Safety Injection reset, OR place the Feedwater Isolation OVRD/RESET key switches in OVRD/RESET.

A feedwater pump will trip from the following:

(refer to Attachment 10.4 for applicable switches and setpoints)

- Electrical overload
- Undervoltage on its bus
- Minimum flow blocked for 30 secs. after starting (935 gpm)
- Loss of condensate pump
- Low lube oil pressure (6 psig)
- Low suction pressure (235 psig) coincident with low flow (3100 gpm)
- Safeguards actuation (SI signal)
- Hi-Hi steam generator level (2/3 in 1/3 S/G ≥75%)

To run both main feedwater pumps, both condensate pumps must be running. If only one main feedwater pump is running and it trips due to minimum flow, low lube oil pressure, or electrical overload, the non-running pump will automatically start providing a condensate pump is still running.

Flow switches are provided for each pump to control its recirculating valve (FCV-1444 and FCV-1445) and annunciate alarm conditions. Each valve can be selected to AUTO or OPEN on the RTGB. When in AUTO the valve opens on low flow and closes at a higher flow. This valve will not automatically open unless its associated pump is running, and fails open on loss of power. The valves purpose is to maintain minimum flow through the main feedwater pumps to ensure pump cooling. The valves will open when a low flow condition (1475 gpm) is sensed (e.g. following a reactor trip and feedwater isolation). Upon low flow, the white light adjacent to the control switch on the RTGB also illuminates. When flow increases to 3100 gpm the valve will close.

Revision 3

INFORMATION USE ONLY

FW

<u>ALARM</u>

COND PMP A MOTOR OVLD/TRIP

AUTOMATIC ACTIONS

- 1. IF COND PUMP "A" has tripped AND COND PUMP "B" is in standby, THEN COND PUMP "B" will start.
- 2. IF COND PUMP "A" trips, THEN one Feed Pump will trip if two Condensate Pumps AND two Feed Pumps were running.

NOTE: The 51¢B device is set at a lower current value than 51¢A and 51¢C. A slow current increase will cause an alarm prior to reaching the long term **OR** short term overcurrent trip setting.

<u>CAUSE</u>

- 1. Electrical fault trip of Pump Breaker
- 2. Electrical overload (without breaker trip)

OBSERVATIONS

- 1. COND PUMP "A" Status Lights
- 2. S/G Level trends

ACTIONS

- 1. **IF** COND PUMP "A" has tripped **AND** the Main Generator is in parallel with the grid, **THEN** refer to AOP-010.
- 2. IF COND PUMP "A" has tripped AND the Unit is shutdown, THEN perform the following:
 - 1) Verify Automatic Actions listed above occur.
 - 2) IF required, THEN feed the S/Gs using AFW Pump(s)
 - 3) IF the cause of the trip is **NOT** known, **THEN** dispatch personnel to inspect the pump **AND** breaker for indications of the cause.

100 007	Pov 25	Page 4 of 57
APP-007	Rev. 25	1 age + 01 01

•

Rev. 18

Page 5 of 16

STEP	INSTRUCTION	s	RESPONSE NOT OBTAINED
4	. Go To The Appropriate The Table Below:	Step from	
	EVENT	STEP	
	Main Feed Pump Trip	Step 5	
	Condensate <u>AND</u> Feed Pump Trip	Step 9	
	Condensate Pump Trip Without MFP Trip	Step 45	
	Heater Drain Pump Trip	Step 14	
	Pipe Break / Leak	Step 20	
	Other	Step 23	
5	. Check Reactor Power - 80%	LESS THAN	Trip the Reactor and Go To Path-1.
6	. Check Reactor Power - THAN 60%	GREATER	Go To Step 12.
7	7. Reduce Turbine Load A 5%/MIN To Achieve Les Reactor Power	t 1%/MIN To s Than 60%	
8	. Go To Step 12		
9). Check Reactor Power - 70%	LESS THAN	Trip the Reactor and Go To Path-1.
10). Check Reactor Power - THAN 50%	GREATER	Go To Step 12.
11	Reduce Turbine Load A 5%/MIN To Achieve Les Reactor Power	t 1%/MIN To s Than 50%	

•

MAIN FEEDWATER/CONDENSATE MALFUNCTION

Rev. 18

Page 6 of 16

		TNO			PREDONSE NOT OBTAINED
STEP		INST			RESPONSE NOT OBTAINED
12	2. Check Ma ONE RUNN	ain Feed NING	1 Pumps - A	AT LEAST	<u>IF</u> Reactor Power is greater than 10%, <u>THEN</u> trip the Reactor and Go To Path-1.
					<u>IF</u> Reactor Power is less than 10%, <u>THEN</u> trip the Turbine and Go To AOP-007, Turbine Trip Below P-7.
13	3. Go To St	ep 36			
14	4. Reduce 7 5%/MIN 7 Less Tha The Fol3	Furbine To Achie an The T Lowing T	Load At 1% eve Reactor Farget Powe Fable:	5/MIN To r Power er Per	
	PUN	APS RUNI	NING	TARGET POWER	
	Main FWP	Cond	Htr Drn	Percent	
	2	2	1	85%	
	2	2	0	80%	
	1	2	0 or 1	60%	
	1	1	0 or 1	50%	
1	5. Check Ma RUNNING	ain FW	Pumps - TWO) PUMPS	Observe <u>NOTE</u> prior to Step 17 and Go To Step 17.
*1	6. Check H OPEN	CV-1459	, LP HEATEI	RS BYP -	Perform the following:
	OPEN				a. Monitor Condensate Pumps header pressure on PI-1458.
					b. <u>IF</u> pressure decreases to less than the applicable setpoint, <u>THEN</u> verify OPEN HCV-1459.
					 Any HDP Running - 300 psig
					• No HDPs Running - 350 psig

AOP-010-03 002

Given the following plant conditions:

- The plant is being shutdown because of high vibrations on Condensate Pump "A"
- The plant is currently at 30% power
- Two Main Feedwater Pumps, two Condensate Pumps and a Heater Drain Tank Pump are in service
- Condensate Pump "A" trips

Which ONE (1) of the following describes the expected plant response?

- A. Both Main Feedwater Pumps will trip resulting in a Reactor trip due to low Steam Generator level.
- ✓B. One Main Feedwater Pump will trip but sufficient Feedwater flow exists to maintain Steam Generator level.
- C. One Main Feedwater Pump will trip which will result in insufficient Feedwater flow to maintain Steam Generator level.

and prove the

D. A Turbine run back will occur bringing Steam flow in-line with Feedwater flow.

Question: 32

Given the following excerpt from OP-922, "Post Accident Containment, Hydrogen Reduction/Venting System", and the following conditions:

- A design basis LOCA occurred 90 days ago.
- Hydrogen Concentration (Hydrogen Monitor Reading) is 2.5%.
- The H₂ Recombiner System is unavailable for Containment Hydrogen Reduction.

From OP-922:

"5.2.8 Determine the following data:

- 1. H₂ generation rate from Curve Book, Curve 7.16, Total Hydrogen Generation Rate From All Sources.
 - Time following DBA _____ Days - H₂ Generation Rate _____ SCFM (Curve 7.16)
- 2. H₂ Concentration from Containment Hydrogen Monitor located in the Control Room or from analysis of Containment samples:
 - H₂ Concentration _____%
- 5.2.9 Calculate the required exhaust flow:
 - 1. Qe = 2400 <u>G</u>
 - C
 - Qe is exhaust flow in SCFM
 - G is H₂ Generation rate
 - C is H₂ Concentration

Required exhaust flow _____ SCFM

NOTE: The Containment Air Exhaust Line (PACV "B") should be used in preference to the Pressure Relief Line (PACV "A").

Given the supplied references, in order to provide required exhaust flow through preferred exhaust path (Containment Air Exhaust), Containment pressure should be raised to approximately ...

- a. 0.9 psig.
- b. 1.1 psig.
- c. 3.7 psig.
- d. 4.6 psig.

Answer:

a. 0.9 psig.

							F	RNP NRC Written Examination Common Question Reference
QUESTION N TIER/GROUF K/A:	IUMBER: : 028A1.02	32	RO	2/3		SRO	2/2	
	Ability to pred associated wit	ict and/or mon th operating th	itor cha e HRPS	nges in p S controls	arame includ	ter (to preve ing: Contair	ent exc nment p	eeding design limits) pressure
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.4 10	55.43	SRO (b) SRO	3.7	
OBJECTIVE:	CVHVAC-09							
EXPLAIN the normal operation of the CV HVAC, PACV and H ² Reombiner control systems. Include function, instrumentation, interlocks, annunciators, and setpoints.							biner control systems. nts.	
REFERENCE	S:	OP-922 Plant Curve 7 Plant Curve 7	7.6 7.16					
SOURCE:	New	Significa	ntly Mo	odified	X		Direct	
			Bank	Numbei	~ C\	/HVAC-09		009
JUSTIFICATI a.	CORRECT	Using Curve calculation, d determine inte	7.16, de etermin ersectio	etermine e require on of 240	interse d vent scfm a	ction of 90 o flow rate is nd PACV-B	day line 240 sc to be (e as 0.25 scfm. Performing fm. Using Curve 7.6,).9 psig.
b.	Plausible since performed correct until using Curve 7.6 and uses PACV-A instead of PACV-B, which is the preferred method.							
с.	<i>c.</i> Plausible if misread Curve 7.16 as 0.5 instead of 0.25. Calculation would then result in 480 scfm. Using PACV-B on Curve 7.6 would result in this response.							
d.		Plausible if m result in 480 response.	iisread (scfm. T	Curve 7. Then usir	16 as 0 ig PAC	.5 instead c V-A on Cur	of 0.25. ve 7.6 v	Calculation would then would result in this
DIFFICULTY Compreher	: asive/Analysis	X Kn	owledg	e/Recall		Rating	4	
	Calculation o of plant curve	f containment s	pressur	e require	ments	based on a	pplicati	on of given conditions to use
REFERENCI		: Plant Cur	ves 7.6	and 7.16	5			

Section 5.2 Page 2 of 4

<u>INIT</u>

- 5.2.7 At least one of the following operable for pressurizing the CV: (N/A method not used)
 - 1. Station Air System components to pressurize the CV, including Station Air Compressor, piping and valves to the CV.
 - 2. Instrument Air System components to pressurize the CV, including an Instrument Air Compressor, piping and valves to the CV (an Instrument Air Prefilter and Dryer should be used if available, however, they can be bypassed).

NOTE: The Containment H_2 Concentration can be determined by chemical analysis of samples collected IAW Section 8.1 if the Containment Hydrogen Monitor is inoperable.

5.2.8 Determine the following data:

- 1. H₂ generation rate from Curve Book, Curve 7.16, Total Hydrogen Generation Rate From All Sources.
 - Time following DBA _____ Days 40
 - H₂ Generation Rate _ SCFM (Curve 7.16)
- 2. H₂ Concentration from Containment Hydrogen Monitor located in the Control Room or from analysis of Containment samples:

- H₂ Concentration
$$\frac{2\cdot}{}$$
 % Samples / Monitor (Circle one)

OP-922	Rev. 14	Page 17 of 62

Section 5.2 Page 3 of 4

<u>INIT</u>

5.2.9 Calculate the required exhaust flow:

1. Qe = 2400 <u>G</u> C

- Qe is exhaust flow in SCFM

- G is H₂ Generation rate

- C is H₂ Concentration Required exhaust flow _____ SCFM

NOTE: The Containment Air Exhaust line (PACV "B") should be used in preference to the Pressure Relief line (PACV "A").

5.2.10 Determine the required Containment pressure from Curve Book, Curve 7.6, System Resistance Curve to obtain required exhaust flow.

Required pressure for PACV "B" = _____ psig

Required pressure for PACV "A" = _____ psig

OP-922	Rev. 14	Page 18 of 62



HYDROGEN GENERATION RATE, SCFM

Rev

72



16

CVHVAC-09 009

A design basis LOCA has occurred. The following data has been obtained:

• Time following the LOCA 10 days

Hydrogen Concentration (Hydrogen Monitor Reading) 5.8%

· Containment pressure 0.2 psig

Which ONE (1) of the following is the correct pressure that the containment should be raised in order to vent the containment using the preferred path? (OP-922 is provided for reference).

✓A. 1.5 psig

B. 1.9 psig

C. 2.0 psig

D. 2.5 psig

Question: 33

Which ONE (1) of the following Fire Brigade qualified personnel would normally serve as the Fire Brigade Team Leader in the event of a fire in the Auxiliary Building of Unit 2?

- a. Fire Protection Auxiliary Operator
- b. WCC Senior Reactor Operator
- c. Unit 1 Superintendent Shift Operations
- d. Environmental & Radiation Control Supervisor

Answer:

b. WCC Senior Reactor Operator

								Common Que	stion Reference
QUESTION NU TIER/GROUP: K/A:	UMBER: : 2.4.26	33	RO	3		SRO	3		
	Knowledge of equipment usa	facility protec age.	tion requ	uirements	s includi	ng fire brig	jade ar	nd portable fire	fighting
K/A IMPORTA 10CFR55 CON	NCE: NTENT:	55.41(b)	RO RO	2.9 10	55.43(SRO b) SRO	3.3		
OBJECTIVE:	OMM-002-03								
	DISCUSS eac of the procedu	ch section of C Ire.	00-MM	2, when p	oossible	e, using the	e inform	nation given in	each section
REFERENCES	S:	OMM-002							
SOURCE:	New	Significa	antly Mo	odified	X		Direc	t 🔲	
SOURCE:	New	Significa	antiy Mo Bank	odified Number	× ON	/ M- 002-03	Direc	t 🔲 002	
SOURCE: JUSTIFICATIO a.	New	Plausible sine licensed ope	antiy Mo Bank ce functi rator.	odified Number ion is to b	ON De on-sł	/IM-002-03	Direc	t 002 expert, but lea	der must be a
SOURCE: JUSTIFICATIO a. b.	<i>New</i> ON: CORRECT	Plausible sind licensed ope Normally the serve as lead	Bank Bank ce functi rator. WCC S der if qua	Number ion is to b RO fills th alified.	ON De on-st	/IM-002-03 hift fire pro tion, althor	<i>Direc</i> tection ugh any	t 002 expert, but lea y licensed oper	der must be a rator can
SOURCE: JUSTIFICATIO a. b. c.	New	Significa Plausible sine licensed ope Normally the serve as lead Plausible sin 1, but leader	Bank Bank ce functi rator. WCC S der if qua ce this p must be	Number ion is to b RO fills th alified.	De on-sh his posi	/IM-002-03 hift fire pro tion, althou an advisor rator.	<i>Direc</i> tection ugh any to the I	<i>t</i> 002 expert, but lea y licensed oper	der must be a rator can ny fire on Unit
SOURCE: JUSTIFICATIO a. b. c. d.	New	Signification Plausible sine licensed ope Normally the serve as lead Plausible sin 1, but leader Plausible sin consideration operator.	antly Mo Bank ce functi rator. WCC S der if qua ce this p must be ce this p	Number ion is to b RO fills th alified. position ac position w ciated with	ON ON	/IM-002-03 hift fire pro tion, althou an advisor rator. de guidan in an RCA	<i>Direc</i> tection ugh any to the I ce for t	<i>t</i> 002 expert, but lea y licensed oper eader during a he radiological ader must be a	der must be a rator can ny fire on Unit a licensed
SOURCE: JUSTIFICATIO a. b. c. d. DIFFICULTY: Comprehens	New ON: CORRECT	Signification Plausible sinulicensed ope Normally the serve as lead Plausible sinul, but leader Plausible sinuconsideration operator.	<i>Bank</i> <i>Bank</i> ce functi rator. WCC S der if qua ce this p must be ce this p ns assoc	Number Number ion is to b RO fills th alified. position ac e a license position w ciated with	ON be on-sh his posi cts as a ed oper vill provi th a fire	/IM-002-03 hift fire pro tion, althou an advisor rator. de guidan in an RCA Rating	<i>Direc</i> tection ugh any to the I ce for t , but le	<i>t</i> 002 expert, but lea y licensed oper eader during a he radiological ader must be a	der must be a rator can ny fire on Unit

-

RNP NRC Written Examination

REFERENCES SUPPLIED:

4.0 **PREREQUISITES**

4.1 Definitions

- 4.1.1 Operations Staff Support (Fire Protection Program) Personnel assigned responsibility for the implementation of the Fire Protection Program.
- 4.1.2 Fire Brigade Those persons designated by the Plant General Manager who comprise the Plant Fire Brigade for each shift of operations. Each shift Fire Brigade is comprised of a Team Leader and at least four qualified brigade members of which at least two must have additional knowledge as described in step 8.6.2.
- 4.1.3 Fire Brigade Member Those persons that have been designated by the Plant General Manager and maintain required security access, current medical qualification, active status by successful completion of required training and participation in drills.
- 4.1.4 Fire Brigade Team Leader <u>Unit 2</u> Normally, the Work Control Center Senior Reactor Operator who is qualified as a Team Leader and is in charge of the Fire Brigade and the emergency scene. Any licensed Operator can serve as Team Leader if qualified. The <u>Unit 1</u> Superintendent Shift Operations/Shift Leader will act as advisor to the Fire Brigade Team Leader concerning a fire on Unit 1.

ОММ-002	Rev. 30	Page 16 of 33

٦

- 3.2 The Fire Protection Auxiliary Operator is responsible to the Superintendent Shift Operations for:
 - 3.2.1 Performing routine fire inspections of Unit 2 to ensure compliance with fire protection procedures.
 - 3.2.2 Conducting and documenting periodic inspections, shift rounds, tests, and preventive minor maintenance of fire protection systems and equipment to ensure proper operational condition.
 - 3.2.3 Being qualified as a Fire Brigade member. During a fire emergency will function as an advisor to the Fire Brigade Team Leader and can function in any capacity on the Fire Brigade as directed by the Team Leader.
 - 3.2.4 Supervising and following-up all valve closures or impairments to any fire protection systems or equipment to ensure adequate back-up protection is provided as required by FP-012 and to prevent extended or unnecessary impairments. Notifying the Superintendent Shift Operations of the above situations.
 - 3.2.5 Functioning as advisor to the Superintendent Shift Operations concerning any fire protection matter.
 - 3.2.6 Preparing Fire Reports in accordance with FP-002.
 - 3.2.7 Complete OMM-001-12 and OMM-007 as applicable.
- 3.3 The on-duty Superintendent Shift Operations is responsible for:
 - 3.3.1 Operation of the fire detection and fire suppression systems in accordance with FP-012 and FP-013 and established procedures.
 - 3.3.2 Ensuring at least five Fire Brigade members are available in accordance with step 8.6.2 and OMM-001.
 - 3.3.3 Providing general direction and support to the Fire Brigade Team Leader in the event of a fire. (If the Emergency Coordinator is activated in accordance with PLP-007 of the Plant Operations Manual, this general guidance and support may be provided by the Emergency Coordinator in lieu of the Superintendent Shift Operations).

OMM-002	Rev. 30	Page 9 of 33

- 3.11.2 Appendix R Safe Shutdown Engineer:
 - 1. Has overall responsibility for the Appendix R Safe Shutdown Program, providing direction to other plant Sections who support and assist in the implementation, maintenance and surveillance of the program.
 - 2. Review procedural or programmatic changes that affect Safe Shutdown.
 - 3. Ensures compliance with regulatory requirements concerning safe shutdown.
 - 4. Provides design and engineering functions for safe shutdown systems.
 - 5. Reviews plant modifications for impact on the Appendix R Program.
 - 6. Prepare and maintain procedures and instructions which the Appendix R Engineer sponsors.
- 3.12 Environmental & Radiation Control (E&RC) is responsible for:
 - 3.12.1 Providing a minimum of one fire brigade member per shift as needed to support the minimum Fire Brigade compliment.
 - 3.12.2 Periodic monitoring of the breathing air quality.
 - 3.12.3 Distribution of dosimetry to arriving off-site fire fighting personnel.
- 3.13 Maintenance is responsible for:
 - 3.13.1 Maintenance of fire protection equipment and systems.
 - 3.13.2 Installing and maintaining the fire barrier penetration seals, fire barrier materials, fire wraps and insulating materials.
 - 3.13.3 Providing a minimum of one fire brigade member per shift as needed to support the minimum Fire Brigade compliment.

OMM-002	Rev. 30	Page 14 of 33

OMM-002-03 002

Which ONE (1) of the following personnel would normally serve as the Fire Brigade Team Leader in the event of a fire in Unit 2?

- A. Fire Protection Technical Aide.
- ✓B. Off Control Operator.
 - C. Unit 1 Shift Supervisor.
- D. RC Fire Support.

Question: 34

Given the following conditions:

- The unit is operating at 100% power.
- APP-001-F7, INST AIR HDR LO PRESS, has illuminated.
- AOP-017, "Loss of Instrument Air", is being implemented.
- Instrument air pressure currently reads 79 psig and slowly decreasing.
- The Station Air Compressor is running.

SA to IA cross connect ...

- a. valve, SA-5 will automatically OPEN to pass SA through the IA aftercoolers and separators to remove contaminants prior to passing into the IA header.
- b. bypass filter isolation valves, SA-220 & SA-221, will automatically OPEN to pass SA through a filter to remove contaminants prior to passing into the IA header.
- c. valve, SA-5 will be manually OPENED to pass SA through the IA aftercoolers and separators to remove contaminants prior to passing into the IA header.
- d. bypass filter isolation valves, SA-220 & SA-221, will be manually OPENED to pass SA through a filter to remove contaminants prior to passing into the IA header.

Answer:

d. bypass filter isolation valves, SA-220 & SA-221, will be manually OPENED to pass SA through a filter to remove contaminants prior to passing into the IA header.

								RNP NRC Written Examination Common Question Reference
QUESTION N	IUMBER:	34						
TIER/GROUP	079K1 01		RO	2/2		SRO	2/2	
	Knowledge of	the physical (connectir	one and/	orcau	e-offect rel:	ations	hins between the SAS and
	the following s	systems: IAS	connectio					
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO) RO	3.0 4	55.43	SRO SRO SRO	3.1	
OBJECTIVE:	AIR-14							
	EXPLAIN the	effect on the	Instrume	nt and S	tation	Air System o	due to	selected failures.
REFERENCE	S:	AOP-017						
SOURCE:	New	Signific	antiy Mo	odified	X	ID 03	Direc	ct
JUSTIFICAT	ION:		Бапк	Number	r A	IK-03		007
a.		Plausible be manually.	cause S/	A-5 is op	ened i	າ AOP-017 ສ	as an	RNO, but it is must be done
b.		Plausible be manually.	cause S/	A-220 & :	221 ar	e opened in	AOP-	-017, but they must be done
С.		Plausible be through the	cause S/ IA afterco	A-5 is op oolers ar	ened i nd sepa	n AOP-017 a arators.	as an	RNO, but it does not go
d.	CORRECT	The preferre allow the Se passing into	ed metho rvice Air oil free I	d is to op to pass nstrume	oen SA throug nt Air H	-220, SA-22 h a filter to r leader.	21 and emov	l verify open IA-18. This will e contaminants prior to
DIFFICULTY	:	-		·		Define	~	
Comprehen	nsive/Analysis		nowledg	e/Recall	X	Rating	3	
	Knowledge o	f IA / SA syste	em auton	natic acti	ions			

REFERENCES SUPPLIED:

Step Description

- 2 Step 2 checks Instrument Air (IA) Header pressure less than 60 psig. Through research it has been determined that major system components required for power operation (i.e. feed reg valves, letdown valves) will start to drift closed. This step is to satisfy an INPO comment that stated "The common industry approach is to direct the operators to manually trip the reactor at a specific decreasing Instrument Air pressure". If pressure does decrease to less than 60 psig, then the operator is directed to trip the reactor in Step 3.
- 3 This step accomplishes two very important action items. First the reactor is manually tripped by the operator. This is in anticipation of loss of control to various air operated valves and their subsequent failing closed (air pressure less than 60 psig). The second action item transitions the operator to concurrently perform PATH-1 while continuing with this procedure.
- 4-5 During normal plant operations Air Compressor D or the Primary Air Compressor should operate to maintain header pressure. Air Compressor D is usually the lead compressor running continuously to maintain system pressure. This step is intended for the operator to start any available compressor that is in standby. It is assumed that Instrument Air Compressors A & B will be running in Auto if power is available.
- 6 This continuous action step checks pressure less than 80 psig. If less than 80 psig the operator is directed to steps that would further increase the supply of air into the IA system.
- N7 This note describes the location of IA-3821 to help expedite the task performed.
- 7 Entering into this step signifies that Instrument Air problems have deteriorated to a point where air pressure is now less than 80 psig. The operator should be prepared for this since he would have received an Instrument Air low pressure alarm at 85 psig. Exiting this step we should find that:
 - (1) Station Air Compressor is backing up the Instrument Air System.
 - (2) Air dryers have been bypassed.
 - (3) Station Air and Instrument Air Compressors are running

The first substep requires the verification that the Station Air Compressor is running. If the compressor can not be started the RNO will bypass steps that cross-connect Station Air with Instrument Air. The second and third substep directs the operator to cross-connect the Station Air Header with the Instrument Air Header. Two methods are available to achieve this step:

(1) The preferred step is addressed in the left column of this procedure (Open SA-220, SA-221 and verify open IA-18). This will allow the Service Air to pass through a filter to remove contaminants prior to passing into oil free Instrument Air Header.

	Dece 4 of 22
l Rev. 28	Page 4 01 22

Rev. 28

Page 5 of 59

		RESPONSE NOT OBTAINED
STEP		
	NOTE	
	IA-3821 is located or	n IA Dryer D.
L		
7	. Dispatch Operator(s) To Perform The Following:	
	a. Verify Station Air Compressor - RUNNING	a. Go To Step 7.c.
	b. Verify the following SA TO IA CROSS CONNECT BYPASS FILTER ISOLATION Valves - OPEN:	b. Open SA-5, STATION AIR TO INST AIR CROSS CONNECT.
	• SA-220	
	• SA-221	
	<pre>c. Verify IA-18, AIR DRYER "A" & "B" BYPASS - OPEN</pre>	
	d. Verify the following Compressors - RUNNING	
	• STATION AIR COMP	
	• INST AIR COMP A	
	• INST AIR COMP B	
	e. Check FCV-1740, AIR DRYER HIGH DP FLOW CONTROL Valve - OPEN	e. Open IA-3665, AIR DRYER "A" & "B" BYPASS.
	f. Open IA-3821, INSTRUMENT AIR DRYER "D" BYPASS	

AIR-03 007

Given the following plant conditions:

- The Unit is at 100% power
- APP-001-F7, INST AIR HDR LO PRESS, has illuminated
- AOP-017, LOSS OF INSTRUMENT AIR, is in use
- · Instrument air pressure currently reads 79 psig and slowly decreasing

Which ONE (1) of the following describes the correct response to the decreasing air pressure?

SA to IA cross connect:

- A. valve, SA-5 will automatically OPEN to pass SA through the IA aftercoolers and separators to remove contaminants prior to passing into oil free IA header.
- B. bypass filter isolation valves, SA-220 & SA-221, will automatically OPEN to pass SA through a filter to remove contaminants prior to passing into oil free IA header.
- C. valve, SA-5 will be manually OPENED to pass SA through the IA aftercoolers and separators to remove contaminants prior to passing into oil free IA header.
- ✓D. bypass filter isolation valves, SA-220 & SA-221, will be manually OPENED to pass SA through a filter to remove contaminants prior to passing into oil free IA header.

11.1
Given the following conditions:

- The unit was operating at 100% with bank D rods at 218 steps when a failure of 'B' inverter occurred.
- Instrument bus 3 de-energized.
- NO reactor trip occurred.
- Rods **CANNOT** be withdrawn.

Which ONE (1) of the following is preventing rod motion?

- a. Power range flux rod stop
- b. Intermediate range flux rod stop
- c. Overtemperature ΔT rod stop
- d. Overpower ΔT rod stop

Answer:

a. Power range flux rod stop

							(Common Question Rei	ference
QUESTION N TIER/GROUP K/A:	UMBER: : 057AA2.20	35	RO	1/1		SRO	1/1		
	Ability to deter Bus: Interlocks restore norma	mine and inter s in effect on lo l equipment op	pret the oss of ac peration	following vital ele	g as the ctrical i	ey apply to nstrument	the Los bus tha	s of Vital AC Instrume It must be bypassed to	nt
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.6 7	55.43(i	SRO b) SRO	3.9		
OBJECTIVE:	NI-06								
	LIST power su the EDPs.	pplies for the	major co	mponen	ts of th	e Nuclear I	Instrum	entation System as list	ed in
REFERENCE	S:	AOP-024							
SOURCE:	New	Significa	ntly Mo	dified			Direct	X	
			Bank N	Number	NI-	09		009	
a.	CORRECT	Loss of powe	r to PR c	hannel :	3 cause	es 1/4 overp	power r	od stop actuation.	
b.		Plausible sind powered by II	ce IR cha 3 3.	annels ca	an prev	ent rod witł	hdrawal	l, but IR channels not	
с.		Plausible sind loss and coin	ce OT ∆T cidence [†]	⁻ can pre is 2/4.	event ro	od withdraw	vai, but	does not actuate on po	ower
d.		Plausible sind loss and coin	ce OP ∆1 cidence	Г can pre is 2/4.	event ro	od withdraw	val, but	does not actuate on po	ower
DIFFICULTY Comprehen	: sive/Analysis	X Kn	owledge	/Recall		Rating	3		
	Comprehensi	on of the effec	t of the l	oss of a	single i	nstrument	bus on	rod control	

RNP NRC Written Examination

Rev. 14

CONTINUOUS USE ATTACHMENT 4

EXTENDED LOSS OF INSTRUMENT BUS 3 (AND 8)

(Page 2 of 3)

- 4. Restore Rod Control as follows:
 - a. At the Miscellaneous Control And Indication Panel, place ROD STOP BYPASS Selector Switch (for PR 41 & PR 43) to BYPASS PR 43 position.
 - b. Position the Control Rods as necessary to control Axial Offset and RCS temperature.
- 5. IF CHARGING PUMP C is in service, THEN perform the following:
 - a. Start CHARGING PUMP A OR B.
 - b. Stop CHARGING PUMP C.
- 6. Place The Control Switch For R-11/R-12 Vacuum Pump To STOP.

<u>NOTE</u>

Lost instrumentation/control is described in EDP-008, Instrument Busses.

- 7. Select and monitor alternate instrumentation.
- 8. Notify Maintenance to determine and correct the cause of Instrument Bus failure.
- * 9. <u>IF</u> power can <u>NOT</u> be restored to Instrument Bus 3 within 2 HOURS <u>THEN</u> place the Plant in Mode 3 within the following 6 HOURS <u>AND</u> Mode 5 within the following 36 HOURS.
- 10. IF APP-005-B5, ROD BANKS A/B/C/D LO LIMIT, is ILLUMINATED, THEN Borate to clear the alarm using OP-301, Chemical and Volume Control System (CVCS), while continuing with this procedure.
- 11. Maintain stable plant conditions until Instrument Bus 3 (and 8) power is restored.
- 12. <u>WHEN</u> power is restored to Instrument Bus 3 (and 8), <u>THEN</u> observe the <u>NOTE</u> prior to Step 13 and Go To Step 13.

Given the following conditions:

- Power has been lost to Containment Pressure channel 954.
- Containment Pressure transmitter PT-950 has failed low.
- NO actions in OWP-032, "Containment Pressure," have been performed.
- A large break LOCA occurs and actual Containment Pressure reaches 21 psig.



Which ONE (1) of the following describes the response of the Containment Spray system?

- a. NEITHER train of Containment Spray will automatically actuate
- b. ONLY Train 'A' of Containment Spray will automatically actuate
- c. **ONLY** Train 'B' of Containment Spray will automatically actuate
- d. BOTH trains of Containment Spray will automatically actuate

Answer:

a. NEITHER train of Containment Spray will automatically actuate

								Common	Question R	leference
QUESTION N TIER/GROUP K/A:	NUMBER: P: 026A1.01	41	RO	2/2		SRO	2/2			
	Ability to prec associated w	lict and/or mor ith operating th	iitor cha ie CSS	inges in controls	paramete including	ers (to pre : Contair	event ex nment pr	ceeding de essure	esign limits)
K/A IMPORT 10CFR55 CC	ANCE: ONTENT:	55.41(b)	RO RO	3.9 8	55.43(l	SRO b) SRO	4.2			
OBJECTIVE	: CSS-09									
	EXPLAIN the interlocks, an	normal operat nunciators, an	tion of th d set po	ne CSS o bints.	control sy	stems. I	nclude f	unction, in	strumentat	ion,
REFERENCE	ES:	SD-024								
SOURCE:	New	X Significa	antly M	odified			Direct			
			Bank	Numbe	r			NEW		
JUSTIFICAT a.	CORRECT	Two-of-three required to g actuate so or	high pre enerate hly one s	essure c a Conta set will g	conditions inment S ienerate t	on both pray sigr he requir	sets of p nal. Bist red signa	oressure tr ables are e al.	ansmitters energized t	are 0
b.		Plausible sine transmitters, energized to	ce the n but requ actuate	ninimum uire both so only	coincide sets trip one set v	nce is me ped to ge vill gener	et for a s enerate a rate the r	ingle train a signal. B equired si	of pressure Bistables are gnal.	e e
C.		Plausible sine transmitters, energized to	ce the n but req actuate	ninimum uire both so only	coincide sets trip one set v	nce is me ped to ge vill gener	et for a s enerate a rate the r	ingle train a signal. E required si	of pressure Bistables are gnal.	e e
d.		Plausible sin transmitters, energized to	ce the n but requ actuate	ninimum uire both so only	coincide sets trip one set v	nce is me ped to ge will gener	et for a s enerate a rate the i	ingle train a signal. E required si	of pressure Bistables ar gnal.	e e
DIFFICULTY Compreher	': nsive/Analysis	s 🗶 Kn	owledg	e/Recal	/ 🔲 R	ating	3			
	Analysis of fa	ailures on Cont	ainmen	t Spray a	actuation	signal				

RNP NRC Written Examination

4.2.2 Spray Header Flow "A", FT-958A and "B", FT-958B

The purpose of these flow transmitters is to provide Spray Header "A" and "B" flow indication. They are located on the RTGB and have a range of 0-1500 gpm.

4.3 CV Pressure

NOTE: The CV pressure transmitters are not part of the Spray system but are listed for information. (See SD-006, Engineered Safety Features)

There are nine (9) transmitters located in the Aux. Bldg. near the IVSW tank area. Three are used for the (2 out of 3) HI pressure SI signal at 4 psig (PC-951B, 953B, & 955B). Six supply the HI-HI pressure signal actuation at 20 psig (PC-950, 951A, 952, 953A, 954 & 955A). (CSS-Figure-3) (NOTE: 2 groups with 3 transmitter each, 2/3 transmitters from 2/2 groups generates the HI-HI signal.)

There is one narrow range pressure transmitter that is used for RTGB indication and alarm, PI-950B. There are two Wide Range Accident channels that are used for indication, PI-956 & 957 and are located on the Core Cooling Monitor Panels.

4.4 Local Instrumentation

There are local pressure indicators on the discharge of Spray Pumps "A" and "B". There is also a local Spray Pump test line flow indicator.

- 4.5 Alarms
 - APP-002-D1 SPRAY ACTUATION and APP-002-D2 CV ISOL PHASE B, Both will alarm at 20 psig from PC-950, PC-951A, PC-952, PC-953A, PC-954, PC-955A. These alarms come in if 2/3 Hi-Hi Containment Pressure Bistable on both channels or if manual initiation has been actuated by depressing 2 pushbuttons simultaneously.
 - APP-002-E1 CV SPY PMP COOL WTR LO FLOW, Alarms at 30 gpm from FIC-657. This alarm is caused by loss of component cooling to the pump (s).
 - APP-002-F1 CV SPY PMP MOTOR OVLD, Alarms when the 19A-74 relay is energized (Spray pump A) or when the 25C-74 relay is energized (Spray pump B). This alarm is caused by an overload on Spray Pump Motor.
 - APP-002-F2 SPRAY ADD TANK LO LEVEL, Alarm at 36% from LC-949. ITS limit is 35.5% (2505 gallons). The tank should be filled to normal level.

Page 13 of 23

Revision 4

INFORMATION USE ONLY

CSS

5.0 CONTROLS AND PROTECTION

- 5.1 Containment Spray Actuation
- 5.1.1 Automatic

Containment Spray Actuation will automatically occur when a Containment Hi-Hi Pressure signal is sensed at 20 psig. This will cause the following:

NOTE: In the year 2000, it is planned to reduce this setpoint to 10 psig to allow the Service Water temperature to be increased without challenging CV pressure. (ESR 99-00153).

- 1) Steam Line Isolation actuation (closes all three MSIVs)
- 2) Spray actuation
- 3) Safety Injection actuation
- NOTE: Containment pressure bistables for spray actuation are energize-to-actuate. This differs from other ESF actuations. The purpose is to minimize the possibility for an inadvertent spray signal due to power interruption.
- Phase "B" Containment Isolation, The following valves close: CC-716A & B, RCP Clg Wtr Inlet Isols
 FCV-626, RCP Thermal Barrier Flow Control
 CC-735, RCP Thermal Barrier Outlet Isol
 CC-381, RCP Seal Wtr Rtrn Isol
 CVC-730, RCP Oil Coolers Outlet Isol
- 5.1.2 Manual

Containment Spray Actuation can be manually actuated when both Spray pushbuttons are simultaneously depressed. There are Containment Spray Defeat pushbuttons on the RTGB that are not used (abandoned in place). Spray actuation will cause the following:

- 1) Spray actuation
- 2) Containment Phase "B"
- 3) Containment Ventilation Isolation The following valves will close:
 - Purge Valves
 - Pressure Relief Valves
 - Vacuum Relief Valves

CSS

Revision 4

١

Given the following conditions:

- The unit is operating at 100% power.
- Normal letdown is in service.
- Pressurizer level control is in automatic
- Leakage passed the hydrogen pressure regulator to the VCT causes pressure in VCT to increase.

Which ONE (1) of the following describes the effect of this on RCP seal flow?

	No. 1 SEAL LEAKOFF FLOW	No. 2 SEAL LEAKOFF FLOW
a.	Increases	Increases
b.	Decreases	Decreases
C.	Decreases	Increases
d.	Increases	Decreases

Answer:

C.	Decreases	Increases

							(Common Qi	uestion Reference
QUESTION N TIER/GROUP K/A:	IUMBER:): 003A2.05	42	RO	2/1		SRO	2/1		
	Ability to (a) p use procedure RCP seal leal	predict the impa es to correct, c koff flows	acts of ti control, c	he follow or mitigat	ing malfun te the cons	nctions o sequenc	or operat es: Effe	ions on the cts of VCT p	RCPS; and (b) pressure on
K/A IMPORT, 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.5 3	S 55.43(b)	RO SRO	2.8		
OBJECTIVE:	CVCS-14								
	EXPLAIN the	effect on the (CVCS du	ue to sele	ected failu	res.			
REFERENCE	:S:	SD-001 APP-003							
SOURCE:	New	Significa	antly Mo	odified	X		Direct		
			Bank	Number	- CVCS	S-14		010	
JUSTIFICAT a.	ION:	Plausible sind but #1 seal le	ce a cha eakoff flo	inge in V w will de	CT pressu ecrease.	ıre will a	iffect the	RCP seal I	eakoff flows,
b.		Plausible sind but #2 seal le	ce a cha eakoff flo	inge in V w will in	CT pressu crease.	ıre will a	iffect the	RCP seal	eakoff flows,
с.	CORRECT	Raising VCT increasing pr causing #2 s pressure in th	pressur essure l eal flow he VCT.	e causes between to increa	s pressure the #1 and ase. #1 se	against d 2 seals al flow c	the #1 s s and d/p lecrease	seal flow to b across the es slightly di	increase, e #2 seal, ue to more
d.		Plausible sin but #1 seal le	ce a cha eakoff flo	ange in V ow will de	CT pressu ecrease ar	ure will a nd #2 se	affect the al leakot	RCP seal If flow will in	leakoff flows, icrease.
DIFFICULTY Compreher	: nsive/Analysis	X Kn	owledg	e/Recall	Ra	ting	3		
	Comprehens	ion of the relat	ionship	hetween	VCT pres	sure and	d RCP s	eal flows	

RNP NRC Written Examination

through the impeller, discharged through passages in the diffuser, and out through the discharge nozzle in the side of the casing. Above the impeller is the labyrinth seal which contains the thermal barrier heat exchanger. The thermal barrier limits heat transfer between hot system water and seal injection water. The thermal barrier heat exchanger provides sufficient cooling of the pump bearing if seal injection is lost.

The thermal barrier heat exchanger, though functioning as a boundary between RCS and Component Cooling Water (CCW), is only designed for a high differential pressure from O.D. to I.D. (CCW side). The pressure inside the heat exchanger should not exceed 200 psi. If a heat exchanger tube leak were to occur, the CCW isolation valves are designed to withstand full RCS pressure.

3.1.2 Seals (RCS-Figure-6)

Туре	Westinghouse controlled leakage seal
	assembly
Seal water injection	8 gpm
Seal water return	3 gpm

The shaft seal section consists of three devices. They are the No. 1 controlled leakage, film-riding face seal, and the No. 2 and 3 rubbing face seals.

During normal system operation the charging pump(s) provide approximately 8 gpm injection flow to each RCP. The injection enters the pump between the thermal barrier and the pump bearing. The flow is then divided with approximately 5 gpm flowing down past the thermal barrier into the RCS and approximately 3 gpm flowing up past the pump bearing. The outlet from the No. 1 seal discharges to the Volume Control Tank (VCT). The VCT maintains a back pressure of at least 15 psig to ensure a flow through the No. 2 seal. The No. 2 seal discharges approximately 3 gph to the associated RCP standpipe. The standpipe overflows at midplane to the reactor coolant drain tank. The standpipe is located so that it maintains at least a seven-foot head to ensure flow through the No. 3 seal. The No. 3 seal discharges approximately 10cc - 100cc/hr to the containment sump.

When starting a RCP, RCS pressure low limit must be greater than 325 psig. With the pump operating, RCS pressure is allowed to decrease to a minimum of 210 psid on the seals before the pump must be secured. The 210 psid limitation is to ensure the #1 RCP seal has proper separation between surfaces. Additional information may be located in GP-001, "Fill and Vent of the Reactor Coolant System".

During heatup and cooldown, when the system water pressure is 1000 psig or below, leakoff flow may be insufficient to cool the bearing and seal components. When leakoff flow is below 1 gpm, the seal bypass valve should be opened. This permits a limited flow to bypass the No. 1 seal through a nonadjustable orifice block (external to the pump

Rev. 2

INFORMATION USE ONLY

RCS

<u>ALARM</u>

VCT HI/LO PRESS *** WILL REFLASH ***

AUTOMATIC ACTIONS

1. Not Applicable

<u>CAUSE</u>

- 1. Failure of N₂ or H₂ Regulator
- 2. Abnormal high level in VCT
- 3. Failure of CVC-258, VCT VENT

OBSERVATIONS

1. Volume Control Tank Pressure (PI-117)

<u>ACTIONS</u>

NOTE:	Minimum VCT pressure for RCP operation is 15 psig.	

- 1. IF VCT pressure is high, THEN open CVC-258, VCT VENT.
- 2. IF VCT pressure is low, THEN verify closed CVC-258, VCT VENT.
- 3. Verify proper operation of N_2 and H_2 regulators.

DEVICE/SETPOINTS

- 1. PC-117 / 65 psig
- 2. PC-117 / 15 psig

POSSIBLE PLANT EFFECTS

- 1. Decreased number 1 seal leakoff (high)
- 2. Decreased number 2 seal leakoff (low)

REFERENCES

1. CWD B-190628, Sheet 473, Cables H, J

APP-003	Rev. 29	Page 40 of 52

CVCS-14 010

Given the following plant conditions:

- The unit is at 100% power
- One charging pump with 45 gpm of letdown is in service
- VCT level is at 20 inches
- All make-up controls are in their normal configuration
- An Automatic makeup is in progress, 70 gpm primary water and 3 gpm boric acid
- LT-115 fails HIGH

Which ONE (1) of the following explain the effect of this failure on VCT level with no operator action?

- A. VCT level will continue to cycle between 20.2"- 24.5" due to make-up system operation
- B. VCT level will continue to increase at a slow rate to 24.5" and stabilize
- ✓C. VCT level will decrease to 0" due to lack of make-up capability
 - D. VCT level will decrease to 0, make-up continues

Given the following conditions:

- A reactor trip occurred from 20% power as a result of a low-low level in 'A' SG.
- Coincident with the reactor trip, 480V Bus E-1 deenergized and was subsequently energized by the EDG.
- Twenty (20) seconds following the trip, SG levels are:

SG	LEVEL
'A'	12%
'B'	28%
'C'	26%

Which ONE (1) of the following describes the expected condition of the Auxiliary Feed Water pumps 20 seconds following the trip?

	MDAFW PUMP 'A'	MDAFW PUMP 'B'	SDAFW PUMP
a.	Running	Running	Off
b.	Off	Running	Running
C.	Off	Running	Off
d.	Off	Off	Running

Answer:

C.	Off	Running	Off

QUESTION NUMBER: TIER/GROUP: K/A: 013A4.03	43	RO	2/1		SRO	2/1	
Ability to man	ually operate ar	nd/or mo	onitor in	the conti	rol room: I	ESFAS initiation	
K/A IMPORTANCE: 10CFR55 CONTENT:	F 55.41(b)	RO RO	4.5 4	55.43(b	SRO) SRO	4.7	
OBJECTIVE: AFW-10							J.
EXPLAIN the	operation of the	e AFW S	System.				
						·	
REFERENCES:	SD-042 APP-004						
SOURCE: New	X Significal	ntly Mo	dified			Direct	
ULCTIFICATION:		Bank I	Number			NEW	
a.	Plausible since the bus, but th	e this wo ne auto s	ould be start on l	the expe low-low l	cted cond evel is blo	ition if the EDG were not c cked for 'A' pump.	arrying
b.	Plausible sinc SDAFW pump	e this is o require	the exp es 2/3 lo	ected co w-low lev	ndition of /els or a lo	the MDAFW pumps, but th oss of both E-1 and E-2 to	ie start.
c. CORRECT	Both MDAFW	' pumps	would n	ormally s	start on lo	w-low level, but the 'A' pur	np low-
	SDAFW pump	o require	ed and es 2/3 lo	w-low lev	vels to sta	rt.	, me
d.	Plausible sinc but only the at	e the EI	DG carŋ MDAFW	ying the t / pump.	ous blocks	s the auto start on low-low	level,
DIFFICULTY:							
Comprehensive/Analysis	X Kno	owledge	e/Recall		ating	3	

Analysis of effect of loss of power on automatic operation of AFW pumps

The auxiliary oil pump runs constantly to insure adequate lubrication to the turbopump.

A knurled knob on the speed governor can be used to control the speed of the turbine at a setpoint less than full speed. For normal automatic operation, the knob is set at the highest point so the turbine will operate at the maximum set speed during emergency conditions.

The SDAFW Pump may be manually tripped by pushing the "RED" trip button (AFW Figure 8). Reset the trip by pushing in the trip lever elbow.

The SDAFW pump will trip on overspeed and also trips on low discharge pressure to protect the pump from a loss of suction supply.

- 650 psig setpoint, 2/2 coincidence
- Shuts steam inlet valves (V1-8A, B and C)
- Note overspeed trip shuts V1-8A, B C due to 650 psig discharge pressure

The signals that will automatically start this pump are covered in Section 6.1 below.

6.0 SYSTEM OPERATION

6.1 Normal Operation

During normal plant operation the AFW system is not in service, except to augment startup, shutdown and cooldown. The Main Feedwater System is used whenever possible. The system must be operable under normal operations and periodic testing is performed to assure its operability.

This system will start automatically as follows: (See AFW Figure 11, AFW Pump Auto-start Logic).

If 2 of the 3 level detectors on any one of the S/Gs indicate low-low level, both MDAFW pumps will start. AMSAC will also cause an automatic start of the MDAFW Pumps. If the breakers of both main FW pumps open the MDAFW pumps will start. Blackout and safeguard conditions (SI) signal the MDAFW pumps to start on a timed sequence. The three motor operated discharge valves (AFW-V2-16A, 16B and 16C) will automatically open. The SGBD isolation valves (FCV-1930A and B, FCV-1931A and B, and FCV-1932A and B) will automatically close when either one of the MDAFW pumps discharge (V2-20A and B) can be used to have one pump feed two of the S/Gs in case of a break in the discharge line of the other pump, and these valves should normally be open.

The automatic AFW pump starts on S/G low-low level, AMSAC and both main FW pump breakers open can be blocked by key switch operations. The key switches are in the back of the RTGB.

Both the low-low S/G, AMSAC and main FW pump breakers automatic starts are blocked when the respective emergency buss is de-energized (loss of power) or when the respective EDG output breaker is shut. In this situation the MDAFW pumps will be started by the safeguards and blackout sequence logic.

The SDAFW pump will automatically start if 2 of 3 level detectors on 2 of 3 S/Gs indicate low-low level. The SDAFW pump will also start from an under voltage on 4160V busses 1 and 4. AMSAC will cause the SDAFW pump to automatically start. A signal to start the SDAFW pump will open the three motor operated steam supply valves (MS-V1-8A, 8B and 8C), open the three motor operated discharge valves (AFW-V2-14A, 14B and 14C) and close the SGBD isolation valves (FCV-1930A and B, FCV-1931A and B, and FCV-1932A and B). The MOVs have individual control switches on the RTGB, so the operator may selectively feed any combination of S/Gs.

During normal plant operation, periodic testing will be performed to assure the AFW pumps ability to function when required. In addition, if for any reason the AFW Pumps are desired, they can be started and operated in the Manual Mode. The proper sequence to follow when securing an MDAFW Pump is, first, stop the pump, allow it to stop rotating, then close the motor operated discharge valves (V2-16A, V2-16B, V2-16C). This sequence will allow proper seating of the check valves and allow the discharge valves to fully seat which prevents back leakage through all these valves.

A possible consequence of check valve or discharge valve backleakage is steam binding of the AFW Pumps. Steam binding of the MDAFW Pumps may be indicated by warm discharge piping between the discharge check valve(s) and the V2-16(s). Steam binding of the SDAFW Pump may be indicated by a warm pump casing. If steam binding of any of the AFW Pumps is suspected, refer to the Infrequent Operation in OP-402.

The CST should be kept full. If the CST level decreases to 10% during AFW operation, a backup water supply should be placed in service. Service Water should be used as first backup supply to AFW Pumps. If Service Water is not available, Deepwell Water should be used as backup to AFW Pumps. Both isolation valves on the Service Water (SW-118 and AFW-24) and the deep well water backup (DW-19 and DW-21) will normally be locked closed with the telltale drain valves (AFW-24A and DW-20) open to prevent the plant condensate from being contaminated with untreated water. If the backup water supplies are required, the appropriate drain valves will be closed and the associated block valves opened. The flowrates from backup water could be limited IAW OP-402, see Attachment 10.2, "Backup Water Flow Limits".

INFORMATION USE ONLY

AFW PUMP AUTO-START LOGIC AFW-FIGURE-11 (REV. 1)



ALARM

S/G A LO-LO LVL TRIP

AUTOMATIC ACTIONS

- 1. Reactor Trip
- 2. Motor-Driven AFW Pumps start
- 3. Blowdown Isolation Valves close

CAUSE

- 1. Any sustained feedwater/steamflow mismatch.
- 2. S/G Shrink caused by sudden reduction in steam demand

OBSERVATIONS

- 1. Reactor trip breaker position
- 2. S/G "A" Level (LI-474, LI-475, LI-476)

ACTIONS

- 1. IF the Reactor has tripped, THEN refer to the EOP Network.
- 2. IF the Reactor is **NOT** tripped **AND** a plant transient is in progress, **THEN** trip the Reactor **AND** refer to the EOP Network.
- 3. IF the Reactor is NOT tripped AND the plant is stable, THEN perform the following:
 - 1) Scan the RTGB for confirmation that a trip is **NOT** required.
 - 2) Inform the CRSS OR SSO of plant conditions to assist in diagnosis.
 - 3) **IF** no supporting indications show a plant trip is required, **THEN** the plant may remain at power for troubleshooting and repairs.

DEVICE/SETPOINTS

1. LC-474A, LC-475A, LC-476A / 16% (2/3 Channels)

REFERENCES

- 1. EOP Network
- 2. 5379-2758, Logic Diagram
- 3. 5379-3440, Block Diagram
- 4. CWD B-190628 SH 440 Cable H

APP-004	Rev. 11	Page 7 of 30

Given the following conditions:

- The plant is operating at 50% power.
- All control systems are operating in automatic.
- The First Stage Pressure Channel Selector switch is aligned to the PT-447 position.
- First Stage Pressure Transmitter PT-446 fails low.

Which ONE (1) of the following plant reponses is expected?

- a. Feedwater Regulating Valves throttle closed
- b. Control Rods step inward
- c. Automatic rod control is blocked
- d. Steam Dumps have a demand signal

Answer:

d. Steam Dumps have a demand signal

						I	RNP NRC Written Examination Common Question Reference
QUESTION N TIER/GROUF	UMBER: 2: 035K4 01	44	RO	2/2	SRO	2/2	
	0001(4.01						
	Knowledge o	f S/GS design	feature	(s) and/or	interlock(s) whic	h provic	te for the S/G level control
K/A IMPORT, 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO) RO	3.6 7	SRO 55.43(b) SRO	3.8	
OBJECTIVE:	SG-08						
	EXPLAIN the System switc	component o hes and contr	peration ols.	associate	ed with each swit	ch posil	tion for the Steam Generator
REFERENCE	:S:	SD-033					
SOURCE:	New	Signific	antly M	odified	X	Direc	t
			Bank	Number	MT-08		003
JUSTIFICAT	ION:					T 440	www.e.elected.butwith DT
а.		Plausible sin 447 selected	there is	vouid be i s no respo	onse in feed wate	r.	/ere selected, but with P1-
b.		Plausible sin 447 selected	ce this v I there is	would be f s no respo	the response if P onse in rod contro	T-446 w bl.	vere selected, but with PT-
с.		Plausible sin 447 selected	ice this v I there is	would be f s no respo	the response if P onse in rod contro	T-446 w bl.	vere selected, but with PT-
d.	CORRECT	The Tref sign a low failure, Dumps rema	nal for s Tavg w ain close	team dum /ould be h ed unless	nps is provided or igher than Tref, c armed.	nly by P creating	T-446 (not selectable). With a steam dump demand.
DIFFICULTY	:						
		—				•	
Comprehen	sive/Analysis		iowledg	e/Recall	X Rating	3	
Comprehen	nsive/Analysis Knowledge o	f instrument a	i ow/edg lignmen	re/Recall t to deterr	X Rating	3 t stage	pressure failure

FIRST STAGE PRESSURE MT-FIGURE-13 (Rev . 0)



MT-08 003

Which ONE (1) of the following choices is supplied by the selector switch from either turbine first stage pressure channel PT-446 or 447?

and seattly the seattly se

- A. Permissive P-7
- B. Turbine load 70% bistables
- C. Steam Dump Control System
- ✓D. Steam Generator Level Control

Given the following conditions:

- Due to low heat loads and extremely cold outside temperatures, Spent Fuel Pool (SFP) water temperature is 65°F.
- CC-775, CC FROM SPENT FUEL PIT HX BUTTERFLY Valve, has been throttled to the maximum allowed closed position.

Which ONE (1) of the following actions should be taken to raise Spent Fuel Pool water temperature?

- a. Place the SFP on recirc to the RWST
- b. Throttle the discharge valve of the in-service SFP Cooling pump
- c. Shutdown the in-service SFP Cooling pump
- d. Start an additional SFP Cooling pump

Answer:

c. Shutdown the in-service SFP Cooling pump

						RNP NRC Written Examination Common Question Reference
QUESTION N	UMBER:	45				
TIER/GROUP K/A:	033K3.03		RO	2/2	SRO	2/2
	Knowledge of have on the fo	the effect that bllowing: Spent	: a loss o t fuel ter	or malfur mperatur	iction of the Spent e	Fuel Pool Cooling System will
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.0 4	SRO 55.43(b) SRO	3.3
OBJECTIVE:	SFP-09					
	EXPLAIN the Include function	normal operat on, instrumenta	ion of th ation, in	ne spent i terlocks,	fuel pit and purifica annunciators, and	tion system control systems. setpoints.
REFERENCE	S:	OP-910				
SOURCE:	New	Significa	antly Mo	odified		Direct X
			Bank	Number	SFP-09	003
JUSTIFICATI a.	ON:	Plausible sinc the SFP HX r	e many esulting	v systems i in a lowe	s heat up on recirc, ering temperature.	but flow would continue through
b.		Plausible sind but this would	ce this w I be offs	vould cre set by the	ate a flow resistand increased heat re	ce and cause the water to heat up, moval from the SFP HX.
с.	CORRECT	The normal m SFP pump m	nethod o ust be s	of control stopped to	is using CC-775, k o stop flow through	out if throttled to max position the the HX.
d.		Plausible sind the increased	ce this w I heat re	vould pro emoval fr	vide additional pun om the SFP HX.	np heat, but this would be offset by
DIFFICULTY: Comprehen	: sive/Analysis	Kno	owledg	e/Recall	X Rating	3
	Knowledge o	f procedural re	quireme	ents to ac	ljust SFP temperat	ure

REFERENCE USE

Section 8.4.3 Page 1 of 1

8.4.3 Adjusting Spent Fuel Pit Temperature (ACR 92-420)

- 1. Initial Conditions
 - a. Spent Fuel Pit Cooling is in operation in accordance with Section 8.1.1 of this procedure.
- 2. Raising SFP Temperature
 - a. Throttle closed CC-775, CC FROM SPENT FUEL PIT HX BUTTERFLY, to raise SFP temperature to between 74 °F and 121 °F.
 - b. **IF** CC-775 has been throttled to the maximum allowable closed position **AND** the SFP Temperature continues to decrease **THEN** Go To Step 8.4.3.4.
- 3. Lowering SFP Temperature
 - a. Throttle open CC-775, CC FROM SPENT FUEL PIT HX BUTTERFLY, to lower SFP temperature to between 74°F and 121°F.
- 4. Controlling SFP Temperature Under Low Heat Load Conditions
 - a. Shutdown the Spent Fuel Pit Cooling Loop by stopping the running SFPC Pump.

OP-910	Rev. 22	Page 34 of 49

Given the following conditions:

- The plant is operating at 68% power.
- Power Range channel N-43 is out of service for repairs.
- N-43 has been removed from service in accordance with the OWP.
- While working on N-43, the technician causes the Control Power fuses to blow.

Which ONE (1) of the following describes the effect of this on the plant?

- a. **NO** effect since the OWP places the DROPPED ROD MODE switch in the "Bypass" position
- b. **NO** effect since the Dropped Rod Runback requires two-of-four (2/4) coincidence to actuate
- c. The turbine will runback for 9 seconds at 200% per minute
- d. The turbine will runback at a cyclic rate of 200% per minute until power is \leq 70%

Answer:

c. The turbine will runback for 9 seconds at 200% per minute

								Common Question Reference
QUESTION N	UMBER:	46	RO	2/1		SRO	2/1	
K/A:	015K6.04							
	Knowledge of and logic circl	the effect of a uits	a loss or	malfunct	tion on t	the followin	ıg will ł	nave on the NIS: Bistables
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.1 7	55.43(SRO (b) SRO	3.2	
OBJECTIVE:	NIS-14							
	EXPLAIN the	effect on the	Nuclear I	nstrume	ntation	System du	e to se	lected failures.
REFERENCE	S:	SD-010						
SOURCE:	New	X Signific	antly Mo	odified			Direc	
JUSTIFICATI	ON:		Bank	Number	-			NEW
а.		Plausible sin maintain the	ce the sv bypass c	witch is p condition	blaced in 1.	n bypass, b	out con	trol power is required to
Ь.		Plausible sin dropped rod	ce all oth runback	ner PR N / rod sto	IIS actu op is 1/4	ations requ	iire a 2	/4 coincidence, but the
с.	CORRECT	Even though bypass cond signal is rese	the swite lition. Th et.	ch is in b ie runbai	oypass, ck lasts	control pov for 9 secol	wer is i nds an	required to maintain the d will not recur until the
d.		Plausible sin seconds. Th	ce a runl ne cyclic	back will runback	occur, is caus	but the run ed by OT a	back v and OF	vill be continuous for 9 ⁰ ∆T signals.
DIFFICULTY Comprehen	: sive/Analysis	X Kn	owledge	e/Recall		Rating	4	
	Analysis of et	fect of failure	on rod di	rop runb	ack circ	uitry		

RNP NRC Written Examination

NIS RUNBACK LOGIC NI-FIGURE-28 (Rev. 0)



NIS PROTECTION REPRESENTATION NI-FIGURE-29 (Rev. 0)



runback relay reenergizes and stops the runback.

Question 3A:

With runback RESET, what will happen if the control power fuses are removed?

A runback will be initiated.

Question 3B:

Why does a runback occur when the control power fuses are removed?

The removal of the control power fuses causes the channel output transformers to deenergize which will initiate a runback.

Question 3C:

What will happen if the control power fuses are reinstalled within seconds?

The runback will stop.

Question 3D:

Why does the runback stop when the control power fuses are reinstalled?

The runback stops because the channel output transformers are reenergized when the fuse is installed.

Question 4A:

With NIS channel in **ROD DROP BYPASS**, what will happen if the control power fuses are pulled?

A runback will be initiated.

Question 4B:

Why does a runback occur if the control power fuses are pulled when the NIS channel is in rod drop bypass?

The removal of the control power fuses causes the channel output transformers to

NIS

Page 42 of 53

Revision 3

INFORMATION USE ONLY

deenergize which will initiate a runback and the runback will not be blocked because the removal of the control power fuses will cause the runback block relay to deenergize and the runback block will be removed.

Question 4C:

What will happen if the control power fuses are reinstalled within a few seconds while the runback is in progress?

The channel output transformers will reenergize and the runback will stop. Ouestion 4D:

Why does the runback stop when the control power fuses are reinstalled?

The runback stops because the channel output transformers are reenergized and the runback relay reenergizes and stops the runback.

Question 5A:

With a NIS channel in Rod Drop Bypass, what will happen if the instrument power fuses are removed?

The channel rod drop bistable will deenergize but no runback will occur.

Question 5B:

Why doesn't a Runback occur?

The channel rod drop bistable will deenergize and this should cause a runback to occur; however, with the Rod Drop Bypass switch in the BYPASS position, the runback will be blocked and will not occur.

Question 5C:

What will happen if the instrument power fuses are reinstalled within seconds?

The rod drop bistable will automatically reset and return to the energized state.

Question 5D:

Why does the rod drop bistable automatically reset when the fuses are reinstalled?

With the rod drop bypass switch in the bypass position, the bistable will reset

NIS

Page 43 of 53

Revision 3

INFORMATION USE ONLY

Given the following conditions:

- A LOCA has occurred inside containment.
- Due to electrical problems an entry was made to EPP-15, "Loss of Emergency Coolant Recirculation."
- One (1) Containment Spray pump was operating upon exiting EPP-15, with containment pressure at 16 psig.
- Subsequently, an entry was made to FRP-J.1, "Response to High Containment Pressure," due to containment pressure being at 14 psig and lowering slowly.

Which ONE (1) of the following describes the actions that are to be taken regarding the Containment Spray system?

- a. Return to EPP-15 to determine Containment Spray system requirements
- b. Stop the running Containment Spray pump
- c. Maintain the current Containment Spray system configuration
- d. Start the second Containment Spray pump

Answer:

c. Maintain the current Containment Spray system configuration

								Common Question Reference
QUESTION N TIER/GROUF K/A:	IUMBER: P: WE14EK1.2	47	RO	1/1		SRO	1/1	
	Knowledge of Containment I (High Contain	the operationa Pressure) Norr ment Pressure	al implic nal, abr e).	ations of normal a	f the follo nd emer	owing con gency ope	cepts a erating	s they apply to the (High procedures associated with
K/A IMPORT. 10CFR55 CO	ANCE: NTENT:	55. 41 (b)	RO RO	3.2 10	55.43(SRO b) SRO	3.7	
OBJECTIVE:	FRP-J.1-08							
	Given plant co related to high	onditions EVAL a containment	UATE [·] pressur	the appro	opriate a ected in l	actions to FRP-J.1.	mitigate	e consequences of steps
REFERENCE	S:	FRP-J.1						
SOURCE:	New	X Significa	ntly M	odified			Direc	t 🔲
SOURCE:	New	X Significa	ntly Mo Bank	odified Numbel	口 r		Direc	
SOURCE: JUSTIFICAT <i>a.</i>	New	X Significat Plausible sind but no conditi	Bank Bank ce EPP- ons me	odified Number -15 has p erit re-ent	r priority o try into E	ver FRP-、 EPP-15.	Direc	t NEW containment spray operation,
SOURCE: JUSTIFICAT a. b.	New	X Significat Plausible sind but no conditi Plausible sind maintained in	Bank Bank ce EPP- ons me ce conta operat	odified Number 15 has p erit re-ent ainment p ion until p	r priority o try into E pressure	ver FRP- EPP-15. e is lowerii e is < 10 p	Direc J.1 for c ng, but ssig.	NEW NEW containment spray operation,
SOURCE: JUSTIFICAT a. b. c.	New	X Signification Plausible sind but no condition Plausible sind maintained in Upon entry to change shou	<i>Bank</i> Bank ce EPP- ons me ce conta operat o FRP-J ld be m	odified Number -15 has p -15 has p -16 has p -17 has p -18 has p -18 has p -19 has p -	r priority of try into E pressure ntainmer he config	over FRP- EPP-15. e is lowerin e is < 10 p nt spray is guration.	Direc J.1 for c ng, but sig. being c	NEW containment spray operation, containment spray is
SOURCE: JUSTIFICAT a. b. c. d.	New	X Signification Plausible sind but no condition Plausible sind maintained in Upon entry to change shou Plausible sind over FRP-J.1	<i>Bank</i> Bank ce EPP- ons me ce conta operat o FRP-J ld be m ce conta for cor	odified Number 15 has p rit re-ent ainment p ion until 1.1, if con ade to th ainment p	r priority of try into E pressure ntainmer he config pressure t spray	ver FRP- EPP-15. e is lowerin e is < 10 p nt spray is guration. e is still ab operation.	Direc J.1 for c ng, but being c bove 10	nt Image: Second and the second and
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	New ION: CORRECT	Signification Plausible sind but no condition Plausible sind maintained in Upon entry to change shou Plausible sind over FRP-J.1	<i>Bank</i> Bank ce EPP- ons me ce conta operat o FRP-J ld be m ce conta for cor	odified Number 15 has p erit re-ent ainment p ion until p 1.1, if con ade to th ainment p ntainmen	r priority of try into E pressure ntainmer ne config pressure t spray	ver FRP- EPP-15. e is lowerin e is < 10 p nt spray is guration. e is still ab operation. Rating	Direc J.1 for c ng, but being c bove 10	nEW NEW containment spray operation, containment spray is operated per EPP-15, no psig, but EPP-15 has priority

4

RNP NRC Written Examination

FRP-J.1

RESPONSE TO HIGH CONTAINMENT PRESSURE

~a -

Rev. 7

Page 4 of 6

	STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED	
	1.	Check CONTAINMENT ISOLATION PHASE A Valves - CLOSED	 Perform the following: a. Momentarily depress either of the CONTAINMENT ISOLATION Pushbuttons. b. IF any CONTAINMENT ISOLATION PHASE A Valve fails to close, THEN locally isolate the affected penetration. 	
	2.	Check CONTAINMENT VENTILATION ISOLATION Valves - CLOSED	 Perform the following: a. Momentarily depress either of the CONTAINMENT ISOLATION Pushbuttons. b. IF any CONTAINMENT VENTILATION ISOLATION Valve fails to close, THEN locally isolate the affected penetration. 	
	3.	Check CV Pressure - HAS INCREASED TO GREATER THAN 10 PSIG	Return to procedure and step in effect.	
	4.	Determine Availability Of CV Spray As Follows:		
		 a. Check CV Spray - BEING CONTROLLED BY EPP-15, LOSS OF EMERGENCY COOLANT RECIRCULATION b. Go To Step 6 	a. Go To Step 5.	
1				

Rev. 7

Page 5 of 6

	CUED	TNSTRICTIONS	RESPONSE NOT OBTAINED	
l	SIEP			
	5.	Establish CV Spray As Follows:		
		a. Verify OPEN CV Spray Pump Inlet Valves:		
		• SI-844A		
		• SI-844B		
		b. Verify both CV Spray Pumps - RUNNING		
		c. Verify OPEN the following Containment Spray Valves:		
		• SI-845A, SAT DISCH		
		• SI-845B, SAT DISCH		
		• SI-880A, PUMP A DISCH		
		• SI-880B, PUMP A DISCH		
		• SI-880C, PUMP B DISCH		
		• SI-880D, PUMP B DISCH		
		d. Check Spray Additive Tank flow - APPROXIMATELY 12 GPM	d. Adjust SI-845C, SAT THROTTLING to obtain approximately 12 gpm Spray Additive Tank flow.	
	6.	Verify CONTAINMENT ISOLATION PHASE B Valves - CLOSED		
	7.	Verify All RCPs - STOPPED		
	8.	Verify CV AIR RECIRC COOLERs - RUNNING		
		• HVH-1		
		• HVH-2		
		• HVH-3		
		• HVH-4		

Given the following conditions:

- A recovery from a small break LOCA is in progress.
- NO RCPs are running.
- EPP-008, "Post-LOCA Cooldown and Depressurization," is being implemented.
- Depressurization of the RCS has commenced.
- Pressurizer level has just risen rapidly from off-scale low to 50%.

The depressurization of the RCS has ...

- a. increased RHR and SI flow, which is rapidly refilling the pressurizer.
- b. caused voiding to occur in the reactor vessel head, which is rapidly refilling the pressurizer.
- c. increased pressurizer spray flow, which is rapidly refilling the pressurizer.
- d. caused voiding in the pressurizer level reference leg, which is providing an indication of rapidly increasing pressurizer level.

Answer:

b. caused voiding to occur in the reactor vessel head, which is rapidly refilling the pressurizer.
							RNP NRC Written Examination Common Question Reference
QUESTION N TIER/GROUP K/A:	UMBER: : WE03EA1.2	48	RO	1/2	SI	RO 1/2	
	Ability to oper Depressurizat	ate and / or m tion) Operating	onitor the g behavio	e followi or chara	ng as they a cteristics of t	pply to the (the facility.	LOCA Cooldown and
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.7 5	SR 55.43(b) Si	O 3.9 RO	
OBJECTIVE:	EPP-008-03						
	DEMONSTRA the basis of e	ATE an unders ach.	tanding	of selec	ted steps, ca	autions, and	notes in EPP-8 by explaining
REFERENCE	S:	EPP-008					
SOURCE:	New	Significa	antly Mo	dified		Dire	ct X
			Bank l	Numbei	EPP-00	8-03	014
а.	UN.	Plausible sind decreases an due to voiding	ce flow fr id increa g in the h	rom cen sed EC nead.	trifugal ECCs CS flow will f	S pumps inc ill the PZR,	creases as RCS pressure but level increases rapidly
b.	CORRECT	The upper he running. This	ad regio may res	n may v sult in a i	oid during R rapidly increa	CS depress asing PZR I	surization if RCPs are not evel.
с.		Plausible sind more water in voiding in the	ce increa ito the P. head.	ised spr ZR via t	ay would cau he spray line	use RCS de e, but level i	pressurization and inject ncreases rapidly due to the
d.		Plausible sind but level incre	ce voidin eases ra	g in the pidly du	reference le e to voiding i	g would inc in the head.	rease PZR level indication,

DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3

Comprehension of the effects of a natural circulation cooldown on RCS head voiding

REFERENCES SUPPLIED:

Rev. 11

Page 13 of 29

.

		
STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
18.	Determine PZR Heater Status:	
	a. Check RCS Leak Location - KNOWN TO BE PZR	a. Go To Step 19.
	b. Place all PZR Heaters in OFF	
	c. Observe the <u>CAUTION</u> prior to Step 21 and Go To Step 21.	
*19.	Check PZR Level - GREATER THAN	Place all PZR Heaters in OFF.
	71% [60%]	<u>IF</u> PZR level increases above 71% [60%], <u>THEN</u> energize PZR heaters to maintain steam bubble.
		Observe <u>CAUTION</u> prior to Step 21 and Go To Step 21.
20.	Energize PZR Heaters To Maintain Steam Bubble	
****	**************************************	**************************************
The	upper head region may void during H ing. This may result in a rapidly	RCS depressurization if RCPs are not increasing PZR level.
* * * *	*****	*******
*21.	Depressurize RCS To Refill PZR As Follows:	
	a. Check PZR level - LESS THAN 24% [45%]	a. Go To Step 22.
	b. Use normal PZR Spray to	b. Use one PZR PORV.
	depressurize the RCS	<u>IF</u> no PZR PORV is available, <u>THEN</u> use Auxiliary Spray.
	c. Check PZR level - GREATER THAN 24% [45%]	c. <u>WHEN</u> PZR level greater than 24% [45%], <u>THEN</u> stop RCS depressurization.
		Go To Step 22.
	d. Stop RCS depressurization	

Question: 49

Given the following conditions:

- The unit is operating at 100% power.
- Rod Control is in Manual.
- A safety valve fails open on SG 'B'.

Which ONE (1) of the following describes the effect on indicated power and RCS Tavg?

÷

	INDICATED NIS POWER	RCS T-AVG
a.	Increases	Remains Relatively Constant
b.	Increases	Decreases
C.	Remains Relatively Constant	Remains Relatively Constant
d.	Remains Relatively Constant	Decreases

Answer:

b.	Increases	Decreases

QUESTION N TIER/GROUF K/A:	IUMBER: 2: 039K5.08	49	RO	2/2		SRO	2/2
	Knowledge of Effect of stea	f the operationa m removal on r	al implica eactivity	ations of	the follo	wing conc	cepts as they apply to the MRSS:
K/A IMPORT. 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.6 5	55.43(l	SRO b) SRO	3.6
OBJECTIVE:	MSS-14						
	EXPLAIN the	effect on the M	lain Stea	am Syste	em due	to selected	d failures.
REFERENCE	S:	Main Steam L	.esson P	'lan			
SOURCE:	New	Significa	ntly Mo	dified			Direct X
SOURCE:	New	Significa	ntly Mo Bank I	dified Number	П мs	S-14	Direct X 003
SOURCE:	New	Significa	ntly Mo Bank I	dified Number	Ш мs	S-14	Direct X 003
SOURCE: JUSTIFICATI <i>a</i> .	New	Plausible since withdraw rods	Bank I Bank I the ex to main	dified Number pected r tain terr	MS response	S-14 e to a pow e, but no ro	<i>Direct</i> X 003 ver increase (controlled) is to od motion is given.
SOURCE: JUSTIFICATI <i>a.</i> <i>b</i> .	New	Signification Plausible since withdraw rods The increased to cool down. power.	a ntly Mo Bank I se the ex to main d heat re This wi	dified Number pected r tain terr emoval d II add ne	MS response operature lue to ine egative r	S-14 e to a pow e, but no ro creased st eactivity w	Direct X 003 ver increase (controlled) is to od motion is given. team demand will cause the RCS which will cause an increase in
SOURCE: JUSTIFICATI a. b. c.	New	Signification Plausible since withdraw rods The increased to cool down. power. Plausible since withdraw rods	Bank I Bank I the the ex to main the the ex this wi the the ex to main	dified Number pected r tain tem moval d II add ne spected r tain tem	MS response operature lue to ind egative r response operature	S-14 e to a pow e, but no re creased st eactivity w e to a pow e, but no re	Direct X 003 ver increase (controlled) is to od motion is given. team demand will cause the RCS which will cause an increase in ver increase (controlled) is to od motion is given.
SOURCE: JUSTIFICATI a. b. c. d.	New	Signification Plausible since withdraw rods The increased to cool down. power. Plausible since withdraw rods Plausible since cause the RC an increase in	antly Mo Bank I E the ex to main d heat re This wi to the ex to the ex to main the the ind to coo the power.	dified Number pected r tain tem moval d ll add ne pected r tain tem creased ol down,	MS response operature lue to ine egative r response operature heat rer but this	S-14 e to a pow e, but no ro creased st eactivity w e to a pow e, but no ro noval due will add no	Direct X 003 Per increase (controlled) is to od motion is given. Team demand will cause the RCS which will cause an increase in Per increase (controlled) is to od motion is given. to increased steam demand will egative reactivity which will cause
SOURCE: JUSTIFICATI a. b. c. d. DIFFICULTY	New ION: CORRECT	Signification Plausible since withdraw rods The increased to cool down. power. Plausible since withdraw rods Plausible since cause the RC an increase in	antly Mo Bank I Be the ex to main d heat re This wi the the ex to main the the ex to coo the power.	dified Number pected r tain tem emoval d II add ne pected r stain tem creased of down,	MS response operature lue to ine egative r response operature heat rer but this	S-14 e to a pow e, but no ro creased st eactivity w e to a pow e, but no ro moval due will add no	Direct X 003 rer increase (controlled) is to od motion is given. team demand will cause the RCS which will cause an increase in rer increase (controlled) is to od motion is given. to increased steam demand will egative reactivity which will cause
SOURCE: JUSTIFICATI a. b. c. d. DIFFICULTY Comprehen	New ION: CORRECT	Signification Plausible since withdraw rods The increased to cool down. power. Plausible since withdraw rods Plausible since cause the RC an increase in Know	<i>Bank I</i> Bank I se the ex to main d heat re This wi the the ex to main the the ex to coor to coor to power.	dified Number pected r train tem emoval d ll add ne pected r train tem creased ol down,	MS response operature lue to ine egative r response operature heat rer but this	S-14 e to a pow e, but no ro creased st eactivity w e to a pow e, but no ro moval due will add no Rating	Direct X 003 er increase (controlled) is to od motion is given. team demand will cause the RCS which will cause an increase in rer increase (controlled) is to od motion is given. to increased steam demand will egative reactivity which will cause

REFERENCES SUPPLIED:

MAIN STEAM	
NORMAL OPERATION	
All three S/Gs supplying 100% steam flow to the main turbine.	
INFREQUENT OPERATION	
Plant heatup	
The system is heated up by using heat developed by the RCPs and the PZR heaters	
Above atmospheric pressure the system can be vented/blown down to remove non- condensable and condensate	
At various RCS temperatures below 543°F the MSIV before and after seat drain valves and S/G blowdown flow will be adjusted to maintain or increase temperatures of the RCS	
At > 543°F the MSIV bypasses will be used to warm up the main steam system. At 50 psid across the MSIVs the valves may be opened and the MSIV bypasses closed.	
Power/load increase	
After the reactor is taken to power the steam dumps are used to control RCS temperature	OBJ. #14
10% load - MSR purge valves opened	
35% load - MSR shutoff valves opened and pneumatic time pattern transmitter started to open the timer valves (LP turbine inlet steam temperature limit 100°F/hour)	
ABNORMAL OPERATION	
Accidental opening of a S/G PORV or safety	

valve while at power will cause an increase in

steam flow for that loop which in turn could:	
Cause excessive cooldown of the RCS	
Cause an increase in reactor power	
Lead to turbine runback, reactor trip, safeguards actuation (steam line Δp)	
Accidental closing of an MSIV while at power will cause an increase in steam pressures for that steam line which in turn could:	
Cause lifting of the PORV and/or safeties in that steam line	OBJ. #12, 13 USE LATEST REVISION OF
Cause shrinkage in the S/G level in the failed loop and increased level (swell) in the non-failed loops	IMPROVED TECH SPECS TO DISCUSS LCO ACTION STATEMENTS, AND BASIS
Lead to reactor trip and safeguards actuation by high steam flow (high stm flow w/low press)	
TECHNICAL SPECIFICATIONS	
LIMITING CONDITIONS FOR OPERATION	
I.T.S. 3.6.3, Containment Systems	OBL #16
Actions	
Basis	
I.T.S. 3.7.1 and 3.7.2, Plant Systems	
Actions	LER-94-020
Basis	
OPERATING EXPERIENCE	
COMMITMENTS	
NONE	
PLANT SPECIFIC EVENTS (NON-	

Question: 50

Given the following conditions:

- The unit is operating at 85% power.
- Control Rod Bank 'D' Demand is at 195 steps.
- IRPI indication for Bank D Control Rods are as follows:

ROD	POSITION
D-8	123"
M-8	121"
H-4	120"
H-8	110"
H-12	122"

Design power peaking and Shutdown Margin Limits ...

- a. are met under these conditions.
- b. will be met if Control Rod H-8 is withdrawn to 115".
- c. will be met if power is reduced below 80%.
- d. will be met if Control Rod D-8 is inserted to 120".

Answer:

b. will be met if Control Rod H-8 is withdrawn to 115".

							(Common Question Reference
QUESTION N TIER/GROUP	UMBER:	50	RO	1/1		SRO	1/1	
<u>к</u> ,	000AR3.03							
	Knowledge of Control Rod:	the reasons for Tech-Spec lim	or the fol its for ro	lowing r d misma	respons atch	es as they	apply to	the Inoperable / Stuck
K/A IMPORT	ANCE:		RO	3.6		SRO	4.1	
10CFR55 CO	NTENT:	55.41(b)	RO	10	55.43	(b) SRO		
OBJECTIVE:	RDCNT-12							
	State the Tec	hnical Specific	ation Lin	nitations	s and ex	plain the ba	ases for	the Rod Control System.
REFERENCE	:S:	Tech Spec 3.	, 1.4					
SOURCE:	New	Significa	ntly Mo	dified			Direct	X
			Bank I	Numbe	r Ri	NP-RO-200	0	07
JUSTIFICATI	ION:							
а.		Plausible sind steps (within inches.	e rods v 15 inche	vould be s). With	e consid h rods t	lered aligne below 200 s	ed if ban teps, re	k position was above 200 quirement is within 7.5
b.	CORRECT	Below 200 ste for the rods in height is 119.	eps, rods the bar 4". If roo	s must k nk. If ro d H-8 is	be align d H-8 is not inc	ed within 7. included ir luded, the a	5 inches this ca average	s of average IRPI indication Iculation, the average rod rod height is 121.5".
С.		Plausible sind aligned within 70%, not 80%	ce action i a time i %.	is are ta period.	iken to l Althoug	lower powe gh rod is mis	r if a mis saligned	saligned rod cannot be I, required power level is
d.		Plausible sind 120 inches w and 118.8" if	ce this ro ould low rod H-8	od is hig er the a is incluc	her tha iverage led. Bo	n the averaged rod height f oth values w	ge of the to 120.7 vould sti	e rods. Lowering rod D-8 to 5" if rod H-8 is not included Il leave rod H-8 misaligned.
DIFFICULTY	:							
Comprehen	sive/Analysis	X Kno	owledge	e/Recall		Rating	3	

RNP NRC Written Examination

Comprehension of rod alignment limits and determination of rod misalignment.

REFERENCES SUPPLIED:

3.1 REACTIVITY CONTROL SYSTEMS

3.1.4 Rod Group Alignment Limits

LCO 3.1.4 All shutdown and control rods shall be OPERABLE.

AND

Individual indicated rod positions shall be as follows:

- a. For bank demand positions \geq 200 steps, each rod shall be within 15 inches of its bank demand position, and
- b. For bank demand positions < 200 steps, each rod shall be within 7.5 inches of the average of the individual rod positions in the bank.

APPLICABILITY: MODES 1 and 2.

ACTIONS

-	CONDITION		REQUIRED ACTION	COMPLETION TIME
	A. One or more rod(s) inoperable.	more rod(s) A.1.1 Verify SDM is within ble. the limits provided in the COLR.		1 hour
		<u>OR</u> A.1.2 AND	Initiate boration to restore SDM to within limit.	1 hour
		A.2	Be in MODE 3.	6 hours

(continued)

HBRSEP Unit No. 2

- N 1

d

SUPPLIED REFERENCE MATERIALS FOR RNP NRC REACTOR OPERATOR EXAMINATION

.

ł

REFERENCE NUMBER	REFERENCE TITLE
NA	Steam Tables
EPP-15, Attachment 1	Required Flow Rate Versus Time After Reactor Trip
GP-005, Attachment 10.1	Reactor Power Ascension Indicator Log
Plant Curve 5.3	Boron Addition – Coolant Hot - Gallons
Plant Curve 5.4	Boron Addition – Coolant Cold - Gallons
Plant Curve 5.7	Dilution – Coolant Hot - Gallons
Plant Curve 5.8	Dilution – Coolant Cold - Gallons
Plant Curve 7.6	System Resistance Curve, Post Accident Containment Venting System
Plant Curve 7.16	Total Hydrogen Generation Rate from All Sources
Plant Curve 7.19	Loss of Residual Heat Removal Cooling Water Level Between 0" to –10" Below Vessel Flange
Plant Curve 7.20	Loss of Residual Heat Removal Cooling Water Level Between –10" to –36" Below Vessel Flange
Plant Curve 7.21	Loss of Residual Heat Removal Cooling Water Level Between –36" to –72" Below Vessel Flange

Page 31 of 31



ATTACHMENT 10.1 Page 1 of 1 REACTOR POWER ASCENSION INDICATOR LOG

AVG PWR % (1)	NI-35 amps	NI-36 amps	NI-41A %	NI-42A %	NI-43A %	NI-44A %	LOOP ∆T ° F (1)	LOOP 1 ΔT °F	LOOP 2 ΔT °F	LOOP 3 ΔT °F	1 st STAGE PRESS psig (1)	PI-446 OR 447 psig (2)	NET MWe MAX (1)	NET MWe	CCP % PWR (3)	NR-45 (4)	SSO (1)
15-20			<u> </u>				9-11.5				68-90		73				
25-30							14.5-17				113-135		153				
35-40							20-23				158-180		235				
45-50							26-28.5				207-230		316				
55-60				·			32-34.5				261-285		398				
65-70	<u> </u>						37-40				320-345		480				
75-80							43-46				384-410		562				
85-90							49-51.5				449-475		643				
95-100							55-57.5				513-540		725				

(1) Listed ranges and Net MWe maximums are predicted based on past plant performance. The maximum value of each indication is the maximum target value for each power increase. The SSO shall initial if plant management has determined that indications are acceptable to continue with the power escalation.

(2) Use indicator that corresponds to the channel selected on the 1st STAGE PRESSURE selector switch.

(3) Record Continuous Calorimetric Program % Power.

(4) Verify NR-45 is selected to the highest reading channel.

1	Day 67	Page 64 of 65
1 (32-005		5



FIGURE S-3.1-3 BORON ADDITION - COOLANT HOT (-580°F)

. ...

. .

S-3.1:13

-- +

J.T



FIGURE S-3.1-4 BORON ADDITION - COOLANT COLD (-100°F)

.:

٠.



ι

S-3.1:2.

. منبعه



- • •

FIGURE S-3.1-S DILUTION NOMOGRAPH - COOLANT COLD (-100°F)

1.

میں۔ معنی ہو ا



ł.,

{:{

KOE 20 X 20 TO THE INCH. COMPANY

Rev.

75







⊟ 100 Hours After Shutdown → 10 Days After Shutdown

tdown 🛛 🛆 20 Days After Shutdown

* 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

.



Curve 7.20 - Loss of Residual Heat Removal Cooling Water Level Between -10" to -36" Below Vessel Flange

Hours After Shutdown → 10 Days After Shutdown A 20 Days After Shutdown ¥ 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153



Curve 7.21 - Loss of Residual Heat Removal Cooling Water Level Between -36" to -72" Below Vessel Flange

⊟ 100 Hours After Shutdown \ominus 10 Days After Shutdown 🛛 ≙ 20 Days After Shutdown 🛛 \star 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153

SUPPLIED REFERENCE MATERIALS FOR RNP NRC REACTOR OPERATOR EXAMINATION

REFERENCE NUMBER REFERENCE TITLE

NA	Steam Tables
EPP-15, Attachment 1	Required Flow Rate Versus Time After Reactor Trip
GP-005, Attachment 10.1	Reactor Power Ascension Indicator Log
Plant Curve 5.3	Boron Addition – Coolant Hot - Gallons
Plant Curve 5.4	Boron Addition – Coolant Cold - Gallons
Plant Curve 5.7	Dilution – Coolant Hot - Gallons
Plant Curve 5.8	Dilution – Coolant Cold - Gallons
Plant Curve 7.6	System Resistance Curve, Post Accident Containment Venting System
Plant Curve 7.16	Total Hydrogen Generation Rate from All Sources
Plant Curve 7.19	Loss of Residual Heat Removal Cooling Water Level Between 0" to –10" Below Vessel Flange
Plant Curve 7.20	Loss of Residual Heat Removal Cooling Water Level Between –10" to –36" Below Vessel Flange
Plant Curve 7.21	Loss of Residual Heat Removal Cooling Water Level Between –36" to –72" Below Vessel Flange

EPP-15

•

Rev. 13

Page 31 of 31



ATTACHMENT 10.1 Page 1 of 1 REACTOR POWER ASCENSION INDICATOR LOG

AVG PWR % (1)	NI-35 amps	NI-36 amps	NI-41A %	NI-42A %	NI-43A %	NI-44A %	LOOP	LOOP 1 ΔT °F	LOOP 2 ΔT °F	LOOP 3 ∆T °F	1 st STAGE PRESS psig (1)	Pl-446 OR 447 psig (2)	NET MWe MAX (1)	NET MWe	CCP % PWR (3)	NR-45 (4)	SSO (1)
15-20							9-11.5				68-90		73				
25-30							14.5-17				113-135		153				
35-40							20-23				158-180		235				
45-50							26-28.5				207-230		316				8. 1
55-60							32-34.5				261-285		398				
65-70		<u></u>					37-40				320-345		480				
75-80							43-46				384-410		562				
85-90							49-51.5				449-475		643				
95-100							55-57.5				513-540		725				

(1) Listed ranges and Net MWe maximums are predicted based on past plant performance. The maximum value of each indication is the maximum target value for each power increase. The SSO shall initial if plant management has determined that indications are acceptable to continue with the power escalation.

(2) Use indicator that corresponds to the channel selected on the 1st STAGE PRESSURE selector switch.

(3) Record Continuous Calorimetric Program % Power.

(4) Verify NR-45 is selected to the highest reading channel.

	Bev 67	Page 64 of 65
GP-005	nev. 07	1 490 0 1 01 00



- 6

FIGURE S-3.1-3 BORCH ADDITION - COOLANT HOT (-580°F)

. ...

•

. .

4.100



_:

۰.

. .

. .



S-3.1:19

. . . .

~

3000

FIGURE S-3.1-4 BORON ADDITION - COOLANT COLD (-100°F)

J.T

:



ι.



FIGURE S-3.1-S DILUTION NOMOGRAPH - COOLANT COLD (-100°F)

1...

- - v



KOE 20 X 20 TO THE INCH. A TO PERIS



Curve 7.1

ŕ

. + .



Curve 7.19 - Loss of Residual Heat Removal Cooling Water Level Between 0" to -10" Below Vessel Flange

Based on calculation RNP-M/MECH-1590

△ 20 Days After Shutdown

* 40 Days After Shutdown



Curve 7.20 - Loss of Residual Heat Removal Cooling Water Level Between -10" to -36" Below Vessel Flange

⊟ 100 Hours After Shutdown → 10 Days After Shutdown △ 20 Days After Shutdown ★ 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153



Curve 7.21 - Loss of Residual Heat Removal Cooling Water Level Between -36" to -72" Below Vessel Flange

* 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153

SUPPLIED REFERENCE MATERIALS FOR RNP NRC REACTOR OPERATOR EXAMINATION

REFERENCE NUMBER REFERENCE TITLE

NA	Steam Tables
EPP-15, Attachment 1	Required Flow Rate Versus Time After Reactor Trip
GP-005, Attachment 10.1	Reactor Power Ascension Indicator Log
Plant Curve 5.3	Boron Addition – Coolant Hot - Gallons
Plant Curve 5.4	Boron Addition – Coolant Cold - Gallons
Plant Curve 5.7	Dilution – Coolant Hot - Gallons
Plant Curve 5.8	Dilution – Coolant Cold - Gallons
Plant Curve 7.6	System Resistance Curve, Post Accident Containment Venting System
Plant Curve 7.16	Total Hydrogen Generation Rate from All Sources
Plant Curve 7.19	Loss of Residual Heat Removal Cooling Water Level Between 0" to –10" Below Vessel Flange
Plant Curve 7.20	Loss of Residual Heat Removal Cooling Water Level Between –10" to –36" Below Vessel Flange
Plant Curve 7.21	Loss of Residual Heat Removal Cooling Water Level Between –36" to –72" Below Vessel Flange

.

Page 31 of 31



ATTACHMENT 10.1 Page 1 of 1 REACTOR POWER ASCENSION INDICATOR LOG

AVG PWR % (1)	NI-35 amps	NI-36 amps	NI-41A %	NI-42A %	NI-43A %	NI-44A %	LOOP ΔT °F (1)	LOOP 1 ΔT °F	LOOP 2 ΔT °F	LOOP 3 ∆T °F	1 st STAGE PRESS psig (1)	PI-446 OR 447 psig (2)	NET MWe MAX (1)	NET MWe	CCP % PWR (3)	NR-45 (4)	SSO (1)
15-20							9-11.5				68-90		73				
25-30							14.5-17				113-135		153				
35-40							20-23				158-180		235				
45-50							26-28.5				207-230		316				
55-60							32-34.5				261-285		398				
65-70			<u> </u>				37-40				320-345		480				
75-80							43-46				384-410		562				
85-90							49-51.5				449-475		643				
95-100							55-57.5				513-540		725				

(1) Listed ranges and Net MWe maximums are predicted based on past plant performance. The maximum value of each indication is the maximum target value for each power increase. The SSO shall initial if plant management has determined that indications are acceptable to continue with the power escalation.

(2) Use indicator that corresponds to the channel selected on the 1st STAGE PRESSURE selector switch.

(3) Record Continuous Calorimetric Program % Power.

(4) Verify NR-45 is selected to the highest reading channel.

GP-005	Rev. 67	Page 64 of 65


FIGURE S-3.1-3 BORON ADDITION - COOLANT HOT (-580°F)

. ...

S-3.1:13

J.T



. .

میبد، مید د FIGURE S-3.1-4 BORON ADDITION - COOLANT COLD (-100°F)

-:

٠,

· . 1



GORE 3-3:1-7 DIEUTION NONVORMENT - COVERNE NOT (- 300.F)

L

S-3.1:2.



FIGURE S-3.1-S DILUTION NOMOGRAPH - COOLANT COLD (-100°F)

1.1

S-3.1:23

- • v

. ...



€

KEE 20 X 20 TO THE INCH. CONTRACTS

46 1240

•





Curve 7.19 - Loss of Residual Heat Removal Cooling Water Level Between 0" to -10" Below Vessel Flange

⊟ 100 Hours After Shutdown → 10 Days After Shutdown

.

سینین سیرت این ا wn 🛛 🛆 20 Days After Shutdown

* 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590



Curve 7.20 - Loss of Residual Heat Removal Cooling Water Level Between -10" to -36" Below Vessel Flange

⊟ 100 Hours After Shutdown → 10 Days After Shutdown A 20 Days After Shutdown ¥ 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153



Curve 7.21 - Loss of Residual Heat Removal Cooling Water Level Between -36" to -72" Below Vessel Flange

 $_{igodot}$ 100 Hours After Shutdown $\,\,
ightarrow$ 10 Days After Shutdown $\,\,
ightarrow$ 20 Days After Shutdown $\,\,$ $\,$ $\,$ 40 D

* 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153

. موت ا

SUPPLIED REFERENCE MATERIALS FOR RNP NRC SENIOR REACTOR OPERATOR EXAMINATION

 $\overline{\wedge}$

REFERENCE NUMBER	REFERENCE TITLE
NA	Steam Tables
AP-030, Attachment 7.1	Immediate (One Hour) Notifications to the NRC
AP-030, Attachment 7.2	Four Hour Notifications to the NRC
EPP-15, Attachment 1	Required Flow Rate Versus Time After Reactor Trip
EPP-17, Attachment 1	Containment Sump Level Vs. RWST Level
GP-005, Attachment 10.1	Reactor Power Ascension Indicator Log
OMM-046, Attachment 10.3	Available Contingency Actions
OMM-048, Attachment 10.2	PSA of On-Line Maintenance for H.B. Robinson Steam Electric Plant Unit 2
Plant Curve 3.5	Time to CV Closure
Plant Curve 5.3	Boron Addition – Coolant Hot - Gallons
Plant Curve 5.4	Boron Addition – Coolant Cold - Gallons
Plant Curve 5.7	Dilution Coolant Hot - Gallons
Plant Curve 5.8	Dilution – Coolant Cold - Gallons
Plant Curve 7.6	System Resistance Curve, Post Accident Containment Venting System
Plant Curve 7.16	Total Hydrogen Generation Rate from All Sources
Plant Curve 7.19	Loss of Residual Heat Removal Cooling Water Level Between 0" to –10" Below Vessel Flange
Plant Curve 7.20	Loss of Residual Heat Removal Cooling Water Level Between10" to36" Below Vessel Flange
Plant Curve 7.21	Loss of Residual Heat Removal Cooling Water Level Between –36" to –72" Below Vessel Flange
TS 3.4.16	RCS Specific Activity
TS 3.7.4	Auxiliary Feedwater (AFW) System
TS 3.7.6	Component Cooling Water (CCW) System

ATTACHMENT 7.1 Page 1 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

 \langle

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC			
10 CFR 50.72 states that immediate reports shall be made to the <u>NRC Operations Center</u> of these Emergency Events via the NRC Emergency Telecommunications System (ETS) as specified in the Emergency Plan. 10 CFR 50.72 additionally identifies Non-Emergency Events which are to be reported within One-Hour or Four-Hours to the NRC. ETS Telephones, which are identified, are located in the Control Room, the TSC, and the EOF.			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
NOTE: 10 CFR 50.72 recognizes Emergency.	the Emergency Plar	n and its four Emergency Classes of Unusual Eve	ent, Alert, Site Area Emergency and General
EMERGENCIES	Emergency Unusual	HBRSEP shall notify the NRC of the declaration of any of the Emergency Classes	 Declaration of an Unusual Event, Alert, Site Area Emergency, or General Emergency
	Event Alert Site Area	specified in the Emergency Plan.	 Discovery of an event that should have resulted in an Emergency Classification, but no emergency was declared
10 CFR 50.72(a)(i) 10 CFR 30.32(i)(3)(viii) 10 CFR 40.31(i)(3)(viii)	Emergency General Emergency		 Discovery that a declared emergency exceeded the Emergency Action Levels for a higher emergency declaration, but the higher classification was not declared
ERDS ACTIVATION	ERDS Emergency	HBRSEP shall activate the ERDS as soon as possible but not later than one hour after declaring an Alert, Site Area Emergency, or General Emergency.	 An Alert, Site Area Emergency, or General Emergency is declared.
10 CFR 50.72(a)(4)			

AB 030	Rev. 29	Page 19 of 76
AF-030		

ATTACHMENT 7.1 Page 2 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC			
If not reported as a declaration of an Emergency Class under paragraph (a) of 10 CFR 50.72, HBRSEP shall notify the <u>NRC Operations Center via NRC</u> Emergency Telecommunications System (ETS) as soon as practical and in all cases within one hour of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
SHUTDOWN REQUIRED BY TS	Shutdown TS Shutdown Power Reduction	The <u>initiation</u> of any shutdown required by the TS.	 Unplanned Shutdown initiated due to maximum specific activity of the Reactor Coolant Water (plant shutdown required by TS) Reactor Coolant System Leakage in excess of 10 GPM for greater than 24 hours (plant shutdown required by TS) Component Cooling Water Heat Exchanger inoperable (if not corrected prior to expiration of Required Action Completion Time)
10 CFR 50.72(b)(1)(i)(A)			
DEVIATION FROM TS (10 CFR 50.54(X))	Deviation Departure License Condition	Any deviation from the TS authorized pursuant to 10 CFR 50.54(x).	 Intentional deviation from an approved plant procedure in order to preserve plant safety 10 CFR 50.54(x) (See PRO-NGGC-0200)

AP-030	Rev. 29	Page 20 of 76

ATTACHMENT 7.1 Page 3 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

•

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC			
If not reported as a declaration of an Emergency Class under paragraph (a) of 10 CFR 50.72, HBRSEP shall notify the NRC Operations Center via ETS as soon as practical and in all cases within one hour of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
PRINCIPAL SAFETY BARRIERS SERIOUSLY DEGRADED	Degraded Safety Barriers Fission Product	Any event or condition <u>during operation</u> that results in the condition of the nuclear power plant, including its principal safety barriers, being seriously degraded;	 Fuel cladding failures in the reactor, or in the storage pool, that exceed expected values, or that are unique or widespread, or that are caused by unexpected factors, and would involve a release of significant quantities of fission products
	Barrier		 Cracks and breaks in the piping or reactor vessel, or major components in the reactor coolant system, that have safety relevance (steam generators, reactor coolant pumps, valves, etc.)
			 Significant welding or material defects in the RCS
			 Serious temperature or pressure transients
			 Loss of relief and/or safety valve functions during operation – Loss of Containment function or integrity
10 CEB 50 72(b)(1)(ii)			 Complete loss of containment integrity function including (1) containment leakage rate greater than allowed value per SR 3.6.1.1 (i.e., entry into LCO 3.6.1 Condition A), (2) loss of containment penetration isolation functional capability (i.e., both barriers), or loss of containment spray capability
	Safety	for that resulted in the nuclear power	 OT_AT changes are declared inoperable due to summator
	Function Unanalyzed	[of that resulted in the haclear power plant being:] In an unanalyzed condition that significantly compromises plant safety;	module lag constants. The channel response time exceeded the value assumed in the accident analysis.
10 CEB 50 72/b)(1)(ii)(A)	Condition		 Accumulation of voids in systems designed to remove heat from the reactor, that could inhibit the ability to adequately remove heat from the core, particularly under natural circulation conditions

AP-030	Rev. 29	Page 21 of 76
/1 000		

ATTACHMENT 7.1 Page 4 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC				
If not reported as a declaration of an Emergency Class under paragraph (a) of 10 CFR 50.72, HBRSEP shall notify the <u>NRC Operations Center via ETS</u> as soon as practical and in all cases within one hour of the occurrence of any of the following:				
EVENT	KEY WORDS	REQUIREMENT		EXAMPLES
CONDITION OUTSIDE DESIGN BASIS OF PLANT	Design Bases Loss of Safety Function	[or that resulted in the nuclear power plant being:] In a condition that is outside the design basis of the plant;	_	Discovery of design errors that renders a safety system inoperable Discovery that a single train of a safety system has been incapable of performing its design function for an extended time (well beyond surveillance intervals or Required Action Completion Times) Safety related piping found not to be seismically qualified in accordance with design bases requirements
CONDITION NOT COVERED BY OPERATING/EMERGENCY PROCEDURES	OP AOP EOP PATH CSFST	[or that resulted in the nuclear power plant being:] In a condition not covered by the operating and emergency procedures.	-	An event is occurring having significant implications for the health and safety of the public and no AOP or EOP is applicable to the condition.
NATURAL PHENOMENON OR CONDITION THREATENING PLANT SAFETY 10 CFR 50.72(b)(1)(iii)	Earthquake Hurricane Tornado Weather Explosion Railroad	Any natural phenomenon or other external condition that poses an actual threat to the safety of the nuclear power plant or significantly hampers site personnel in the performance of duties necessary for the safe operation of the plant.	-	Natural phenomenon (ice storm that significantly hampers personnel in the conduct of activities necessary for safe operation of the plant). External hazards (railroad tank car explosion that poses an actual threat to Plant safety)
ECCS DISCHARGE INTO RCS	ECCS Actuation Safety Injection	Any event that results or should have resulted in ECCS discharge into the reactor coolant system as a result of a valid signal.	_	Manual or automatic Safety Injection System actuation in response to a valid signal (Section 4.5 of this procedure)

AP-030	Rev. 29	Page 22 of 76

ATTACHMENT 7.1 Page 5 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
LOSS OF EMERGENCY ASSESSMENT, OFF-SITE RESPONSE, OR COMMUNICATIONS CAPABILITY 10 CFR 50.72(b)(1)(v)	Selective Signaling System Sirens ETS	Any event that results in a major loss of emergency assessment capability, off-site response capability, or communications capability (e.g., significant portion of control room indication, ETS, or off-site notification system).	 Loss of 23 or more of 45 Public Warning Sirens (≥50%) as indicated on the siren activation system for a period of at least 30 minutes at any one time. Loss of greater than 50% of communications capability (i.e., offsite communications systems which include the Selective Signaling System, the Essex System and the Local Government Radio System). Loss of greater than 50% of the ability of the TSC or EOF to function. Loss of instrumentation indication capability to the extent that an Emergency Action Level cannot be determined to exceed an emergency classification. Loss of ETS if identified by the plant (Not reportable if identified by NRC) Loss of commercial telephone system to the extent that required communications could not be made to official offsite locations (e.g., EOCs, Warning Points)
INTERNAL THREAT TO PLANT SAFETY (FIRES, TOXIC GAS, RADIOLOGICAL RELEASE) 10 CFR 50.72(b)(1)(vi)	Fire Toxic Explosive Release Personnel Safety	Any event that poses an actual threat to the safety of the nuclear power plant or significantly hampers site personnel in the performance of duties necessary for the safe operation of the nuclear power plant including fires, toxic gas releases, or radioactive releases.	 Fire confirmed inside Protected Area (if fire poses an actual threat to plant safety or significantly hampers site personnel in the performance of duties necessary for the safe operation of the plant). Unplanned release of radioactive gases or toxic gas inside Protected Area (if release significantly hampered site personnel in the performance of duties necessary for safe operation of the plant).

ATTACHMENT 7.1 Page 6 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC			
HBRSEP shall immediately notify the NRC Operations Center via ETS as soon as practical and in all cases within one hour of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
SAFETY LIMIT, LIMITING SAFETY SYSTEM SETTING EXCEEDED	Safety Limit Limiting Safety System Setting	If any safety limit is exceeded, shut down the reactor. HBRSEP shall notify the [NRC within 1 hour via ETS per 10 CFR 50.72(a)(1), See Emergency Plan Procedures]. Operation must not be resumed until authorized by the NRC.	 Reactor pressure exceeds 2735 psig while at power The limits of TS Table 2.1.1-1 are exceeded Limiting Safety System Settings in TS Table 3.3.1-1 are exceeded
SAFETY SYSTEM DOES NOT FUNCTION AS REQUIRED 10 CFR 50.36(c)(1)(ii)(A)	ESF RPS Limiting Safety System Setting	HBRSEP shall notify the NRC if the automatic safety system [to correct an abnormal situation before a safety limit is exceeded] has been determined not to function as required.	 A failure mechanism is discovered that indicates that the RPS will not function to trip the reactor under certain required conditions.

AP-030	Rev. 29	Page 24 of 76

ATTACHMENT 7.1 Page 7 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - SECURITY SAFEGUARDS EVENTS			
HBRSEP shall notify the NRC Operations Center via the ETS within one hour after discovery of the safeguards events described as follows (10 CFR 73.71(b)(1)):			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
THEFT/UNLAWFUL DIVERSION OF SNM OR SPENT FUEL SHIPMENT	SNM Spent Fuel Security Safeguards	Any discovery of the loss of any shipment of SNM or spent fuel, and within one hour after recovery of or accounting for such lost shipment	 Shipment Emergency Event
THEFT/UNLAWFUL DIVERSION OF SNM 10 CFR 73.71(b)(1) 10 CFR 73, Appendix G, I(a)(1)	Theft of SNM Diversion Security Safeguards	Any event in which there is reason to believe that a person has committed or caused, or attempted to commit or cause, or has made a credible threat to commit or cause: (1) A theft or unlawful diversion of SNM	 Shipment Emergency Event
SABOTAGE OF PLANT EQUIPMENT 10 CFR 73.71(b)(1) 10 CFR 73. Appendix G. 1(a)(2)	Sabotage Damage to Plant SNM Spent Fuel Security Safeguards	 [Any event in which there is reason to believe that a person has committed or caused, or attempted to commit or cause, or has made a credible threat to commit or cause:] (2) Significant physical damage to a power reactoror its equipment or carrier equipment transporting nuclear fuel or spent nuclear fuel, or to the nuclear fuel or spent fuel a facility or carrier possesses. 	 Shipment Emergency Event Security Event (Reference 2.11)

AP-030	Rev. 29	Page 25 of 76
1	1	

ATTACHMENT 7.1 Page 8 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIA	ATE (ONE HOUR) N	OTIFICATIONS TO THE NRC - SECURITY SA	FEGUARDS EVENTS
HBRSEP shall notify the <u>NRC Operations Center</u> via the ETS within one hour after discovery of the safeguards events described as follows (10 CFR 73.71(b)(1)):			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
UNAUTHORIZED TAMPERING WITH PLANT EQUIPMENT	Unauthorized Use Tampering Security System Safeguards	[Any event in which there is reason to believe that a person has committed or caused, or attempted to commit or cause, or has made a credible threat to commit or cause:] (3) Interruption of normal operation of HBRSEP through the unauthorized use of or tampering with its machinery, components, or controls including the accurity system	 Security Event (Reference 2.11)
10 CFR 73, Appendix G, I(a)(3)		security system.	
ENTRY OF UNAUTHORIZED PERSON INTO PROTECTED OR VITAL AREA 10 CFR 73, Appendix G, I(b)	Unauthorized Entry Security Safeguards	An actual entry of an unauthorized person into a protected area, material access area, controlled access area, vital area, or transport.	 Security Event (Hererence 2.11)
FAILURE, DEGRADATION, OR DISCOVERED VULNERABILITY OF SAFEGUARD SYSTEM 10 CFR 73, Appendix G, I(c) Procedure SEC-NGGC-2147	Degradation Vulnerability Safeguards Unauthorized Undetected Access Security	Any failure, degradation, or the discovered vulnerability in a safeguard system that could allow unauthorized or undetected access to a protected area, material access area, controlled access area, vital area or transport for which compensatory measures have not been employed.	
INTRODUCTION OF CONTRABAND INTO VITAL OR PROTECTED AREA 10 CFR 73. Appendix G, I(d)	Contraband Unauthorized Security Safeguards	The actual or attempted introduction of contraband into a protected area, material process area, vital area, or transport.	Contraband applies to items that could be used to commit radiological sabotage as defined in 10 CFR 73.2.

AP-030	Rev. 29	Page 26 of 76

ATTACHMENT 7.1 Page 9 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - SOURCE, BYPRODUCT AND SNM			
HBRSEP shall immediately notify the NRC Operations Center via ETS, when:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
LOSS OR THEFT OF LICENSED MATERIAL (>1000X 10 CFR 20 LIMITS)	Loss Theft Missing Licensed Radioactive Material	Immediately notify the NRC, after its occurrence becomes known, any lost, stolen, or missing licensed material in an aggregate quantity equal to or greater than 1,000 times the quantity specified in [10 CFR 20] Appendix C under such circumstances that it appears to HBRSEP that an exposure could result to persons in unrestricted areas.	 A radiography source is discovered missing. The source is licensed to the radiography contractor. If the contractor does not make the required notification, HBRSEP should notify the <u>NRC Operations</u> <u>Center via ETS</u>.
EXTERNAL EXPOSURE FROM BYPRODUCT, SOURCE, OR SNM (5X ANNUAL LIMIT)	Byproduct Source SNM Exposure Dose Release Occupational	 Notwithstanding any other requirements for notification, immediately notify the NRC of any event involving byproduct, source, or SNM possessed by HBRSEP that may have caused or threatens to cause any of the following conditions: An individual to receive: A total effective dose equivalent of 25 rems or more; or An eye dose equivalent of 75 rems or more; or A shallow dose equivalent to the skin or extremities of 250 rads or more; or The release of radioactive material, inside or outside the restricted area, so that, had an individual could have received an intake five times the occupational annual limit on intake. 	

AP-030	Rev. 29	Page 27 of 76

ATTACHMENT 7.1 Page 10 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMME	DIATE (ONE HOUF	R) NOTIFICATIONS TO THE NRC - SOURCE, BYPR	ODUCT AND SNM
HBRSEP shall immediately notify the 1	NRC Operations Ce	nter via ETS, when:	
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
INTERNAL EXPOSURE FROM BYPRODUCT, SOURCE, SNM (>5X OCCUPATIONAL LIMIT) 10 CFR 20.2201(a)(i)	Intake Ingestion Release Source Byproduct SNM	The release of radioactive material, inside or outside the restricted area, so that, had an individual been present for 24 hours, the individual could have received an intake five times the occupational annual limit on intake.	

AP-030	Rev. 29	Page 28 of 76
AF-030	1100.20	1 age 20 0.

ATTACHMENT 7.1 Page 11 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

	IMMEDIATE	(ONE HOUR) NOTIFICATIONS TO THE NRC -	ISFSI
HBRSEP shall immediately notify the NRC Operations Center via ETS, when:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
ISFSI - ACCIDENTAL CRITICALITY OR LOSS OF SNM 10 CFR 72.74	ISFSI Criticality SNM Loss	The licensee shall notify the NRC Operations Center via ETS within one hour of discovery of accidental criticality or any loss of SNM.	 Unusually high radiation readings discovered in the vicinity of the ISFSI that could indicate possibility of a criticality event
	IMMEDIATE (ONE	HOUR) NOTIFICATIONS TO THE NRC - SNM	SHIPMENTS
HBRSEP shall notify the NRC Operatic	ons Center via the E	TS within one hour of the following:	
LOST OR UNACCOUNTED SHIPMENT OF SNM 10 CFR 70.52(b) 10 CFR 73.71(a)(1)	Shipment Loss SNM Spent Fuel Theft Diversion Safeguards Security	HBRSEP shall notify the <u>NRC Operations</u> <u>Center</u> via the ETS within one hour after discovery of any loss of any shipment of SNM or spent fuel or any incident in which an attempt has been made, or is believed to have been made, to commit a theft or unlawful diversion of SNM.	 Shipment Emergency Event Security Event (Reference 2.11)
LOST OR UNACCOUNTED SHIPMENT OF SNM - RECOVERY 10 CFR 73.71(a)(1)	Recovery Accounting Shipment SNM Security Safeguards	HBRSEP shall notify the <u>NRC Operations</u> <u>Center</u> via the ETS within one hour after recovery of, or accounting for, any lost shipment of SNM.	

AP-030	Rev. 29	Page 29 of 76

ATTACHMENT 7.1 Page 12 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - FOLLOW-UP			
With respect to the telephone notifications made under paragraphs (a) and (b) of 10 CFR 50.72, in addition to making the required initial notification, HBRSEP shall during the course of the event immediately report:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
FOLLOW-UP NOTIFICATION	Degradation Emergency Class Change Update Termination	 (i) any further degradation in the level of safety of the plant or other worsening plant conditions, including those that require the declaration of any of the Emergency Classes, if such a declaration has not been previously made, or (ii) any change from one Emergency Class to another, or (iii) a termination of the Emergency Class. 	 Refer to Reference 2.27
FOLLOW-UP NOTIFICATION	Result Evaluation Effectiveness Unknown	 (i) the results of ensuing evaluations or assessments of plant conditions, (ii) the effectiveness of response or protective measures taken, and (iii) information related to plant behavior that is not understood. 	
FOLLOW-UP NOTIFICATION	Open Continuous Communication	Maintain an open, continuous communication channel with the <u>NRC</u> <u>Operations Center</u> <u>upon request</u> by the NRC.	 Refer to Reference 2.27

AP-030	Rev. 29	Page 30 of 76

ATTACHMENT 7.1 Page 13 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS - NRC REGION II OFFICE			
HBRSEP shall immediately notify the fi	nal delivery carrier a	nd, by telephone and telegram, mailgram, or fac	simile, the <u>NRC Region II Office</u> when:
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
THEFT/UNLAWFUL DIVERSION OF TRITIUM	Incident Theft Tritium Attempt Security Safeguards	Any incident in which an attempt has been made or is believed to have been made to commit a theft of more than 10 curies of tritium (outside of spent fuel) at any one time or more than 100 curies of tritium in one calendar year.	 10 Curies of tritium discovered missing from the Chemistry Laboratory, and reason exists to suspect that the tritium was stolen
10 CFR 30.55(c)			· · · · · · · · · · · · · · · · · · ·
THEFT/UNLAWFUL DIVERSION OF SOURCE MATERIAL	Incident Attempt Theft Diversion Source Security Safeguards	Any incident in which an attempt has been made or is believed to have been made to commit a theft or unlawful diversion of more than 15 pounds of Source Material at any one time or 150 pounds of Source Material in any one calendar year.	 A source assembly is discovered missing from a new fuel shipment.
SHIPPING PACKAGE RADIOACTIVELY CONTAMINATED 10 CFR 20.1906(d)(1)	Contamination Shipment	Removable radioactive surface contamination exceeds the limits of 10 CFR 71.87;	 New or Spent Fuel Shipment Cask arrives with surface contamination in excess of limits.
SHIPPING PACKAGE EXCEEDING EXTERNAL DOSE RATE LIMITS 10 CFR 20.1906(d)(2)	Radiation Dose Rate Shipment	External radiation levels exceeds of the limits of 10 CFR 71.47.	 New or Spent Fuel Shipment Cask arrives with external radiation levels in excess of limits.

AP-030	Rev. 29	Page 31 of 76

ATTACHMENT 7.1 Page 14 of 14 IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC

IMMEDIATE (ONE HOUR) NOTIFICATIONS TO THE NRC - FFD				
The NRC Region II Administrator must	The NRC Region II Administrator must be notified immediately by telephone of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES	
NRC EMPLOYEE NOT FIT FOR DUTY	Alcohol Influence Substance NRC employee FFD Fitness for Duty	If HBRSEP has a reasonable belief that an NRC employee may be under the influence of any substance, or unfit for dutythe Region II Administrator must be notified immediately by telephone. During other than normal working hours, the <u>NRC</u> <u>Operations Center via ETS</u> must be notified.		
10 CFR 26.27(d)				
	IMMEDIATE	(ONE HOUR) NOTIFICATIONS TO THE NRC	- FFD	
The NRC Operations Center via ETS r	nust be notified imme	ediately by telephone of the following:		
FALSE POSITIVE ERROR ON FFD SPECIMEN 10 CFR 26, Appendix A, Subpart B, 2 8(e)(5)	FFD Fitness for Duty False Positive Specimen Laboratory	Should a false positive error occur on a blind performance test specimen and the error is determined to be an administrative error, HBRSEP shall promptly notify the NRC.		
		(ONE HOUR) NOTIFICATIONS TO THE NRC	- IAEA	
The NBC Director NBB or Director NMSS must be notified immediately by telephone of the following:				
SURPRISE VISIT OF IAEA OFFICIAL	IAEA International Atomic Energy Agency Credential	HBRSEP shall immediately communicate by telephone, with respect to the credentials of any other person who claims to be an IAEA representative and shall accept telephone confirmation of such credentials by the Commission.	 Person arrives on site bearing IAEA credentials, who is not accompanied by an NRC employee, and has had no prior confirmation in writing of credentials. 	

AP-030	Rev. 29	Page 32 of 76

ATTACHMENT 7.2 Page 1 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

FOUR HOUR NOTIFICATIONS TO THE NRC If not reported under paragraphs (a) or (b)(1) of 10 CFR 50.72, HBRSEP shall notify the <u>NRC Operations Center via ETS</u> as soon as practical and in all cases, within four hours of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
DEGRADED SAFETY BARRIERS DISCOVERED WHILE SHUT DOWN	Shutdown Safety Barrier Fission Product Barriers Degrade Unanalyzed	Any event, found while the reactor is shut down, that, had it been found while the reactor was in operation, would have resulted in the nuclear power plant, including its principal safety barriers, being seriously degraded or being in an unanalyzed condition that significantly compromises plant safety.	 Corrosion of Reactor Coolant System piping found while shutdown (indicative of a material problem that caused abnormal degradation of the RCS pressure boundary). Significant degradation of Reactor Fuel Rod Cladding identified during testing of fuel assemblies (Reference 2.19).

AP-030	Rev. 29	Page 33 of 76
AI -000		

ATTACHMENT 7.2 Page 2 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

FOUR HOUR NOTIFICATIONS TO THE NRC				
If not reported under paragraphs (a) or (b)(1) of 10 CFR 50.72, HBRSEP shall notify the NRC Operations Center via ETS as soon as practical and in all cases,				
within four hours of the occurrence of	of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES	
EVENT ESF OR RPS INITIATION (MANUAL/AUTOMATIC)	KEY WORDS Manual Automatic Actuation Engineered Safety Feature ESF Valid Clearance Ventilation System Reactor Protection System RPS Reactor Trip	REQUIREMENT Any event or condition that results in a manual or automatic actuation of any ESF, including the RPS, except when: (A) The actuation results from and is part of a pre-planned sequence during testing or reactor operation; (B) The actuation is invalid and: (1) Occurs while the system is properly removed from service; (2) Occurs after the safety function has been already completed; or (3) Involves only the following specific ESFs or their equivalent systems: (i) Not Applicable (ii) Control Room emergency ventilation system; (iii) Reactor building ventilation system; (iv) Fuel building ventilation system; (iv) Auxiliary building ventilation system;	 Safety Injection System actuation (also see Emergency Plan Procedures) Reactor Trip (Manual or Automatic). EDG start due to a valid undervoltage trip signal on emergency bus E1 or E2 A single train of Containment Isolation actuates. A valid signal for Containment Ventilation Isolation occurs. All ESF actuations are reportable except the following three categories. An invalid ESF or RPS actuation occurs when the system is already properly removed from service if all requirements of plant procedures for removing equipment from service have been met. This includes required clearance documentation, equipment and control board tagging, and properly positioned valves and power supply breakers. An invalid ESF or RPS actuation occurs after the safety function has already been completed (e.g., an invalid containment isolation signal while the containment isolation signal while the containment isolation of the RPS when all rods are fully inserted). ESF actuations that are caused by non-ESF systems may be excluded because these are not considered ESF actuations of safety significance. (Reference 2.19)	
10 CEB 50.72(b)(2)(ii)	1		systems.	

AP-030	Rev. 29	Page 34 of 76

ATTACHMENT 7.2 Page 3 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

FOUR HOUR NOTIFICATIONS TO THE NRC			
If not reported under paragraphs (a) or (b)(1) of 10 CFR 50.72, HBRSEP shall notify the NRC Operations Center via ETS as soon as practical and in all cases, within			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
CONDITION THAT COULD PREVENT FULFILLMENT OF SAFETY FUNCTIONS	Loss of Safety Function Residual Heat Mitigation Shutdown Generic Setpoint Drift Engineering Evaluation Operability Determination Common Mode Failure	 Any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to: (A) Shut down the reactor and maintain it in a safe shutdown condition. (B) Remove residual heat, (C) Control the release of radioactive material, or (D) Mitigate the consequences of an accident. 	 Loss (inoperability) of both Trains, e.g., ECCS, Low Temperature Overpressure Protection System, or Lake Robinson water level below LCO 3.7.8 limit. Overpressurization of the RCS (if Overpressure Protection System fails to perform its intended function) Loss of one Train of required equipment, and the cause of the failure could fail the other train, and there is a reasonable expectation that the other train would not fulfill its safety function if required. Contaminated lubrication fluid degrades SI Pump operation (a single condition could prevent fulfillment of a safety function if both trains could be reasonably expected to be inoperable). EDG Air Start Solenoids (if it demonstrates a design, procedural, or equipment deficiency that could prevent the fulfillment of a safety function, i.e., if both diesels are susceptible to same problem) Multiple equipment inoperability or unavailability. Generic setpoint drift (if indicative of a generic and/or repetitive problem with switches used in safety systems) Oversized breaker wiring lugs (incompatible pigtails and lugs could cause one or more safety systems to fail to perform their intended functions) Control Rod failure (if failure prevented the fulfillment of a safety function) Operator action to inhibit the RPS (actions would prevent fulfillment of a safety function)

AP-030	Rev. 29	Page 35 of 76

ATTACHMENT 7.2 Page 4 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

	FOU	R HOUR NOTIFICATIONS TO THE NRC	
If not reported under paragraphs (a) or (b)(1) of 10 CFR 50.72, HBRSEP shall notify the NRC Operations Center via ETS as soon as practical and in all cases, within four hours of the occurrence of any of the following:			
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
AIRBORNE RELEASE TO UNRESTRICTED AREA (>20X 10 CFR 20 LIMITS)	Airborne Release Unrestricted Public Radioactive Effluent	Any airborne radioactive release that, when averaged over a time period of 1 hour, results in concentrations in unrestricted area that exceeds 20 times the applicable concentration specified in Appendix B to 10 CFR 20, Table 2, Column 1.	 Unplanned gaseous release (if release exceeded 20 times the applicable concentrations specified in Appendix B, Table 2, Column 1 of 10 CFR 20 averaged over a time period of one hour)
10 CFR 50.72(b)(2)(iv)(A)			
LIQUID EFFLUENT RELEASE TO UNRESTRICTED AREA (>20X 10 CFR 20 LIMITS)	Liquid Release Unrestricted Public Radioactive Effluent Concentration Discharge	Any liquid effluent release that, when averaged over a time period of 1 hour, exceeds 20 times the applicable concentration specified in Appendix B to 10 CFR 20, Table 2, Column 2, at the point of entry into the receiving waters (i.e., unrestricted area) for all radionuclides except tritium and dissolved noble gases.	 Radioactive release exceeding 1S (if release exceeds 20 times the applicable limit of Appendix B, Table 2, Column 2 of 10 CFR 20 when averaged over one hour)
	Contaminate Injured Person Medical Transport Rescue Hospital	Any event requiring the transport of a radioactively contaminated person to an off-site medical facility for treatment.	 Any event requiring the transport of a radioactively contaminated or potentially contaminated (Reference 2.19) person to an off-site medical facility for treatment

AP-030	Rev. 29	Page 36 of 76

,

ATTACHMENT 7.2 Page 5 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

FOUR HOUR NOTIFICATIONS TO THE NRC								
If not reported under paragraphs (a) or (within four hours of the occurrence of ar	If not reported under paragraphs (a) or (b)(1) of 10 CFR 50.72, HBRSEP shall notify the NRC Operations Center via ETS as soon as practical and in all cases, within four hours of the occurrence of any of the following:							
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES					
PRESS RELEASES AND GOVERNMENT NOTIFICATIONS	News Release Press Radio Television Fatality Environment Public Health and Safety Release	Any event or situation, related to the health and safety of the public or on-site personnel, or protection of the environment, for which a news release is planned or notification to other government agencies has been or will be made. Such an event may include an on-site fatality or inadvertent release of radioactively contaminated materials.	 Any News release concerning A fatality, Inadvertent release of radioactively contaminated materials to public areas unusual or abnormal releases of radioactive effluents, or Information associated with an Emergency Event except when the ERO is activated (Reference 2.27) Notification to other government agencies concerning A fatality on site, Health and safety of the public or site personnel, Inadvertent release of radioactively contaminated materials to public areas, Discovered endangered species kill. 					

AP-030	Rev. 29	Page 37 of 76

ATTACHMENT 7.2 Page 6 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

		OUR HOUR NOTIFICATIONS TO THE NRC					
HBRSEP shall notify the NRC Operations Center via ETS as soon as possible but not later than 4 hours after the discovery of any of the following events or conditions involving spent fuel.							
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES				
ISFSI - EXPOSURES TO RADIATION OR RADIOACTIVE MATERIALS IN EXCESS OF LIMITS, OR RELEASES IN EXCESS OF LIMITS	ISFSI Release Exposure Fire Explosion Toxic	Any event that prevents immediate actions necessary to avoid exposures to radiation or radioactive materials that could exceed regulatory limits, or releases of radioactive materials that could exceed regulatory limits (e.g., events such as fires, explosions, and toxic gas releases).	 Explosion or fire involves ISFSI resulting in radiological releases 				
ISFSI - DEFECT IMPORTANT TO SAFETY 10 CFR 50.72(b)(2)(vii)(A) 10 CFR 72.75(b)(2)	ISFSI Defect Safety	A defect in any spent fuel storage structure, system, or component which is important to safety.	 A defect discovered in the design or construction of ISFSI units that could result in releases or radiation doses to the public in excess of 10 CFR 20 limits 				
ISFSI - REDUCTION IN EFFECTIVENESS 10 CFR 50.72(b)(2)(vii)(B) 10 CFR 72.75(b)(3)	ISFSI Confinement Reduction Effectiveness	A significant reduction in the effectiveness of any spent fuel storage cask confinement system during use.	 Wear or degradation of ISFSI units that could result in releases or radiation doses to the public in excess of 10 CFR 20 limits 				
ISFSI - DEPARTURE FROM LICENSE CONDITION	ISFSI Emergency Departure Deviation Health and Safety License Condition	An action taken in an emergency that departs from a condition or a technical specification contained in a license or certificate of compliance issued under 10 CFR 72 when the action is immediately needed to protect the public health and safety and no action consistent with license conditions or technical specifications that can provide adequate or equivalent protection is immediately apparent.	 Action taken in an emergency that departs from procedure that is deemed necessary to prevent releases or radiation doses to the public in excess of 10 CFR 20 limits (See PRO-NGGC- 0200) 				

AP-030	Rev. 29	Page 38 of 76

ATTACHMENT 7.2 Page 7 of 7 FOUR HOUR NOTIFICATIONS TO THE NRC

HBRSEP shall notify the <u>NRC Opera</u> conditions involving spent fuel.	FOL tions Center via ETS as	JR HOUR NOTIFICATIONS TO THE NRC soon as possible but not later than 4 hours after	er the discovery of any of the following events or
EVENT	KEY WORDS	REQUIREMENT	EXAMPLES
ISFSI - TREATMENT OF	ISFSI	An event that requires unplanned medical	 An individual is injured requiring offsite medical treatment and receives

ISFSI - TREATMENT OF CONTAMINATED PERSON AT OFFSITE MEDICAL FACILITY	ISFSI Contaminate Injured Person Medical Transport Rescue Hospital	An event that requires unplanned medical treatment at an offsite medical facility of an individual with radioactive contamination on the individual's clothing or body which could cause further radioactive contamination.	 An individual is injured requiring offsite medical treatment and receives contamination from ISFSI(s) that cannot be removed prior to transport
ISFSI - FIRE OR EXPLOSION	ISFSI Fire Explosion Damage Integrity	An unplanned fire or explosion damaging any spent fuel, or any device, container, or equipment containing spent fuel when the damage affects the integrity of the material or its container	 ISFSI unit is damaged by an external explosion and the integrity of the ISFSI unit is potentially affected

ΔP-030	Rev. 29	Page 39 of 76

Page 31 of 31



SGTR WITH LOSS OF REACTOR COOLANT: SUBCOOLED RECOVERY

Rev. 12

Page 35 of 35



ATTACHMENT 10.1 Page 1 of 1 REACTOR POWER ASCENSION INDICATOR LOG

AVG PWR % (1)	NI-35 amps	NI-36 amps	NI-41A %	NI-42A %	NI-43A %	NI-44A %	LOOP	LOOP 1 ΔT °F	LOOP 2 ΔT °F	LOOP 3 ΔT °F	1 st STAGE PRESS psig (1)	PI-446 OR 447 psig (2)	NET MWe MAX (1)	NET MWe	CCP % PWR (3)	NR-45 (4)	SSO (1)
15-20							9-11.5				68-90		73			L	
25-30							14.5-17				113-135		153				
35-40							20-23				158-180		235				
45-50							26-28.5				207-230		316				
55-60							32-34.5				261-285		398				
65-70							37-40				320-345		480				
75-80							43-46				384-410		562				
85-90							49-51.5				449-475		643				
95-100							55-57.5				513-540		725				

(1) Listed ranges and Net MWe maximums are predicted based on past plant performance. The maximum value of each indication is the maximum target value for each power increase. The SSO shall initial if plant management has determined that indications are acceptable to continue with the power escalation.

(2) Use indicator that corresponds to the channel selected on the 1st STAGE PRESSURE selector switch.

(3) Record Continuous Calorimetric Program % Power.

(4) Verify NR-45 is selected to the highest reading channel.

GP-005	Rev. 67	Page 64 of 65

ATTACHMENT 10.3 Page 1 of 5 AVAILABLE CONTINGENCY ACTIONS

INFORMATION USE

1.0 Decay Heat Removal:

1) In the case of a loss of the normal decay heat removal equipment while the Residual Heat Removal System is aligned for shutdown cooling, AOP-020 should be followed.

NOTE: In order to supply power to the RHR pump in accordance with the referenced procedure (EPP-025) in the following step, electrical terminations are required.

- 2) If a loss of station power is the cause of the loss of normal decay heat removal equipment, the backup diesel power that is required by OMP-003 should be placed in service automatically or, manually if necessary, by the normal operating procedures listed on the appropriate attachment to this procedure. (OP's 601,603,604). If the normal diesel backup power is not available, or fails to operate, then the contingency actions necessary to provide alternate power to the decay heat removal equipment provided in EPP-025 should be performed, and heat removal capability restored.
- 3) In the event that the Reactor is completely defueled and the normal supplies of cooling water to the SFP heat exchanger are lost, the engine driven fire pump in conjunction with the alignment of the fire water system to the SFP heat exchanger, will provide an available backup to all other supply pumps that are powered from the onsite or offsite power supplies in the event that all onsite and offsite power is lost
- 4) The steps necessary to connect the fire water system to the SFP heat exchanger as a temporary cooling water supply can be found in OP-306, Component Cooling Water System, Section 8.3 Spent Fuel Pit Heat Exchanger Emergency Cooling.
- 5) Spent Fuel Pit Cooling Pump "A" is powered form 480v Bus No.3, and 480v Bus No. 3 may be powered from the Dedicated Shutdown Diesel Generator (DSDG) via the Dedicated Shutdown (DS) Bus in the event that offsite and onsite backup power is lost. Alignment of the DS Bus to 480v Bus No. 3 is contained in EPP-025.

OMM-046	Rev. 6	Page 17 of 23
---------	--------	---------------

ATTACHMENT 10.3 Page 2 of 5 AVAILABLE CONTINGENCY ACTIONS

NOTE: This attachment provides the available contingency actions for the operations personnel to restore the "Shutdown Safety Functions" under conditions of either fuel in the Containment or with the Reactor completely "defueled".

2.0 Electrical Power:

1) <u>IF</u> the normal 115KV switch yard supply to the Start Up Transformer has been lost due to relay action, and the normal "Backfeed" method is not available (downstream equipment unavailable). The dispatcher should be contacted to determine if switching instructions may be issued to reenergize one section of the 115KV bus. This section of 115KV bus may then supply the Start Up Transformer, via the auto transformer, from the 230KV switch yard. Under these conditions the fault that caused the original relay action must be verified not to be on the section of 115KV bus to be used.

NOTE: In order to supply power to the RHR pump in accordance with the referenced procedure (EPP-025) in the following step, electrical terminations are required.

2) With fuel in the Reactor, or with the Reactor completely defueled, the contingency actions associated with EPP-025 will supply power to the minimum equipment necessary to maintain the Decay Heat Removal, and Inventory Control "Shutdown Safety Functions"

OMM-046	Rev. 6	Page 18 of 23
ATTACHMENT 10.3 Page 3 of 5 AVAILABLE CONTINGENCY ACTIONS

3.0 Inventory Control:

- 1) Normal inventory maintenance is controlled by the Operating Procedures. In the event that excessive leakage occurs with the refueling cavity full, AOP-020 - Loss of Residual Heat Removal (Shutdown Cooling), should be followed to isolate the leak, establish makeup to the cavity at the maximum available rate, and place the RHR system in the recirculation mode if the leakage cannot be isolated and the CV sump level rises to the minimum required to operate the RHR pumps in the recirculation mode.
- 2) In the event that leakage from the Spent Fuel Pit occurs while the Reactor has been offloaded to the Spent Fuel Pit, OP-910 - Spent Fuel Pit Cooling and Purification System, or OP-913, Refueling Water Purification Pump Operation, are used to initiate make up to the spent fuel pit.
- 3) The following Procedures are also available to establish alternative means to make-up to the Spent Fuel Pit:
 - a. OP-301 Chemical And Volume Control System, may be used to initiate blended make-up to the RWST, and OP-913, Refue ling Water Purification Pump Operation used to subsequently make-up to the SFP.

CAUTION

The flow path aligned in the following step is non-borated water and may lead to a dilution accident in the SFP if used to make up for a large loss of SFP inventory.

- b. The demineralized water system may be connected directly to the SFP clean up loop for make-up through the valves listed below:
 - DW-215 DEMINERALIZED WATER TO PLANT COMPONENTS
 - SFPC-808 DEMIN WATER INLET

OMM-046	Rev. 6	Page 19 of 23
		the second se

ATTACHMENT 10.3 Page 4 of 5 AVAILABLE CONTINGENCY ACTIONS

4.0 Reactivity Control:

- 1) Borated makeup sources, and all components necessary to inject the borated water are required to be operable in accordance with OMP-003 when fuel is in the vessel. Other means of borated makeup when the RCS is intact include the flow path through the RCP seals, however this should only be used as a last resort. Normal letdown if available when fuel is in the vessel, may be used to divert displaced inventory to the CVCS Hold Up Tank (HUT). As an alternate means of increasing the Boron Concentration in the Refueling cavity when the vessel head has been removed, 100 lb. bags of Granulated Boric Acid may be added to the cavity. One 100 lb. bag of Granulated Boric Acid will increase the Cavity Boron Concentration approximately 6 ppm. Contact the Reactor Engineer to provide guidance IAW the Reactivity Management Program. (SOER 94-2)
- 2) When the core is offloaded to the SFP, borated make-up is available from the RWST in accordance with the procedure listed on Attachment 10.2 of this procedure, however if the SFP is at the full level and no more inventory can be added, Boron Concentration may be increased by adding Granulated Boric Acid to SFP locally. One 100 lb. bag of Granulated Boric Acid will increase the Boron Concentration of the SFP approximately 6 ppm. Contact the Reactor Engineer to provide guidance IAW the Reactivity Management Program. (SOER 94-2)

OMM-046	Rev. 6	Page 20 of 23

ATTACHMENT 10.3 Page 5 of 5 AVAILABLE CONTINGENCY ACTIONS

5.0 Containment:

- 1) Containment Closure is controlled by the Improved Technical Specifications and plant procedures based on the current plant status, the procedures listed below are intended to maintain the applicable degree of isolation at the plant conditions indicated in the procedures and are either successful or are performed until the proper degree of isolation is achieved, therefore there are no contingency actions applicable that are not contained in the controlling procedures:
 - a. GP-002 COLD SOLID TO HOT SUBCRITICAL AT NO LOAD T-avg (establishes "Containment Integrity" in accordance with OP-923 when RCS is at 200°F)
 - OMM-033 IMPLEMENTATION OF CV CLOSURE (controls closure of CV penetrations when RCS temperature is less than 200°F)
 - c. GP-010 REFUELING (establishes "Containment Closure" for refueling when the Reactor Vessel head is removed and core components are being moved)

OMM-046	Rev. 6	Page 21 of 23
---------	--------	---------------

ATTACHMENT 10.2 Page 1 of 14 PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

1.0 **INTRODUCTION**

This document identifies the risk impact of various combinations of equipment safety functions being unavailable due to maintenance during reactor critical and power operation ("on-line maintenance"). The risk impact measure for this analysis is core damage frequency (CDF), as calculated using the current probabilistic safety analysis (PSA) model of the Robinson plant. While this analysis provides risk insights that can be obtained in no other way, it is intended that the information contained in this document be used in conjunction with design basis information, operational experience, and engineering judgment to determine the extent and scope of any planned on-line maintenance activity. Because the PSA only measures risk impact, and not defense in depth, the allowed out of service times presented in this document may be different than those of the plant's technical specifications. This document shall not be used as a basis for extending a Tech. Spec. Action Statement but should be observed when the recommended limits of this document are more restrictive than the limits imposed by technical specifications.

2.0 METHODOLOGY

2.1 Determination of Train Combinations for On-line Maintenance

Systems identified as safety significant by the maintenance rule expert panel were evaluated for on-line maintenance impact on core damage risk. These systems were broken down into two major trains and separated on the 12-week on-line schedule. This schedule was used to determine the presentation of results.

Note that the 12-week on-line schedule contains some systems or trains that are maintained on-line but whose function is not impaired by the maintenance action. These systems were not included in the PSA analysis, since the PSA considers the impact of unavailable functions when determining risk impact. However, some maintenance actions, even if they do not render the system incapable of performing its accident mitigation function, may increase the likelihood of a transient or other initiating events. Systems or trains in this category were included in the analysis.

2.2 Calculation of Core Damage Frequencies

In order to determine the risk impact of planned maintenance, a "baseline" core damage frequency was required. This baseline core damage frequency served as the basis for determining whether the calculated risk increase for a given equipment configuration was safety significant or non-safety significant. This baseline CDF was determined by setting all unavailability events in the PSA model to the "in service" value of zero. The model was then quantified to obtain the baseline CDF.

	1 ·····	·····
OMM-048	Rev. 11	Page 32 of 69

ATTACHMENT 10.2 Page 2 of 14 PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

In order to assess the relative impact of performing on-line maintenance on a single system or a pair of systems, the system train function was made unavailable. All other system functions in the PSA model except those being taken out for on-line maintenance were made available. The PSA model was then solved for this combination of equipment out of service to determine the new core damage frequency for that condition.

If maintenance could increase the likelihood of a transient or other initiating event, this impact had to be considered in the analysis. This was addressed by assuming that the maintenance would cause the appropriate initiating event in the model to increase in frequency by a factor of ten. An example of this "environmental event" would be work on Reactor Protection Logic. While planned logic testing at power would not remove the reactor trip function, the likelihood of a reactor trip initiating event is considered greater than during periods when no testing is conducted. Another example is switchyard work. Switchyard work is not considered safety significant in itself and is not included in the matrices. However, switchyard work in combination with EDG or AFW steam driven pump maintenance is a higher risk impact evolution due to the increased potential for a station blackout, and should be avoided.

2.3 Determination of Significant Risk Increase due to On-line Maintenance

There are several criteria for determining whether a given risk increase is safety significant or non-safety significant. The criteria utilized in this analysis were based on the EPRI PSA Applications Guide. Three thresholds for safety significance were applied in the present analysis:

- The instantaneous value of CDF calculated for the given condition should not be above 1E-3 per year.
- The change in core damage probability for the condition, which is the product of the instantaneous CDF increase (over the baseline) for the given condition and the length of time the condition would exist, should not be allowed to exceed 1E-6 without consideration of additional, nonquantifiable factors.
- The change in core damage probability for the condition may exceed 1E-6 provided: 1) the change in core damage probability does not exceed 1E-5;
 2) additional, non-quantifiable factors (possibly including contingency measures) are considered; 3) an appropriate level of management approval is obtained.

These three thresholds were applied, using the calculated CDF for each combination of equipment functions unavailable, the baseline CDF with no equipment in test or maintenance, and an assumed equipment unavailable time of 72 hours.

OMM-048	Rev. 11	Page 33 of 69

ATTACHMENT 10.2 Page 3 of 14 PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

3.0 **RESULTS**

3.1 Assumptions and Considerations

This analysis does not consider all Safety Significant Systems identified by the maintenance rule expert panel, but rather is limited to those systems whose maintenance activities may contribute to core damage through unavailability of system train functions. Some electrical systems whose functions are not made unavailable while on-line are not included in the list of system train functions. These systems are discussed in Section 3.2 and in the Notes on Table 1.

The EPRI PSA applications guide recommends an evaluation of Large Early Release Frequency (LERF) for applications. A review of the level 2 (containment performance) PSA analysis reveals that functional failures of containment safeguards systems (containment isolation, containment spray, containment fan coolers) do not significantly contribute to the potential for large early releases from sever accidents. LERF scenarios are dominated by interfacing-system LOCAs (RHR-750/751) and steam generator tube ruptures, which by nature create a release path. The status of the containment safeguards systems have little impact on large early releases, and would not be considered Safety Significant based on their limited impact on the PSA results.

Since the on-line maintenance matrix was quantified with core damage as the end-state, containment systems were not included on the matrix. However, if consideration is given to potential performance degradation of containment isolation, the frequency of large early releases would increase. Therefore, maintenance activities that render a containment isolation valve open (nonisolatable) or that compromise Main Steam isolation via the SRVs, PORVs or MSIVs should not be done while any core-damage mitigating system function listed in Table 1 is unavailable.

While instantaneous CDF and increase in core damage probability (delta CDF * time out of service) were considered, the cumulative safety impact associated with on-line maintenance activity over the entire cycle was not included. The impact of maintenance activity on initiating event frequencies, where applicable, was assumed to be an increase by a factor of ten.

As stated in the introduction, this analysis is intended to be used in conjunction with design basis information, operational experience, and engineering judgment to determine the extent and scope of any planned on-line maintenance activity.

OMM-048	Rev. 11	Page 34 of 69
---------	---------	---------------

ATTACHMENT 10.2 Page 4 of 14 PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

3.2 Presentation of Results

The results of the analysis are presented in matrix format to facilitate determination of the safety significance of system train functions being unavailable. Because of the amount of information resulting from this study, a number of different views of the results are presented. The matrices and other information are contained in Tables 1 and 2.

Table 1 lists the maintenance events that were analyzed. The table lists the maintenance event description, the system or train accident mitigation function, and the assumed impact on initiating events, if applicable. The table details the safety function to be maintained for combinations that are considered safety significant. A number of power systems, that will not have planned maintenance out of service time, have been removed from the matrix: 4KV AC (5170), 480V AC (5175 non-safety related), 208/120V AC (5185), and transformers and switchyard (5120). However, testing of these systems may introduce a higher probability of an undervoltage initiator. Therefore, work on the AFW steam driven pump and the EDGs should not be performed in conjunction with maintenance or test on these systems due to the increased potential for a station blackout.

Table 2 is a matrix which shows the number of hours that a combination of equipment can be unavailable before the change in core damage probability (delta CDF * time) would exceed 1E-6. Note that the 1E-6 core damage probability threshold is only one part of the analysis. Cells marked with an X are not recommended because the instantaneous CDF would exceed the 1E-3 threshold.

It is made up of three separate matrices: One for train A equipment, one for train B equipment, and one for "cross-train" equipment. These matrices list the maintenance events across the top and down the left side

Maintenance that exceeds the allowed hours in Table 2 will place the plant in a potentially High Risk Impact configuration and is not recommended. Planning maintenance to exceed the hours in Table 2 should be accompanied with plant general manager approval per Attachment 10.4 and a review of non-quantifiable factors (e.g. reason maintenance is necessary on-line). Any maintenance, planned or emergent, which exceeds the hours in Table 2 should be accompanied be accompanied with risk impact insights from PSA, and development of contingency plans.

OMM-048	Rev. 11	Page 35 of 69

ATTACHMENT 10.2 Page 5 of 14 PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

3.3 Use of the On-line Maintenance Matrices

The matrices apply only for reactor critical and power operation (all trips and actuation signals in place) and only for combinations of one or two system trains at a time. If three or more system train functions need to be unavailable at the same time, then further analysis needs to be performed.

The matrices only address best estimate risk impact, and not defense in depth. The most limiting configurations must be determined through a combination of Technical Specifications, the matrix, and other design basis documents.

When using these results to determine appropriate on-line maintenance, it is important to remember that all functions listed in Table 1, which are not designated as unavailable, are assumed to be functional. The scope of this application assumes that equipment must be available to provide its safety function. If the system, structure or component (SSC) is in service providing the safety function, some components may be defeated such that the ability to maintain the function is not degraded. Existing plant procedures shall be used to determine the availability of an SSC.

In case of emergent equipment unavailability, a review of the equipment functions already unavailable must be performed. Potential high risk impact situations need to be identified and non-quantifiable factors and contingency plans must be identified. An example of a non-quantifiable factor would be the need to shutdown the plant if the repair is not expedited. Plant shutdowns introduce additional risk through challenging safety systems which in itself is not quantifiable. The potential High Risk Impact configurations need to be avoided or limited in duration as much as practical. It is not recommended to intentionally enter what are potentially high risk impact configurations.

ATTACHMENT 10.2 Page 6 of 14 PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

3.4 Matrix Limitations

Not all high safety significant SSC are included directly in the matrices. Any maintenance activities or emergent conditions that could degrade any of these safety functions should be evaluated against other equipment that is unavailable. These SSCs fall in the following categories:

- Normally passive high safety significant SSCs: Reactor coolant system boundary Containment structure
- SSCs for which on-line maintenance or unavailability is not expected: Pressurizer safety valves Steam generator safety valves Safety injection accumulators Main steam isolation valves Feedwater isolation valves Station batteries

Note: The unavailability of these SSCs is controlled through short duration Tech Specs. Restoration of the unavailable function should be a top priority.

 SSCs that support containment integrity and environmental control Containment spray
 Service water booster pumps Containment cooling

Note: When performing maintenance or removing these components from service, a qualitative assessment addressing the remaining defense in depth should be performed.

Support systems
 Diesel fuel oil
 Nitrogen supply to PORVS
 Auxiliary building HVAC

Note: Maintenance activities and unavailability of these systems should be evaluated for the impact on the supported front-line system.

– Other

Control room emergency filtration and pressurization

Note: Maintenance activities and unavailability or these components are adequately controlled through Tech Spec adherence.

OMM-048	Rev. 11	Page 37 of 69
		J

ATTACHMENT 10.2 Page 7 of 14

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 1. Matrix Event Description And Safety Function

SYS	TRAIN	MATRIX EVENT DESCRIPTION	SHORT NAME	TRAIN SAFETY FUNCTION	MODELLING NOTES
	(Note 1)	(Note 5)	(see matrices)	To Be Maintained for Not Recommended Combinations	
1080	A	RPS Channel A Logic In Test & Maintenance (Includes RX Trip Bkr 1065, And Safeguards Train A)	RPS CHANNEL A	Prevent Inadvertent RX Trip, Provide RX Trip and Safeguards Actuation Logic on Valid Transient. (See Note 2)	Conservatively assumed train A SI actuation signal Fails, Increase frequency of ATWS and RX Trip.
2005	A	RCS PZR PORV Train A Unavailable (RC- 456, N2 Header, Block Valve RC-535)	RCS PZR PORV 456	Provide a Bleed Path for Feed and Bleed Cooling, and Maintain RCS Integrity.	Assumes PORV or Block Valve will not open. Stuck open Block Valve not analyzed. See Block Valve entry under train B.
2045	A	RHR Train A Unavailable	RHR PUMP A	Provide RCS Inventory Control and Decay Heat Removal	
2060	A	CVCS Charging Pump B Unavailable (Train A)	CVCS CHGP B	Provide RCP Seal Injection. If removal of function is permitted, prevent total loss of CVCS which could lead to a plant trip.	Increased frequency of total loss of CVCS initiator not included.
2080	A	SI Pump A Unavailable (Train A)	SI PUMP A	Provide RCS Inventory Control	Pump B can be swapped to the A train to maintain function.
3020	A	S/G A PORV RV-1 Unavailable (Includes Specific IA Support Manifold)	S/G A PORV RV-1	Provide Ability for Cooldown From Hot to Cold Shutdown	Open function failed: Results conservative by allowing reclose failures in cutsets.
3020	A	S/G B PORV RV-2 Unavailable (Includes Specific IA Support Manifold)	S/G B PORV RV-2	Provide Ability for Cooldown From Hot to Cold Shutdown	Open function failed: Results conservative by allowing reclose failures in cutsets.
3020	A	S/G C PORV RV-3 Unavailable (Includes Specific IA Support Manifold)	S/G C PORV RV-3	Provide Ability for Cooldown From Hot to Cold Shutdown	Open function failed: Results conservative by allowing reclose failures in cutsets.
3050	A	MFW Pump Train A Unavailable	MFWP A	Prevent Loss Causing Plant Trip, and mitigate ATWS or Loss of AFW	Assumes A train MFW or CND pumps are unavailable and increased frequency of Total Loss of MFW initiator.
3065	A	AFW MD Pump Train A Unavailable (Includes Actuation Channel)	AFW MDP A	Automatically Deliver Condensate From the CST to the S/Gs Following a Plant Trip (See Note 3)	

OMM-048	Rev. 11	Page 38 of 69

ATTACHMENT 10.2 Page 8 of 14

.

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 1 .Matrix Event Description And Safety Function

SYS	TRAIN (Note 1)	MATRIX EVENT DESCRIPTION (Note 5)	SHORT NAME (see matrices)	TRAIN SAFETY FUNCTION To Be Maintained for Not Recommended Combinations	MODELLING NOTES
3065	A	AFW SD Pump Train Unavailable	AFW SDP	Automatically Deliver Condensate From the CST to the S/Gs Following a Plant Trip (See Notes 3 and 4)	Pump is unavailable when 2 or 3 S/Gs are unavailable to supply steam or receive flow via MS-V1-8A,B,C or AFW-V2-14A,B,C
4060	A	SW Pump A Unavailable	SW PUMP A	Provide Cooling for Safety Related Equipment, Prevent Loss of SW Initiator	
4060	A	SW Pump B Unavailable	SW PUMP B	Provide Cooling for Safety Related Equipment, Prevent Loss of SW Initiator	
4080	A	CCW Pump A Unavailable (Train DS)	CCW PUMP A	Provide Cooling for Safety Related Equipment, Prevent Loss of CCW Initiator	
4080	A	CCW Pump B Unavailable (Train A)	CCW PUMP B	Provide Cooling for Safety Related Equipment, Prevent Loss of CCW Initiator	
5095	A	EDG A Unavailable (Includes Room Cooling 8210, And Fuel Oil 5100)	EDG A	Provide Power to the Emergency Bus (See Note 4)	
5175	A	480V Emergency Bus E1 In Test Or Maintenance, Assumed Available	EMERGENCY BUS E1	Prevent Bus Undervoltage Initiator and Provide Power to Emergency Bus and Safety Related MCC Loads	Assumes increased frequency of Loss of Emergency Bus E1 Initiator.
5235	A	DC, One Train A Battery Charger Unavailable	DC BAT CHG A/A1	DC Bus, supplied by a Battery Charger, Must be Available to Provide Control Power.	Assumes increased frequency of Loss of DC Bus A Initiator.
6135	A	Air Compressor A Unavailable	AIR COMP A	Prevent Loss of Instrument Air, and Provide Instrument Air to S/G PORVs and CVCS	Increased frequency of loss of Instrument Air initiator not included.
6135	A	Air, Primary Air Compressor Unavailable	AIR COMP PRIM	Prevent Loss of Instrument Air, and Provide Instrument Air to S/G PORVs and CVCS	Increased frequency of loss of Instrument Air Initiator not included.
6175	A	Fire Pump, Engine Driven Unavailable	FIRE PUMP DIESEL	Provide Alternate Cooling to SI, AFW, and Charging Pumps	
6270	A	Deepwell Pump B Unavailable	DEEPWELL PUMP B	Provide Makeup to CST or Alternate AFW Supply	

OMM-048	Rev. 11	Page 39 of 69

ATTACHMENT 10.2 Page 9 of 14

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 1 .Matrix Event Description And Safety Function

SYS	TRAIN	MATRIX EVENT DESCRIPTION	SHORT NAME	TRAIN SAFETY FUNCTION	MODELLING NOTES
	(Note 1)	(Note 5)	(see matrices)	To Be Maintained for Not Recommended Combinations	
1080	В	RPS Channel B Logic In Test & Maintenance (Includes RX Trip Bkr 1065, And Safeguards Train B)	RPS CHANNEL B	Prevent Inadvertent RX Trip, Provide RX Trip and Safeguards Actuation Logic on Valid Transient. (See Note 2)	Conservatively assumed train B SI actuation signal fails, Increase frequency of ATWS and RX trip.
2005	В	RCS PZR PORV Train B Unavailable (RC- 455C, N2 Header, Block Valve RC-536)	RCS PZR PORV 455C	Provide a Bleed Path for Feed and Bleed Cooling, and Maintain RCS Integrity Given a Stuck Open PORV.	Assumes PORV or Block Valve will not open. Stuck open Block Valve not analyzed.
2005	В	Both RCS PZR Block Valves Closed But Available	RCS BLOCK VALVES	Provide at Least One Path to Mitigate a Pressure Challenge	Assumes PORV is operable when Block Valve is open. See Block Valve entry below.
2045	В	RHR Train B Unavailable	RHR PUMP B	Provide RCS Inventory Control and Decay Heat Removal	
2060	В	CVCS Charging Pump A Unavailable (Train DS)	CVCS CHGP A	Provide RCP Seal Injection. If removal of function is permitted, prevent total loss of CVCS which could lead to a plant trip.	
2060	В	CVCS Charging Pump C Unavailable (Train B)	CVCS CHGP C	Provide RCP Seal Injection. If removal of function is permitted, prevent total loss of CVCS which could lead to a plant trip.	
2080	В	SI Pump C Unavailable (Train B)	SI PUMP C	Provide RCS Inventory Control	Pump B can be swapped to the B train to maintain function.
3050	В	MFW Pump Train B Unavailable	MFWP B	Prevent Loss Causing Plant Trip, and mitigate ATWS or Loss of AFW	Assumes B train MFW or CND pumps are unavailable and increased frequency of total loss of MFW initiator.
3065	В	AFW MD Pump Train B Unavailable (Includes Actuation Channel)	AFW MDP B	Automatically Deliver Condensate From the CST to the S/Gs Following a Plant Trip	
4060	В	SW Pump C Unavailable	SW PUMP C	Provide Cooling for Safety Related Equipment, Prevent Loss of SW Initiator	

OMM-048	Rev. 11	Page 40 of 69

ATTACHMENT 10.2 Page 10 of 14

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 1 .Matrix Event Description And Safety Function

SYS	TRAIN (Note 1)	MATRIX EVENT DESCRIPTION (Note 5)	SHORT NAME (see matrices)	TRAIN SAFETY FUNCTION To Be Maintained for Not Recommended Combinations	MODELLING NOTES
4060	В	SW Pump D Unavailable	SW PUMP D	Provide Cooling for Safety Related Equipment, Prevent Loss of SW Initiator	
4080	В	CCW Pump C Unavailable (Train B)	CCW PUMP C	Provide Cooling for Safety Related Equipment, Prevent Loss of CCW Initiator	
5095	В	EDG B Unavailable (Includes Room Cooling 8210, And Fuel Oil 5100)	EDG B	Provide Power to the Emergency Bus (See Note 4)	
5098	В	DSDG (Includes DS Fuel Oil 5100) Unavailable	DSDG	Provide Power to the DS Bus	Taking out the DSDG is not as limiting as taking out the DS Bus.
5114	В	DS Bus Unavailable	DS BUS	Provide Power to Chg Pump A, CCW Pump A (Alternate for SW Pump D, MCC5 and Deepwell Pumps)	Taking out the DS Bus takes out the DSDG, CCWA, CVCS CHGP A and can be considered one function.
5175	В	480V Emergency Bus E2 In Test Or Maintenance, Assumed Available	EMERGENCY BUS E2	Prevent Bus Undervoltage Initiator and Provide Power to Emergency Bus and Safety Related MCC Loads	Assumes increased frequency of Loss of Emergency Bus E2.
5235	В	DC, One Train B Battery Charger Unavailable	DC BAT CHG B/B1	DC Bus, supplied by a Battery Charger, Must be Available to Provide Control Power.	Assumes increased frequency of Loss of DC Bus B Initiator.
6135	В	Air Compressor B Unavailable	AIR COMP B	Prevent Loss of Instrument Air, and Provide Instrument Air to S/G PORVs and CVCS	Increased frequency of loss of Instrument Air Initiator not included.
6135	В	Air Compressor D Unavailable	AIR COMP D	Prevent Loss of Instrument Air, and Provide Instrument Air to S/G PORVs and CVCS	Increased frequency of loss of Instrument Air Initiator not included.

OMM-048	Rev. 11	Page 41 of 69
OMM-048	Rev. 11	Page 41 of

ATTACHMENT 10.2 Page 11 of 14

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 1 .Matrix Event Description And Safety Function

SYS	TRAIN (Note 1)	MATRIX EVENT DESCRIPTION (Note 5)	SHORT NAME (see matrices)	TRAIN SAFETY FUNCTION To Be Maintained for Not Recommended Combinations	MODELLING NOTES
6175	В	Fire Pump, Motor-Driven Unavailable	FIRE PUMP MOTOR	Provide Alternate Cooling to SI, AFW, and Charging Pumps	
6270	В	Deepwell Pump A Unavailable	DEEPWELL PUMP A	Provide Makeup to CST or Alternate AFW Supply	
6270	В	Deepwell Pump C Unavailable	DEEPWELL PUMP C	Provide Makeup to CST or Alternate AFW Supply	

NOTES:

- 1. Trains as designated by 12 week on-line schedule.
- 2. Do not perform RPS channel logic test for combinations designated as not allowed. Matrix assumes that test does not remove RX Trip and actuation function.
- 3. The CST must be available to provide suction to the AFW Pumps otherwise all three pumps are considered unavailable.
- 4. A number of power systems that will not have planned maintenance unavailabilities, are not included on the matrix: 4KV AC (5170), 480V AC (5175 non -safety related), 208/120V AC (5185) and transformers and switchyard (5120). However, testing or maintenance activities on these systems may introduce additional risk of an undervoltage initiator. Therefore, do not perform testing or maintenance activities on these systems while performing EDG or AFW SDP maintenance due to increased risk of a station blackout.
- 5. This matrix considers risk only from a Core Damage.

ļ	OMM-048	Rev. 11	Page 42 of 69

ATTACHMENT 10.2 Page 11 of 14

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 1 .Matrix Event Description And Safety Function

SYS	TRAIN (Note 1)	MATRIX EVENT DESCRIPTION (Note 5)	SHORT NAME (see matrices)	TRAIN SAFETY FUNCTION To Be Maintained for Not Recommended Combinations	MODELLING NOTES
6175	В	Fire Pump, Motor-Driven Unavailable	FIRE PUMP MOTOR	Provide Alternate Cooling to SI, AFW, and Charging Pumps	
6270	В	Deepwell Pump A Unavailable	DEEPWELL PUMP A	Provide Makeup to CST or Alternate AFW Supply	
6270	В	Deepwell Pump C Unavailable	DEEPWELL PUMP C	Provide Makeup to CST or Alternate AFW Supply	

NOTES:

- 1. Trains as designated by 12 week on-line schedule.
- 2. Do not perform RPS channel logic test for combinations designated as not allowed. Matrix assumes that test does not remove RX Trip and actuation function.
- 3. The CST must be available to provide suction to the AFW Pumps otherwise all three pumps are considered unavailable.
- 4. A number of power systems that will not have planned maintenance unavailabilities, are not included on the matrix: 4KV AC (5170), 480V AC (5175 non -safety related), 208/120V AC (5185) and transformers and switchyard (5120). However, testing or maintenance activities on these systems may introduce additional risk of an undervoltage initiator. Therefore, do not perform testing or maintenance activities on these systems while performing EDG or AFW SDP maintenance due to increased risk of a station blackout.
- 5. This matrix considers risk only from a Core Damage.

		1
OMM-048	Rev. 11	Page 42 of 69

ATTACHMENT 10.2 Page 12 of 14

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 2. Matrix Showing Allowable Hours for Plant Configurations To Remain Non-Risk Significant (DELTA CDP<1E-06)

Exceeding these allowed hours PGM approval, review of non-qua factors, contingency planning a insights. X - Safety Significant Exceeds M Instantaneous CDF of 1E-3 SHOULD BE AVOIDED	require antifiable and PSA faximum 3 and	RPS CHANNEL A	RCS PZR PORV 456	RHR PUMP A	CVCS CHGP B	SI PUMP A	S/G A PORV RV-1	S/G B PORV RV-2	S/G C PORV RV-3	MFWP A	AFW MDP A	AFW SDP	SW PUMP A	SW PUMP B	CCW PUMP A	CCW PUMP B	EDG A	EMERGENCY BUS E1	DC BAT CHG A/A1	AIR COMP A	AIR COMP PRIM	FIRE PUMP DIESEL	
	1000	1080	2005	2045	2060	2080	3020	3020	3020	3050	3065	3065	4060	4060 594	4080	4080	122	718	630	804	775	617	303
RPS CHANNEL A	1080	804	00	130	401	320	<u> </u>	<u> </u>	<u> </u>	290	27	26	06	05	400	76	24	01	000	004	97	017	70
RCS PZR PORV 456	2005	56	93	11	80	20	54	- 54	00	110	05	20	161	161	15/	155	106	160	165	172	170	164	142
	2045	136		1/4	1001	109	104	104	104	262	05	00	719	719	506	270	165	030	804	1068	10/2	780	461
	2060	461	85	149	1001	147	124	124	02	070	70	00	156	156	404	407	199	521	190	576	560	103	227
	2080	326	20	169	147	5/6	100	50	<u> </u>	2/0	- <u>/0</u> =0	50	100	100	104	12/	80	12/1	121	126	136	121	117
S/G A PORV RV-1	3020		54	22	124	83	130	100	52	109	59	59	120	120	124	124	<u>90</u>	12/1	121	136	136	121	117
S/G B PORV RV-2	3020			22	124	83	52_	130	52	109	59	59	100	120	124	124	<u>00</u>	12/1	121	126	126	121	117
S/G C PORV RV-3	3020		54	22	124	070	52	100	100	510	14	45	120	120	280	202	144	506	169	5/9	5/1	163	211
	3050	296	39	110	303	2/0	109	108	109	14	104	40	430	430	07	07	72	102	101	104	102	100	02
	3065	/8	37	65	95	/8	59	59	59	14	104	105	30	30	57		10	100	02	104	102	100	02
AFW SDP	3065	71	26	60	90	450	100	100	100	40		02	2100	70	700	90	10/	171.0	1207	2100	2006	002	551
	4060	584	86	161	718	450	120	120	100	430	90	92	70	2100	021	950	104	1710	1207	2100	2000	012	551
SW PUMP B	4060	584	85	161	/18	456	128	128	128	438	90_	90	700	2190	10/0	000 V	104	005	001	1040	12000	022	500
CCW PUMP A	4080	466	83	154	506	404	124	124	124	389	97	30	102	004	1 <u>340</u>	1000	170	4450	004	1060	1007	932	500
CCW PUMP B	4080	4/1	76	155	279	407	124	124	124	393	9/	98	104	050	<u> </u>	1390	1/2	100	104	1009	104	942	100
EDG A	5095	122	24	106	165	188	80	80	80	144	/3	14	184	184	161	1/2	196	190	184	190	194	131	128
EMERGENCY BUS E1	5175	718	91	169	932	531	134	134	134	506	102	100	1/18	1/18	995	1153	190	6/38	2137	6257	5475	2037	706
DC BAT CHG A/A1	5235	639	90	165	804	489	131	131	131	468	101	92_	1307	1307	834	963	184	2137	3129	3129	2920	1537	93
AIR COMP A	6135	804	91	173	1068	576	136	136	136	548	104	105	2190	2190	1348	1369	196	6257	3129	8760	8/60	2920	804
AIR COMP PRIM	6135	775	87	172	1043	569	136	136	136	541	102	102	2086	2086	1307	1327	194	54/5	2920	8/60	8/60	2/38	/89
FIRE PUMP DIESEL	6175	617	92	164	789	484	131	131	131	463	100	100	903	913	932	942	131	2037	1537	2920	2738	2920	635
DEEPWELL PUMP B	6270	303	79	143	461	337	117	117	117	311	93	93	551	551	506	509	128	706	93	804	789	635	804

Train A Matrix

OMM-048	Rev. 11	Page 43 of 69

ATTACHMENT 10.2 Page 13 of 14

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 2. Matrix Showing Allowable Hours for Plant Configurations To Remain Non-Risk Significant

(DELTA CDP<1E-06)

											<u></u>												
Exceeding these allowed hours PGM approval, review of r quantifiable factors, conting planning and PSA insigh X - Safety Significant Exceeds Instantaneous CDF of 1E- SHOULD BE AVOID	s require non- gency nts. Maximum -3 and DED	B RPS CHANNEL B	RCS PZR PORV 455C	RCS BLOCK VALVES	RHR PUMP B	CVCS CHGP A	CVCS CHGP C	S SI PUMP C	MFWP B	AFW MDP B	SW PUMP C		CCW PUMP C	EDG B	5 DSDG	SNB SD	EMERGENCY BUS E2	DC BAT CHG B/B1	AIR COMP B	AIR COMP D	FIRE PUMP MOTOR		
	1080	804	56	400	168	100	461	503	326	124	105	101	479	89	163	66	558	712	804	730	226	701	303
	2005	56	90	92	15	85	85	36	40	44	57	56	86	10	85	52	88	91	91	87	72	90	79
RCS BLOCK VALVES	2005	400	92	2738	210	654	775	932	244	148	143	137	952	76	241	90	1095	1947	2576	1825	293	1947	596
BHB PLIMP B	2005	168	15	210	229	180	188	199	143	85	91	89	198	78	121	66	204	221	229	222	135	222	178
CVCS CHGP A	2060	409	85	654	180	859	153	95	370	147	124	83	466	85	207	93	576	762	859	782	238	768	417
CVCS CHGP C	2060	461	85	775	188	153	1081	97	404	153	132	126	283	107	192	38	679	922	1068	963	252	932	461
SLPUMP C	2080	503	36	932	199	95	97	1413	411	122	137	131	718	110	216	49	804	1168	1413	1217	267	1184	512
MEWP B	3050	326	40	244	143	370	404	411	644	23	122	117	447	100	184	78	476	588	644	600	217	528	173
AFW MDP B	3065	124	44	148	85	147	153	122	23	178	75	73	158	72	98	51	162	169	177	136	116	173	146
SW PUMP C	4060	105	57	143	91	124	132	137	122	75	151	27	137	67	93	56	140	148	151	148	76	145	79
SW PUMP D	4060	101	56	137	89	83	126	131	117	73	27	144	131	57	92	56	128	141	144	142	73	139	76
CCW PUMP C	4080	479	86	952	198	466	283	718	447	158	137	131	1460	110	201	Х	819	1200	1436	1234	268	1200	518
EDG B	5095	89	10	76	78	85	107	110	100	72	67	57	110	119	26	22	111	116	119	117	87	117	102
DSDG	5098	163	85	241	121	207	192	216	184	98	93	92	201	26	258	93	225	248	258	250	145	249	196
DS BUS	5114	66	52	90	66	93	38	49	78_	51	56	56	X	22	93	93	78	91	93	92	70	91	74
EMERGENCY BUS E2	5175	558	88	1095	204	576	679	804	476	162	140	128	819	111	225	78	1825	1436	1825	1510	278	1348	528
DC BAT CHG B/B1	5235	712	91	1947	221	762	922	1168	588	169	148	141	1200	116	248	91	1436	6738	6257	3809	313	3021	695
AIR COMP B	6135	804	91	2576	229	859	1068	1413	644_	177	151	144	1436	119	258	93	1825	6257	8760	5153	328	6738	804
AIR COMP D	6135	730	87	1825	222	782	963	1217	600	136	148	142	1234	117	250	92	1510	3809	5153	8760	316	3809	701
FIRE PUMP MOTOR	6175	226	72	293	135	238	252	267	217	116	76	73	268	87	145	70	278	313	328	316	328	314	234
DEEPWELL PUMP A	6270	701	90	1947	222	768	932	1184	528	173	145	139	1200	117	249	91	1348	3021	6738	3809	314	6738	21
DEEPWELL PUMP C	6270	303	79	596	178	417	461	512	173	146	79	76	518	102	196	74	528	695	804	701	234	21	804

Train B Matrix

OMM-048	Rev. 11	Page 44 of 69

ATTACHMENT 10.2 Page 14 of 14

PSA OF ON-LINE MAINTENANCE FOR H.B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

Table 2. Matrix Showing Allowable Hours for Plant Configurations To Remain Non-Risk Significant (DELTA CDP<1E-06)

								.~/											_				
Exceeding these allowed hours PGM approval, review of r quantifiable factors, conting planning and PSA insigh X - Safety Significant Exce Maximum Instantaneous CDF 1E-3 and SHOULD BE AVO	s require non- gency nts. eeds of NDED	B RPS CHANNEL B	RCS PZR PORV 455C	RCS BLOCK VALVES	B RHR PUMP B	CVCS CHGP A	S CVCS CHGP C	S SI PUMP C	S MFWP B	AFW MDP 8	D AMUA WS		D AMDA WDD	в БОЭ 2005	5098	SNB S0	EMERGENCY BUS E2	DC BAT CHG B/B1	AIR COMP B	AIR COMP D	FIRE PUMP MOTOR		2 22 22 22 22
	1080	105	2005	400	168	2000	461	421	326	124	105	101	479	89	163	66	558	712	804	730	226	701	303
	2005	56	72	93	15	85	85	36	40	44	57	56	86	10	85	52	88	91	91	87	72	90	79
	2045	136	11	134	X	144	149	155	119	86	81	78	155	20	104	60	159	167	173	170	113	169	143
CVCS CHGP B	2060	461	85	775	188	376	487	97	404	153	132	126	521	102	192	44	679	922	1068	963	252	932	461
	2080	326	26	289	164	142	147	Х	301	136	119	116_	413	21	178	60	436	531	576	541	209	534	337
S/G A PORV RV-1	3020	117	54	130	22	121	124	65	113	77	71	70	124	64	89	56	128	134	136	134	97	134	117
S/G B PORV RV-2	3020	117	54	130	22	121	124	65	113	77	71	70_	124	_64_	89	56	128	134	136	134	97	134	117
S/G C PORV RV-3	3020	117	54	130	22	121	124	65	113	77	71	70	124	64	89	56	128	134	136	134	. 97	134	117
MFWP A	3050	296	39	229	138	336	363	370	85	106	119	114	398	98_	176	79	152	348	548	515	205	461	311
AFW MDP A	3065	78	40	94	71	93_	95	97	77	10	61	60	_ 97	22	74	49	17	27	104	102	79	102	93
AFW SDP	3065	71	26	80	65	_94	96	94	51	15	45	43	98	12	74	49	79	93	105	100	76	104	93
SW PUMP A	4060	584	87	1217	207	541	718	859	498_	164	76	59	876_	69	217	66	649	1653	2190	1752	159	1390	551
SW PUMP B	4060	584	85	1217	207	548	718	859	498	164	_77_	59		65	211	65	649	1653	2190	1752	159	1390	551
CCW PUMP A	4080	466	83	903	196	167	528	690	436	157	136	131	<u> </u>	100	218	93	718	1109	1348	1168	265	1138	506
CCW PUMP B	4080	471	76	894	196	459	515	701	440_	157	136	131	<u> </u>	83	155_	<u> </u>	724	1138	1369	1184	265	1153	509
EDG A	5095	122	24	145	72	116	155	98	150	43	48	40	151		29	23	154	188	196	191	122	190	128
EMERGENCY BUS E1	5175	718	91	1947	221	762_	932	1153	548	121	25	25	1043	116	247	83	X	3244	6257	3650	204	3021	706
DC BAT CHG A/A1	5235	639	90	1460	206	679	804	826	231	27_	34	34	867	113	238	85	1068	2137	3129	2037	231	2190	93
AIR COMP A	6135	804	91	2576	229	859	1068	1413	644	177	151	144	1436	119	258	93	1825	6257	2920	5153	328	6738	804
AIR COMP PRIM	6135	775	87	2137	226	842	1043	1369	635	177	151	144	1390	119	256	93	1752	5153	8760	1436	326	5840	789
FIRE PUMP DIESEL	6175	617	92	1413	213	7.82	789	963	531	167	136	90	973	92	248	91	1138	2037	2920	2190	_26	2086	635
DEEPWELL PUMP B	l 6270	303	79	596	178	417	461	512	173_	146	79	76	518	102	196	74	528	695	804	701	234	21	

Train A by Train B Matrix

OMM-048	Rev. 11	Page 45 of 69



Based on Calculation RNP-M/MECH-1590 Use Thermal Inertia Factor = $0.00167 \times t(hrs)$ prior to 100 Hours After Shutdown



FIGURE S-3.1-3 BORCH ADDITION - COOLANT HOT (-580°F)

...

. . ند . .

-.

. .

1.11

3



22M BORGN IN COOLANT

ير الله

FIGURE S-3.1-4 BORON ADDITION - COOLANT COLD (-100°F)

VOLUME, GAL*

-i -: -:

ADDITION

:



5

• /

. L.



1.1



· • 0



KE 20 X 20 TO THE INCH. S TO PACHES REDUCTED A ESSERIC OF THE BOOM

46 1240

1





Curve 7.1

1:

٩...٩



Curve 7.19 - Loss of Residual Heat Removal Cooling Water Level Between 0" to -10" Below Vessel Flange

5.00

Based on calculation RNP-M/MECH-1590

△ 20 Days After Shutdown

* 40 Days After Shutdown



Curve 7.20 - Loss of Residual Heat Removal Cooling Water Level Between -10" to -36" Below Vessel Flange

. •

⊟ 100 Hours After Shutdown → 10 Days After Shutdown △ 20 Days After Shutdown ★ 40 Days After Shutdown

Based on calculation RNP-M/MECH-1590

Rev. 153



Curve 7.21 - Loss of Residual Heat Removal Cooling Water Level Between -36" to -72" Below Vessel Flange



Based on calculation RNP-M/MECH-1590

Rev. 153

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.16 RCS Specific Activity

- LCO 3.4.16 The specific activity of the reactor coolant shall be within limits.
- APPLICABILITY: MODES 1 and 2, MODE 3 with RCS average temperature $(T_{avg}) \ge 500^{\circ}F$.

ACTIONS

-

CONDITION	REQUIRED ACTION	COMPLETION TIME
<pre>A. DOSE EQUIVALENT I-131 > 1.0 μCi/gm.</pre>	Note LCO 3.0.4 is not applicable.	
	A.1 Verify DOSE EQUIVALENT I-131 within the acceptable region of Figure 3.4.16-1.	Once per 4 hours
	AND	
· -	A.2 Restore DOSE EQUIVALENT I-131 to within limit.	48 hours
B. Gross specific activity of the reactor coolant not within limit.	B.1 Be in MODE 3 with T _{avg} < 500°F.	6 hours

(continued)

ACTIONS (continued)

ACTI	ONS (continued)	1				
CONDITION			REQUIRED ACTION	COMPLETION TIME		
C.	Required Action and associated Completion Time of Condition A not met.	C.1	Be in MODE 3 with T _{avg} < 500°F.	6 hours		
	<u>OR</u>					
	DOSE EQUIVALENT I-131 in the unacceptable region of Figure 3.4.16-1.					

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.4.16	.1 Verify reactor coolant gross specific activity ≤ 100/Ē μCi/gm.	7 days
SR 3.4.16	.2	14 days <u>AND</u> Between 2 and 6 hours after a THERMAL POWER change of ≥ 15% RTP within a 1 hour period

SURVEILLANCE REQUIREMENTS (continued)

SR 3.4.16.3	Not required to be performed until 31 days after a minimum of 2 effective full power days and 20 days of MODE 1 operation have elapsed since the reactor was last subcritical for \geq 48 hours.	
	Determine \overline{E} from a sample taken in MODE 1 after a minimum of 2 effective full power days and 20 days of MODE 1 operation have elapsed since the reactor was last subcritical for \geq 48 hours.	184 days



Figure 3.4.16-1 Reactor Coolant DOSE EQUIVALENT I-131 Specific Activity Limit Versus Percent of RATED THERMAL POWER

HBRSEP Unit No. 2

Amendment No. 176

3.7 PLANT SYSTEMS

3.7.4 Auxiliary Feedwater (AFW) System

LCO 3.7.4 Four AFW flow paths and three AFW pumps shall be OPERABLE.

Only one AFW flow path with one motor driven pump is required to be OPERABLE in MODE 4.

APPLICABILITY: MODES 1, 2, and 3, MODE 4 when steam generator is being used for heat removal.

ACTIONS

	CONDITION		REQUIRED ACTION	COMPLETION TIME	
Α.	One AFW pump inoperable in MODE 1, 2, or 3. <u>OR</u> One or two AFW flow paths inoperable in MODE 1, 2, or 3.	A.1	Restore AFW pump or flow path(s) to OPERABLE status.	7 days <u>AND</u> 8 days from discovery of failure to meet the LCO	
Β.	Two motor driven AFW pumps inoperable in MODE 1, 2, or 3. OR Three motor driven AFW flow paths inoperable in MODE 1, 2, or 3.	B.1	Restore one motor driven AFW pump or one flow path to OPERABLE status.	24 hours <u>AND</u> 8 days from discovery of failure to meet the LCO	

(continued)

HBRSEP Unit No. 2

	CONDITION		REQUIRED ACTION	COMPLETION TIME	
C.	Required Action and associated Completion Time for Condition A or B not met.	C.1 <u>AND</u> C.2	Be in MODE 3. Be in MODE 4.	6 hours 18 hours	
D.	Steam driven AFW pump or flow path inoperable in MODE 1, 2, or 3. <u>AND</u> One motor driven AFW pump or flow path inoperable in MODE 1, 2, or 3.	D.1 <u>AND</u> D.2	Be in MODE 3. Be in MODE 4.	6 hours 18 hours	
Е. <u>OR</u>	Four AFW flow paths inoperable in MODE 1, 2, or 3. Three AFW pumps inoperable in MODE 1, 2, or 3.	E.1	NOTE	Immediately	
F.	Required AFW pump and flow path inoperable in MODE 4.	F.1	Initiate action to restore AFW pump and flow path to OPERABLE status.	Immediately	

HBRSEP Unit No. 2

~

Amendment No. 176

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.7.4.1	Verify each AFW manual, power operated, and automatic valve in each water flow path, and in the steam supply flow path to the steam driven AFW pump, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days
SR 3.7.4.2	NoTE Not required to be performed for the steam driven AFW pump until 24 hours after ≥ 1000 psig in the steam generator. Verify the developed head of each AFW pump at the flow test point is greater than or equal to the required developed head.	31 days on a STAGGERED TEST BASIS
SR 3.7.4.3	Not applicable in MODE 4 when steam generator is being used for heat removal. Verify each AFW automatic valve that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	18 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

م مرجع المرجع ا

	SURVEILLANCE	FREQUENCY			
SR 3.7.4.4	 3.7.4.4NOTES 1. Not required to be performed for the steam driven AFW pump until 24 hours after ≥ 1000 psig in the steam generator. 2. Not applicable in MODE 4 when steam generator is being used for heat removal 				
	Verify each AFW pump starts automatically on an actual or simulated actuation signal.	18 months			
SR 3.7.4.5	Not required to be performed for the steam driven AFW pump until prior to entering MODE 1. Verify proper alignment of the required AFW flow paths by verifying flow from the condensate storage tank to each steam generator.	Prior to entering MODE 2, whenever unit has been in MODE 5 or 6 for > 30 days			
SR 3.7.4.6	Verify the AFW automatic bus transfer switch associated with discharge valve V2-16A operates automatically on an actual or simulated actuation signal.	18 months			

Amendment No. 176
3.7 PLANT SYSTEMS

3.7.6 Component Cooling Water (CCW) System

LCO 3.7.6 Two CCW trains powered from emergency power supplies shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION		REQUIRED ACTION		COMPLETION TIME
Α.	One required CCW train inoperable.	A.1	NOTE	72 hours
В.	Required Action and associated Completion Time of Condition A not met.	B.1 <u>AND</u> B.2	Be in MODE 3. Be in MODE 5.	6 hours 36 hours

.

SURVEILLANCE REQUIREMENTS

		SURVEILLANCE	FREQUENCY
SR	3.7.6.1	NOTE- Isolation of CCW flow to individual components does not render the CCW System inoperable. Verify each required CCW manual, power operated, and automatic valve in the flow path servicing safety related equipment, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days
SR	3.7.6.2	Verify each required CCW pump starts automatically on an actual or simulated LOP DG Start undervoltage signal.	18 months

7

INITIAL SUBMITTAL

ROBINSON EXAM 2001-301 MARCH 26 - APRIL 2, 2001

INITIAL SUBMITTAL -RO/SRO COMMON WRITTEN EXAMINATION QUESTIONS 51-95

Question: 51

Given the following conditions:

- A reactor trip and safety injection have occurred.
- Due to multiple failures, an entry has been made to EPP-16, "Uncontrolled Depressurization of All Steam Generators."

i

- Containment pressure is 8 psig.
- The RCS cooldown rate is 130 °F/hour.
- SG levels are:

SG	LEVEL	
'A'	1%	
'B'	3%	
'C'	14%	

Which ONE (1) of the following actions should be taken?

- a. Secure all AFW to 'A' and 'B' SGs, while feeding 'C' SG at a rate between 80 gpm and 90 gpm
- b. Secure all AFW flow to all SGs until 'C' SG is below 8%, then feed **ONLY** 'C' SG at a rate between 80 gpm and 90 gpm
- c. Feed 'A' and 'B' SGs at a rate between 80 gpm and 90 gpm, while feeding 'C' SG only as needed to maintain the RCS cooldown rate below 100 °F/hour
- d. Feed all SGs at a rate between 80 gpm and 90 gpm

Answer:

d. Feed all SGs at a rate between 80 gpm and 90 gpm

								Common Question Reference	ce
QUESTION N TIER/GROUF K/A:	NUMBER: P: WE12EK1.2	51	RO	1/1		SRO	1/1		
	Knowledge of (Uncontrolled operating pro-	f the operation Depressurizat cedures.	al implic tion of al	ations of Il Steam	the foll Genera	owing con tors) Norm	cepts a ıal, abr	s they apply to the ormal and emergency	
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	55.41(b)	RO RO	3.5 4	55.43(SRO b) SRO	3.8		
OBJECTIVE:	EPP-016-08								
	Given plant co directed in EF	onditions EVAl PP-16.	_UATE t	the appro	opriate a	actions to r	nitigate	e consequences of steps as	
REFERENCE	ES:	EPP-016							
SOURCE:	New	X Significa	antly Mo	odified			Direc	t 🔲	
SOURCE:	New	X Significa	antly Mo Bank	odified Numbei	□		Direc		
SOURCE: JUSTIFICAT <i>a.</i>	New	X Significat Plausible sind cooldown, bu 18%.	antly Mo Bank ce this is t all SGs	odified Number s the req s must b	uired ra e fed at	te for 'C' S a minimur	<i>Direc</i> G and m	t D NEW this would limit the of 80 gpm until level is above	
SOURCE: JUSTIFICAT a. b.	New	X Significat Plausible sind cooldown, bu 18%. Plausible sind minimum rate	antly Mo Bank ce this is t all SGs ce this w e of 80 g	odified Number s the req s must b yould lim	uired ra e fed at it the cc level is	te for 'C' S a minimur oldown, bi above 189	Direc G and f m rate o ut all So %.	t D NEW this would limit the of 80 gpm until level is above Gs must be fed at a	
SOURCE: JUSTIFICAT a. b. c.	New	X Signification Plausible sind cooldown, but 18%. Plausible sind minimum rate Plausible sind cooldown, but 18%, not 8%	antly Mo Bank ce this is t all SGs ce this w e of 80 g ce this is t all SGs due to a	odified Number s the req s must b yould lim pm until s the req s must b adverse	uired ra e fed at it the co level is uired ra e fed at contain	te for 'C' S a minimur oldown, bi above 189 te for 'A' ai a minimur ment condi	<i>Direc</i> G and f m rate c wut all SC %. nd 'B' S m rate c itions.	this would limit the of 80 gpm until level is above Gs must be fed at a Gs and this would limit the of 80 gpm until level is above	
SOURCE: JUSTIFICAT a. b. c. d.	New	X Signification Plausible sind cooldown, but 18%. Plausible sind minimum rate Plausible sind cooldown, but 18%, not 8% With an exce All SGs must	antly Mo Bank be this is t all SGs t all SGs t all SGs t all SGs due to a ssive co be fed a	odified Number s the req s must b yould lim pm until s the req s must b adverse poldown at a rate	uired ra e fed at it the cc level is uired ra e fed at containn rate, AF of at lea	te for 'C' S a minimur oldown, br above 189 te for 'A' ar a minimur ment cond W flow is f ast 80 gpm	Direc G and f m rate o wt all S0 %. nd 'B' S m rate o itions. throttleo n due to	t D NEW this would limit the of 80 gpm until level is above Gs must be fed at a Gs and this would limit the of 80 gpm until level is above d to between 80 and 90 gpm. b level being below 18%.	
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Comprehen	New ION: CORRECT	X Signification Plausible sind cooldown, but 18%. Plausible sind minimum rate Plausible sind cooldown, but 18%, not 8% With an exce All SGs must	antly Mo Bank De this is t all SGs t all SGs t all SGs due to a ssive co be fed a	odified Number s the req s must b yould lim pm until s the req s must b adverse boldown at a rate	uired ra e fed at it the co level is uired ra e fed at containn rate, AF of at lea	te for 'C' S a minimur oldown, bu above 189 te for 'A' au a minimur ment condi W flow is f ast 80 gpm Rating	Direc G and f m rate o wt all So %. nd 'B' So m rate o itions. throttleo n due to	t D NEW this would limit the of 80 gpm until level is above Gs must be fed at a GGs and this would limit the of 80 gpm until level is above d to between 80 and 90 gpm. o level being below 18%.	

RNP NRC Written Examination

REFERENCES SUPPLIED:

Ŀ

ł

UNCONTROLLED DEPRESSURIZATION OF ALL STEAM GENERATORS

Rev. 13

Page 7 of 31

	TNOTDIIOTONO	RESPONSE NOT OBTAINED
STEP	INSTRUCTIONS	
6.	Locally Verify The Following Valves - CLOSED	
	a. BYPASS DRN & WARM-UP LINE TO AFW PUMP:	
	• MS-20	
	• MS-29	
	• MS-38	
	b. STEAM LINE BEFORE SEAT DRAIN ROOT ISOL:	
	• MS-19	
	• MS-28	
	• MS-37	
	C. STEAM LINE AFTER SEAT DRAIN ROOT ISOL:	
	• MS-21	
	• MS-30	
	• MS-39	
7.	. Check Cooldown Rate In RCS Cold Legs - GREATER THAN 100°F/HR IN LAST 60 MINUTE	Go To Step 11.
8	. Check MDAFW Pump Status - AT LEAST ONE AVAILABLE	Go To Step 10.

EPP-16	UNCONTROLLED DEPRESSUR GENERA	IZATION OF ALL STEAM TORS	Rev. 13 Page 8 of 31
9. Contro RCS Co a. Th: 80 us: •	GENERA INSTRUCTIONS ol Feed Flow To Minimize boldown As Follows: cottle feed flow to between gpm and 90 gpm to each S/G ing MDAFW FLOW CONTROLLER: FIC-1424, AFW PUMP A DISCH FLOW OR FIC-1425, AFW PUMP B DISCH FLOW	a. Establish between 90 gpm feed flow to as follows: 1) Open the breake MDAFW HEADER DI Valves: • V2-16A (MCC COMPT-2ML) • V2-16C (MCC COMPT-3J) • V2-16A (MCC COMPT-4C) • V2-16B (MCC COMPT-4C) • V2-16B (MCC COMPT-4C) • V2-16B (MCC COMPT-4F) 2) Locally thrott1 DISCH Valves to 80 gpm to 90 gH S/G: • AFW-V2-16A • AFW-V2-16B	Page 8 of 31 TAINED 80 gpm and co each S/G ers for SCHARGE 2-9, 2-9, 2-10, 2-10, 2-10, 2-10, 4 AFW HDR b establish pm to each - S/G "A" - S/G "B" - S/G "C"
b. Go	To Step 11	3) Go To Step 11.	

EPP-16		UNCONTROLLED DEPRESSURI GENERAT	Rev. 13 Page 9 of 31	
STEP		INSTRUCTIONS	RESPONSE NOT OB	rained
10.	Contro RCS Co a. Th: 80 us: CO	ol Feed Flow To Minimize coldown As Follows: rottle feed flow to between gpm and 90 gpm to each S/G ing FIC-6416, SDAFW FLOW NTROLLER	 a. Establish between 90 gpm feed flow to as follows: 1) Open the breake PUMP TO S/G: V2-14A (MCC CMPT-3C) V2-14B (MCC COMPT-1C) V2-14C (MCC COMPT-1C) V2-14C (MCC COMPT-4M) 2) Locally thrott PUMP FW DISCH establish 80 g; to each S/G: AFW-V2-14A AFW-V2-14C 	80 gpm and to each S/G ers to SDAFW C-10, C-9, C-10, le SDAFW TO SG to pm to 90 gpm - S/G "A" - S/G "B"
11.	Maint Flow Than	ain A Minimum Of 80 GPM AFW To Each S/G With Level Less 8% [18%]		
12.	Check 50%	S/G Levels - ALL LESS THAN	Control feed flow to level less than 50%	maintain in all S/Gs.
13.	. Reque Sampl	st Periodic RCS Boron es		
14.	Check STABL	: RCS Hot Leg Temperatures - E <u>OR</u> DECREASING	Control feed flow <u>OR</u> to stabilize RCS Hot temperatures.	, steam dump Leg

Question: 52

Given the following conditions:

- The unit is operating at 100% power.
- Testing is being performed on Reactor Trip Breaker 'B' and it is currently open.
- A loss of the 'A' 125 VDC Distribution Panel occurs.
- Reactor Trip Breaker 'A' fails to open.

Which ONE (1) of the following describes the expected response of the plant due to this sequence of events, assuming **NO** operator action?

- a. **NO** reactor trip occurs
- b. Reactor Trip Bypass Breaker 'B' opens on an Undervoltage trip **ONLY**, resulting in a reactor trip
- c. Reactor Trip Bypass Breaker 'B' opens on a Shunt trip **ONLY**, resulting in a reactor trip
- d. Reactor Trip Bypass Breaker 'B' opens on **BOTH** an Undervoltage trip and a Shunt trip, resulting in a reactor trip

Answer:

b. Reactor Trip Bypass Breaker 'B' opens on an Undervoltage trip **ONLY**, resulting in a reactor trip

QUESTION N TIER/GROUF K/A:	UMBER: ': 012K2.01	52	RO	2/2	SRO	2/2	
	Knowledge of interconnectic	bus power sup ns	oplies to	the follo	wing: RPS chanr	iels, compor	ients, and
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55. 4 1(b)	RO RO	3.3 8	SRO 55.43(b) SRO	3.7	
OBJECTIVE:	RPS-06						
	LIST power si	upplies for the	major Rl	PS Syste	em components a	as listed in th	e EDPs.
REFERENCE	:S:	SD-011 EDP-004					
SOURCE:	New	Significa	ntly Mo	dified	X	Direct]
			Bank I	Number	RPS-09	00)6
a.	ION.	Plausible sinc performed on	e no trip 'A' trip b	would o breaker.	occur if 'B' bus we	re lost or if t	esting were being
b.	CORRECT	A loss of 125 and the opposition of the oppositi	VDC bu site train cause a	s will ca bypass shunt tr	use an undervolta breaker, but will ip.	age trip of the not cause a	e related trip breaker shunt trip since power
C.		Plausible sind actually cause local trip mec	ce the au e a shun hanism i	itomatic it trip and is actuat	shunt trip relay lo d the bypass brea ed.	eses power, l akers only tri	but power is required to p on a shunt trip if the
d.		Plausible sind	ce an un	dervolta	ge trip will occur,	but no shuni	t trip will occur.
DIFFICULTY Compreher	': nsive/Analysis	X Kno	owledge	e/Recall	Rating	3	

Analysis of the conditions expected during trip breaker testing and the effect of a loss of power

REFERENCES SUPPLIED:

The two Reactor Trip Breakers connect the output of the Rod Drive M-G Sets to the Control Rod Drive Cabinets.

The two Reactor Trip Bypass Breakers also connect the output of the M-G Sets to the Control Rod Drive Cabinets. The Bypass Breakers are used, one at a time, to allow for on-the-line testing and repair of the Reactor Trip Breakers and the logic trains. The Bypass Breakers are not to be in continuous service for > 12 hours.

The Reactor Trip Breakers are opened both mechanically (UV Coils) and electrically (automatic Shunt Trip Relays) by the RPS and/or either of the Reactor Trip Pushbuttons.

The Reactor Trip Bypass Breakers are opened mechanically (UV Coils) by the RPS and/or either of the Reactor Trip Pushbuttons, or electrically (Shunt Trip Relays) by the pushbutton located on the front of the breaker panel.

The UV Coils and Automatic Shunt Trip (AST) Relays for Reactor Trip Breaker "A" and Reactor Trip Bypass Breaker "B" (UV Coil only) are powered from "A" 125VDC Distribution Panel (same Power Supply Breaker as Logic Channel 1). The Trip Coils for Reactor Trip Breaker "A" and Reactor Trip Bypass Breaker "B" are also powered from "A" 125VDC Distribution Panel (different Power Supply Breaker than Channel 1).

The UV Coils and Automatic Shunt Trip (AST) Relays for Reactor Trip Breaker "B" and Reactor Trip Bypass Breaker "A" (UV Coil only) are powered from "B" 125VDC Distribution Panel (same Power Supply Breaker as Logic Channel 2). The Trip Coils for Reactor Trip Breaker "B" and Reactor Trip Bypass Breaker "A" are powered from "B" 125VDC Distribution Panel (different Power Supply Breaker than Logic Channel 2).

3.4 Reactor Trip Pushbuttons

The two Reactor Trip Pushbuttons are wired in series. This series wiring arrangement will cause the Reactor Trip and Reactor Trip Bypass Breakers to be opened by depressing either of the Reactor Trip Pushbuttons.

3.5 Trip Reset Pushbutton

After all the Reactor Trip signals have been removed, depressing the Trip Reset Pushbutton will cause the Reactor Trip Breakers to close.

3.6 Bistable Status Panels

RPS

SIMPLIFIED TRAIN "A" REACTOR TRIP BREAKER DIAGRAM RPS-FIGURE-5 (Rev. 1)



2.0 DISTRIBUTION PANEL "A"

DISTRIBUTION PANEL "A"					
Power Supply: 125V DC MCC "A" Location: On 125V DC MCC "A" Drawings:B-190627, SH 40A					
CKT#	CKT# LOAD				
1	480V Switchgear No. E-1	955			
2	4160V Switchgear Busses 1 & 2	955			
3	Hydrogen Control Panel	875			
4	480V Switchgear Busses 1 & 2A	955			
5	Lighting Panel LP-33 (Alt Pwr via Auto Transfer Switch)				
6	125V DC Power Panel "A-1"				
7	Startup Transformer Motor Operated Disconnects	925			
8	Diesel Generator "A" Exciter	880			
9	Inverter "C"				
10	Reactor Trip Breaker "A" and Reactor trip Bypass Breaker "B"	45			
11	Inverter "A"				
12	Rod Drive M-G Set "A"	71			
13	Main Generator Exciter Field Breaker	862			
14	Gas Stripper Control Cabinet "A"	173			
`15	Generator Lockout Relay 86P	912			
16	Aux. Panel "D-C" Fuse Panel	955			
17	Main and Auxiliary Transformer Annunciators	940, 942			
18	Reactor Protection Train "A"	955			
19	Spare				
20	Safeguards Train "A"	955			
21	Spare				
22	Turbine Auto Trip	710			
23	Startup Transformer Annunciator	942			
24	Diesel Generator "A" Control Power	945			

EDP-004	Rev. 11	Page 5 of 14

1

5.0 **DISTRIBUTION PANEL "B"**

DISTRIBUTION PANEL "B"							
Power Su	Power Supply: 125V DC MCC "B" Location: On 125V DC MCC "B"						
Drawings:	Drawings: B-190627 Sh 40B						
CKT#	LOAD	CWD					
1	480V Switchgear No. E-2	956					
2	4160V Switchgear Busses 3 & 4	956, 1341					
3	4160V Breaker Test Panel	(Dwg 5379-1702)					
4	480V Switchgear Busses 2B & 3	956, 1341					
5	125V DC MCC "B-A"						
6	Sample Panel	88					
7	Spare						
8	Diesel Generator "B" Exciter	881					
9	Reactor Trip Breaker "B" & Reactor Trip Bypa	ss Breaker "A" 46					
10	Annunciator Panel (RTGB)	956					
11	Waste Disposal Panel	351					
12	Diesel Generator "B" Control Panel	950					
13	Turbine Emergency Trip	711					
14	Gas Stripper Panel "B"	174					
15	Gas Analyzer Panel	319					
16	Aux . Panel "G-C" Fuse Panel	956					
17	Generator Lockout Relay 86 BU	913					
18	Reactor Protection Train "B"	956					
19	Reverse Current Valves	740					
20	Safeguards Train "B"	956					
21	Drumming Room Control Panel	378					
22	Distribution Panel "B-1"						
23	Steam Driven AFW Pump Control Power	630					
24	Rod Drive M-G Set "B"	73					

EDP-004	Rev. 11	Page 8 of 14

RPS-09 006

Given the following plant conditions:

· The unit is at 100% power

· All equipment is operational

 \cdot Maintenance requests to de-energize 125 VDC panels one at a time for testing

Which ONE (1) of the following describes the control power supply for Reactor Trip Breaker "B" and Reactor Trip Bypass Breaker "B"?

Reactor Trip "B"	Reactor Trip Bypass "B"
A. "A" 125 VDC Dist. Panel	"A" 125 VDC Dist. Panel
B. "A" 125 VDC Dist. Panel	"B" 125 VDC Dist. Panel
C. "B" 125 VDC Dist. Panel	"B" 125 VDC Dist. Panel
✓D. "B" 125 VDC Dist. Panel	"A" 125 VDC Dist. Panel

Question: 53

Given the following conditions:

- The unit is in Hot Standby.
- A change in boron concentration from 500 ppm to 470 ppm is required.

Given the supplied references, which ONE (1) of the following identifies approximately how many gallons of primary water must be added to make this change?

- a. 70 gallons
- b. 90 gallons
- c. 3000 gallons
- d. 4500 gallons

Answer:

c. 3000 gallons

QUESTION N TIER/GROUP K/A:	UMBER: 2: 004A4.04	53	RO	2/1	SRO	2/1		
	Ability to man changes	ually operate a	ind/or m	ionitor ir	the control roor	n: Calculat	ion of boron co	ncentration
K/A IMPORT. 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.2 6	SRO 55.43(b) SRO	3.6		
OBJECTIVE:	CVCS-10							
	EXPLAIN the	operation of th	e CVCS	S.				
REFERENCE	S:	OP-301 Plant Curve 5	.7					
SOURCE:	New	Significa	ntly Mo	odified		Direct	005	
JUSTIFICATI	ON:		Bank	Numbel	r CVCS-10		005	
a.		Plausible sinc were used, bu	e this va ut Curve	alue wou 5.7 is to	uld be obtained i b be used.	f Curve 5.3	3 (boron additio	n - hot)
b.		Plausible sinc were used, bu	e this va ut Curve	alue wou 5.7 is to	uld be obtained i b be used.	f Curve 5.4	l (boron additio	n - hot)
C.	CORRECT	[•] Using Curve 5.7 (dilution - hot), a line drawn through 500 ppm coolant boron and 30 ppm dilution will intersect 3000 gallons dilution required.						
d.		Plausible sinc used, but Cur	e this va ve 5.7 is	alue woι s to be ι	uld be obtained i ised.	f Curve 5.8	3 (dilution - cold) were
DIFFICULTY Comprehen	: sive/Analysis	X Kno	owledge	e/Recall	Rating	3		
Application of given data to plant curves to determine required dilution								

REFERENCES SUPPLIED: Plant Curves 5.3, 5.4, 5.7, 5.8

Section 8.2.2 Page 4 of 16

8.2.2.2 (continued)

CAUTION

When the Reactor is subcritical, positive reactivity changes shall **NOT** be made by more than one method at a time.

- Determine the rate and magnitude of the RCS Boron concentration change required to accomplish the desired reactivity change.
- IF dilution is for conditions other than normal plant operations, such as fuel depletion or small RCS Tavg adjustments, THEN estimate the total volume of dilution water required from the proper dilution nomograph OR POWERTRAX.
- For large additions estimate expected PWST level decrease for target dilution.
- b. Place the RCS MAKEUP MODE selector switch in DILUTE.
- c. **IF** desired, **THEN** place controller FCV-114A, PRIMARY WTR FLOW DILUTE MODE, in MAN **AND** adjust the Controller as follows:
 - 1) Using the UP/DOWN arrow pushbuttons, adjust FCV-114A Controller output to 30-50%.
- d. Set the PRIMARY WTR TOTALIZER, YIC-114, to the desired quantity as follows:
 - 1) Depress BUTTON "A".
 - 2) Depress "CLR" BUTTON.
 - 3) Key in the desired quantity **AND** depress the "ENT" BUTTON.

OP-301	Rev. 70	Page 26 of 89



FIGURE S-3.1-3 BORCH ADDITION - COOLANT HOT (-580°F)

1 . . .

. т. .

; 5.3





3.4

t

· 1

:.**.** .,



FIGURE S-3.1-7 DILUTION NOMOGRAPH - COOLANT HOT (~580°F)

: Ł

 \leq

S-3.1:2.

5.7



í

~100°F) FIGURE S-3.1-S DILUTION NOMOGRAPH - COOLANT COLD (

 \mathcal{O}

CVCS-10 005

A power change is going to be made that requires a change in boron concentration from 900 ppm to 810 ppm. Using the attached Nomographs, which ONE (1) of the following is the amount of primary water that will be added to make this change?

- A. 3500 gallons
- ✓B. 5500 gallons
 - C. 7500 gallons
- D. 9500 gallons

Question: 54

Given the following conditions:

- Unit 2 is being ramped to 100% following a refueling outage.
- The following Plant Parameters are noted:

PARAMETER	VALUE
Loop 'A' Tavg	576°F
Loop 'B' Tavg	575°F
Loop 'C' Tavg	576°F
NI-41	100.0%
NI-42	99.0%
NI-43	99.0%
NI-44	100.0%
Loop 'A' ∆T	58.2°F
Loop 'B' ∆T	57.8°F
Loop 'C' ∆T	58.2°F
Loop 'A' Steam Flow	3.40 x 10 ⁶ lbm/hr
Loop 'B' Steam Flow	3.40 x 10 ⁶ lbm/hr
Loop 'C' Steam Flow	3.45 x 10 ⁶ lbm/hr
Loop 'A' Feed Flow	3.40 x 10 ⁶ lbm/hr
Loop 'B' Feed Flow	3.40 x 10 ⁶ lbm/hr
Loop 'C' Feed Flow	3.50 x 10 ⁶ lbm/hr
1 st Stage Press (446)	545 psig
1 st Stage Press (447)	546 psig
Generator Output	730 Mwe

Given the supplied references, reactor power is ...

- a. 99.5%. The power ramp may continue until the plant is at 100%.
- b. 99.5%. Power should be held constant to perform a calorimetric.
- c. greater than 100%. Power should be held constant to perform a calorimetric.
- d. greater than 100%. Power should be immediately lowered.

Answer:

d. greater than 100%. Power should be immediately lowered.

QUESTION N TIER/GROUP K/A:	NUMBER: P: 002K5.10	54	RO	2/2		SRO	2/2		
	Knowledge of the operational implications of the Relationship between reactor power and RCS differential temperature.								
K/A IMPORT 10CFR55 CC	ANCE: DNTENT:	55.41(b)	RO RO	3.6 7	55.43(b)	SRO) SRO	4.1		
OBJECTIVE:	: GP-005-03								
	DEMONSTR/ explaining the	ATE an unders e basis of each	tanding	of select	ted steps,	, cautions	s, and notes in GP-005 by		
REFERENCE	ES:	GP-005							
SOURCE:	New	Significa	ntly Mo	odified			Direct X		
SOURCE:	New	Significa	ntly Mo Bank	odified Number	GP-0	005-03	Direct X		
SOURCE: JUSTIFICAT <i>a.</i>	New	Plausible since above 100%.	ntly Mo Bank ce NIS a	odified Number average is	GP-0 s 99.5%,	005-03 but other	Direct X 017 r indications indicate power is		
SOURCE: JUSTIFICAT <i>a.</i> <i>b.</i>	New	Significat Significat Plausible since above 100%. Plausible since above 100%.	ently Mo Bank ce NIS a ce NIS a	odified Number average is average is	GP-0 is 99.5%, is 99.5%,	005-03 but other but other	Direct X 017 r indications indicate power is		
SOURCE: JUSTIFICAT a. b. c.	New	Signification Plausible sind above 100%. Plausible sind above 100%. Plausible sind must be redu performed	ently Mo Bank ce NIS a ce NIS a ce indica ced to h	odified Number average is average is ations oth highest va	GP-0 is 99.5%, is 99.5%, her than N alue at or	005-03 but other but other IIS indica below 10	Direct X 017 r indications indicate power is r indications indicate power is ate plant is above 100%, but power 00% before calorimetric is		
SOURCE: JUSTIFICAT a. b. c. d.	New	Signification Plausible sind above 100%. Plausible sind above 100%. Plausible sind must be redu performed .All indication immediate red	ently Mo Bank Se NIS a Se NIS a Se NIS a ce indica ced to h s other duction	odified Number average is average is ations off highest va than NIS to mainta	r GP-0 is 99.5%, is 99.5%, her than N alue at or S indicate ain at or b	005-03 but other but other IIS indica below 10 plant is a below 100	Direct X 017 r indications indicate power is r indications indicate power is ate plant is above 100%, but power 00% before calorimetric is above 100%, which requires 0%.		
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY	New ION: CORRECT	Signification Plausible sinct above 100%. Plausible sinct above 100%. Plausible sinct must be redu performed .All indication immediate red	ently Mo Bank Se NIS a Se NIS a Se NIS a ce indica ced to h s other duction	odified Number average is average is average is than NIS to mainta	r GP-0 is 99.5%, is 99.5%, her than N alue at or S indicate ain at or b	005-03 but other but other IIS indica below 10 plant is a pelow 100	Direct X 017 r indications indicate power is r indications indicate power is ate plant is above 100%, but power 00% before calorimetric is above 100%, which requires 0%.		
SOURCE: JUSTIFICAT a. b. c. d. DIFFICULTY Compreher	New ION: CORRECT	Signification Plausible sind above 100%. Plausible sind above 100%. Plausible sind must be redu- performed .All indication immediate red	Bank Bank Re NIS a Re NIS a Re NIS a Re indica ced to h s other duction	odified Number average is average is average is ations oth highest va than NIS to mainta e/Recall	r GP-0 is 99.5%, is 99.5%, her than N alue at or S indicate ain at or b	005-03 but other but other IIS indica below 10 plant is a below 100	Direct X 017 r indications indicate power is r indications indicate power is ate plant is above 100%, but power 00% before calorimetric is above 100%, which requires 0%.		

REFERENCES SUPPLIED: GP-005, Attachment 10.1

ATTACHMENT 10.1 Page 1 of 1 REACTOR POWER ASCENSION INDICATOR LOG

AVG PWR % (1)	NI-35 amps	NI-36 amps	NI-41A %	NI-42A %	NI-43A %	NI-44A %	LOOP ΔT °F (1)	LOOP 1 ΔT °F	LOOP 2 ΔT °F	LOOP 3 ΔT °F	1 st STAGE PRESS psig (1)	PI-446 OR 447 psig (2)	NET MWe MAX (1)	NET MWe	CCP % PWR (3)	NR-45 (4)	SSO (1)
15-20							9-11.5				68-90		73				
25-30							14.5-17				113-135		153				
35-40							20-23				158-180		235				
45-50							26-28.5				207-230		316				
55-60							32-34.5				261-285		398				
65-70							37-40				320-345		480				
75-80							43-46				384-410		562				
85-90							49-51.5				449-475		643				
95-100							55-57.5				513-540		725				

(1) Listed ranges and Net MWe maximums are predicted based on past plant performance. The maximum value of each indication is the maximum target value for each power increase. The SSO shall initial if plant management has determined that indications are acceptable to continue with the power escalation.

(2) Use indicator that corresponds to the channel selected on the 1st STAGE PRESSURE selector switch.

(3) Record Continuous Calorimetric Program % Power.

(4) Verify NR-45 is selected to the highest reading channel.

|--|

8.5.29	WHEN the highest indicator of Reactor Power listed on Attachment 10.1 indicates 90% power, OR as directed by the Reactor Engineer, THEN depress the HOLD pushbutton AND maintain indicated power.						
8.5.30	IF this power escalation is the initial power escalation to 90% following a core alteration, THEN perform the following: (SOER 90-003)						
	1.	Stabilize reactor power between 87% and 90%, OR as directed by the Reactor Engineer.					
	2.	Perform physics tests as directed by the Reactor Engineer.					
	3.	Verify NIS Power Range High Level Trip is set per the Reactor Engineer.					
8.5.31	Perform OST-010, Power Range Calorimetric.						
8.5.32	IF all indications of Reactor Power agree within 5% of each other, OR management approval has been obtained, THEN perform the following:						
	1.	Adjust the SETTER indication using the REF ∇ and/or REF \triangle pushbuttons to indicate no greater than 100.0 load.					
	2.	Depress the GO and/or HOLD pushbuttons AND the REF ⊽ and/or REF △ as necessary to continue the load increase to less than or equal to 100% Reactor Power, OR as directed by the Reactor Engineer OR SSO.					
8.5.33	WHE Attacl as dir HOLE	N the highest indicator of Reactor Power listed on hment 10.1 indicates 100% power, OR the maximum power ected by the Reactor Engineer OR SSO, THEN depress the D pushbutton AND maintain indicated power.					

GP-005	Rev. 66	Page 63 of 67

Question: 55

Given the following conditions:

- A Temporary Change (TC) to Revision 44 of OP-305, Boron Recycle Process, was issued on March 1, 2001.
- Revision 45 of OP-305 was issued on March 6, 2001.
- The Temporary Change was **NOT** incorporated into Revision 45, but was cancelled and subsequently reissued (using a new TC number) with the issue of Revision 45.

The Temporary Change now expires on ...

- a. March 15, 2001.
- b. March 20, 2001.
- c. March 22, 2001.
- d. March 27, 2001.

Answer:

c. March 22, 2001.

QUESTION N TIER/GROUF K/A:	IUMBER: 	55	RO	3		SRO	3		
	Knowledge of	f the process fo	or control	lling ten	nporary cha	anges.			
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.5 10	S 55.43(b)	RO SRO	3.4		
OBJECTIVE:	AP-022-03								
	DEMONSTR/ explaining the	ATE an underst eir basis.	tanding o	of select	ted steps,	cautions	, and note	es in AP-022	2 by
REFERENCE	S:	AP-022							
					,				
SOURCE:	New	X Significa	ntly Mo	dified			Direct		
JUSTIFICATI	ON.		Bank N	Number	•			NEW	
a.		Plausible if misconception is that expiration is 14-day instead of 21-day since this date would be determined based on original issue date of TC.							ay since this
b.		Plausible if mi expiration cloo	sconcep ck is rese	otion is t et, but d	hat expirat late is base	tion is 14 ed on ori	I-day inste iginal issu	ead of 21-da le date of T(ay and C.
С.	CORRECT	Reissue of the clock for expir	e same 1 ation of	ГС, evei the TC	n under a c be based c	different on the or	number, riginal issu	requires tha ue date of th	t the 21-day le TC.
d.		Plausible sinc and not reset	e expira to reissu	tion is 2 ıe date.	1-day, but	date is l	based on	original issu	e date of TC
DIFFICULTY: Comprehen	: sive/Analysis	X Kno	wledge	/Recall	Rat	ting	3		

Calculation of temporary change expiration based on knowledge of administrative requirements

REFERENCES SUPPLIED:

- 8.3.3.2(Continued)
 - d. When revising a document to delete requirements, a review of all references, as well as the document's historical file should be performed to allow appropriate consideration of past revisions which may have incorporated significant commitments or resolutions to problems or requirements. Regulatory requirements and commitments must be addressed elsewhere prior to deleting requirements/commitments or voiding a procedure. The location of the regulatory requirements/commitments are to be noted in the Summary of Changes of the voided procedure.
 - e. If a procedure is being written or revised to add comments or requirements, note in the Reason for Change.
 - f. Changes to the document may be highlighted, red-lined, or typed using a different font to facilitate reviews. These must be removed by the **Writer** prior to submitting the document for distribution.
 - g. If a procedure number needs to be changed, the Sponsor/Writer must first delete the existing procedure.
 - h. If not previously filled out, enter information into the "Revision is a result of an ESR/DCF/CR/Other" field as applicable.

EXAMPLE: If the revision is a result of an ESR, list the ESR Number and Revision in this field.

i. Incorporate any Temporary Changes intended to be made permanent. If the Temporary Change cannot be included in this permanent revision, cancel the present Temporary Change and reissue it against the new approved permanent revision or cancel the TC. The Temporary Change will have a new TC Number and the time clock will have **only the remainder** of the original 21 days if reissued.

AP-022	Rev. 33	Page 41 of 118

Question: 61

Given the following conditions:

- A licensed operator who has an inactive license has been performing administrative duties in the Training Section for twelve (12) months.
- He is returning to Operations and is to be placed back on shift.
- All licensed operator continuing training and fire brigade qualifications are current.

Which ONE (1) of the following are the additional **MINIMUM** requirements for returning his license to an active status?

- a. Complete **FOUR** normal shifts, including shift turnovers IAW plant procedures, before and after each watch, and review all the procedure changes for the past three (3) months
- b. Complete **FOUR** normal shifts, including shift turnovers IAW plant procedures, before and after each watch, and conduct a complete plant tour
- c. Complete **FIVE** normal shifts, including shift turnovers IAW plant procedures, before and after each watch, and review all the procedure changes for the past three (3) months
- d. Complete **FIVE** normal shifts, including shift turnovers IAW plant procedures, before and after each watch, and conduct a complete plant tour

Answer:

b. Complete **FOUR** normal shifts, including shift turnovers IAW plant procedures, before and after each watch, and conduct a complete plant tour

QUESTION I TIER/GROUI K/A:	NUMBER: P: 2.1.3	61	RO	3	SRO	3	
	Knowledge of shift turnover practices.						
K/A IMPORT 10CFR55 CC	ANCE: ONTENT:	55.41(b)	RO) RO	3.0 10	SRO 55.43(b) SRO	3.4	
OBJECTIVE	: OMM-001-05	-03					
	DISCUSS eached by a section of the	ch section of C procedure.	OMM-001	1-05, wł	en possible, using	the info	rmation given in each
REFERENCE	ΞS:	OMM-001-05	5				
SOURCE:	New	Significa	antly Mo	odified		Direct	X
			Bank	Numbe	r 10CFR-55.13	3-22	001
JUSTIFICAT a.	ION:	Plausible sin complete tou	ce watch ir of the p	standin blant.	g requirements are	e correct	, but must also perform a
b.	CORRECT	Four complet plant must be	te 12-hou e comple	ur watch ted.	ies, plus shift turno	overs, an	id a complete tour of the
C.		Plausible sine perform a co	ce this w mplete to	ould sa our of th	tisfy watchstanding e plant.	g require	ments, but must also
d.		Plausible sin requirement.	ce this w	ould sa	tisfy all requiremer	nts, but is	s not the minimum
DIFFICULTY: Comprehensive/Analysis Knowledge/Recall X Rating 3							
Knowledge of administrative requirements for activating an inactive license							

REFERENCES SUPPLIED:

8.2 Inactive Status

- 8.2.1 If a licensee has **NOT** been actively performing the functions of an operator or senior operator for the periods defined in Section 8.1, then the individual's license is declared inactive and the licensee may **NOT** resume activities authorized by a license issued under 10CFR55.
- 8.2.2 Inactive licensees may still fulfill the functions of Fire Brigade Team Leader and Fire Brigade Member if all fire brigade training is current, act in the capacity of WCC SCO or WCC CO and perform WCC functions, or perform valve manipulations and independent verifications with approved procedures.
- 8.2.3 If a non-licensed watchstander has **NOT** been actively performing the functions for which he/she is qualified for the periods defined in Section 8.1, the watchstander may **NOT** resume activities authorized by their gualifications.
- 8.2.4 Inactive non-licensed watchstanders may still fulfill the functions of Fire Brigade Member (if all fire brigade training is current) or perform valve manipulations and independent verifications with approved procedures.
- 8.3 Reactivation of a Licensed Watchstander
 - 8.3.1 **IF** an individual's license becomes inactive status, **THEN** before resumption of activities authorized by a license issued under 10CFR55, the Manager - Operations shall certify, using Attachment 10.2, that qualifications and status of the licensee are current and valid as discussed in Section 8.7, **AND** that the licensee has completed a minimum of 48 hours of shift functions in the position in which the individual will be qualified.
 - 8.3.2 **IF** an individual has an active license and it is desired to reactivate his qualification at another watchstation, **THEN** the individual must complete a minimum of 48 hours of shift functions in that watchstation. Attachment 10.2 Steps 1 and 4 are used to document the watches stood and Steps 2 and 3 of the attachment should be marked N/A.

OMM-001-5	Rev. 13	Page 9 of 40
		the second se

- 8.3.3 The following guidelines apply regarding the required number of watches stood:
 - 1. The 48 hours shall be performed as four complete shift watches including shift turnovers IAW plant procedures before and after each watch under the direction of an individual qualified to stand that watchstation.
 - 2. The 48 hours shall include a complete tour of the plant as defined in Section 8.5.
 - 3. The 48 hours of reactivation time should take place over a maximum period of four weeks **AND** shall occur in the same calendar guarter.
- 8.3.4 An inactive SRO may reactivate as an SRO limited to fuel handling duties by standing 8 hours under instruction from an active licensed SRO performing fuel handling duties. The 8 hours are not required to be consecutive.
- 8.3.5 Inactive licensees may stand watch on non-licensed watchstations provided <u>ONE</u> of the following conditions are met:
 - The individual has reactivated their license IAW Section 8.3
 - The individual stands one 12-hour watch, including shift turnovers and a complete set of logs, under the supervision of an active watchstander for the particular non-licensed watchstation(s) AND completes Attachment 10.3
 - Manager Operations waives requirement to reactivate for the particular non-licensed watchstation(s) AND documents on Attachment 10.3
- 8.3.6 Completed Attachments 10.2 and 10.3 shall be routed to the Operations Scheduler who will revise Attachment 10.4 to reflect the reactivation of qualification.

OMM-001-5	Rev. 13	Page 10 of 40

- 8.4 Reactivation of a Non-Licensed Watchstander
 - 8.4.1 **IF** active status, as defined herein, is not met, **THEN** before resumption of watchstanding activities, the Manager Operations shall certify using Attachment 10.3 that <u>ONE</u> of the following conditions are met:
 - The individual stands one 12-hour watch, including shift turnovers and a complete set of logs (N/A for STA), under the supervision of an active watchstander for the particular non-licensed watchstation(s) AND completes Attachment 10.3
 - Manager Operations waives requirement to reactivate for the particular non-licensed watchstation(s) AND documents on Attachment 10.3
 - 8.4.2 The completed Attachment 10.3 shall be routed to the Operations Scheduler who will revise Attachment 10.4 to reflect the reactivation of qualification.
- 8.5 Plant Tours (For Reactivation Purposes Only)
 - 8.5.1 The plant tour required for reactivation of NRC issued licenses shall be conducted under the supervision of an appropriate active license holder **AND** shall consist of the entire plant inside the protected and vital areas EXCEPT the following areas:
 - Containment Vessel
 - RHR Pit
 - Office buildings that are not part of the watchstanders normal tour
 - Areas specifically excluded in writing by the SSO in the Comments section of Attachment 10.2.
 - 8.5.2 The supervising license holder is not required to accompany the reactivating individual. However, the reactivation tour shall be conducted with the cognizance of, and under the direction of, the supervising license holder as appropriate.

OMM-001-5 Rev. 13	Page 11 of 40
-------------------	---------------

- 8.5.3 Plant tours shall include entry and visual surveillance of each room in the Turbine Building and RCA that is not specifically excluded by this section or the SSO. Room entry is not necessary for rooms that can be visually checked through cage doors with confidence that OMM-001-11 requirements are satisfied.
- 8.5.4 Plant tours for reactivation of non-licensed watchstations shall consist of a complete set of rounds and logs for the position being reactivated unless waived by the Manager Operations IAW Section 8.4.
- 8.6 Crew Rotations and Reassignments (CR 96-02954)
 - 8.6.1 Reactivation of an individual's qualifications or the addition of newly licensed individuals may require crew rotations and reassignments. Prior to making a crew rotation or adding personnel to a shift, the Manager Operations shall consider the following:
 - The experience level of each crew member
 - The composite experience levels to achieve a balanced crew
 - Personality conflicts
 - Maturity level of shift members
 - Leadership ability of individuals

The above considerations ensures a nucleus of experienced personnel are maintained.

8.6.2 Crew rotations are typically made following refueling outages or soon after a new group of candidates receive their licenses. For newly licensed individuals, they normally remain as an extra person on the assigned shift. This allows the opportunity for the individual to attend Licensed Operator Continuing Training with the crew and integrate with the crew prior to assuming a licensed position. Other rotations are normally made between training cycles. This allows the crews to change and then be trained as a team at the earliest available opportunity.

OMM-001-5	Rev. 13	Page 12 of 40
-----------	---------	---------------
8.7 Qualification Documentation

- 8.7.1 Automatic notifications made in PQD ensure that personnel are aware of the status of qualification expiration dates. PQD information for the following qualifications is maintained on the LAN. (CR 96-01883)
 - NRC License and Medicals
 - Fire Brigade Qualifications and Medicals (CR 96-00729)
 - Respirator Qualifications and Medicals
- 8.7.2 Watchstander qualifications should be considered active if the following criteria are met:
 - License holders and STAs satisfactorily participate in the Licensed Operator Continuing Training program.
 - Auxiliary Operators satisfactorily participate in the AO Continuing Training Program.
 - The required number of watch hours are satisfied IAW Section 8.10 as documented on Attachment 10.1, Proficiency Watch Tracking Sheets.
 - Watchstanders are respirator qualified in at least one type of respiratory protection.
 - Fire Brigade training and qualifications are current for Fire Brigade members and Team Leaders.
- 8.7.3 Licensed watchstanders should be qualified as a member of the Fire Brigade to reactivate. **IF** the individual was previously qualified as a Team Leader, **THEN** it is desired (but not required) that the individual be qualified as Team Leader prior to reactivation. The total number of qualified Team Leaders should not exceed 35 at any one time.
- 8.7.4 Reactivation of watchstander qualifications are verified using Attachment 10.2 or 10.3 as appropriate **AND** the reports stated above.

OMM-001-5	Rev. 13	Page 13 of 40

- 8.9.4 The Supervisor SHALL notify the Manager Operations of the situation.
- 8.9.5 Upon being contacted by the licensed operator, the Examining Physician will determine the need for a clinical assessment of the potential medical restriction. If a clinical assessment is required, a determination of the licensee's medical condition will be made based on the available medical records, the results of the clinical assessment, or any special testing performed. Any documentation or notifications will be IAW SAF-NGGC-2171.

NOTE: SEC-NGGC-2130 states: "Any worker with unescorted access shall notify his or her supervisor or designee of (1) any arrest or (2) any incident that may impact the worker's trustworthiness or reliability, in accordance with SEC-NGGS-2101 Nuclear Worker Screening Program for Unescorted Access."

SEC-CPL-025 has additional directions and forms concerning reporting arrests.

- 8.9.6 Upon being notified of a licensee felony conviction **OR** upon being notified by the Examining Physician that a licensee has a medical condition exists that invalidates or restricts the individual's license, the Manager Operations **SHALL** notify Training and Regulatory Affairs.
- 8.9.7 Control Room personnel who wear corrective lenses as a condition of their license **SHALL** maintain a pair of SCBA glasses in the Control Room. Each shift has a drawer containing trays in which to store the glasses.
- 8.9.8 Control Room personnel whose respiratory protection qualifications permit the wearing of contact lenses, **MAY** wear soft, gas-permeable contact lenses with their respiratory protection face pieces.
- 8.10 Tracking Watchstander Hours
 - 8.10.1 At the **END** of each shift, the SSO **OR** CRSS should update attachment 10.1 by initialing and dating the appropriate watch block for the Licensed and Non-Licensed watchstander that stood a watch.
 - DO NOT make any entry UNLESS the watchstander stood the entire 12 hour watch. A watch must be a minimum of 12 hours in length in order to count as a watch used to maintain active watchstation status.
 - AFTER the minimum number of watches has been completed for the quarter, no further entries for that individual are required UNTIL the next calendar quarter.

OMM-001-5	Rev. 13	Page 16 of 40
		5

ATTACHMENT 10.2 Page 1 of 1 LICENSED WATCHSTANDER REACTIVATION

NAME:

SSN:

1. Watchstanding Log:

DATE	POSITION	HOURS	TURNOVER YES/NO	ACTIVE WATCHSTANDER SIGNATURE
			· · · · · · · · ·	

2. The following are current:

- Licensed Operator Continuing Training requirements.

- Fire Brigade qualification (Yes/No)
- circle one
- Team Leader qualification (Yes/No) circle one

		Superintendent - Operator Training	Date
3.	Respirator qualified (expiration date:		
	(oxpiresoff deto:/	E&RC	Date
4.	Plant tour completed.		
		Superintendent Shift Operations	Date
Comn	nents:		

I certify that the qualifications, status, training, and watchstanding requirements of the above named licensed individual are current and valid, allowing return to active license status for the position assigned.

Manager - Operations

Date

Route completed form to:

.

Operations Scheduler

Operations Tech Aide

OMM-001-5	Rev. 13	Page 25 of 40
		······································

Given the following conditions:

- The unit is operating at 100% power.
- RCS Tavg is 575.4°F.
- PZR level is 53%
- VCT level is 23" and stable.
- Letdown flow is 45 gpm (FI-150).
- RCP seal injection flows are:

RCP	SEAL INJ
'A'	8.3 gpm
'B'	7.9 gpm
'C'	7.8 gpm

Which ONE (1) of the following would be the expected flow indication on FI-122A, Charging Header Flow, assuming **NO** RCS leakage?

- a. 21 gpm
- b. 30 gpm
- c. 36 gpm
- d. 54 gpm

Answer:

b. 30 gpm

						RN C	NP NRC Written Examination
QUESTION N TIER/GROUP K/A:	IUMBER: : 004A1.11	62	RO	2/1	SRO	2/1	
	Ability to pred associated wi	ict and/or mon th operating th	itor chan e CVCS	iges in pa controls	arameters (to prev including: Letdow	vent exce vn and ch	eeding design limits) narging flows
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.0 6	SRO 55.43(b) SRO	3.0	
OBJECTIVE:	CVCS-05						
	DESCRIBE th	e performance	and dea	sign attril	outes of the major	CVCS o	components.
REFERENCE	S:	AOP-016			-		
		SD-021					
SOURCE:	New	Significa	ntly Moo Bank N	dified Number	X CVCS-03	Direct	010
JUSTIFICATI	ON:		Dank	umocr	0100.00		
a.		Plausible if mi required to be	sconcep made u	otion is th p. 45 - 2	at seal leakoff flov 24 = 21.	w is igno	red, but leakoff flow is not
Ь.	CORRECT	Charging flow gpm) plus sea	should a al return :	equal leto flow (9 g	down flow (105 gr pm). 45 - 24 + 9 :	om) less = 30.	seal injection flow (24
с.		Plausible if mi flow and seal included. 45	sconcep leakoff n · 9 = 36.	otion that nust be s	seal injection flov ubtracted, but se	v is meas al injectio	sured as part of charging on is required to be
с. d.		Plausible if mi flow and seal included. 45 Plausible if mi flow, but seal	sconcep leakoff n · 9 = 36. sconcep injection	nust be s nust be s otion that is requir	seal injection flov subtracted, but se seal injection flov ed to be included	v is meas al injectio v is meas . 45 + 9	sured as part of charging on is required to be sured as part of charging = 54.
c. d. DIFFICULTY: Comprehen	sive/Analysis	Plausible if mi flow and seal included. 45 Plausible if mi flow, but seal	sconcep leakoff n · 9 = 36. sconcep injection	otion that nust be s otion that is requir / Recall	seal injection flow subtracted, but se seal injection flow ed to be included Rating	v is meas al injectio v is meas . 45 + 9 3	sured as part of charging on is required to be sured as part of charging = 54.

300-	01	٢.
AUP-	UΤ	0

Rev. 14

Page 9 of 37

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
OS me	NOT T-051, Reactor Coolant System Leak thod of leak rate determination if	E age Evaluation, is the preferred plant conditions permit.
26.	 Initiate Leak Rate Determination Using One Or More Of The Following Methods: OST-051, Reactor Coolant System Leakage Evaluation 	
	OR • OST-901, HVH Condensate Measuring System	
	OR • Charging versus letdown flow balance	
27.	Check R-17, COMPONENT COOLING WATER RADIOACTIVE LIQUID - INCREASING <u>OR</u> IN ALARM	Go To Step 29.
28.	Go To AOP-014, Component Cooling Water System Malfunction	
29.	Check Refueling Cavity Status - FLOODED	Go To Step 41.
30.	Check Status Of Fuel Handling Activities Or Reactor Vessel Internals Movement - IN PROGRESS	Go To Step 32.

-

seal water flow.

Prior to or during the heatup process the CVCS is employed to obtain the correct chemical properties in the RCS. Reactor coolant makeup control is operated on a continuous basis to replace system leakage. Chemicals are added via the chemical mixing tank as required to control reactor coolant chemistry such as pH and dissolved oxygen content.

During a plant startup and power ascension, boron concentration is usually reduced due to the increased negative reactivity addition from power defect and the increase in Xenon and Samarium. For planned plant power changes, Reactor Engineering provides the Control Room with the necessary blended additions to the VCT to accomplish the power change. For instances when Reactor Engineering has not provided the calculated blends, the Reactor Operator must calculate the actual amount of water used to dilute the RCS and account for this. Nomographs and figures such as Figures 18 to 21 of this System Description are used to perform these calculations.

6.2 Normal Operation

Normal Operation includes operation at power and hot zero power.

6.2.1 Letdown and Charging

During normal operation at a constant power level, the letdown flow is equal to the sum of the charging flow (passing through the tubes of the regenerative heat exchanger) and the flow through the thermal barrier of the reactor coolant pumps. The letdown flow is controlled by means of the letdown orifices in the letdown line (under normal condition the 45 gpm orifice is employed), and cooled by the charging line flow in the regenerative heat exchanger.

It then flows to the nonregenerative heat exchanger where it is cooled to approximately 105°F by component cooling water. On leaving the nonregenerative heat exchanger the letdown normally flows through one of the two mixed bed demineralizers, through the reactor coolant filter, and then via a spray nozzle into the VCT. Hydrogen pressure in the volume control bank insures that coolant returning to the RCS has the appropriate hydrogen concentration for oxygen control.

From the volume control tank the charging pump delivers the reactor coolant at about 105°F to the tube side of the regenerative heat exchanger. The coolant is heated to approximately 493°F at the exit end. The coolant is then injected into the RCS cold leg.

A portion of the flow from the charging pump passes through the reactor coolant pump seals. The charging pump speed (flowrate) is controlled automatically to maintain the pressurizer water level at the setpoint programmed for the RCS average temperature at

CVCS FLOW DIAGRAM CVCS-FIGURE-1 (Rev. 1)



INFORMATION USE ONLY

CVCS-03 010

Given the following plant conditions:

- Mode 1 at 100% RTP
- RCS Tavg = 575.4
- PZR level = 53%
- · VCT level = 23 " and steady
- Letdown flow is 60 gpm (FI-150)
- RCP seal injection flows: 8.3 gpm (A) 7.9 gpm (B) 7.8 gpm (C)

Which ONE (1) of the following would be the expected flow indication on FI-122A, Charging Header Flow?

.....

.

- A. 24 gpm
- **√**B. 45 gpm
 - C. 60 gpm
 - D. 69 gpm

The following personnel are entering the RCA to perform plant related activities:

- 1. Two operators doing a valve lineup in the RCA expect to receive a dose of about 125 mrem each.
- 2. Operators doing routine radwaste processing.
- 3. Electrical maintenance workers cleaning and inspecting an MCC breaker in the RCA.

Which ONE (1) of the following identifies ALL of the above activities which can be performed using a General RWP in accordance with HPP-006, "Radiation Work Permits"?

- a. 1 and 2 ONLY
- b. 1 and 3 ONLY
- c. 2 and 3 ONLY
- d. 1, 2, and 3

Answer:

c. 2 and 3 ONLY

QUESTION NUMBER: TIER/GROUP: K/A: 2.3.2	63 RC	D 3	SRO	3	
Knowledge of	f facility ALARA pro	ogram.			
K/A IMPORTANCE: 10CFR55 CONTENT:	RO 55.41(b) RO	2.5 12	SRO 55.43(b) SRO	2.9	
OBJECTIVE: 10CFR20-04					
Recognize ho a. Surveys b. Postings c. Records	ow the practical asp	pects of the	radiation protectio	n program will be effected.	
REFERENCES:	HPP-006				
SOURCE: New	Significantly	Modified ank Numbe	r НРР-006	Direct X	
JUSTIFICATION: a.	Plausible since ro mRem requires a	utine radwa Special RV	aste processing is VP.	permissible, but exposure of > 100)
Ь.	Plausible since m radiological conse Special RWP.	aintenance equence are	activities which ar e permissible, but e	e expected to involve minimal exposure of > 100 mRem requires	а
c. CORRECT	Routine radwaste involve minimal ra individual is expe	processing adiological o cted to rece	and maintenance consequence are p vive > 100 mRem r	e activities which are expected to permissible. Any task where an require a Special RWP.	
d.	Plausible since ro expected to invol exposure of > 10	outine radwa ve minimal i 0 mRem rec	aste processing ar radiological conse quires a Special R\	id maintenance activities which are quence are permissible, but WP.	3
DIFFICULTY: Comprehensive/Analysis	Knowle	edge/Recal	IX Rating	3	

Knowledge of administrative requirements for RWP usage

8.10 ALARA Planning

- 8.10.1 Work activities and associated dose are tracked by work order task and generic tasks.
- 8.10.2 The RC Planner ensures work order task (s) are transferred from the WORK MANAGEMENT SYSTEM to RIMS and assigned to the correct RWP number. The following criteria is used to evaluate which type of RWP will be assigned to the task or work activity:
 - 1. <u>General RWP(s)</u> are used by individuals entering RCA(s) whose work activities do not require stringent radiation protection controls. General RWP(s) may be used for the following activities unless deemed otherwise by RC Supervision: (SER 88-023).
 - a. <u>Radiation Control Surveillance</u> Radiation Control surveys, inspections, and activities can be conducted on a general RWP.
 - b. <u>Operations Rounds</u> Operations activities to support and maintain desired plant conditions.
 - c. <u>Radiochemistry Sample Collection and Analysis</u> Radioactive sample collection and work within the radiochemistry laboratory by chemistry and support personnel.
 - d. <u>Routine Radwaste Processing</u> Routine radwaste processing operations.
 - e. <u>General Entry into RCA(s)</u> Entries made into made into RCA(s) to work on noncontaminated systems.
 - f. <u>Planning, Scheduling, Audits, Security, and Inspections</u> Entries made by personnel, to include Security, into RCA(s) provided no physical work is accomplished. Personnel supporting activities controlled by a special RWP should utilize the special RWP rather than the general RWP.

HPP-006	Rev. 56	Page 29 of 59
	1	

- g. <u>Maintenance</u> Entries made into RCA(s) to perform maintenance activities that are expected to involve minimal radiological consequence as determined by RC Supervision or designee.
- 2. <u>Special RWP(s)</u> are required for specific plant locations/radiological conditions and tasks which require stringent radiation protection controls and are not otherwise covered by the general RWP criteria. Special RWP(s) are not limited to, but will be used for the following activities unless otherwise authorized by RC Supervision or designee (SER 88-023):
 - a. Entries into HPA(s) with the exception of Radiation Control, Chemistry and Operations.
 - Any breaching of a contaminated system other than instrument calibrations/repairs, sampling, and maintenance activities involving <u>minimal</u> radiological consequences.
 - c. Abrasive work (e.g. grinding, cutting, machining, or welding) on <u>contaminated</u> surfaces.
 - d. Any task where an individual will receive greater than 100 mrem.
 - e. Entries into <u>VHRA(s)</u>.
 - f. With the <u>exception</u> of Radiation Control, Chemistry, Operations, and inspections, all work in:
 - Areas with contamination levels in excess of 100,000 dpm/100 cm² and/or 30 cm radiation levels of 100 mRem/hr or greater
 - 2) Locked High Radiation Area Entries
 - 3) With the <u>exception</u> of Radiation Control, Chemistry, and Operations activities, all work and inspections in Airborne Radioactivity Areas.
- 8.10.3 The RC Planner evaluates the task to determine any radiological protection measures or hold-points that may need to be added to the Special Instructions of the work order task .

 Day 56	Page 30 of 59 I
Rev. 50	l ago oo o. oo l
· · · · · · · · · · · · · · · · · · ·	

Given the following conditions:

- The unit was operating at 100% power.
- All IRPI indication fails to zero with NO rod bottom bistable lights.
- A Turbine Runback to 70% has occurred.
- APP-005-A3, PR DROP ROD ROD STOP, is illuminated.

Which ONE (1) of the following procedures should be used to mitigate this plant transient?

- a. AOP-001, Malfunction of Reactor Control System
- b. AOP-015, Secondary Load Rejection or Turbine Runback
- c. AOP-024, Loss of Instrument Buses
- d. AOP-025, RTGB Instrument Failures

Answer:

a. AOP-001, Malfunction of Reactor Control System

								Common Question Reference
QUESTION N TIER/GROUF K/A:	IUMBER: 2: 003 2.4.4	64	RO	1/2		SRO	1/1	
	Ability to reconcern	gnize abnorma emergency an	l indicati d abnori	ions for mal ope	system rating pi	operating rocedures	parame (Dropp	eters which are entry-level ed Rod).
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	4.0 10	55.43()	SRO b) SRO	4.3	
OBJECTIVE:	AOP-001-02							
	RECOGNIZE	the selected e	ntry leve	el condit	ions of A	AOP-001.		
REFERENCE	ES:	AOP-001 AOP-015 AOP-024 AOP-025 APP-005						
SOURCE:	New	Significa	ntly Mo	dified			Direc	t X
JUSTIFICAT <i>a.</i>	ION: CORRECT	Any indication AOP-001.	Bank i n of a ma	<i>Numbel</i> alfunctio	r AC n involv	P-001-02	sition ii	006 ndication is addressed by
b.		Plausible sind by an NIS fail	ce a runt lure not a	back ha an IRPI	s occurr failure.	ed, but ent	try into	AOP-015 would be caused
С.		Plausible sind entry into AO indication.	ce a loss P-024 is	s of pow s exclud	er to the ed for a	e rod positi loss of the	on indi instru	cation has occurred, but ment bus for rod position
d.		Plausible sind made into AC	ce rod po DP-001.	osition i	ndiction	is located	on the	RTGB, but entry should be
DIFFICULT Comprehe	(: nsive/Analysis	Kn	owledge	e/Recal	X	Rating	2	
	Knowledge c	f entry require	nents / j	purpose	of AOP	S		

RNP NRC Written Examination

Page 3 of 80

					Page 5 OL 80	
 1		······································				
-	STEP	INSTRUCTIONS		RESPONSE NOT OBT	AINED	
_	1.	PURPOSE This procedure provides the inst Operator to recover a dropped ro abnormal continuous rod motion a	ructi d, re nd op	ons necessary for the align a misaligned ro perate with an IRPI fa	d, stop ilure.	
		This procedure is applicable in	Modes	: 1, 2, and 3.		
	2.	ENTRY CONDITIONS				
		Any indication of a dropped rod, motion, inability to move rod(s)	misa or s	ligned rod, unwarrant suspected IRPI malfunc	ed rod tion.	
		-	END -			
l						

Purpose and Entry Conditions

(Page 1 of 1)

1. <u>PURPOSE</u>

The purpose of this procedure is to provide instructions to stabilize plant conditions following a secondary load rejection or Turbine runback.

<u>NOTE</u>

Entry to AOP-015 is <u>NOT</u> required if a PR NIS failure occurs <u>AND</u> a runback fails to actuate.

2. ENTRY CONDITIONS

- a. This procedure is entered upon a secondary load rejection or Turbine runback caused by a failure of a PR NIS.
- b. When directed from AOP-026, Low Frequency Operation.

- END -

Purpose and Entry Conditions

(Page 1 of 1)

1. PURPOSE

The purpose of this procedure is to provide instructions to be followed in the event of a loss of power to any Instrument Bus (excluding the Instrument Bus for RPI).

This procedure is applicable under Modes 1, 2, and 3.

2. ENTRY CONDITIONS

This procedure is entered on any indication of a Loss of an Instrument Bus (excluding Instrument Bus for RPI).

- END -

<u>Purpose & Entry Conditions</u> (Page 1 of 1)

1. PURPOSE

This procedure provides instructions for failure of process variable transmitters which provide input to RTGB controllers.

IF an applicable transmitter fails while the controller is operating in manual <u>OR</u> is being fed from an alternate channel, <u>THEN</u> entry to this procedure is <u>NOT</u> required.

This procedure is applicable in Modes 1, 2, 3, and 4.

2. ENTRY CONDITIONS

Failure of any process variable transmitter which affects automatic operation of RTGB controllers with the following exceptions:

- FT-605, RHR Flow
- LT-115, VCT Level
- LT-112, VCT Level
- PR NIS (NI-41, 42, 43, & 44)

- END -

<u>ALARM</u>

PR DROP ROD ROD STOP

AUTOMATIC ACTIONS

1. Turbine Runback (Load Reference and Load Limit)

<u>CAUSE</u>

- 1. Dropped Rod
- 2. Failure of a Power Range Channel

OBSERVATIONS

- 1. Power Range Indication
- 2. Generator Output
- 3. Rod Bottom Lights
- 4. RPIs

ACTIONS

- 1. **IF** a dropped rod has occurred, **THEN** refer To AOP-001.
- 2. IF a Power Range channel has failed with the Unit on the line, THEN refer to AOP-015.
- 3. **IF** a Power Range channel has failed with the Unit off the line, **THEN** remove the affected channel from service using OWP-011.

DEVICE/SETPOINTS

1. N-41, N-42, N-43, or N-44 / 5% Power change in 5 sec.

POSSIBLE PLANT EFFECTS

1. Radial Flux Tilt

REFERENCES

- 1.
- 2. AOP-001, Malfunction of Reactor Control System
- 3. AOP-015, Secondary Load Rejection Or Turbine Runback
- 4. OWP-011, Nuclear Instrumentation (NI)
- 5. CWD B-190628, Sh 440, Cable BH

APP-005 Rev. 19 Page	6 of 40
----------------------	---------

Given the following conditions:

- A line break caused the Fire Header pressure to drop.
- Fire Header pressure eventually stabilized at 83 psig.

Which ONE (1) of the following expected fire system responses would have resulted in this condition?

- a. The Electric Fire Pump automatically started, then the Diesel Fire Pump automatically started.
- b. The Electric Fire Pump automatically started and the Diesel Fire Pump remained in standby.
- c. The Diesel Fire Pump automatically started, then the Electric Fire Pump automatically started.
- d. The Diesel Fire Pump automatically started and the Electric Fire Pump remained in standby.

Answer:

a. The Electric Fire Pump automatically started, then the Diesel Fire Pump automatically started.

QUESTION N TIER/GROUP K/A:	UMBER: : 086A3.01	65	RO	2/2	SR	O 2/2	
	Ability to moni mechanisms o	itor automatic o of fire water pu	operation mps	n of the l	Fire Protectio	n System i	ncluding: Starting
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.9 4	SRC 55.43(b) SR	0 3.3 O	
OBJECTIVE:	FPW-09						
	EXPLAIN the instrumentatic	normal operati on, interlocks, a	on of the annuncia	e Fire W ators, an	ater control s d setpoints.	ystems. Ir	nclude function,
REFERENCE	S:	SD-041					
SOURCE:	New	Significa	ntiy Mo	dified	X	Direc	zt 🔲 🖉
SOURCE:	New	Significa	ntiy Mo Bank l	dified Number	FP-05	Direc	ct
JUSTIFICATI	New	Significa	ntly Mo Bank l	dified Number	FP-05	Direc	003
SOURCE: JUSTIFICATI <i>a</i> .	New ON: CORRECT	The electric fin Pressure wou based on dem	ntly Mo Bank I re pump Id stabli nand.	dified Number starts a ze at so	FP-05 t 100 psig and me value belo	<i>Direc</i> d the diese ow the star	003 el fire pump starts at 90 psig. ting setpoint for both pumps
SOURCE: JUSTIFICATI a. b.	New ON: CORRECT	The electric fin Pressure wou based on dem Plausible sinc start setpoint	ntly Mo Bank I re pump Id stabli hand. e the ele so it woo	dified Number starts a ze at so ectric pu uld also	FP-05 t 100 psig and me value belo mp would state be operating.	<i>Direc</i> d the diese ow the star rt, but pres	003 el fire pump starts at 90 psig. ting setpoint for both pumps ssure is below diesel pump
SOURCE: JUSTIFICATI a. b. c.	New ON: CORRECT	The electric fil Pressure wou based on dem Plausible sinc start setpoint Plausible sinc backwards.	ntly Mo Bank I re pump Id stabli nand. re the ele so it woo re both p	dified Number starts a ze at so ectric pu uld also oumps w	FP-05 t 100 psig and me value belo mp would sta be operating. rould be runni	<i>Direc</i> d the diese ow the star rt, but pres ng, but sta	003 el fire pump starts at 90 psig. ting setpoint for both pumps ssure is below diesel pump rt order of pumps is
SOURCE: JUSTIFICATI a. b. c. d.	New ON: CORRECT	The electric fil Pressure wou based on dem Plausible sinc start setpoint Plausible sinc backwards. Plausible if mi is below 83 ps	ntly Mo Bank I re pump Id stablit nand. e the ele so it woo e both p isconcep sig, but I	Number starts a ze at sol ectric pu uld also pumps w ption is t	FP-05 t 100 psig and me value belo mp would sta be operating. rould be runni hat diesel pur nps would be	<i>Direc</i> d the diese ow the star rt, but pres ng, but sta ng, but sta np starts fi running.	o03 el fire pump starts at 90 psig. ting setpoint for both pumps ssure is below diesel pump rt order of pumps is rst and electric pump setpoint
SOURCE: JUSTIFICATI a. b. c. d. DIFFICULTY Comprehen	New ON: CORRECT sive/Analysis	Signification Signification Signification Signification Signification Signification Statement of the section of	ntly Mo Bank I re pump Id stablit nand. e the ele so it woo e both p isconcep sig, but I	bdified Number starts a ze at sol ectric pu uld also pumps w ption is t both pun	FP-05 t 100 psig and me value belo mp would state be operating. ould be runni hat diesel pur nps would be	<i>Direc</i> d the diese ow the star rt, but pres ng, but sta np starts fi running.	o03 el fire pump starts at 90 psig. ting setpoint for both pumps ssure is below diesel pump rt order of pumps is rst and electric pump setpoint

Fuel oil sufficient for at least eight (8) hours of operation is supplied by a 450 gallon fuel tank located outside of the intake structure. Normal usage is approximately 10 gal. per hour when the pump is running.

Upon a reduction of pressure in the fire main loop, pressure switches initiate a sequential starting of the fire pumps. The Motor Driven Fire Pump starts at 100 psig (95 psig - 105 psig). Should the fire main pressure drop to 90 psig (85 psig - 95 psig), the Engine Driven Fire Pump will automatically start. Each pump discharges through a swing check valve and gate valve to the fire water header. The swing check valves prevent reverse flow through the non-running fire pumps.

Pressure relief valves set at 135 psig provide protection for each fire pump by discharging excess water back into Lake Robinson. Air release valves adjacent to the relief valves are connected to high points and vent air from the discharge piping in an effort to reduce water hammer. Hose manifolds are provided as a means of testing fire pump capacity and can also be used as fire hydrants.

The three (3) fire pumps can be manually operated at their respective local control panels. Remote operation and indications for the Motor Driven Fire Pump (MDFP) are provided in the Control Room on the Containment Fire Protection Panel (CFPP). The Fire Alarm Console (FAC) in the Control Room provides alarms only. Operations, indications and alarms for the Engine Driven Fire Pump (EDFP) and its control system occur locally on its controller. The Fire Alarm Console (FAC) in the Control Room provides alarms only. The booster pump is only operated at its local control panel. There are no local or remote indication or alarms other than pressure gauge indications.

Post indicator gate valves (P.I.V.'s) are strategically located within the fire main loop. The normally open valves permit isolation of a section of the fire main loop without loss of fire service to other than the isolated section. A section of the fire main loop may be defined by its boundary valves.

Attachment 3 lists the systems, hydrants and hose stations which would be rendered inoperable by the isolation of various sections of the fire main loop. Attachment 3 also lists back-up sources of fire water for the affected systems, hydrants and hose stations.

FP-05 003

Which ONE (1) of the following describes the AUTOMATIC operation of the Fire Water Protection System?

 \checkmark A. The diesel fire pump will start if system pressure drops to 85 psig.

- B. The electric fire pump will start if system pressure drops to 115 psig.
- C. The electric fire pump will stop if system pressure is restored to 125 psig.
- D. The diesel fire pump will start on a loss of power to the jockey pump.

Given the following conditions:

- Emergency Diesel Generator 'A' is in the process of being started on Unit 2 to parallel it to the E-1 Bus.
- A "Remote Manual Slow Speed Start" is being performed in accordance with OP-604, "Diesel Generators A and B."

Which ONE (1) of the following describes the operation of the diesel generator voltage control during this evolution?

- a. The Voltage Regulator will automatically control voltage between 470 VAC and 490 VAC during the entire start after the field is automatically flashed at 200 RPM.
- b. The Voltage Regulator must be manually shutdown after the field is automatically flashed at 200 RPM, and will be automatically reinstated when engine speed is above 900 RPM to control voltage between 470 VAC and 490 VAC.
- c. The Voltage Regulator will be automatically shutdown 5 seconds after the field is flashed at 200 RPM if engine speed does **NOT** reach 900 RPM, and must be manually reinstated when engine speed is above 900 RPM to control voltage between 470 VAC and 490 VAC.
- d. The Voltage Regulator must be manually shutdown after the field is automatically flashed at 200 RPM, and must be manually reinstated when engine speed is above 900 RPM to control voltage between 470 VAC and 490 VAC.

Answer:

d. The Voltage Regulator must be manually shutdown after the field is automatically flashed at 200 RPM, and must be manually reinstated when engine speed is above 900 RPM to control voltage between 470 VAC and 490 VAC.

QUESTION N TIER/GROUF K/A:	IUMBER: 2: 064A4.02	66	RO	2/2		SRO	2/2	
	Ability to man (using voltage	ually operate a control switch	nd/or m)	onitor in t	the cont	rol room:	Adjustment of exciter	voltage
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.3 4	55.43(b	SRO 5) SRO	3.4	
OBJECTIVE:	EDG-08							
	EXPLAIN the Diesel Genera	component op ator System sw	eration a vitches a	associate and contr	ed with e ols.	each switc	h position for the Eme	ergency
REFERENCE	ES:	OP-604						
SOURCE:	New	Significa	ntly Mo	odified	X		Direct	
			Ponk	Numbor		G-08	001	
JUSTIFICAT	ION:		Dank	NUIIIDEI	LD	0-00	001	
a.		Plausible sind field automati prevent dama	e the re cally flas ige after	gulator is shes abo ⁻ 5 secon	s design ve 200 i ds.	ed to con rpm, but il	trol voltage in this rang must be manually sh	ge and the utdown to
b.		Plausible sind manually shu	e the fie tdown, t	eld autom out it mus	natically st be ma	flashes a nually rei	bove 200 rpm and mu nstated above 900 rpn	st be n.
с.		Plausible sinc reaching 200	ce the vo rpm, bu	oltage reç it this is a	gulator i 1 manua	s to be sh Il operatio	utdown within 5 secor n not automatic.	ids after
d.	CORRECT	The field auto regulator mus below 900 rpt rpm.	omaticall st be ma m and th	ly flashes inually sh nen mani	s when s nutdown ually reir	speed incr within 5 s nstated wl	reases above 200 rpm seconds if speed will b nen speed is increase	. The voltage e maintained d above 900
DIFFICULTY Compreher	': nsive/Analysis		owleda	e/Recall	ाजा व	Patina	3	
	,o,,, o,,, i,,u,,, o,o		0			anng	·	

- 4.6 When the Fuel Oil Filter pressure differential exceeds 10 psid, cartridge replacement is required.
- 4.7 Diesel Generator loads shall **NOT** exceed ratings of 2,500 KW for continuous operation **AND**:
 - 2750 KW shall NOT be exceeded.
 - Operation at 2750 KW for more than 2 hours within a 24 hour period shall **NOT** occur.
 - 4,000 amps on the Generator shall NOT be exceeded.
- 4.8 The Diesel Generators should not be set for automatic start after draining the EDG Fuel Oil System. The fuel oil system should be hand primed after the system is restored prior to EDG startup. To ensure the EDG Fuel Oil System is not airbound after refilling, the EDGs should be run prior to being set for automatic. A manual start is preferred so as not to challenge the overcranking feature associated with an automatic start.
- 4.9 When the Diesel is running and the Trips Defeat Key Switch is in the TRIPS DEFEATED position; the Diesel should be manually tripped if a condition exists that would automatically trip the Diesel. These conditions are: (Rail 92R0044)
 - Coolant Temperature High 205°F
 - Crankcase Pressure + 0.5 inches H₂O
 - Lube Oil Low Pressure 18 psig
 - Coolant Low Pressure 12 psig
- 4.10 Synchroscopes will be left OFF unless in use for synchronizing to prevent damaging by inadvertent energizing of two synchroscopes.
- 4.11 The Diesel Generator shall not be operated at speeds below 900 rpm with the Field Excitation in service. To take Field Excitation out-of-service, the Diesel Generator shall be above a speed of 200 rpm and below a speed of 900 rpm and the Field flashed. With the Field flashed, depressing the VOLTAGE SHUTDOWN pushbutton on Generator Control Panel, will remove Field Excitation from service. To reinstate Field Excitation, bring Diesel Generator speed to between 890 and 910 rpm and depress the RESET pushbutton on the Generator Control Panel. If the Field Excitation was taken out-of-service and Diesel Generator speed was dropped below 200 rpm or Diesel Generator was stopped, Field Excitation will reset automatically and is required to be taken out-of-service if Diesel Generator speeds stays below 900 rpm.

OP-604	Rev. 47	Page 8 of 150

Section 6.3 Page 5 of 7

6.3.2 (Continued)

<u>INIT</u>

CAUTION

If EDG Field Excitation is **NOT** removed within 5 seconds after the EDG is started, Regulator damage can result. It should be removed when "Generator AC Volts" and "Generator Hertz" meters first show indication. This occurs approximately 2-3 seconds after the Air Start Solenoids open.

- 8. Station an Operator at EDG "A" Generator Control Panel to depress the VOLTAGE SHUTDOWN pushbutton.
- 9. Start EDG "A" from the RTGB. TIME STARTED _____ ____
- 10. Depress the VOLTAGE SHUTDOWN pushbutton at EDG "A" Generator Control Panel within 5 seconds of EDG "A" start.
- 11. Verify OPEN TCV-1660, DIESEL "A" TEMP CONTROL VALVE.

CAUTION

Lube Oil Pressure shall not exceed 55 psig with the Lube Oil Temperature at or below 130°F.

12. Raise EDG "A" speed to maintain Lube Oil Pressure greater than 18 psig.

NOTE: Approximately 2 minutes will be required to raise from 400 rpm to 900 rpm.

13. With the Speed Control Lever on EDG "A" Generator Control Panel, raise engine speed to 900 rpm as indicated on the local RPM indicator beside EDG "A" Generator Control Panel OR as indicated by portable RPM Indicator AND record which RPM indicator was used. Local / Portable

(Circle one)

OP-604	Rev. 47	Page 29 of 150
-		

Section 6.3 Page 6 of 7

6.3.2	(Cont	inued)			<u>INIT</u>
NOTE: pushbutton a	The RE ctivates	SET p the "G	ushbutt enerato	ton located just left of the VOLTAGE or Hertz" meter.	SHUTDOWN
	14.	Perfor	m the f	following:	
		a.	Depre to the pushb	ss the RESET pushbutton located ju left of the VOLTAGE SHUTDOWN utton.	st
		b.	Recor	d Generator voltage. Voltage	
		C.	IF ED greate Room	G "A" voltage is less than 470V OR or than 490V, THEN notify the Contro to perform the following:	bl
			1)	Record voltage from ERFIS point DGV3026A, "A" D/G Voltage. Voltage	
			2)	IF voltage is less than 467V OR greater than 493V, THEN request Engineering personnel to review EE107-CS-65 and EE107-CS-68 Al perform an Operability Determinatio	ND m
NOTE: be observed. the jacket wa erosion of bo	Coolan Fluctu ter syst th the c	t discha ations o em and ylinder	arge pr of great I the cy liner ar	essure fluctuations on the jacket wat ter than 3 psig indicate a possible wa linder liner. A water leak of this type nd pistons.	er system shall ater leak between could lead to

15. Operate EDG "A" for 3 to 5 minutes after starting, to warm EDG "A".

OP-604	Rev. 47	Page 30 of 150

EDG-08 001

Given the following plant conditions:

• Emergency Diesel Generator "A" is in the process of being started on Unit 2 to parallel it to the E-1 Bus.

Which ONE (1) of the following describes the operation of the diesel generator voltage control switch during this evolution?

- A. Lowering the voltage control knob has no effect on the generator voltage if selected to the AUTO mode of operation
- ✓B. Raising the voltage control knob to a higher value, will cause the generator to pick up a larger share of the reactive load after breaker closure
 - C. Raising the voltage control knob will correct a synchroscope which is traveling slowly in the SLOW direction
 - D. Lowering the voltage control knob raises the speed of the generator when operating in the MANUAL mode prior to paralleling with offsite source

Given the following conditions:

- The unit is in Hot Standby.
- All systems are operating normally.
- SG "A" PORV is closed.
- SG "A" PORV automatic potentiometer is adjusted from "3.10" to "1.50".

Which ONE (1) of the following describes the effect adjusting the potentiometer will have on the PORV?

	SETPOINT	PORV
a.	Increases	Opens
b.	Decreases	Open
c.	Increases	Remains Closed
d.	Decreases	Remains Closed

Answer:

|--|

								Common Question Reference
QUESTION I TIER/GROUI K/A:	UMBER: ?: 041K6.03	67	RO	2/3		SRO	2/3	
	Knowledge of and positione	f the effect of a ers, including IC	a loss or CS, S/G	malfunc , CRDS	tion on the	followin	ig will ł	nave on the SDS: Controller
K/A IMPORT 10CFR55 CC	ANCE: DNTENT:	55.41(b)	RO RO	2.7 7	S 55.43(b)	RO SRO	2.9	
OBJECTIVE	: SD-09							
	EXPLAIN the instrumentation	normal operation, interlocks,	tion of th annunci	ne Steam ators, an	Dump co d setpoints	ntrol sys s.	stems.	Include function,
REFERENCE	ES:	SD-031						
SOURCE:	New	Significa	antly Mo	odified	X		Direc	t 🔲
			Bank	Number		40		002
			Dann	Number	· MSS-	12		
JUSTIFICAT <i>a.</i>	ION:	Plausible sin	ce the s	etpoint is	raised, bu	12 It the PC	DRV w	ould remain closed.
JUSTIFICAT a. b.	ION:	Plausible sin Plausible sin controllers, b	ce the s ce the s ut POR	etpoint is etpoint w v station:	raised, bu rould be de s are rever	t the PC creased rsed so s	DRV wo d on mo setpoir	ould remain closed. ost potentiometer adjusted at actually increases.
JUSTIFICAT a. b. c.	ION: CORRECT	Plausible sin Plausible sin controllers, b Setting of 3.1 Changing the higher than e	ce the s ce the s out POR 10 is 103 e setpoir even the	etpoint is etpoint w v stations 5 psig. nt to 1.50 safety se	raised, bu rould be de s are rever The range would rais etpoins, the	t the PC creased rsed so s for the t se the se e PORV	DRV wo d on me setpoir en turr etpoint ' will re	build remain closed. Dest potentiometer adjusted at actually increases. In pot is 0-1500 psig. to 1351.5 psig. Since this is main closed.
JUSTIFICAT a. b. c. d.	ION: CORRECT	Plausible sin Plausible sin controllers, b Setting of 3.1 Changing the higher than e Plausible sin on most pote setpoint actu	ce the s ce the s out POR' 10 is 103 e setpoir even the ce the F entiomet ally incr	etpoint is etpoint w v stations at to 1.50 safety so PORV will er adjust eases.	raised, bu rould be de s are rever The range would rais etpoins, the l remain clo ed controll	t the PC ecreased rsed so s for the t se the se e PORV osed and ers, but	DRV we d on me setpoint etpoint ' will re d the s PORV	build remain closed. Dest potentiometer adjusted at actually increases. In pot is 0-1500 psig. to 1351.5 psig. Since this is main closed. etpoint would be decreased istations are reversed so
JUSTIFICAT a. b. c. d. DIFFICULTY Compreher	ION: CORRECT	Plausible sin Plausible sin controllers, b Setting of 3.1 Changing the higher than e Plausible sin on most pote setpoint actu	ce the s ce the s out POR 10 is 103 e setpoir even the ce the F entiomet ally incr	etpoint is etpoint w v stations 35 psig. ⁻ to 1.50 safety se PORV will er adjust eases. e/Recall	raised, but rould be de s are rever The range would raise etpoins, the remain close ed controlle Rat	ting	DRV we d on me setpoir en turr etpoint ' will re d the s PORV 3	build remain closed. Dest potentiometer adjusted at actually increases. A pot is 0-1500 psig. to 1351.5 psig. Since this is main closed. etpoint would be decreased stations are reversed so

RNP NRC Written Examination

4.1.4 Low T_{avg} Interlock

The steam dump valves will lose their arming signal if 2/3 Low T_{avg} (543°F) signals are received. This signal comes from T_{avg} protection channels and will lock out the steam dumps to prevent inadvertent cooldown due to steam dump valves.

With T_{avg} less than 543°F, three of the dumps (Bank 1) can be made operable by operator action to bypass the T_{avg} interlock. This limits the cooldown rate available from the steam dump system.

4.2 Power Operated Relief Valve Controls

The controls for the S/G PORVs are located in the Secondary Control Panel on the mezzanine level of the turbine building, with the exception of the automatic setpoint adjustment potentiometer which is located on the RTGB. Their normal setpoint at power is 1035 psig, which is 30 psi above the pressure corresponding to the no load Tavg of 547° F. The setpoint can be can be changed by adjusting the potentiometer on the RTGB. This 10 turn potentiometer controls over a 0 - 1500 psig range, with a setting of 10.0 corresponding to 0 psig. This controller is reverse acting. Instead of the potentiometer increasing setpoint with increased value, raising the setting decreases the setpoint at which the pressure will be controlled. When actual pressure increases to the setpoint, the PORV throttles open to relieve pressure.

The controllers for each S/G PORV (PIC-477, PC-487 and PC-497), are adjusted at the secondary control panel. These controllers are pneumatic (with no electronics) and sense S/G pressure directly off the main steam lines upstream of the MSIVs. The directions for adjusting these controllers, which requires coordination between the Outside Auxiliary Operator and the Control Room, are contained in GP-001.

The PORVs can only be controlled by the steam dump controller if the system is selected to Tave mode ,and then, only if a turbine trip has not occured.

4.2.1 Switches

There are three DEFEAT switches located at the Secondary Control Panel to allow manual control of the S/G PORVs from the Secondary Control Panel. After placing each switch in the DEFEAT position, the S/G PORV is controlled by selecting MANUAL on the transfer switch located inside the controller box and using the manual thumbwheel on the pressure controller. When in the DEFEAT position, automatic control from the RTGB is removed as is the ability to place the S/G PORV under steam dump control in the event of a 70% load rejection without a turbine trip. Remote indication of this action

Steam Dumps

INFORMATION USE ONLY

Revision 3

<u>SD-031</u>

MSS-12 002

Given the following plant conditions:

- Mode 1 at 100% RTP
- All systems are operating normally
- S/G "A" PORV automatic potentiometer is adjusted clockwise 1.7 turns

Which ONE (1) of the following describes the effect adjusting the pot will have on the PORV and Plant conditions?

A. Increases the setpoint; the PORV will open, increasing steam demand above 100%.

✓B. Decreases the setpoint; the PORV will open, increasing steam demand above 100%.

C. Increases the setpoint; the PORV will not open due to current system pressures.

D. Decreases the setpoint; the PORV will not open due to current system pressures.

· · · · ·

Given the following conditions:

- A small break LOCA has occurred.
- Entry has been made into FRP-C.1, "Response to Inadequate Core Cooling."
- CETs are all indicating between 740 °F and 760 °F and rising slowly.
- RCS pressure has stabilized at 1605 psig.
- PZR level is off-scale low.
- RVLIS Full Range is indicating 39% and lowering slowly.
- Charging flow is NOT available.
- SG pressures are all between 360 psig and 400 psig.

Which ONE (1) of the following actions should be taken?

- a. Dump steam to cooldown and depressurize the RCS to provide Safety Injection flow
- b. Open the RCS Vent System valves to depressurize the RCS to provide Safety Injection flow
- c. Start an RCP immediately to provide forced cooling flow
- d. Open the PZR PORVs to depressurize the RCS to provide Safety Injection flow

Answer:

a. Dump steam to cooldown and depressurize the RCS to provide Safety Injection flow

QUESTION N TIER/GROUP K/A:	UMBER: : WE06EK2.2	68	RO	1/1		SRO	1/1	
	Knowledge of removal system systems, and it	the interrelati ms, including relations betw	ons betw primary veen the	veen the coolant, proper o	(Degradeo emergenc peration o	d Core 0 y coolar f these :	Cooling) and th nt, the decay h systems.	e facility's heat eat removal
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO) RO	3.8 5	S 55.43(b)	RO SRO	4.1	
OBJECTIVE:	FRP-C.1-08							
	Given plant co related to inad	enditions EVA equate core o	LUATE t	he appro s directe	opriate acti d in FRP-(ions to r C.1.	nitigate conse	quences of steps
REFERENCE	S:	FRP-C.1						
SOURCE:	New	X Signific	antly Mo	odified			Direct	
			Bank	Number			NEV	V
JUSTIFICATION: a. CORRECT		SGs should be depressurized in 2 steps (140 psig and atmospheric pressure) in an attempt to cooldown and depressurize the RCS to provide injection flow.						
Ь.	Plausible since this is an alternate bleed flowpath if entry had been made to FRP- H.1, but valves are only verified closed in FRP-C.1 to ensure that these are not the cause of the LOCA.							
с.	Plausible since RCPs will be started if CETs exceed 1200 °F and attempts to cooldown and depressurize using other means are not successful, but start requirements are not yet met.							and attempts to ssful, but start
d.		Plausible sir H.1, but valv cause of the	nce this is /es are o	s the nor nly verifi	mal bleed ed closed	flowpatl in FRP-	h if entry had k C.1 to ensure	been made to FRP- that these are not the
			. 200,					

Analysis of plant conditions to determine appropriate actions in response to inadequate core cooling
תמים		1
FRP-	C.	Т

RESPONSE TO INADEQUATE CORE COOLING

Page 6 of 24

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
7.	Determine SI Accumulator Isolation Valve Status As Follows:	
	a. Check SI ACCUM DISCHs - POWER AVAILABLE	 a. Locally close the breakers for the following valves: SI-865C, ACCUMULATOR C DISCHARGE (MCC-5, CMPT 9F) SI-865A, ACCUMULATOR A DISCHARGE (MCC-5, CMPT 14F)
		 DISCHARGE (MCC-6, CMPT 10J)
	 b. Check ACCUM DISCHs - OPEN SI-865A 	b. Open the ACCUM DISCH Valves unless closed after Accumulators discharged.
	• SI-865B	
	• SI-865C	
8.	Check Core Exit T/Cs - LESS THAN 1200°F	Go To Step 17.
9.	Check RCP Status - ANY RUNNING	Go To Step 11.
10.	Reset SPDS <u>AND</u> Return To Procedure And Step In Effect	
11.	Check RVLIS Full Range Indication - GREATER THAN 41%	Go To Step 13.
12.	Reset SPDS <u>AND</u> Return To Procedure And Step In Effect	
13.	Check RVLIS Trend - STABLE <u>OR</u> DECREASING	Observe <u>CAUTION</u> prior to Step 1 and Go To Step 1.
14.	Check Core Exit T/Cs - LESS THAN 700°F	Go To Step 16.
15.	Reset SPDS <u>AND</u> Return To Procedure And Step In Effect	

Page 7 of 24

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
16.	Check Core Exit T/C Trend - STABLE <u>OR</u> INCREASING	Observe <u>CAUTION</u> prior to Step 1 and Go To Step 1.
*17.	Determine Containment Hydrogen Concentration From Either Of The Following: • PI-8101-1, CHANNEL I H ₂ ANALYZER <u>OR</u> • PI-8111-2, CHANNEL II H ₂ ANALYZER	 Perform the following: a. Notify Chemistry personnel to perform the following: Obtain a sample of Containment atmosphere using the Post Accident Sample System Analyze sample to determine Containment hydrogen concentration b. WHEN Containment hydrogen concentration sample results are available, THEN perform Step 18. Go To Step 19.
18.	Evaluate Containment Hydrogen Concentration As Follows:	
	a. Check hydrogen concentration - LESS THAN 6.0%	 a. Consult Plant Operations Staff for additional recovery actions. Go To Step 19.
	b. Check hydrogen concentration - LESS THAN 0.5% <u>AND</u> STABLE	b. Notify Plant Operations Staff to make arrangements for delivery of the Hydrogen Recombiner.
*19.	Check CST Level - LESS THAN 10%	<u>IF</u> CST level decreases to less than 10%, <u>THEN</u> perform Step 20.
		Observe <u>NOTE</u> prior to Step 21 and Go To Step 21.
20.	Align SW To The AFW Pump Suction Using OP-402, Auxiliary Feedwater System	

ם מים	\sim	1
r r r -	<u> </u>	1

~

Page 8 of 24

SIEF	INSTRUCTIONS	RESPONSE NOT OBTAINED
Th	NOTE e preferred order of S/G use in the ulted, then ruptured. The step refe	subsequent step is intact, rs to "intact", however, faulted
OF	ruptured may be used if that is al	l that is available.
21.	Control Intact S/G Levels As Follows:	
	a. Check any S/G - INTACT	a. <u>IF</u> a faulted S/G is available, <u>THEN</u> use a faulted S/G.
		<u>IF</u> no intact <u>OR</u> faulted S/G is available, <u>THEN</u> use a ruptured S/G.
	b. Check intact S/G levels - LESS THAN 8% [18%]	b. Go To Step 21.e.
	c. Perform either of the following:	
	 Establish FW bypass flow greater than 0.2x10⁶ pph until level in at least one intact S/G is greater than 8% [18%] 	
	OR	
	 Establish AFW flow greater than 300 gpm until level in at least one intact S/G is greater than 8% [18%] 	
	d. Check feed flow - GREATER THAN 300 GPM <u>OR</u> 0.2x10 ⁶ PPH	d. Continue attempts to establish feed flow.
		Go To Step 30.
	e. Control feed flow to maintain intact S/G levels - BETWEEN 8% [18%] <u>AND</u> 50%	

	FRP-	c.	1
--	------	----	---

3 -

RESPONSE TO INADEQUATE CORE COOLING

Rev. 15

Page 9 of 24

ſ			
Π	STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
	*22.	Check RCS Vent Paths:	
		a. Check power to PZR PORV BLOCK Valves - AVAILABLE	a. Close the breakers for the following PRESSURIZER PORV BLOCK Valves:
			• RC-535 (MCC 6, CMPT 7J)
			• RC-536 (MCC 6, CMPT 8J)
		b. Check RCS pressure - LESS THAN 2335 PSIG	b. <u>WHEN</u> RCS pressure decreases to less than 2335 psig, <u>THEN</u> verify CLOSED PZR PORVS <u>OR</u> associated PORV BLOCK Valves.
			Go To Step 22.e.
		c. Verify PZR PORVs - CLOSED	c. Verify CLOSED the associated PORV BLOCK Valve(s).
		d. Check PORV BLOCKs - AT LEAST ONE OPEN	d. Open one PORV BLOCK Valve unless it was closed to isolate an open PZR PORV.
		e. Verify RCS Vent System Valves - CLOSED <u>OR</u> DEENERGIZED:	
		• RC-567, HEAD VENT	
		• RC-568, HEAD VENT	
		• RC-569, PZR VENT	
		• RC-570, PZR VENT	
		• RC-571, PRT ISO	
		• RC-572, CV ATMOS	

Rev. 15

Page 10 of 24

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
	NOTE	
•	Partial uncovery of S/G tubes is a due to steaming faster than feeding	cceptable in the following steps g.
•	After the Low Steamline Pressure S steamline isolation will occur if setpoint is exceeded.	I Signal is blocked, main the high steam flow rate
*23.	Depressurize All Intact S/Gs To 140 PSIG As Follows:	
	a. Check Steam Dump to Condenser - AVAILABLE	a. Dump steam at maximum rate using STEAM LINE PORVs.
		Go To Step 23.c.
	b. Dump steam to Condenser at maximum rate	
	c. Check RCS Hot Leg Temperatures - LESS THAN 543°F	c. <u>WHEN</u> RCS hot leg temperatures less than 543°F, <u>THEN</u> perform Step 23.d.
		Go To Step 23.e.
	d. Defeat Low Tavg Safety Injection Signal as follows:	
	1) Momentarily place SAFETY INJECTION T-AVG Selector Switch to BLOCK position	
	2) Verify LO TEMP SAFETY INJECTION BLOCKED status light - ILLUMINATED	
	e. Check S/G pressures - LESS THAN 140 PSIG	e. <u>IF</u> S/G pressure is decreasing, <u>THEN</u> observe <u>NOTE</u> prior to Step 21 and Go To Step 21.
		<u>IF</u> S/G pressure is increasing, <u>THEN</u> Go To Step 30.
	(CONTINUED 1	NEXT PAGE)

Given the following conditions:

- The unit is at operating at 35% power in preparation for increasing power to 100%.
- Circulating Water Pump 'A' is under clearance for maintenance.
- A fault occurs on 4KV Bus #4 and all loads are lost.

Which ONE (1) of the following describes the effect on the turbine to the above conditions?

- a. The turbine will **NOT** automatically trip, but must be manually tripped when condenser vacuum lowers to 24.5" Hg
- b. The turbine will automatically trip due to all 3 Circulating Water Pump breakers being open
- c. The turbine will automatically trip when condenser vacuum decreases to 17" Hg unless load is lowered to within the capacity of the one remaining Circulating Water Pump
- d. The turbine will **NOT** automatically trip due to load already being within the capacity of the one remaining Circulating Water Pump

Answer:

b. The turbine will automatically trip due to all 3 Circulating Water Pump breakers being open

QUESTION N TIER/GROUP K/A:	UMBER: -: 075A2.02	69	RO	2/2		SRO	2/2
	Ability to (a) p water system circulating wa	redict the impa ; and (b) use p ter pumps	acts of th procedure	ne follow es to co	ving malfur rrect, cont	nctions c rol, or m	or operations on the circulating itigate the consequences: Loss of
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	55.41(b)	RO RO	2.5 7	55.43(b)	SRO SRO	2.7
OBJECTIVE:	CW-09						
	EXPLAIN the interlocks, an	normal operat nunciators, and	ion of th d setpoir	e CW co nts.	ontrol syste	ems. Ind	clude function, instrumentation,
REFERENCE	REFERENCES: APP-008 OP-603						
SOURCE: New Significantly Modified Direct X							
					L		
	ION [,]		Bank	Numbe	r EHC	-11	004
JUSTIFICAT <i>a.</i>	ION:	Plausible sind manual trip, b	Bank of the Bank o	<i>Numbe</i> ering va utomatic	r EHC cuum with trip will oc	-11 cout any cour due	004 chance of recovery will require a to the loss of all 3 CW pumps.
JUSTIFICAT a. b.	ION: CORRECT	Plausible sind manual trip, b The loss of p generate an a	Bank ce a lowe out an au ower wil automati	<i>Numbe</i> ering va utomatic I result i ic turbin	r EHC cuum with trip will oc n all 3 CW e trip.	-11 lout any f ccur due / pump b	004 chance of recovery will require a to the loss of all 3 CW pumps. preakers being open. This will
JUSTIFICAT a. b. c.		Plausible sind manual trip, b The loss of p generate an a Plausible sind were not able available.	Bank of the second seco	Number ering va utomatic I result i ic turbin tomatic ove enot	r EHC cuum with trip will oc n all 3 CW e trip. trip on low ugh heat to	-11 cout any cour due / pump b v vacuun o mainta	004 chance of recovery will require a to the loss of all 3 CW pumps. preakers being open. This will n would occur if one CW pump in vacuum, but no CW pumps are
JUSTIFICAT a. b. c. d.	ION: CORRECT	Plausible sind manual trip, b The loss of p generate an a Plausible sind were not able available. Plausible sind power level, l	Bank a ce a lowe out an au ower wil automati ce an au e to remo ce a sing but no C	Number ering va utomatic I result i ic turbin tomatic ove eno gle CW pump	r EHC cuum with trip will oc n all 3 CW e trip. trip on low ugh heat to pump migh os are ava	-11 fout any ccur due / pump b v vacuun o mainta ht be able ilable.	004 chance of recovery will require a to the loss of all 3 CW pumps. preakers being open. This will n would occur if one CW pump in vacuum, but no CW pumps are e to remove adequate heat at this
JUSTIFICAT a. b. c. d. DIFFICULTY Compreher	ION: CORRECT	Plausible sind manual trip, b The loss of p generate an a Plausible sind were not able available. Plausible sind power level, l	Bank of ce a lowe out an au ower wil automati ce an au e to remo ce a sing but no C	Number ering va utomatic I result i ic turbin tomatic ove eno gle CW p W pump W pump	r EHC cuum with trip will oc n all 3 CW e trip. trip on low ugh heat to pump migh os are ava	-11 fout any f ccur due / pump b v vacuun o mainta ht be abl ht be abl hilable.	004 chance of recovery will require a to the loss of all 3 CW pumps. oreakers being open. This will n would occur if one CW pump in vacuum, but no CW pumps are e to remove adequate heat at this

REFERENCES SUPPLIED:

<u>ALARM</u>

CW PMP A MOTOR/DISCH VLV TRIP/OVLD

AUTOMATIC ACTIONS

1. Turbine trip on last CW pump trip.

<u>CAUSE</u>

- 1. Open Supply Breaker **OR** Motor Overload Trip on Discharge Valve Motor
- 2. Electrical Fault OR Overload Trip of CWP Breaker
- 3. ØB Overload of CWP but no TRIP

OBSERVATIONS

- 1. V6-50A, CIRC WATER PUMP "A" DISCH, position/status
- 2. CWP Motor Breaker Status
- 3. Condenser Vacuum
- 4. CWP Discharge Pressure (PI-1600A)

<u>ACTIONS</u>

- 1. **IF** Turbine is operating, **THEN** refer to AOP-012.
- 2. **IF** Turbine is **NOT** operating, **THEN** perform the following:
 - 1) **IF** V6-50A, CIRC WATER PUMP "A" DISCH, breaker is tripped, **THEN** attempt one reset of the breaker located at MCC 7, Compartment 1M.
 - IF Circ Water Pump "A" breaker is tripped, THEN perform the following:
 - a. Verify CLOSED V6-50A, CIRC WATER PUMP "A" DISCH.
 - b. Start an available Circ Water Pump.
 - c. **IF** the minimum number of Circ Water Pumps required for liquid waste releases are **NOT** operating, **THEN** verify any Liquid Waste Batch Releases are terminated.

DEVICE/SETPOINTS

2)

- 1. CWP Breaker 74 Relay / energized
- 2. CWP Breaker ØB51 Device / energized
- 3. Discharge Valve 74 Relay / deenergized

POSSIBLE PLANT EFFECTS

- 1. Decrease **OR** Loss of Vacuum
- 2. Plant Shutdown

REFERENCES

- 1. AOP-012, Partial Loss of Condenser Vacuum or Circulating Water Pump Trip
- 2. CWD B-190628, Sheet 811, cable G
- 3. Flow Diagram G-190199, Sheet 1

APP-008	Rev. 27	Page 32 of 51	
,			

ATTACHMENT 9.1 Page 9 of 37 ELECTRICAL DISTRIBUTION SYSTEM STARTUP LINEUP

4160V BUS 4

DESCRIPTION	BREAKER POSITION	INITIALS
4KV BUS 3-4 TIE BKR 52/19	CLOSED*	
UNIT AUX TO 4KV BUS 4 BKR 52/20	OPEN*	
CONDENSATE PUMP "B" BKR 52/22	RACKED IN	
CIRCULATING WATER PUMP "B" BKR 52/23	RACKED IN	
FEED TO 4KV BUS 5 BKR 52/24	CLOSED	
Local CIRCUIT BREAKER CONTROL Switch for BKR 52/24,	PUSHED IN	
FEED TO 4KV BUS 5	AND	
	VERTICAL	
HEATER DRAIN PUMP "B" BKR 52/25	RACKED IN	
FEEDWATER PUMP "B" BKR 52/26	RACKED IN	
REACTOR COOLANT PUMP "B" BKR 52/27	RACKED IN	
STATION SERVICE TRANSFORMER 2D BKR 52/28	CLOSED	
Local CIRCUIT BREAKER CONTROL Switch for BKR 52/28,	PUSHED IN	
STATION SERVICE TRANSFORMER 2D	AND	
	VERTICAL	

4160V BUS 5

SPARE BKR. 52/31	RACKED OUT	
STATION SERVICE TRANSFORMER 2E BKR 52/32	RACKED IN	
Local BREAKER CONTROL Switch for BKR 52/32,	PUSHED IN	
STATION SERVICE TRANSFORMER 2E	AND	
	VERTICAL	
CIRCULATING WATER PUMP "C" BKR 52/33	RACKED IN	
SPARE BKR 52/34	RACKED OUT	
4160V BUS 5 BREAKERS RELAY TARGETS	RESET	

*Breaker position varies with Plant conditions IAW general procedures.

Exceptions

OP-603	Rev. 56	Page 112 of 142

٦

Given the following conditions:

- The unit is operating at 2% power.
- The following RCP indications are observed:

INDICATION	RCP 'A'	RCP 'B'	RCP 'C'
Motor Bearing Temperatures	210°F and ↑ slowly	180°F and stable	195°F and ↑ slowly
#1 Seal Leakoff Temperatures	150°F and stable	150°F and stable	165°F and ↑ slowly
#1 Seal Leakoff Flow	5.8 gpm and stable	4.2 gpm and stable	3.8 gpm and stable
Thermal Barrier ΔP	10" and stable	10" and stable	8" and stable
Frame Vibration	3.6 mils and ↑ at 0.1 mil per hr	2.8 mils and stable	4 mils and ↑ at 0.05 mil per hr
Shaft Vibration	12 mils and stable	7 mils and stable	9.5 mils and ↑ at 0.6 mils per hour

Which ONE (1) of the following describes the actions required for this condition?

- a. Stop 'A' RCP and enter Technical Specification 3.4.4, RCS Loops Modes 1 & 2
- b. Trip the reactor, stop 'A' RCP, and go to PATH-1
- c. Stop 'C' RCP and enter Technical Specification 3.4.4, RCS Loops Modes 1 & 2
- d. Trip the reactor, stop 'C' RCP, and go to PATH-1

Answer:

a. Stop 'A' RCP and enter Technical Specification 3.4.4, RCS Loops - Modes 1 & 2

				RNP Cor	NRC Writter	n Examinatio ion Referenc	n e
UMBER: : 015/017AA1.20	70 RO	1/1	SRO	1/1			
Ability to operate Malfunctions (Los	and / or monitor ss of RC Flow): R	the followi CP bearir	ing as they apply to ng temperature ind	o the React icators	or Coolant P	ump	
ANCE: NTENT:	RO 55.41(b) RO	2.7 3	SRO 55.43(b) SRO	2.7			

OBJECTIVE: AOP-018-03

K/A IMPORTANCE:

10CFR55 CONTENT:

QUESTION NUMBER:

TIER/GROUP:

K/A:

DEMONSTRATE an understanding of selected steps, cautions, and notes in AOP-018 by explaining the basis of each.

REFERENCES: AOP-018 AOP-014

SOURCE:	New	Significantly Modified	X	Direct
	м.	Bank Number	AOP-014-03	011
a.	CORRECT	A' RCP motor bearing tempera stopped. With the plant in Mo	ature has exceed de 2, a reactor tri	ed limits and the pump must be p is not required.
b.		Plausible since these would be the plant is in Mode 2.	e the correct actio	ons if the plant was in Mode 1, but
C.		Plausible since these are the o limits while 'A' RCP has.	correct actions, b	ut 'C' RCP has not reached any trip
d.		Plausible since these would be 'C' RCP has not reached any 2.	e the correct action trip limits while 'A	ons if the plant was in Mode 1, but ' RCP has and the plant is in Mode
DIFFICULTY: Comprehens	ive/Analysis	X Knowledge/Recall	Rating	4
/	Analysis to de	etermine which RCP must be sf	topped and comp	arison to power level to determine

REFERENCES SUPPLIED:

proper action

<u> </u>	n1	1
AUF-	ບມ	

COMPONENT COOLING WATER SYSTEM MALFUNCTION

Rev. 17

Page 47 of 103

I			DESDONSE NOT OPTAINED
	STEP		RESPONSE NOT OBTAINED
		SECTIO	
		<u>CCW SYSTEM LOW FLOW</u>	<u>OR HIGH TEMPERATURE</u>
		(Page 2	of 5)
	2.	Check APP-001-B1, RCP BRG COOL WTR LO FLOW - EXTINGUISHED	Verify the following CCW Valves open:
			• CC-716A, CCW TO RCP ISO
			• CC-716B, CCW TO RCP ISO
			• CC-730, BRG OUTLET ISO
			<u>IF</u> CCW to the RCP(s) can <u>NOT</u> be restored, <u>THEN</u> perform the following:
			a. Trip the reactor
			b. Trip the affected RCPs
			c. Go To Path-1 while continuing with this procedure.
			d. Go To Step 4.
	* 3.	Check ALL RCP Motor Bearing Temperature - LESS THAN 200°F	<u>IF</u> the Plant is in Mode 2 <u>OR</u> less, <u>THEN</u> stop the affected RCP.
			<u>IF</u> the Plant is in Mode 1, <u>THEN</u> perform the following:
			a. Trip the reactor.
			b. Stop the affected RCP(s).
			c. Go To Path-1 while continuing with this procedure.
	4.	Check CCW HX OUTLET Temperature - GREATER THAN 105°F	Go To Step 12.
1			

AOD-	. 01	Q
AUF -	- U Т	0

REACTOR COOLANT PUMP ABNORMAL CONDITIONS

Rev. 11

Page 16 of 47

CUERD		RESPONSE NOT OBTAINED								
	SECTION									
	HIGH REACTOR COOLANT PUMP VIBRATION									
	(Page 1 of 4)									
	NOTE									
	ibration rate changes (increase or d	ecrease) for diagnosing a problem								
a	re valid only during steady state co	onditions.								
		-								
* 1.	Check The Following Vibration	IF any of the vibration limits								
	Levels To Determine If RCP Trip(s) Are Required:	are exceeded, <u>THEN</u> Go To Step 2.								
	• Frame - GPEATER THAN 5 MILS	Go To Step 8.								
	OR									
	 Frame - GREATER THAN 3 MILS AND INCREASING AT GREATER 									
	THAN 0.2 MILS/HOUR									
	OR									
	• Shaft - GREATER THAN 20 MILS									
	OR									
	• Shaft - GREATER THAN 15 MILS									
	AND INCREASING AT GREATER									
	ITAN I MIL FER ROOK	then the offerted PCP(a)								
2.	Check Plant Status - MODE 1	Stop the affected RCP(S).								
		Go To Step 4.								
3.	Perform The Following:									
	a. Trip the reactor									
	b. Trip the affected RCP(s)									
	c. Go To Path-1 while continuing									
	with this procedure.									
4.	Check RCP B <u>OR</u> C - RUNNING	Go To Step 10.								

REACTOR COOLANT PUMP ABNORMAL CONDITIONS

Rev. 11

Page 5 of 47

Г			DEGDONGE NOT OPENINED									
٦	STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED									
		SECTION	A									
	REACTOR COOLANT PUMP SEAL FAILURE											
	(Page 1 of 11)											
	* 1.	Check Any RCP #1 Seal Leakoff Flow - GREATER THAN 5.7 GPM	<u>IF</u> seal leakoff exceeds 5.7 gpm, <u>THEN</u> Go To Step 2.									
			Go To Step 8.									
	2.	Check Either Of The Following Conditions Exist:	Perform the following:									
		 RCP #1 Seal Leakoff Flow On Unaffected RCP(s) - DECREASED 	a. Perform cross-check of all RCP parameters to determine cause of indicated high leakoff flow.									
		<u>OR</u>	b. Observe The <u>NOTE</u> Prior To									
		 RCP Thermal Barrier AP On Affected RCP(s) - DECREASED 	Body, Step 1 Of This Procedure									
	****	****	**************************************									
			2									
	To p Isol the	prevent damage to the RCP Seal Stack ation valve must be closed between 3 RCP.	, the affected RCP Seal Leakoff 3 minutes and 5 minutes of stopping									
	* * * *	*****	*******									
	3.	Check Plant Status - MODE 1	Stop the affected RCP(s)									
			Observe the <u>CAUTION</u> prior to Step 5 and Go To Step 5.									
	4.	Perform The Following:										
		a. Trip the reactor										
		b. Trip the affected RCP(s)										
		c. Go To Path-1 while continuing with this procedure.										

AOP-014-03 011

Given the following plant conditions:

- Mode 1 at 35% RTP
- Two charging pumps are running
- The following RCP indications are observed:

		RCP "A"	RCP "B"	RCP "C"
0	RCP motor bearing	180°F	180°F	210°F
	temperatures			
0	#1 seal leakoff temperatures	150°F	150°F	165°F
0	Thermal barrier delta P	10"	10"	8"

Which ONE (1) of the following describes the action(s) required for this condition?

- A. Stop "C" RCP, shutdown IAW GP-006, Normal Plant Shutdown From Power Operation To Hot Shutdown, and be in Mode 3 within 6 hours.
- B. Throttle CVC-297C, "C" RCP Seal Water Flow Control valve, to obtain between 8 and 13 gpm flow to each "C" RCP Seals.
- C. Close CVC-303C, "C" RCP Seal Leakoff valve.
- ✓D. Trip the reactor, stop RCP "C".

Which ONE (1) of the following requires entry into DSP-001, "Alternate Shutdown Diagnostic"?

- a. A fire in the Main Turbine that has the potential to destroy the generator when the reactor is above 10% power
- b. A fire in the Containment Vessel that has the potential to destroy the pressurizer heater power cables when in hot standby
- c. A fire in the Control Room that has the potential to destroy RHR pump control cables when refueling
- d. A fire in the Auxiliary Building that has the potential to destroy the running Charging Pump when in cold shutdown

Answer:

b. A fire in the Containment Vessel that has the potential to destroy the pressurizer heater power cables when in hot standby

					Common (Question Reference	
QUESTION N TIER/GROUF K/A:	NUMBER: ?: 067AA2.04	71 RO) 1/1	SRO	1/1		
	Ability to deter extent of pote	rmine and interpret ntial operational da	the following mage to plan	as they apply to t equipment	the Plant Fire on	Site: The fire's	
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	RO 55.41(b) RO	3.1 10	SRO 55.43(b) SRO	4.3		
OBJECTIVE:	: DSP-001-02						
	RECOGNIZE	the selected entry	level conditio	ns of DSP-001.			
REFERENCE	-8.	DSP-001					
SOURCE:	New	Significantly	Modified		Direct X		
		Ba	nk Number	DSP-001-02	005		
JUSTIFICAT	ION:		and the set of NA a		domogo oguinmor	at witch to	
a.		Plausible since of generating capaci	ity, but not loc	cated in AB, CV,	or CR.		
b.	CORRECT	Entry conditions a vital controls/com higher.	are a fire in the ponents and/	e AB, CV, or CR or their power/co	that has the poter ntrol cables when	itial to damage in Mode 4 or	
с.		Plausible since er temperature is be	ntry would be low required	made into DSP-lentry conditions.	001 if in a higher N	Aode, but	
d.		Plausible since er temperature is be	ntry would be low required	made into DSP- entry conditions.	001 if in a higher N	<i>l</i> lode, but	
DIFFICULTY Comprehei	(: nsive/Analysis	Knowle	edge/Recall	X Rating	2		
	Knowledge of the entry conditions / purpose of AOPs						

RNP NRC Written Examination

REFERENCES SUPPLIED:

Purpose and Entry Conditions

(Page 1 of 1)

1. <u>PURPOSE</u>

This procedure determines whether conditions exist that warrant the use of the DSPs and to provide guidance as to which specific DSP should be implemented.

For entry into the Dedicated Shutdown Procedures, the following assumptions were made:

- a. All plant equipment will function at designed capability and may be lost only as a result of fire damage.
- b. No accidents or equipment failures other than those caused by the fire are assumed to occur coincident with a complete 72 hour loss of offsite power.

2. ENTRY CONDITIONS

A fire in the AUX BLDG, CV, or Control Room that has the potential to damage vital plant components/controls and/or their power/control cables when Tavg is greater than 200°F.

- END -

٢

Question: 72

CC-707, Component Cooling Water Surge Tank relief valve, is sized to accommodate the ...

- a. maximum CCW insurge to the tank resulting from a loss of the Residual Heat Removal system.
- b. maximum flowrate associated with a rupture of a Reactor Coolant Pump Thermal Barrier Heat Exchanger.
- c. maximum CCW insurge to the tank resulting from a loss of the Service Water system.
- d. maximum flowrate associated with a rupture of a Residual Heat Removal pump cooler during the recirculation phase of an accident.

Answer:

b. maximum flowrate associated with a rupture of a Reactor Coolant Pump Thermal Barrier Heat Exchanger.

								RNP NRC Written Examination Common Question Reference
QUESTION N	UMBER:	72						
TIER/GROUF	008K4 02		RO	2/3		SRO	2/3	
	Knowledge of Operation of t	CCWS desig he surge tank	n feature , includii	e(s) and/ ng the as	or intei sociat	lock(s) whic ed valves ar	ch pro nd cor	vide for the following: htrols
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.9 4	55.43	SRO (b) SRO	3.7	
OBJECTIVE:	CCW-05							
	DESCRIBE th	e performanc	e and de	esign attı	ibutes	of the majo	r CCV	V System components.
REFERENCE SOURCE	ES: New	SD-013	antiv M	odified			Dire	ct X
0001(021								
JUSTIFICAT <i>a.</i>	ION:	Plausible sin CCW to cool	Bank ce CCW down no	x Numbe V and RH ot heatup	r C IR syst	CW-04 ems interfac	ce, bu	t loss of RHR would cause
b.	CORRECT	Sized to relie thermal barri	eve the r er coolir	maximun ng coil.	n flowra	ate of water	follow	ring the rupture of a RCP
C.		Plausible sin sufficient ma	ce CCV gnitude	V is coole to cause	ed by S e an ins	W, but loss surge to cha	of SV llenge	V would not cause a heatup of the capacity of this valve.
d.		Plausible sin cause insurg	ice CCV je.	V cools F	tHR ρι	mp cooler, l	but dif	fferential pressure would not
DIFFICULTY Compreher	′: nsive/Analysis	Kr.	owledg	ge/Recal	' X	Rating	3	
	Knowledge o	f CCW systen	n design	attribute	es			

REFERENCES SUPPLIED:

ATTACHMENT 10.4 Page 1 of 2

CCW RELIEF VALVE AND SET POINTS

RELIEF	DESCRIPTION	<u>SETPOINT</u>
CC-707	Component Cooling Surge Tank Relief Valve.	100 psig <u>+</u> 3 psig
	Discharges to the LWD-Waste Holdup Tank - Sized to relieve the maximum flow rate of water following a rupture of a RCP thermal barrier cooling coil.	
CC-715	Excess Letdown Heat Exchanger CCW Outlet Relief Valve.	125 psig <u>+</u> 3.75 psig
	Discharges to the Containment Sump.	2105
CC-722A	RCP A Thermal Barrier Cooler CCW Outlet Relief Valve.	2485 psig <u>+</u> 74.6 psig
	Discharges to the Containment Sump.	
CC-722B	RCP B Thermal Barrier Cooler CCW Outlet Relief Valve.	2485 psig <u>+</u> 74.6 psig
	Discharges to the Containment Sump.	
CC-722C	RCP C Thermal Barrier Cooler CCW Outlet Relief Valve.	2485 psig <u>+</u> 74.6 psig
	Discharges to the Containment Sump.	
CC-729	RCPs A, B, & C Motor Bearing Oil Cooler CCW Outlet Relief Valve.	125 psig <u>+</u> 3.75 psig
	Discharges to Containment Sump.	
CC-747A	RHR Heat Exchanger A CCW Outlet Relief Valve.	150 psig <u>+</u> 4.5 psig
	Discharge to the CCW Return Header.	
CC-747B	RHR Heat Exchanger B CCW Outlet Relief Valve.	150 psig <u>+</u> 4.5 psig
	Discharges to the CCW Return Header.	

Which ONE (1) following procedures is used to provide instructions in the event of a cask drop when loaded with spent fuel in Dry Shielded Canister (DSC)?

- a. AOP-005, Radiation Monitoring System
- b. AOP-008, Accidental Release of Liquid Waste
- c. AOP-013, Fuel Handling Accident
- d. AOP-028, ISFSI Abnormal Events

Answer:

d. AOP-028, ISFSI Abnormal Events

QUESTION NUMBER: TIER/GROUP: K/A: 036 2.2.28	73	RO	1/3	SRO	1/3	
Knowledge c	f new and spent	t fuel mo	vement p	rocedures (Fuel	Handling Accider	nt).
K/A IMPORTANCE: 10CFR55 CONTENT:	F 55.41(b) I	RO RO	2.6 10 {	SRO 55.43(b) SRO	3.5	
OBJECTIVE: AOP-028-01						
STATE the p	urpose of AOP-(028.				
REFERENCES:	AOP-028					
SOURCE: New	Significar	ntly Mod	dified		Direct X	
		Bank N	lumber	AOP-028-01	004	
JUSTIFICATION: a.	Plausible since	e this eve	ent could	result in increas	ed radiation level	s, but AOP-028
	specifically ad	dresses	this conc	lition.		
b.	Plausible since	e this ev	ent could	result in release	e, but AOP-028 sp	ecifically
	addresses this	s conditio	on.			
с.	Plausible since addresses this	e this eve s conditio	ent could on.	occur while refu	eling, but AOP-02	28 specifically
d. CORRECT	Entry conditior shielded canis	ns for AC ster.	DP-028 ir	iclude cask drop	when loaded with	n spent fuel in dry
DIFFICULTY: Comprehensive/Analysis	s Kno	wledge/	(Recall	X Rating	2	
Knowledge o	of the entry cond	litions / p	ourpose c	f AOPs		

REFERENCES SUPPLIED:

··· ···

Purpose and Entry Conditions

(Page 1 of 1)

1. <u>PURPOSE</u>:

This procedure provides the instructions necessary for the operator to respond to any abnormal ISFSI condition under all plant conditions.

2. <u>ENTRY CONDITIONS</u>:

Any indication of an ISFSI abonormal condition as follows:

- Blockage of the HSM Drains, Air Inlets, or Air Outlets
- High Radiation at the Surface of the HSM
- Cask Drop when Loaded with Spent Fuel in Dry Shielded Canister
- Damage to HSM Air Outlet Shield Block

- END -

Given the following conditions:

- The unit is in Mode 2.
- PZR level transmitter LT-460 failed low and was removed from service.
- The PZR high-high level and low level bistables associated with LT-460 were placed in the TRIPPED condition.
- PZR level channel selector switch LM-459 was selected to "461 REPL 460".

Which ONE (1) of the following describes the function provided by PZR level transmitter LT-461 under these conditions?

- a. Energizes the backup heaters on a high level deviation
- b. Decreases charging pump speed on an increasing level
- c. Deenergizes the proportional and backup heaters on a low level
- d. Trips the reactor on a high-high level

Answer:

c. Deenergizes the proportional and backup heaters on a low level

								Common Questio	n Reference
QUESTION N TIER/GROUF K/A:	UMBER: P: 011K6.04	74	RO	2/2		SRO	2/2		
	Knowledge of	the effect of a l	oss or i	malfunc	tion on [.]	the Operat	ion of F	ZR level controlle	rs
	5					·			
K/A IMPORT 10CFR55 CO	ANCE: INTENT:	F 55.41(b) F	70 70	3.1 7	55.43(SRO (b) SRO	3.1		
OBJECTIVE:	: PZR-08								
	EXPLAIN the System switcl	component openes and controls	eration a s.	associat	ed with	each swite	ch posit	ion for the PZR ar	d PRT
REFERENCE	ES:	AOP-025 SD-059 SD-011							
SOURCE:	New	Significar	ntly Mo	dified	X		Direct	t 🔲	
			Bank	Numbe	r PZ	ZR-07		003	
JUSTIFICAT a.	ION:	Plausible since position, but the	e LT-46 his funct	i1 could tion is p	perforn erforme	n this functi d by LT-45	ion if sv 59 unde	vitch in 461 REPL r these conditions	459
b.		Plausible since position, but th	e LT-46 nis func	1 could tion is p	perforn erforme	n this functi d by LT-45	ion if sv 59 unde	vitch in 461 REPL er these conditions	459
с.	CORRECT	LT-461 perform isolating letdow independent o	ms all fu wn and of contro	unctions deener ol switch	norma gizing a positio	lly perform Il heaters c n.	ed by L on a low	T-460. This inclue v level. Input to RI	des ⊃S is
d.		Plausible since below 10% po	e 2/3 hi wer.	gh level	s would	l trip the rea	actor if	above P-7, but pla	ant is
DIFFICULTY Compreher	′: nsive/Analysis	Кпо	wledge	e/Recali	×	Rating	3		
	Knowledge o	f the Pressurize	er Level	Control	system	n design at	tributes		

RNP NRC Written Examination

REFERENCES SUPPLIED:

AOP-025

Rev. 3

Page 6 of 22

STEP	INSTRUCTIONS RESPONSE NOT OBTAINED	
	<u>SECTION B</u>	
	Pressurizer Level Transmitter Failure	
	(Page 1 of 3)	
1.	Check CVC-460 A&B, LTDN LINE Go To Step 3. STOP - CLOSED	
2.	Place CVC-460 A & B In The CLOSE Position	
3.	Place Pressurizer Level Controller, LC-459G, In The MAN Position	
4.	Restore PRZR LEVEL To Between 22% TO 53%	
5.	Check Number Of Operable PZR Go To Step 12. Level Channels - GREATER THAN ONE	
6.	Place LM-459, PZR LEVEL, In The Switch Position For The Alternate Channel Below:	
	FAILED CHANNELSWITCH POSITIONLT-459461 REPL 459LT-460461 REPL 460	
7.	Verify Selector Switch LR-459 - SELECTED TO THE CONTROLLING CHANNEL	
	• REC 459	
	• REC 461	

-

There is one alarm associated with each channel of LTOPP. It actuates for 3 reasons: (1) RCS temperature is <360°F and LTOPP is not selected on the key switch for OVERPRESSURE PROTECTION, (2) The PORV has received an actuation signal based upon current pressure and temperature or (3) the associated Block valve is shut.

5.1.5 PZR Level Control (PZR-Figure 12)

PZR level is controlled by controlling charging pump speed. The level is programmed to ramp up as Tavg increases by LC-459G. This maintains approximately constant mass in the RCS as Tavg is increased and the coolant in the RCS expands. Level program is 22.2% at Tavg of 547°F and 53.3% at Tavg of 575.4°F.

There are 3 PZR level channels LT-459, LT-460 and LT-461. LC-459G the PZR level controller is normally fed by level channel LT-459 but can be replaced by LT-461 with a selector switch on the RTGB. The output of LC-459G is then fed to the charging pump speed controllers to control speed of the charging pump if their controllers are selected to Auto.

If PZR level increases 5% above program LC-459D will turn on the backup heaters and sound an annunciator for High Level Heaters on.

On PZR low level of 14.4%, proportional and backup heaters are deenergized and letdown is isolated by shutting LCV-460A & B if respective control switches are in auto. LC-459 and the LC-460, the low level bistables, are normally supplied by LT-459 and LT-460 respectively but either can be replaced by LT-461 with a selector switch on the RTGB.

LC-459 will only turn off the backup heaters that are selected to Automatic where LC-460 will turn off the backup heaters in Automatic or Manual. The only time this would have any bearing would be in the event of an instrument failure. If the channel feeding LC-459, usually LT-459, were to fail low the proportional heaters and any backup heaters in Automatic would deenergize and any backup heater in manual would remain energized.

PZR

Page 20 of 27

Revision 2

INFORMATION USE ONLY

LEVEL CONTROLLER PZR-FIGURE-12 (Rev. 0)



INFORMATION USE ONLY

PZR-07 003

Given the following plant conditions:

- Mode 1 at 100% RTP
- PZR level transmitter LT-459 fails low and is being removed from service
- PZR level channel selector switch LM-459 is selected to "461 REPL 459"

Which ONE (1) of the following describes the function provided by PZR level transmitter LT-461 with the level channel selector switch LM-459 is selected to "461 REPL 459"?

- A. Changes the PZR high level reactor trip to 1/3 logic.
- B. Can deenergize the backup heaters in AUTO or MANUAL.
- ✓C. Provides input to PZR low level letdown isolation.
- D. Can energize proportional heaters upon 5% level deviation.

Given the following conditions:

- Reactor power was initially 100%.
- All CCW flow has been lost to the RCPs and a reactor trip has been initiated.

Which ONE (1) of the following nuclear instrument indications would warrant entry into FRP-S.1, "Response To Nuclear Power Generation/ATWS"?

a. **BOTH** source range channels are energized and intermediate range startup rate is +0.1 dpm

ŧ

- b. Power range indicates 3%
- c. Source range startup rate is +0.3 dpm
- d. **NEITHER** source range channel is energized and intermediate startup rate is -0.1 dpm

Answer:

a. **BOTH** source range channels are energized and intermediate range startup rate is +0.1 dpm

QUESTION N TIER/GROUP K/A:	UMBER: : 029EA2.01	75	RO	1/2	SRO	1/1	
	Ability to deter instrumentatio	mine or interpr n	et the fo	llowing as	they apply to	a ATWS:	Reactor nuclear
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	l 55.41(b)	RO RO	4.4 10 5	SRO 5.43(b) SRO	4.7	
OBJECTIVE:	FRP-S.1-02						
	RECOGNIZE	the selected e	ntry leve	l conditior	ns of FRP-S.1.		
REFERENCE	S:	CSFST					
SOURCE:	New	Significa	ntiv Moo	dified [7	Direct	X
			•				
			Bank N	∟ lumber	FRP-S.1-02	2	005
JUSTIFICAT <i>a.</i>	ION: CORRECT	Either the PR SUR > 0.0 dp	Bank N instrume m (ORA	Lumber ents indica NGE) wor	FRP-S.1-02 ating > 5% (RE uld require ent	2 ED) or the ry into FR	005 IR instruments indicating a P-S.1.
JUSTIFICATI a. b.	ION: CORRECT	Either the PR SUR > 0.0 dp Plausible sinc tripped, but po	Bank M instrume m (ORA e excess ower ran	<i>lumber</i> ents indica NGE) wor sive powe	FRP-S.1-02 ating > 5% (RE uld require ent or range level i w the 5% level	2 ED) or the ry into FR ndicates th I which wa	005 IR instruments indicating a P-S.1. hat the reactor is not arrants enty into FRP-S.1.
JUSTIFICATI a. b. c.	ION: CORRECT	Either the PR SUR > 0.0 dp Plausible sinc tripped, but po Plausible sinc satisfied, but o	Bank M instrume m (ORA e excess ower ran e source entry into	<i>lumber</i> ents indica NGE) wor sive powe ge is belo e range st o FRP-S.2	FRP-S.1-02 ating > 5% (RE uld require ent or range level in the 5% level artup rate is g 2 vice S.1 is wa	2 ED) or the ry into FR ndicates the el which wa reater than arranted.	005 IR instruments indicating a P-S.1. hat the reactor is not arrants enty into FRP-S.1. h 0.0 and CSF-1 is not
JUSTIFICATI a. b. c. d.	ION: CORRECT	Either the PR SUR > 0.0 dp Plausible sinc tripped, but po Plausible sinc satisfied, but o Plausible sinc startup rate le FRP-S.2 vice	Bank M instrume m (ORA ee excess ower ran ee source entry into es with th ess nega S.1 is w	<i>lumber</i> ents indica NGE) wor sive powe ge is belo e range st o FRP-S.2 ne source tive than arranted.	FRP-S.1-02 ating > 5% (RE uld require ent or range level in w the 5% level artup rate is g 2 vice S.1 is w range not ene -0.2 dpm and 0	2 ED) or the ry into FR ndicates the el which wa reater than arranted. ergized and CSF-1 is r	005 IR instruments indicating a P-S.1. nat the reactor is not arrants enty into FRP-S.1. n 0.0 and CSF-1 is not d intermediate range not satisfied, but entry into
JUSTIFICATI a. b. c. d. DIFFICULTY Compreher	ION: CORRECT	Either the PR SUR > 0.0 dp Plausible sinc tripped, but po Plausible sinc satisfied, but of Plausible sinc startup rate le FRP-S.2 vice	Bank M instrume m (ORA) e excess ower ran e source entry into se with th ess nega S.1 is w	Iumber ents indica NGE) wor sive powe ge is belo e range st o FRP-S.2 he source tive than arranted.	FRP-S.1-02 ating > 5% (RE uld require ent or range level in the 5% level artup rate is g 2 vice S.1 is wa range not ene -0.2 dpm and 0 X Rating	2 ED) or the ry into FR ndicates the el which wa reater than arranted. ergized and CSF-1 is r	005 IR instruments indicating a P-S.1. hat the reactor is not arrants enty into FRP-S.1. h 0.0 and CSF-1 is not d intermediate range not satisfied, but entry into

REFERENCES SUPPLIED:



Given the following conditions:

- The unit is operating at 100% power.
- Channel III PZR Pressure PT-457 is failed, with all bistables in the TRIPPED condition.
- An electrical fault occurs which results in a loss of Instrument Bus 2.

Which ONE (1) of the following describes the impact that the loss of Instrument Bus 2 has on the plant?

- a. A reactor trip and SI occur and **BOTH** trains of Engineered Safeguards loads are automatically started by the sequencers
- b. A reactor trip and SI occur, but **ONLY** Train 'A' Engineered Safeguards loads are automatically started by the sequencers
- c. A reactor trip and SI occur, but **ONLY** Train 'B' Engineered Safeguards loads are automatically started by the sequencers
- d. A reactor trip occurs, but **NO** SI occurs.

Answer:

c. A reactor trip and SI occur, but **ONLY** Train 'B' Engineered Safeguards loads are automatically started by the sequencers

QUESTION N TIER/GROUP K/A:	UMBER: : 013K2.01	81	RO	2/1		SRO	2/1	
	Knowledge of	bus power su	pplies to	o the ESI	FAS/safe	guards e	quipment control	
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.6 8	55.43(b)	SRO) SRO	3.8	
OBJECTIVE:	ESF-06							
	LIST power si	upplies for the	major E	SFAS co	omponen	ts as list	ed in the EDPs.	
REFERENCE	S:	SD-006						
		AOP-024						
SOURCE:	New	Significa	antly Mo	odified	X		Direct	
SOURCE:	New	Significa	antly Mo Bank	odified Numbei	r ESF	-09	Direct 015	
SOURCE:	New	Significa	antly Mo Bank	odified Numbei	r ESF	-09	Direct 015	
SOURCE: JUSTIFICATI a.	New	Plausible sind by IB 7, but II available.	Bankiy Mo Bank Ce a rea B 7 gets	odified Number ctor trip a power f	x r ESF and SI wi from IB2 s	-09 Il occur a so only tr	Direct 015 and train 'A' sequencer is power ain 'B' sequencer has power	ered
SOURCE: JUSTIFICATI a. b.	New	Plausible sind by IB 7, but II available. Plausible sind power available	Bank Bank ce a rea B 7 gets ce a rea ble.	odified Number actor trip a power fi actor trip a	x ESF and SI wi from IB2 s and SI wi	-09 Il occur a so only tr Il occur,	Direct 10 015 and train 'A' sequencer is power ain 'B' sequencer has power but only train 'B' sequencer has	ered
SOURCE: JUSTIFICATI a. b. c.	New	 Significat Plausible sind by IB 7, but II available. Plausible sind power available A loss of Inst generate a S it is powered 	antly Mo Bank Ce a rea B 7 gets Ce a rea ole. rument I and re by IB 3	<i>Number</i> <i>Number</i> actor trip a actor trip Bus 2 wi actor trip and train	x ESF and SI wi Si wi from IB2 s Si wi and SI wi Si wi and SI wi Si wi ill cause 2 Si Only training	-09 Il occur a to only tr Il occur, 2/3 low p ain 'B' se wered b	Direct 015 and train 'A' sequencer is power ain 'B' sequencer has power but only train 'B' sequencer has ressure conditions which will equencer has power available y IB 7, which gets power from	ered as since IB 2.
SOURCE: JUSTIFICATI a. b. c. d.	New	 Significat Plausible sind by IB 7, but II available. Plausible sind power available A loss of Inst generate a S it is powered Plausible sind pressure, red and an SI will 	antly Mo Bank Ce a rea B 7 gets Ce a rea ole. rument I and re by IB 3 Ce a rea quire por I also oc	<i>Number</i> <i>Number</i> actor trip a actor trip a actor trip and train actor trip wer to ac actor.	x ESF and SI wi Si wi irrom IB2 s Si wi and SI wi Si wi ill cause 2 Si Only training trangle training trangle training trangle tra	-09 Il occur a to only tr Il occur, 2/3 low p ain 'B' se wered b wered b and sor t low pre	Direct	ered as IB 2. 7 high litions
SOURCE: JUSTIFICATI a. b. c. d. DIFFICULTY Comprehent	New ON: CORRECT	Significat Plausible sind by IB 7, but II available. Plausible sind power available A loss of Inst generate a S it is powered Plausible sind pressure, red and an SI will	antly Mo Bank Ce a rea B 7 gets Ce a rea ble. rument I and re by IB 3 ce a rea quire po I also oc owledg	<i>Number</i> <i>Number</i> octor trip a power find actor trip actor trip actor trip wer to accord cour.	x ESF and SI wi irom IB2 s and SI wi ill cause 2 o. Only transmitted n 'A' is poor will occur ctuate, bu / R	2-09 Il occur a so only tr Il occur, 2/3 low p ain 'B' se wered b and sor t low pre ating	Direct 015 and train 'A' sequencer is power ain 'B' sequencer has power but only train 'B' sequencer has ressure conditions which will equencer has power available y IB 7, which gets power from the ESF functions, such as CV essure goes to its tripped cond	ered as since IB 2. ' high litions

REFERENCES SUPPLIED:

2.2 Design Basis2.2 Design Basis

Combined with the Reactor Trip System, the ESFAS is designed to perform all protective actions associated with the Reactor Safeguards and Protection System (RSPS).

The RSPS receives redundant inputs that include process variables, nuclear measurements, and equipment operational status. These inputs are provided by the Nuclear Instrumentation System, Analog Process Instrumentation and Control System, the Electrical Power Distribution System, and the Turbine Control System. Inputs to the Reactor Trip System are developed by redundant coincidence logic within the Reactor Protection Relay Racks, while inputs to the ESFAS are developed via similar logic within the Safeguards Relay Racks. These inputs enable the Reactor Trip System and the ESFAS to perform their respective protective actions.

2.3 System Description2.3 System Description

The ESFAS consists of two completely independent trains (A and B). The trains receive DC power from "A" and "B" station batteries respectively. AC power is supplied by station battery backed instrument buses. Instrument Bus 7A supplies Train "A" and Instrument Bus 3 supplies Train "B". Both trains have a complete set of matrices and both receive the same actuating signals. All of the circuits are redundant unless otherwise noted.

The bistables generating the input signals, with the exception of the Hi-Hi Containment Pressure bistables, are designed to actuate upon a loss of power.

3.0 COMPONENT DESCRIPTION3.0 COMPONENT DESCRIPTION

3.1 ESFAS Cabinets3.1 ESFAS Cabinets

Two trains of ESFAS cabinets are provided. They operate completely independent from each other. Switches, pushbuttons and status lights are provided for periodic online testing of the ESFAS circuits.

The cabinets, located in the E-1 and E-2 room, are supplied power from independent 125 VDC supplies. The DC power for Train "A" is supplied from MCC "A"; Train "B" is supplied from MCC "B". MCC"A" and "B" are located in the A/B Battery Room. This DC power is used to actuate components.

Instrument Bus 7A supplies AC power to Train "A" while Instrument Bus 3 supplies

Revision 5

INFORMATION USE ONLY

ESF
BASIS DOCUMENT, LOSS OF INSTRUMENT BUS

Discussion (Continued)

Instrument Power:

On a loss of Instrument Power (Secondary busses), all instrument signals in that Channel will be reduced to a zero state. Thus, for example, Steam Generator A pressure and VCT levels will indicate zero. A zero input signal trips low bistables and inhibits high bistables from providing a trip output to a protection matrix. This will not normally result in, or prevent, protective actuations (Since most matrices are 2/3, a loss of a single channel will change them to 2/2 or 1/2.) Analog Control systems, however, will respond to the signal change (such as a zero S/G Level signal causing an increase in FW Flow).

Control Power:

On a loss of Control Power (Primary bus), all Bistables in that Channel will go to their fail-safe condition. (Exceptions to this are CV Hi-Hi pressure, and the P-6 bistables which are energize to actuate) Thus, the 2/3 matrices will become 1/2, etc. This will not normally result in a protective actuation. However, if for example, a Channel II trip already exists (from some other cause), and Channel I experiences a loss of Control Power, two trips will exist for that protective feature and an actuation will occur. Loss of Primary bus will also result in a loss of Secondary bus (Instrument Power), but the Bistables will trip anyway. However, the indications themselves will fail. This will provide conflicting information to the operator and may cause a plant control response.

2. Safeguard Racks - Control Features:

IB 7 (Train A) and IB 3 (Train B) supply power to the interposing relays for the loads started from their sequencer. A loss of either of these busses will prevent that sequencer from starting its loads. (Note: These loads may still be started manually by the operator after the EDG has loaded the bus)

AOP-024-BD	Rev. 14	Page 4 of 58

ESF-09 015

Given the following plant conditions:

- Mode 1 at 100% RTP
- An electrical fault occurs which results in a loss of power to Instrument Bus 3

Which ONE (1) of the following describes the impact that the loss of Instrument Bus 3 has on the automatic operation of the Engineered Safeguards Features (ESF) Actuation System?

- A. Neither train of the Engineered Safeguards Actuation System is affected
- ✓B. The sequencers will not be able to automatically start any train "B" Engineered Safeguards Loads
- C. The sequencers will not be able to automatically start any train "A" Engineered Safeguards Loads
- D. The sequencers will not be able to automatically start any train "A" or "B" Engineered Safeguards Loads

Given the following conditions:

- The plant is in Hot Shutdown.
- A loss of 4KV Bus 2 occurs.

Which ONE (1) of the following identifies plant equipment that is affected by the power loss?

- a. Reactor Coolant Pump 'B'
 - Station Service Transformer 2B
- b. Reactor Coolant Pump 'C'
 - Station Service Transformer 2A and 2F
- Main Feedwater Pump 'B'
 Station Service Tranformer 2D
- d. Main Feedwater Pump 'B'
 - Reactor Coolant Pump 'C'

Answer:

- b. Reactor Coolant Pump 'C'
 - Station Service Transformer 2A and 2F

QUESTION N TIER/GROUP K/A:	UMBER: : 062K2.01	82	RO	2/2	SRO	2/2
	Knowledge of	^f bus power s	upplies to	o the Maj	or system loads	
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b	RO) RO	3.3 3	SRO 55.43(b) SRO	3.4
OBJECTIVE:	KVAC-06					
	LIST power s	upplies for the	e major 2	30/4KV I	Electrical System	components as listed in the EDPs.
REFERENCE	S:	EDP-001				
SOURCE:	New	Signific	antly Mo	odified	X	Direct
	0 11		Bank	Number	KVAC-06	003
JUSTIFICATI <i>a.</i>	ON:	Plausible sir KV Bus 1 ar	<i>Bank</i> nce these nd the RC	<i>Number</i> are both P by Bu	KVAC-06 n 'B' equipment, b s 4.	003 but the transformer is supplied by 4
JUSTIFICATI <i>a</i> .	ON:	Plausible sir KV Bus 1 ar	<i>Bank</i> nce these nd the RC	<i>Number</i> are both CP by Bu	· KVAC-06 n 'B' equipment, k s 4.	003 out the transformer is supplied by 4
JUSTIFICATI a. b.	ON: CORRECT	Plausible sir KV Bus 1 ar Major loads 2F and RCF	Bank nce these nd the RC supplied P 'C'.	<i>Number</i> are both CP by Bu by 4 KV	· KVAC-06 n 'B' equipment, k s 4. Bus 2 include St	003 out the transformer is supplied by 4 ation Service Transformers 2A and
JUSTIFICATI a. b. c.	ON: CORRECT	Plausible sir KV Bus 1 ar Major loads 2F and RCF Plausible sir supplied by	Bank noce these nd the RC supplied P 'C'. noce the F Bus 4.	<i>Number</i> are both P by Bu by 4 KV WP is ide	KVAC-06 n 'B' equipment, b s 4. Bus 2 include St entified as 'B', bu	003 but the transformer is supplied by 4 ation Service Transformers 2A and t the FWP and transformer are both
JUSTIFICATI a. b. c. d.	ON: CORRECT	Plausible sir KV Bus 1 ar Major loads 2F and RCF Plausible sir supplied by Plausible sir is supplied b	Bank noce these nd the RC supplied o 'C'. noce the F Bus 4. noce RCP by Bus 4.	Number e are both CP by Bu by 4 KV WP is ide 'C' is sup	KVAC-06 n 'B' equipment, b s 4. Bus 2 include St entified as 'B', bu	003 but the transformer is supplied by 4 ation Service Transformers 2A and t the FWP and transformer are both and the FWP is identified as 'B', bu
JUSTIFICATI a. b. c. d. DIFFICULTY	ON: CORRECT	Plausible sir KV Bus 1 ar Major loads 2F and RCF Plausible sir supplied by Plausible sir is supplied b	Bank noce these nd the RC supplied o 'C'. noce the F Bus 4. noce RCP by Bus 4.	Number are both P by Bu by 4 KV WP is ide	KVAC-06 n 'B' equipment, b s 4. Bus 2 include St entified as 'B', bu	003 but the transformer is supplied by 4 ation Service Transformers 2A and t the FWP and transformer are both and the FWP is identified as 'B', bu
JUSTIFICATI a. b. c. d. DIFFICULTY Comprehen	ON: CORRECT	Plausible sir KV Bus 1 ar Major loads 2F and RCF Plausible sir supplied by Plausible sir is supplied t	Bank noce these nd the RC supplied o 'C'. noce the F Bus 4. noce RCP by Bus 4.	Number are both P by Bu by 4 KV WP is ide 'C' is sup e/Recall	KVAC-06 n 'B' equipment, b s 4. Bus 2 include St entified as 'B', bu oplied by this Bus	003 but the transformer is supplied by 4 ation Service Transformers 2A and t the FWP and transformer are both and the FWP is identified as 'B', bu

REFERENCES SUPPLIED:

1.0 4160V AC Buss No. 1

Location: 4160V Switchgear Room

Power Supply: As per RTGB Line Up

Loads:	Cubicle	Breaker	CWD
Reactor Coolant Pump "A"	1	52/1	109
Circulating Water Pump "A"	2	52/2	811
Feedwater Pump "A"	3	52/3	615
Station Service Transformer 2B	4	52/4	933
Heater Drain Pump "A"	5	52/5	625
Condensate Pump "A'	6	52/6	605
Unit Aux to 4KV Bus 1	7	52/7	926
PTs and Fan Equipment	8	N/A	948
PTs and Fan Equipment and Metering	9	N/A	948
4KV Bus 1 - 2 Tie	10	52/10	928

۲

7

EDP-001	Rev. 4	Page 4 of 8

2.0 4160V BUSS NO. 2

Location: 4160V Switchgear Room

Power Supply: As per RTGB Line Up

Loads:	<u>Cubicle</u>	<u>Breaker</u>	<u>CWD</u>
PTs and Fan Equipment	11	N/A	948
Start-Up to 4KV Bus 2	12	52/12	927
Station Service Transformers 2A and 2F	13	52/13	932
Reactor Coolant Pump "C"	14	52/14	105

EDP-001	Rev. 4	Page 5 of 8

3.0 4160V AC BUSS NO. 3

Location: 4160V Switchgear Room

Power Supply: As per RTGB Line Up

Loads:	<u>Cubicle</u>	<u>Breaker</u>	<u>CWD</u>
Station Service Transformer 2C and 2G	15	52/15	934
PTs and Fan Equipment	16	N/A	949
Start-Up Transformer to 4KV Bus 3	17	52/17	929B
PTs and Fan Equipment	18	N/A	949

٦

EDP-001	Rev. 4	Page 6 of 8
		la construction of the second s

4160V AC BUSS NO. 4 4.0

Location: 4160V Switchgear Room

Power Supply: As per RTGB Line Up

Loads:	<u>Cubicle</u>	<u>Breaker</u>	<u>CWD</u>
4KV Bus 3 - 4 Tie	19	52/19	931
Unit Aux to 4KV Bus 4	20	52/20	930
PTs and Fan Equipment	21	N/A	949
Condensate Pump "B"	22	52/22	606
Circulating Water Pump "B"	23	52/23	813
Feed to 4KV Bus 5	24	52/24	1344
Heater Drain Pump "B"	25	52/25	626
Feedwater Pump "B"	26	52/26	620
Reactor Coolant Pump "B"	27	52/27	101
Station Service Transformer 2D	28	52/28	1041

EDP-001	Rev. 4	Page 7 of 8

5.0 4160V AC BUSS NO. 5

Location: Turbine Bldg., 1st Level,

Grid Location 3B

Power Supply: As per RTGB Line Up

Loads:	<u>Cubicle</u>	<u>Breaker</u>	<u>CWD</u>
4KV Bus 4 to 4KV Bus 5	29	N/A	1344
PTs and Control Power Transformer	30	N/A	N/A
SPARE	31	52/31	N/A
Station Service Transformer 2E	32	52/32	1399
Circulating Water Pump "C"	33	52/33	815
SPARE	34	52/34	N/A

EDP-001	Rev. 4	Page 8 of 8

٦

KVAC-06 003

Given the following plant conditions:

 \cdot The plant is in hot shutdown

 \cdot A partial loss of AC power has occurred

• The operating crew has diagnosed a loss of 4KV bus 1

Which ONE (1) of the following describes the plant equipment that is affected by the power loss?

- ✓A. Circulating Water Pump "A", Station Service Transformer 2B
 - B. Main Feedwater Pump "A", Circulating Water Pump "B"
 - C. Station Service Tranformer 2D, Heater Drain Pump "B"
 - D. Reactor Coolant Pump "A", Main Feedwater Pump "B"

In accordance with AOP-032, "Response To Flooding From The Fire Protection System," the concern for a fire water break in containment is ...

- a. the adverse affects on safeguards equipment.
- b. the thermal stress effects of water coming in contact with the reactor vessel.
- c. the adverse impact on the instrumentation associated with systems in containment.
- d. the unanalyzed dilution caused by the water in the event of a LOCA.

Answer:

^

d. the unanalyzed dilution caused by the water in the event of a LOCA.

								Common Question Reference
QUESTION N TIER/GROUF K/A:	IUMBER:): WE15EK3.1	83	RO	1/3		SRO	1/3	
	Knowledge of Flooding) Fac chemistry and	the reasons f ility operating I the effects of	or the fo charact f temper	ollowing r eristics d rature, pr	espons luring tr essure,	es as they ansient col and reacti	apply indition: vity cha	to the (Containment s, including coolant anges
K/A IMPORT. 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.7 9	55.43	SRO (b) SRO	2.9	
OBJECTIVE:	AOP-032-03							
	DEMONSTRA explaining the	ATE an unders basis of each	standing 1.	of selec	ted ster	os, caution	s, and	notes in AOP-032 by
REFERENCE	:S:	AOP-032						
SOURCE:	New	Signific	antly M	odified			Direc	et X
			Bank	Numbe	r AG	DP-032-03		002
30311FICAT a.	ION.	Plausible sin concern is di	ce some ilution of	e safegua f LOCA w	ards eq vater.	uipment is	located	d inside containment, but
b.		Plausible sin the vessel ar	ice fire v re an int	vater is n ernal stre	nuch co ess con	lder than tl cern.	he ves:	sel, but thermal stresses on
С.		Plausible sin instruments	ice som are des	e instrum igned to l	ients m be in ar	ay be affec adverse e	cted, bu environ	ut the qualified post-accident ment.
d.	CORRECT	Safeguards from the sun water before	equipmo np since a sump	ent will no e it repres o recirc c	ot be af sents ar onditior	fected, but i unanalyzo i.	the wa	ater needs to be removed dition that would dilute LOCA
DIFFICULTY								
Compreher	nsive/Analysis	Kr.	nowledg	ge/Recal	/ X	Rating	3	

RNP NRC Written Examination

/

REFERENCES SUPPLIED:

.

BASIS DOCUMENT, RESPONSE TO FLOODING FROM THE FIRE PROTECTION SYSTEM

DISCUSSION:

The purpose of this procedure is to provide instructions to be followed in the event of flooding caused by a break in the Fire Protection System. This procedure is designed to isolate the break and deal with the resulting water prior to operability concerns arising. This procedure is not intended for small system leaks that do not pose a threat to safety related equipment or that can be handled by the floor drain systems.

A break may range is size from several gpm to the design flow of the system (5,000 gpm at 125 psig), to maximum runout flow (≈7,500 gpm at 80 psig). The larger size breaks can do significant damage and can quickly overwhelm the capacity of installed sump pumps and floor drains.

There are many symptoms, but the first, and most likely, will be when the low header pressure auto-starts one or both of the fire pumps with no corresponding alarm from a system actuation.

Since a leak in one area has different required actions than a leak in another, the most important procedural action is to determine where the break is. The location will normally be discovered by verbal reports of geysers/flooding or area sump high level alarms. If these do not exist, then a walkdown inspection must be performed.

This procedure is divided into three main parts; break in the Auxiliary Building, break in Containment and break at the Intake structure.

The most serious location for a break is in the Aux Building. This is due to the fact that when water level reaches a certain height, both trains of Safeguards Equipment can be rendered inoperable. This event is further compounded by the fact that all spilled water may become contaminated and must be treated so until proven otherwise. (Note that other major system breaks in the Aux Building are addressed by their appropriate procedures - AOP-008 for LWS, AOP-014 for CCW, and AOP-022 for SWS).

The break in Containment is a situation where local inspection could be delayed. Safeguards equipment will not be affected, but the water needs to be removed from the Containment Sump since it represents an unanalyzed condition that would dilute LOCA water before a sump recirc condition.

The break at the Intake Structure is easily isolable and results in restoring the Unit 2 FPS from another source using OP-801, Fire Water System. (Note that this AOP does not refer to AOP-22 for Service Water Pit Breaks to avoid needless isolation of Service Water.)

AOP-032-BD	Rev. 4	Page 3 of 10

Given the following conditions:

- Inverter 'C', is being shut down in accordance with OP-601, "DC Supply System."
- The N-43 DROPPED ROD MODE switch is placed in the BYPASS position prior to aligning PP-26 to its alternate supply (IB-3).

Which ONE (1) of the following describes the consequences of failing to place the switch in the BYPASS position?

- a. A turbine runback may occur due to an Instrument Bus transient
- b. A reactor trip and safety injection may occur due to an Instrument Bus transient
- c. The inverter power supply breaker may trip open
- d. The backup power supply breaker may trip open when attempting to close

Answer:

a. A turbine runback may occur due to an Instrument Bus transient

QUESTION NUMBER: TIER/GROUP: K/A: 063 2.1.	: 84 32	RO	2/2	SRO	2/1
Ability to	explain and apply a	all syster	m limits a	nd precautions (DC Electrical).
K/A IMPORTANCE: 10CFR55 CONTENT:	55.41(b)	RO RO	3.4 7	SRO 55.43(b) SRO	3.8
OBJECTIVE: DC-10					
EXPLAII	N the operation of th	ne DC El	ectrical S	System.	
REFERENCES:	OP-601				
SOURCE:	New 🔲 Significa	antly Mo	dified		Direct X
SOURCE:	Vew 🔲 Significa	antly Mo Bank I	odified Number	DC-10	Direct X 003
SOURCE: / JUSTIFICATION: <i>a.</i> CORR	ECT Due to the port a turbine run	Bank I Bank I ower tran back sigr	dified Number Isient a m nal.	DC-10 nomentary signal	Direct X 003 may be generated which results in
SOURCE: A JUSTIFICATION: a. CORR b.	Vew Signification ECT Due to the point of the power transformed by the	Bank I Bank I bower tran boack sigr ce the co unsient, b	<i>Number</i> Number Isient a m nal. Dincern is	DC-10 nomentary signal that a momentar ld affect the runb	Direct X 003 may be generated which results in y signal may be generated due to back circuitry.
SOURCE: A JUSTIFICATION: a. CORR b. c.	Vew Signification ECT Due to the portion of the power transformed but concern in the	antly Mo Bank I ower tran back sigr ce the co insient, b ce a pow s that a r	<i>dified</i> <i>Number</i> asient a m nal. oncern is out it woul ver transie momenta	DC-10 DC-10 nomentary signal that a momentar Id affect the runb ent may occur wh ry runback signa	Direct X 003 may be generated which results in y signal may be generated due to back circuitry. hich could cause a trip of a breaker, al would be generated.
SOURCE: A JUSTIFICATION: a. CORR b. c. d.	Vew Signification ECT Due to the point of the power transformed but concern in Plausible since but concern in Plausible sinc	Bank I Bank I ower tran back sign ce the co unsient, b ce a pow s that a r ce a pow s that a r	Adified Number Number Isient a m nal. Doncern is Dout it woul ver transie momenta	DC-10 DC-10 nomentary signal that a momentar Id affect the runb ent may occur wi ry runback signa	Direct X 003 I may be generated which results in y signal may be generated due to back circuitry. hich could cause a trip of a breaker, al would be generated.
SOURCE: A JUSTIFICATION: a. CORR b. c. d. DIFFICULTY:	Vew Signification ECT Due to the point of the power transformed but concern in Plausible sind bu	antly Mo Bank I ower tran back sigr ce the co unsient, b ce a pow s that a r ce a pow s that a r	<i>Mumber</i> Number Isient a m nal. Doncern is Dout it woul ver transie momenta	DC-10 DC-10 nomentary signal that a momentar Id affect the runb ent may occur wi ry runback signa	Direct X 003 I may be generated which results in y signal may be generated due to back circuitry. hich could cause a trip of a breaker, al would be generated.
SOURCE: A JUSTIFICATION: a. CORR b. c. d. DIFFICULTY: Comprehensive/Ana	New Signification ECT Due to the point of the power transmission Plausible sind the power transmission Plausible sind but concern i Plausible sind but concern i Plausible sind but concern i	antly Mo Bank I ower tran back sigr ce the co insient, b ce a pow s that a r ce a pow s that a r	Mumber Number Issient a m nal. Dincern is Dut it woul ver transie momenta ver transie momenta	DC-10 DC-10 nomentary signal that a momentar Id affect the runb ant may occur wi any runback signated ant may occur wi any runback signated any runback signated any runback signated	Direct X 003 may be generated which results in y signal may be generated due to back circuitry. hich could cause a trip of a breaker, al would be generated. hich could cause a trip of a breaker, al would be generated.

REFERENCES SUPPLIED:

CONTINUOUS USE

Section 7.8 Page 1 of 1

7.8	Shutdo	own of	Inverter "C"			INIT	VER	<u> २।</u>
	7.8.1	Initial	Conditions					
		1.	This revision latest revision	on has been v ion available.	erified to be the			
	Na	me (Pr	int)	Initial	Signat	ure	Date	 }
	7.8.2	Instru	ictions					
		1.	Place N-43 switch to B possible To	B DROPPED F SYPASS to pre urbine Runbac	ROD MODE event a ck.			
		2.	Verify PP-2 Instrument	26 is on Backı Bus 3.	up power from			
		3.	Place N-43 switch to N	3 DROPPED F IORMAL.	ROD MODE			
		4.	Open the A	AC Output Bre	eaker.	<u> </u>		
		5.	Open the [DC Input Brea	ker.			
				Initials	Name (F	Print)	<u>[</u>)ate
		Perfo	ormed by:					
							<u></u>	
							. <u></u>	
		Appr	oved by:	Super	intendent Shift (Operations	 [Date

OP-601	Rev. 29	Page 47 of 65

Given the following conditions:

- A batch release of Waste Condensate Tank 'E' is scheduled to be performed.
- The Waste Condensate Recirc Pump is out-of-service.

Waste Condensate Tank 'E' ...

- a. can be recirculated after transferring to Waste Condensate Tank 'C'.
- b. **CANNOT** be recirculated unless transferred to Waste Condensate Tank 'D'.
- c. can be recirculated using Waste Condensate Pump 'B'.
- d. **CANNOT** be recirculated until the Waste Condensate Recirc Pump is repaired.

Answer:

d. **CANNOT** be recirculated until the Waste Condensate Recirc Pump is repaired.

QUESTION NUMBER: TIER/GROUP: K/A: 068 2.3.11	85	RO	2/1		SRO	2/1
Ability to cont	rol radiation rel	eases (l	Liquid R	adwaste)		
K/A IMPORTANCE: 10CFR55 CONTENT:	55.41(b)	RO RO	2.7 13	55.43(b)	SRO) SRO	3.2
OBJECTIVE: WD-03						
Describe the	major flow path	ı(s) throi	ugh the	Waste Di	sposal Sy	ystem. Liquid Waste Disposal
REFERENCES:	SD-023					
SOURCE: New	Significa	ntly Mo	dified			Direct X
		Bank	Numbe	r RNP	-RO-200	0 85
JUSTIFICATION: a.	Plausible sinc	e 2 Was	ste Con	densate T	anks use	their individual pumps to recirc the
	tank. Waste	Conden	sate Tai	nks with th	nis capab	ility are 'A' and 'B'.
b	Plausible sinc	e transf	errina c	ontents of	Waste C	Condensate Tank 'E' to a different
~	tank would all	low use	of Wast	e Conden	sate Pun	np 'C' or 'D' for discharge. Waste
	Condensate 1	lanks C	, D, ai	na e mus	st use the	e waste Condensate Recirc Fump.
с.	Plausible sind	e either	Waste	Condensa	ate Tank	'A' or 'B' can be recirculated with
	'E' must use t	the Was	te Cond	lensate Re	ecirc Pun	np.
d. CORRECT	Waste Conde Condensate F	ensate T Recirc P	anks 'C ump.	', 'D', and	'E' can o	nly be recirculated using Waste
DIFFICULTY: Comprehensive/Analysis	s X Kno	owledge	e/Recali	Ra	ating	3

Comprehension of system operations to determine acceptable alternative liquid waste flowpaths

REFERENCES SUPPLIED:

Туре	Horiz. Cent.
Design flow rate	20 gpm at 3500 RPM
Design head	100 ft
Material of construction, wetted surfaces	Austenitic SS

The WCT pumps "A" and "B" are horizontal centrifugal type. These pumps, located by the corresponding "A" and "B" waste condensate tanks, are used to pump liquids to the WHUT, to condenser circulating water or to recirculate back to the respective WCT.

3.14 WCT Pumps "C" and "D"

Manufacturer	Gould
Type	Horiz. Cent.
Design flow rate	55 gpm at 3500 rpm
Design head	110 ft
Material of construction, wetted surfaces	Austenitic SS

There are two pumps provided to release wastes from "C", "D" and "E" WCTs. These pumps transfer liquids to the WHUT, to the polishing demineralizers for processing or to the condenser circulating water for discharge.

3.15 WCT Recirculating Pump

Manufacturer	Gould
Model	3196 MT
Number	1
Type	Horiz. Cent.
Design flow rate	275 gpm at 1750 rpm
Design head	110 ft
Material of construction, wetted surfaces	Austenitic SS

A pump is provided to recirculate liquid waste from tanks "C", "D" and "E" for sampling prior to discharge. This pump is located in the same building area as "C" and "D" WCT pumps.

3.16 CHT Pump

Manufacturer	Crane Co.
Number	1
Type	Rotary screw
Design flow rate	Variable
Design head	Variable
Material of construction, wetted surfaces	Austenitic SS

The CHT pump is used for discharging stored waste concentrates from the CHT to the drumming room for drumming. This pump is located in the Auxiliary Building in a cubicle

Given the following conditions:

- The plant is being started up with the Feed Water Regulating Valves and Feed Water Regulating Bypass Valves all open.
- A Reactor Trip occurs.
- RCS Tavg stabilizes at no load Tavg.
- The Feed Water Regulating Valves automatically close.

Which ONE (1) of the following identifies the expected position of the Feed Water Regulating Bypass Valves (FRBVs) and the Feed Water Block Valves (FBVs)?

	FRBVs	FBVs
a.	Open	Open
b.	Open	Closed
C.	Closed	Open
d.	Closed	Closed

Answer:

a.	Open	Open

								RNP NRC Written Examination Common Question Reference
	UMBER:	86						
TIER/GROUF K/A:): 059K4.19		RO	2/1		SRO	2/1	
	Knowledge of Automatic fee	MFW design dwater isolatio	feature(on of MF	s) and/oi W	r interlo	ck(s) which	ı provi	de for the following:
K/A IMPORT 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.2 7	55.43	SRO (b) SRO	3.4	
OBJECTIVE:	FW-09							
	EXPLAIN the instrumentation	normal operation, interlocks,	tion of th annunci	ne Feedw iators, an	vater co id setpo	ntrol syste bints.	ms. lı	nclude function,
REFERENCE	ES:	SD-027						
SOURCE:	New	Significa	antiy Mo	odified			Dire	ct X
			Bank	Number	r FV	V-09		004
JUSTIFICAT <i>a.</i>	ION: CORRECT	Only the FR\ and FBVs wi	/s receiv Il close d	ve a clos on an SI	e signa signal.	l on a react	tor trip	and low Tavg. The FRBVs
b.		Plausible sin open.	ce the p	osition o	f the FF	RVs is cor	rect, t	out the FBVs will also be
C.		Plausible sin open.	ce the p	osition o	f the FE	3Vs is corre	ect, bu	t the FRBVs will also be
d.		Plausible sin a reactor trip	ce both with low	sets of v v Tavg.	alves d	o receive a	iutoma	atic close signals, but not from
DIFFICULTY Compreher	': nsive/Analysis	X Kn	owledg	e/Recall		Rating	3	
	Analysis of pl	ant response	to trip to	o determi	ne FW	system res	ponse	2

REFERENCES SUPPLIED:

These flow control valves (FCV-478, -488, -498) regulate flow of feedwater to the steam generators to maintain a specified programmed level. The main feedwater regulating valves (FRVs) are used from approximately 15% load to 100% load. The main feedwater regulating valve bypass valves are used during low load conditions for finer feedwater flow control.

The FRVs are 12 inch air operated plug and cage type valves. The cage has offset variable size ports which act as an orifice. The balanced plug attached to the stem moves up and down to uncover/cover these ports to control flow through the valve. This type of valve internals provides a linear flow change throughout the length of valve operator travel (≈ 3 1/16 inch). Each valve can be controlled automatically via the Hagan control system through the RTGB controller, with input from the steam generator water level control system. Each valve can also be controlled manually from the RTGB Hagan controller using pushbuttons to open or close the FRV. Operators also have the capability to operate the valves locally using an installed reverse acting manual handwheel. When taking local-manual handwheel control of the valve in accordance with OP-403, the handwheel is rotated clockwise to open and counterclockwise to close. The time limits of Technical Specification 3.7.3 are applicable during this evolution. The air operator is constructed such that the diaphragm is mounted to the frame, and as air is supplied to the actuator, the yoke is pulled up against spring tension (the stem is attached to the yoke).

The FRVs auto-close from the following:

- Feedwater Isolation signal (Safety Injection), all FRVs close
- Reactor Trip with low Tavg (554°F), all FRVs close
- High-High steam generator level (2/3 ≥75%), the FRV associated with the high-high level closes
- 3.6 Main Feedwater Regulating Valves Bypass Valves

These flow control valves (FCV-479, -489, -499) regulate flow of feedwater to the steam generators under manual control from ten-turn potentiometers located on the RTGB. The main feedwater regulating valve bypass valves are used during low load conditions($\langle \approx 15\% \rangle$).

The main feedwater regulating valve bypass valves are four inch air operated valves. The function similar to the FRVs, relative to their flow characteristics and local manual valve operation.

The main feedwater regulating valve bypass valves auto-close from the following:

• Feedwater Isolation signal (Safety Injection), all bypass valves close

Revision 3

Page 9 of 33

INFORMATION USE ONLY

FW

The tubes in the heaters are horizontal U-tubes with feedwater flowing through the tubes and extraction steam around the tubes. These heaters may be removed from service individually by a 3-way bypass (FW-3A or -B) and manual isolation valves (FW-4A or -B).

Feedwater heater level indication is provided by either a sight glass, or magnetically coupled level indicator. The sight glass provides direct indication by seeing the actual liquid level through the glass. These types of indications are being replaced, as needed, by Penberthy magnetically coupled level indicators. The Penberthy indicators are not susceptible to the clouding and leaks of the glass type. The magnetic type indicator is a sealed tube. It has a float inside the pressure boundary that is magnetically coupled to a follower outside the pressure boundary to provide level indication. Liquid level changes in the feedwater heater cause the float to rise or fall in the sealed chamber, and the follower rises and falls with the float.

The feedwater enters the steam generator through a header pipe in the form of a ring that distributes the incoming water via inverted "J" nozzles located on the ring. The "J" nozzles are arranged on the feedwater ring to distribute approximately 80 percent of the feedwater toward the hot leg side of the steam generator. This feedwater mixes with recirculated water within the steam generator. This mixture flows down between the shell and down comer (tube bundle wrapper) to the bottom where it enters the tube area. More information concerning the steam generators can be found in SD-048, Steam Generator System.

3.3 Feedwater/Condensate Recirculation (BOP Cleanup)

During periods of cold shutdown a feedwater recirculating line can be utilized to reduce corrosion product buildup in the feedwater system and condensate system using the condensate polishers. Opening locked gate valve FW-232, globe valve FW-238 and turning the spectacle blind flange puts the flow path in service. The recirculating piping runs from the outlet side of the high pressure feedwater heaters 6A and B to the main condenser "B" via the downstream side of main steam dump (PRV-1324B-3).

3.4 Feedwater Header Block Valves

The feedwater header block valves (FW-V2-6A, -6B, -6C) isolate the feedwater pump discharge from each main feedwater regulating valve. Each valve is motor operated, and all three must be closed prior to start of the first main feedwater pump. This reduces the load on the feedwater pump motor, and prevents runout. The valves receive an auto-close signal from any Safety Injection signal. These valves are cycled during plant cooldown to prevent thermal binding of the 16 inch solid wedge gate valve.

3.5 Main Feedwater Regulating Valves

Page 8 of 33

Revision 3

INFORMATION USE ONLY

FW

Given the following conditions:

- A small break LOCA has occurred.
- Due to problems with the Containment Cooling system, containment pressure increased to 6.1 psig.
- After establishing proper operation of the Containment Cooling system, containment pressure has been lowered to 3.2 psig.
- A step in one of the EPPs states:

"Depressurize RCS To Minimize RCS Leakage:

c. Check EITHER of the following:

PZR LEVEL - GREATER THAN 71% [60%]

OR

RCS SUBCOOLING – LESS THAN 45 °F [65 °F]

d. Stop RCS depressurization"

 As the RCS is being depressurized, PZR level is noted to be 62% and RCS Subcooling is 76 °F.

The RCS depressurization should ...

- a. be stopped immediately.
- b. continue until PZR level exceeds 71%.
- c. continue until RCS subcooling drops below 65 °F.
- d. continue until RCS subcooling drops below 45 °F.

Answer:

a. be stopped immediately.

		1						RNP NRC Written Examination Common Question Reference
QUESTION N	UMBER:	87						
TIER/GROUP) :		RO	2/1		SRO	2/1	
K/A:	022K3.02							
	Knowledge of Containment	the effect the instrumentation	it a loss on readir	or malfu ngs	inction (of the CCS v	vill ha	ve on the following:
K/A IMPORT 10CFR55 CC	ANCE: INTENT:	55.41(b)	RO) RO	3.0 10	55.43	SRO 3(b) SRO	3.3	
OBJECTIVE:	OMM-022-03							
DEMONSTRATE an understanding of selected steps, cautions, and notes in OMM-022 by explaining the basis of each.								
REFERENCE	ES:	OMM-022						
SOURCE:	New	X Signific	antly M	lodified			Dire	ct
			Bank	(Numbe	ər			NEW
JUSTIFICAT	ION:							wist due to propouro boing
а.	CORRECT	Although adverse containment conditions no longer exist due to pressure being below 4 psig, adverse values are used until the EOP network is exited.						network is exited.
Ь.		Plausible since containment pressure is below the adverse containment value, but adverse values are used until the EOP network is exited.						
с.		Plausible since adverse containment value must be used, but pressurizer level already exceeds the adverse value.						
d.		Plausible since containment pressure is below the adverse containment value, but adverse values are used until the EOP network is exited.						
		adverse van	ues are	used uni	til the E	OP network	IS EX	ileu.
DIFFICULTY Comprehei	r: nsive/Analysis	x Kr	ues are nowledg	used unt ge/Reca		OP network <i>Rating</i>	3	ilea.

REFERENCES SUPPLIED:

ATTACHMENT 10.4 Page 1 of 3 GLOSSARY

1.1 Definitions

- 1.1.1 Adverse Containment Conditions If the CV pressure is greater than or equal to 4 psig, then adverse containment conditions exist. When adverse setpoints are provided, they will be enclosed by brackets: [].
- 1.1.2 **Core Cooling Mode** When referenced for the current status of the RHR System, the system is aligned to remove decay heat via the normal pathway from RCS loop "B" hot leg back through RHR to the loop cold legs.
- 1.1.3 **Diverse** (In reference to an indication) Having multiple indications of different types for indication of the same parameter. An example of diverse indications for the same parameter would be the use of S/G level increase, as well as AFW Line Flow Indication to verify that AFW Flow exists.
- 1.1.4 **Go To** An action verb requiring the operator to leave the procedure or step currently in effect and implement the referenced procedure or step. The operator does not return to the EOP or AOP unless explicitly directed to by the procedure transitioned to.
- 1.1.5 **Injection Mode** When referenced for the current status of the RHR System, the system is aligned to take a suction on the RWST and discharge to the loops. (Normal at-power RHR line up)
- 1.1.6 **Normal** Describes a condition in which the parameter under consideration is within a range that can be expected during routine plant operation or is being controlled in accordance with approved plant procedures. When making this determination previous trends should be used. (RAIL 94R0296)
- 1.1.7 **Nuclear Safety Concern** A condition is said to have a Nuclear Safety Concern when that condition has the possibility of jeopardizing the health and/or safety of the public to the extent that the SSO determines that action is needed to mitigate the condition.
- 1.1.8 **Perform** An action verb directing the operator to accomplish certain actions using the referenced procedure and implicitly requiring the operator to remain in the procedure in effect. This action may be reinforced by the statement, "while continuing with this procedure".

OMM-022	Rev. 17	Page 48 of 50
---------	---------	---------------

8.3.10 Incorrect EOP Transition

- 1. Should the Operator determine that he is in an incorrect Path or EPP, he has two options:
 - If the incorrect transition is immediately recognizable **AND** no alterations of the WOG mitigative strategy have occurred, he may move back to the point in the Network where the incorrect transition has occurred.
 - If the incorrect transition is not immediately recognizable **OR** alterations in the mitigative strategy have occurred, the Operator should move to Path-1, Entry Point A, and start over.
- 2. During the rediagnosis described above, complete reactuation of the Engineered Safety Features is allowed, but not required. Reactuation of necessary safety features during rediagnosis is guided by the requirements of the applicable Foldout and Operator judgement based on the symptoms present.
- 8.3.11 Adverse Containment Conditions Usage
 - 1. When adverse containment conditions develop, the use of adverse containment condition setpoints shall be initiated.
 - 2. The use of adverse containment condition setpoints shall be maintained from that point forward, even when adverse containment conditions no longer exist.
 - 3. An adverse containment condition setpoint may or may not be provided. The operator shall use a setpoint with no brackets if no setpoint within brackets is provided, even if adverse containment conditions exist.
- 8.3.12 Special EPP Priority
 - 1. Certain contingency EPPs take precedence over FRPs because of their treatment of specific initiating events. In all such cases, this precedence is identified in a CAUTION or NOTE at the beginning of the EPP.

Given the following conditions:

- The unit is in Hot Shutdown.
- The Startup Transformer (SUT) is supplying all 4KV buses.
- A severe short has resulted in a loss of the 'B' DC Bus.

Which ONE (1) of the following describes the response of the emergency diesel generators (EDG's)?

	EDG 'A'	EDG 'B'
a.	Starts and loads	Does NOT start
b.	Does NOT start	Starts, but field fails to flash
C.	Starts and loads	Starts, but does NOT load
d.	Starts, but does NOT load	Starts and loads

Answer:

fails to flash	b. Do	es NOT start	Starts, but field fails to flash
----------------	-------	--------------	----------------------------------

							i	RNP NRC Written Examination Common Question Reference
	IUMBER:	88						
TIER/GROUF K/A:	°: 058AK3.01		RO	1/2		SRO	1/2	
	Knowledge of Use of dc cor	the reasons f trol power by	or the fo D/Gs	llowing r	espon	ses as they a	apply t	o the Loss of DC Power:
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.4 7	55.43	SRO 3(b) SRO	3.7	
OBJECTIVE:	EPP-026/27-0)3						
DEMONSTRATE an understanding of selected steps, cautions, and notes in EPP-26 by explaining the basis of each.								
REFERENCE	S:	EPP-27						
SOURCE:	New	Significa	antly Mc	odified			Direct	
			Bank	Number	Ε	PP-026/27-1	4	001
JUSTIFICATI a.	ON:	Plausible sind it by not flash	ce the lo ing the f	ss of DC field or al	contr llowing	ol power doe g the output b	s affeo oreake	ct the 'B' EDG, but it affects r to close.
b.	CORRECT	The 'B' EDG will start, but field flashing will not be available due to no DC power. The 'A' train is not affected.						
с.		Plausible since the 'B' EDG will start and will not load due to no field flash or output breaker closure, but the 'A' EDG is not affected.						
d.		Plausible since the 'B' EDG will start, but the 'B' EDG field will not flash and the output breaker will not close.						
DIFFICULTY: Comprehen	: sive/Analysis	X Kn	owledge	e/Recall		Rating	3	
	Analysis of ef	fect of loss of	control p	ower on	opera	ation of EDGs	6	

REFERENCES SUPPLIED:

Rev. 6

Page 16 of 27

	INFORMATION USE
	ATTACHMENT 1
	MAJOR EFFECTS / LOAD LIST
	(Page 1 of 4)
<u>Major Effects:</u>	
Reactor	Will trip due to loss of power to 52/RTB undervoltage coil.
Turbine	Will trip via 20/AST from Rx Trip (20/ET has lost power).
Generator	Will receive lockout signal. However, 86P cannot open OCB 52/8 & 52/9 due to the loss of their control power. This causes a Breaker Failure scheme which trips OCB 52/3, 52/6, 52/7, 52/12 and the downstream breakers on the Darlington SCPSA line. The Exciter Field Breaker will open.
4KV Busses 1 & 2	If initially on SUT, nothing will happen. If initially on UAT, the busses will auto-transfer due to the Rx Trip.
	In either case, 4KV busses 1 and 2 and all downstream busses and equipment will remain energized.
4KV Bus 3	Will remain energized on the SUT. 4KV Bus 3 and 480V Bus 3 will lose DC Control Power (including a loss of protective relaying).
4KV Busses 4 & 5	4KV Bus 4 will try to auto-transfer to Bus 3 but cannot due to the loss of DC Control Power. Thus, 4KV Busses 4 & 5 and all downstream busses and equipment will deenergize.
	4KV Bus 4 and 480V Bus 4 will lose DC Control Power (including a loss of protective relaying). Control Power (and protective relaying) will remain for 4KV Bus 5 and 480V Bus 5.
Emergency Bus E-1	Will remain energized. SST 2F will lose cooling fans.
Emergency Bus E-2	Will remain energized on the SUT but will lose DC Control Power (including a loss of protective relaying). SST 2G will lose cooling fans.
DS Bus	Will remain energized with Control Power available.
EDG A	Remains available, if needed.
EDG B	Auto-starts due to loss of power to air start solenoids but will not field flash and output breaker will not close.

				····	
EPP-2	7	LOSS OF DC	BUS "	в"	Rev. 6
				Page 13 of 27	
STEP		INSTRUCTIONS		RESPONSE NOT OBI	AINED
25.	Place	Normal RCS Letdown In ce Using OP-301, Chemical	L		
	And Vo	olume Control System (CVCS)			
****	*****	**************************************	***** N	*****	****
If St air d attem	arting listril pt.	g Air has been cut in to the butor may be damaged and the	EDG f EDG n	for more than 2 minu may fail during the	tes, the next start
* * * * *	*****	********	****	*****	* * * * * * * * * *
26.	Perfo:	rm The Following For EDG B:			
	a. Re	set Fuel Racks as follows:			
	1)	Slowly move the Reset Lever towards the EDG SW Heat Exchangers			
	2)	Release the Reset Lever			
	3)	Repeat Steps 26.a.1 and 26.a.2			
	b. Ch Li	eck the FUEL RACK TRIP ght - EXTINGUISHED	b	On the Engine Cont depress the ALARM pushbutton.	rol Panel, RE-SET
	c. Re no Va Di	store EDG B Starting Air to rmal using the Starting Air lve Lineup of OP-604, esel Generators A and B			
	d. No St be wa	tify System Engineer that arting Air Distributor has en in service while the EDG s running			

Г

Given the following conditions:

- The plant is operating at 90% power.
- Control Bank "D" Step Counters indicate 198 steps.
- A check of the Rod Position indications for Control Bank "D" shows the following rod positions:

D8 at 124" M8 at 116" H4 at 120" H8 at 121" H12 at 131"

Which ONE (1) of the following describes the status of the rods in Control Bank 'D'?

- a. **BOTH** rods M8 and H12 are misaligned from the bank
- b. **ONLY** rod M8 is misaligned from the bank
- c. **ONLY** rod H12 is misaligned from the bank
- d. All rods are within rod alignment limits

Answer:

c. **ONLY** rod H12 is misaligned from the bank

Replacement.

QUESTION NUMBER: 89 TIER/GROUP: RO 2/2 SRO 2/1 K/A: 014A2.04 Ability to (a) predict the impacts of the following malfunctions or operations based on those on those predictions, use procedures to correct, control, or consequences of those malfunctions or operations: Misaligned rod K/A: MPORTANCE: RO 3.4 SRO 3.9 10CFRSS CONTENT: 55.41(b) RO 6 55.43(b) SRO 3.9 OBJECTIVE: AOP-001-03 DEMONSTRATE an understanding of selected steps, cautions, and notes explaining the basis of each. REFERENCES: AOP-001 SOURCE: New Significantly Modified Direct X JUSTIFICATION: a Plausible since rod H12 is misaligned and 198 steps correspond M8 would also be considered misaligned if requirement group counter, but average IRPI is used. b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps. Duit than or equal to 200 steps. DEFFICULTY: Comprehensive/Analysis Knowledge/Rec									Common Question Reference
Ability to (a) predict the impacts of the following malfunctions or operations based on those on those predictions, use procedures to correct, control, or consequences of those malfunctions or operations: Misaligned rod K/A IMPORTANCE: RO 3.4 SRO 3.9 10CFR55 CONTENT: 55.41(b) RO 6 55.43(b) SRO 3.9 OBJECTIVE: AOP-001-03 DEMONSTRATE an understanding of selected steps, cautions, and notes explaining the basis of each. REFERENCES: AOP-001 SOURCE: New Significantly Modified Direct X JUSTIFICATION: a. Plausible since rod H12 is misaligned and 198 steps corresp. rod M8 would also be considered misaligned if requirement to group counter, but average IRPI is used. b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned if grout than or equal to 200 steps, but rod H12 is considered misali position is less than 200 steps. DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3	QUESTION TIER/GROU K/A:	NUMBER: IP: 014A2.04	89	RO	2/2	S	SRO	2/1	
K/A IMPORTANCE: RO 3.4 SRO 3.9 10CFR55 CONTENT: 55.41(b) RO 6 55.43(b) SRO 3.9 OBJECTIVE: AOP-001-03 DEMONSTRATE an understanding of selected steps, cautions, and notes explaining the basis of each. DEMONSTRATE an understanding of selected steps, cautions, and notes explaining the basis of each. REFERENCES: AOP-001 SOURCE: New Significantly Modified Direct X Bank Number AOP-001-03 08 JUSTIFICATION: a. Plausible since rod H12 is misaligned and 198 steps corresponds to 123.75" so rod M8 would also be considered misaligned if requirement group counter, but average IRPI is used. b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement twas to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misaligned if grout than or equal to 200 steps. DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3		Ability to (a) p based on tho consequence	predict the imp se on those pr s of those ma	eacts of ediction	the follow ns, use p ns or ope	wing malfund rocedures to erations: Mis	ctions or correc aligned	r opera t, cont rod	ations on the RPIS; and (b) rol, or mitigate the
OBJECTIVE: AOP-001-03 DEMONSTRATE an understanding of selected steps, cautions, and notes explaining the basis of each. REFERENCES: AOP-001 SOURCE: New Significantly Modified Direct X Bank Number AOP-001-03 08 JUSTIFICATION: a. Plausible since rod H12 is misaligned and 198 steps correspond to 123.75" so rod M8 would also be considered misaligned if requirement group counter, but average IRPI is used. b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misaligned if grout than or equal to 200 steps. Source of the considered aligned if grout than or equal to 200 steps. DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3 Difficultry: Comprehensive/Analysis X Knowledge/Recall Rating 3	K/A IMPOR 10CFR55 C	TANCE: ONTENT:	55.41(b,	RO) RO	3.4 6	SI 55.43(b) \$	RO SRO	3.9	
DEMONSTRATE an understanding of selected steps, cautions, and notes explaining the basis of each. REFERENCES: AOP-001 SOURCE: New Significantly Modified Direct X Bank Number AOP-001-03 08 JUSTIFICATION: Bank Number AOP-001-03 08 JUSTIFICATION: Plausible since rod H12 is misaligned and 198 steps corresponds to requirement group counter, but average IRPI is used. b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misaligned if grout than or equal to 200 steps, but rod H12 is considered misaligned if grout than or equal to 200 steps. 3 DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3	OBJECTIVE	E: AOP-001-03							
REFERENCES: AOP-001 SOURCE: New Significantly Modified Direct X Bank Number AOP-001-03 08 JUSTIFICATION: Bank Number AOP-001-03 08 JUSTIFICATION: Plausible since rod H12 is misaligned and 198 steps correspond to 123.75" so rod M8 would also be considered misaligned if requirement group counter, but average IRPI is used. Direct X b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misaligned in grout than or equal to 200 steps. Source aligned if grout than or equal to 200 steps. Rating 3 DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3		DEMONSTR explaining the	ATE an unders basis of eact	standing 1.	g of selec	cted steps, c	cautions	, and r	notes in AOP-001 by
SOURCE: New Significantly Modified Direct X Bank Number AOP-001-03 08 JUSTIFICATION: AOP-001-03 08 a. Plausible since rod H12 is misaligned and 198 steps correspress rod M8 would also be considered misaligned if requirement group counter, but average IRPI is used. b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misaligned in grout than or equal to 200 steps. DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3	REFERENC	ES:	AOP-001						
SOURCE: New Significantly Modified Direct X Bank Number AOP-001-03 08 JUSTIFICATION: a. Plausible since rod H12 is misaligned and 198 steps corresponds to misaligned if requirement of group counter, but average IRPI is used. 08 b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misali position is less than 200 steps. DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3									
Bank Number AOP-001-03 08 JUSTIFICATION: a. Plausible since rod H12 is misaligned and 198 steps correspond M8 would also be considered misaligned if requirement group counter, but average IRPI is used. b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misaligned if position is less than 200 steps. 3 DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3	SOURCE:	New	Signific	antiy M	odified			Direc	t X
 a. Plausible since rod H12 is misaligned and 198 steps correspond M8 would also be considered misaligned if requirement group counter, but average IRPI is used. b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misali position is less than 200 steps. DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3 				Bank	(Numbe	er AOP-0	01-03		08
 b. Plausible since 198 steps corresponds to 123.75" so rod M8 misaligned if requirement was to compare to group counter, used. c. CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misali position is less than 200 steps. DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3 	JUSTIFICA a.	HUN:	Plausible since rod H12 is misaligned and 198 steps corresponds to 123.75" so rod M8 would also be considered misaligned if requirement was to compare to group counter, but average IRPI is used.						orresponds to 123.75" so ment was to compare to
 CORRECT With group position less than 200 steps, rod alignment must average IRPI position in the bank. The average IRPI for the only rod H12 is misaligned. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misalignosition is less than 200 steps. DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3 	b.		Plausible since 198 steps corresponds to 123.75" so rod M8 would be considered misaligned if requirement was to compare to group counter, but average IRPI is used.						
 d. Plausible since the rods would be considered aligned if grout than or equal to 200 steps, but rod H12 is considered misaling position is less than 200 steps. DIFFICULTY: Comprehensive/Analysis X Knowledge/Recall Rating 3 	с.	CORRECT	With group position less than 200 steps, rod alignment must be within 7.5" of the average IRPI position in the bank. The average IRPI for these rods is 122.4", so only rod H12 is misaligned.						t must be within 7.5" of the for these rods is 122.4", so
DIFFICULTY: <i>Comprehensive/Analysis</i> X <i>Knowledge/Recall</i> Rating 3 Determination of rod misalignment	d.		Plausible since the rods would be considered aligned if group position was greater than or equal to 200 steps, but rod H12 is considered misaligned since group position is less than 200 steps.						if group position was greater misaligned since group
Determination of rod misalignment	DIFFICULT Comprehe	Y: ensive/Analysis	SX Kn	owledg	ge/Recai	ll 🔲 Rati	ing	3	
		Determinatio	n of rod misali	gnment					

RNP NRC Written Examination

REFERENCES SUPPLIED:

·

4

RNP NRC Written Examination Common Question

Question: 89

Given the following conditions:

- The unit is operating at 80% power.
- A misaligned rod in Group 2 of Control Bank 'D' has occurred.
- A recovery of the misaligned rod has begun.
- APP-005-E2, ROD CONT SYSTEM URGENT FAILURE, has just alarmed.

The power cabinet causing the urgent alarm is ...

- a. 1AC.
- b. 2AC.
- c. 1BD.
- d. 2BD.

Answer:

c. 1BD.

								Common Question Reference
QUESTION N TIER/GROUP K/A:	IUMBER: : 014A2 04	89	RO	2/2		SRO	2/1	
	Ability to (a) p based on thos consequence	predict the impa se on those pre s of those malf	cts of th dictions unctions	ie follow , use pro s or oper	ing malfu ocedures ations: N	unctions or to correct Aisaligned	r opera t, contr rod	tions on the RPIS; and (b) ol, or mitigate the
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.4 6	55.43(b	SRO) SRO	3.9	
OBJECTIVE:	RDCNT-14							
	EXPLAIN the	effect on the R	od Cont	trol Syste	em due t	o selected	l failure	es.
REFERENCE	S:	AOP-001				·		
SOURCE:	New	X Significa	ntly Mo	dified			Direct	
			Bank I	Number	HNF	P-RO-2000	0	76
JUSTIFICATI a.	ON:	Plausible sinc powered from	e other (same p	group of lower ca	rods, Gi binet.	roup 1, cai	uses al	larm, but group must be
b.		Plausible sinc must be powe	e alarm red fron	caused n same j	by other bower ca	group, an binet.	d this i	s other bank, but group
с.	CORRECT	The other group of rods in the bank do not move when directed due to the lift coil disconnect switches being open and cause the urgent failure.						
d.		Plausible since this is the group of rods which are being moved and other rods in the group have the disconnect switch open, but caused by other group in same bank.						
DIFFICULTY Comprehen	: sive/Analysis	X Kno	wledge	/Recall		ating	3	

RNP NRC Written Examination

Comprehension of rod control system design and operation during misaligned rod recovery

REFERENCES SUPPLIED:

AOP-	001
AOI	001

MALFUNCTION OF REACTOR CONTROL SYSTEM

Rev. 15

Page 52 of 80

STEP	INSTRUCTIONS RESPONSE NOT OBTAINED
	SECTION B
	IMMOVABLE/MISALIGNED_RODS
	(Page 17 of 31)
	NOTE
•	APP-005-E2, ROD CONT SYSTEM URGENT FAILURE, will illuminate when the rod is moved due to all Lift Coil Disconnect Switches being off in the unaffected group.
•	APP-005-B5, ROD BANKS A/B/C/D LO LIMIT, and APP-005-C5, ROD BANKS A/B/C/D LO-LO LIMIT, may illuminate when the rod is stepped in due to the P-A Converter input to the Rod Insertion Limit Monitoring System.
37.	Align The Affected Rod As Follows:
	a. Depress <u>AND</u> hold the AUTO ROD DEFEAT Pushbutton
	b. Select the affected bank with the ROD BANK SELECTOR Switch
	c. Release the AUTO ROD DEFEAT Pushbutton
	d. Insert the rod at the rate specified in Step 28 to the Group Step Counter position recorded in Step 31
Question: 90

Given the following condiditons:

- Pressurizer pressure transmitter PT-457 has failed low and is being removed from service in accordance with the OWP.
- The OWP requires the low pressure bistables in the Hagan racks be placed in the TRIPPED condition.

Which ONE (1) of the following describes the verification required for this function?

- a. Independent verification with the second initials "N/A'd" by the SSO
- b. Independent verification with the second initials required
- c. Concurrent verification with the second initials required
- d. Functional verification with second initials required

Answer:

c. Concurrent verification with the second initials required

QUESTION N TIER/GROUP K/A:	UMBER: ?: 2.1.29	90	RO	3	:	SRO	3
	Knowledge of	f how to condu	ct and v	erify valv	e lineups.		
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.4 10	Si 55.43(b) \$	RO SRO	3.3
OBJECTIVE:	PLP-030-04						
	Given a set o DETERMINE	f conditions or the applicable	compon functior	ients nee nal testing	ding positi g and inde	on chec pendent	ks or positioning actions verification requirements.
REFERENCE	S:	OPS-NGGC-	1303				
SOURCE:	New	Significa	ntly Mo	odified			Direct X
SOURCE:	New	Significa	ntly Mo Bank	odified Number	PLP-0	30-04	Direct X
SOURCE:	New ON:	Significa	ntly Mc Bank	odified Number	PLP-0	30-04	Direct X 005
SOURCE: JUSTIFICATI <i>a.</i>	New ON:	Plausible since verification is	Bank . Bank . ce indep what is	odified Number endent ve used.	PLP-0 erification i	30-04 is identif	Direct X 005 ied on the OWP, but concurrent
SOURCE: JUSTIFICATI a. . b.	New	Plausible sind verification is Plausible sind verification is	<i>Bank</i> Bank ce indep what is ce indep what is	odified Number endent ve used. endent ve used.	PLP-0 erification i erification i	30-04 is identif is identif	Direct X 005 ied on the OWP, but concurrent ied on the OWP, but concurrent
SOURCE: JUSTIFICATI a. . b. c.	New	Signification is Plausible since verification is Plausible since verification is Concurrent verification is Selecting the	<i>Bank</i> Bank ce indep what is ce indep what is erificatio pility of re wrong o	odified Number endent ve used. endent ve used. on is used esulting ir cabinet or	PLP-0 erification i erification i where an man imme bistable c	30-04 is identif is identif imprope diate pla could cau	Direct X 005 ied on the OWP, but concurrent ied on the OWP, but concurrent er positioning of a component has ant trip or safety actuation. use a trip in this condition.
SOURCE: JUSTIFICATI a. b. c. d.	New	Signification is Plausible since verification is Plausible since verification is Concurrent verification is Selecting the Plausible since but the bistable since	<i>Bank</i> Bank ce indep what is ce indep what is erificatio pility of re wrong co ce functioned would	bdified Number endent ve used. endent ve used. on is used esulting ir cabinet or onal verif d already	PLP-0 erification i erification i where an h an imme bistable c ication car be tripped	30-04 is identif is identif imprope diate pla could cau n be use l in this c	Direct X 005 ied on the OWP, but concurrent ied on the OWP, but concurrent er positioning of a component has ant trip or safety actuation. use a trip in this condition. d to verify bistable status change, condition.
SOURCE: JUSTIFICATI a. b. c. d. DIFFICULTY: Comprehen	New ON: CORRECT	Signification is Plausible since verification is Plausible since verification is Concurrent verification is Selecting the Plausible since but the bistab	Bank Bank Bank ce indep what is ce indep what is	bdified Number endent ve used. endent ve used. on is used esulting in cabinet or onal verif d already	PLP-0 erification i erification i where an man imme bistable c ication car be tripped	30-04 is identif is identif in identif diate pla could cau h be use l in this c ing	Direct X 005 ied on the OWP, but concurrent ied on the OWP, but concurrent er positioning of a component has ant trip or safety actuation. use a trip in this condition. ed to verify bistable status change, condition.

REFERENCES SUPPLIED:

6.3 Concurrent Verification Guidelines

- 6.3.1 CONCURRENT VERIFICATION, as defined in Section 3.0, is particularly useful in preventing an unintended plant response while conducting tests. CONCURRENT VERIFIC ATION positively identifies the correct unit, train, or componend and ensures a review of the intended action is performed, eliminaling the possibility of an unintended plant response due to a single porsonnel error. Identification of actions that, if performed is properly, could result in an immediate threat to safe and reliable plant operation, along with use of CONCURRENT VERIFICATION prior to performing such actions, will enhance plant reliability during system testing.
- 6.3.2 CONCURRENT VERIFICATION satisfies the requirements of INDEPENDENT VERIFICATION under the following circumstances unless specifically required by procedure and should be performed for the following:
 - 1. Specific evolutions or actions where an improper positioning of a component has a high probability of resulting in an immediate plant trip, Safety System actuation <u>OR</u> could to cult in an immediate threat to safe and reliable plant operation. Examples of such evolutions are:
 - Installing or removing jumpers
 - Lifting or landing leads
 - Fuse removal
 - Operating a valve, switch or breaker
 - Placing bistable switches in the THP position
 - 2. Positioning a throttle valve to a specific position when the valve has no accurate and discernable position indicator and is a component or system listed in Attachments 1(BNP), 2(HNP), and 3(BNP).
 - 3. Performing position verification of locked valves which require a second position verification.
 - 4. When INDEPENDENT VERIFICATION would invalidate initial component positioning (throttled valve position).

OPS-NGGC-1303	Rev. 0	Page 13 of 29

RNP NRC Written Examination Common Question

Question: 91

Given the following conditions:

- The unit has just experienced a reactor trip.
- NO SI equipment has actuated.
- 1/2 turbine stop valves are shut.
- 3/4 turbine governor valves are shut.
- RCS pressure is 1860 psig.
- Tavg is 542°F.
- All MSIVs are open.
- SG Pressures and Steam Flows are:

SG	PRESSURE	STEAM FLOW
'A'	925 psig	0.1 x 10 ⁶ lbm/hr
'B'	935 psig	0.1 x 10 ⁶ lbm/hr
'C'	845 psig	1.3 x 10 ⁶ lbm/hr

The reactor is tripped, the turbine is ...

- a. tripped, and SI is **NOT** required.
- b. tripped, and SI is required.
- c. NOT tripped, and SI is NOT required.
- d. **NOT** tripped, and SI is required.

Answer:

c. **NOT** tripped, and SI is **NOT** required.

QUESTION N TIER/GROUF K/A:	UMBER: 2: 007EK3.01	91	RO	1/2		SRO	1/2		
	Knowledge of EOP for react	the reasons fo or trip	or the fol	lowing a	s they ap	ply to a re	eactor trip	: Actions co	ntained in
K/A IMPORT 10CFR55 CO	ANCE: NTENT;	55.41(b)	RO RO	4.0 10	55.43(b)	SRO SRO	4.6		
OBJECTIVE:	PATH-1-05								
	DEMONSTRA	TE an unders	tanding	of the st	eps of PA	TH-1 whi	ch requir	e outside as	sistance
REFERENCE	:S:	SD-006 FRP-S.1							
SOURCE:	New	Significa	antly Mo	dified		Н. 1-05	Direct	003	
JUSTIFICAT	ION:		валкі	vumber	FAI	n-1-00		000	
a.		Plausible since the steamflow SI coincidence has not been exceeded, but the turbine is not considered tripped.							
b.		Plausible sind not considere	ce the tu ed trippe	rbine va d.	lves have	received	a close s	signal, but th	e turbine is
C.	CORRECT The turbine is only considered to be tripped if both stop valves or all 4 governor valves are closed, but no SI setpoints have been reached.								
d.		Plausible sind	ce the tu	rbine is	not trippe	d, but no	SI setpoi	nt has been	exceeded.
DIFFICULTY Compreher	': nsive/Analysis	X Kn	owledge	e/Recall		ating	3		
	Comparison or requirements	of abnormal re	esponse "	to reacto	or trip to d	etermine	equipme	nt status and	1

REFERENCES SUPPLIED:

RESPONSE TO NUCLEAR POWER GENERATION/ATWS

Rev. 12

٠

Page 5 of 18

STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
2.	Check Turbine Trip As Follows:	Perform the following:
	 BOTH Turbine Stop Valves - CLOSED <u>OR</u> 	a. Manually trip the Turbine by simultaneously depressing the THINK and TURBINE TRIP Pushbuttons.
	• All Governor Valves - CLOSED	b. <u>IF</u> Turbine will <u>NOT</u> trip, <u>THEN</u> run back Turbine at maximum rate until the Governor Valves are closed.
		<pre>c. IF Turbine can <u>NOT</u> be run back, <u>THEN</u> verify CLOSED the following:</pre>
		• All MSIVs
		• All MSIV BYPs
3.	Verify All AFW Pumps - RUNNING	

4.1.2 Reactor Coolant Temperature (ESF-Figure-1)4.1.2 Reactor Coolant Temperature

The RCS Low Tavg signal (2 of 3 channels below 543°F) is used to initiate the Safety Injection signal, when coincident with high steam flow; and close the Main Steam Isolation Valves, when coincident with high steam flow (i.e., generate the Steam Line Isolation Signal).

4.1.3 Steam Flow (ESF-Figure-1)4.1.3 Steam Flow

Hi Steam Flow (37.25% flow at no load to 20% load, increases linearly to 109% at full load) detected by at least one sensor on two of three steam lines, coincident with low Tavg (543°F) or low steam line pressure (614 psig), generates a Safety Injection signal and closes all MSIVs. Two flow controllers on each steam line are used to sense high steam line flow. This circuit is designed to detect steam line breaks downstream of the MSIVs.

4.1.4 Steam Line Pressure (ESF-Figure-1 & 3)4.1.4 Steam Line Pressure

Steam Line Pressure measurement is utilized for steam line break protection. Low steam line pressure (614 psig) in two of three main steam lines or Low Tavg ($543^{\circ}F$) in two of three loops, coincident with high steam line flow in two-of-three main steam lines, will initiate the Steam Line Isolation and Safety Injection signals. This is to protect against: a steam line break upstream of the main steam check valves, a feed line break, and/or an inadvertent opening of a SG safety.

In addition, each steam line pressure measurement is compared with a main steam header pressure measurement to determine if a high steam line differential pressure exists. A coincidence of two-of-three steam line differential pressures (100 psid) in any one steam line, that is, steam line pressure lower than main steam header pressure, will initiate a Safety Injection signal.

The steam header pressure is electronically limited to a minimum value of 585 psig. Therefore, this SI signal must be blocked before a plant cooldown is started to prevent SI actuation when S/G pressures drop below 485 psig(approximately 467° F). The steam line differential pressure circuit detects faults upstream of the MSIVs. Since the steam line check valves prevent reverse flow to the faulted S/G, excessive steam line differential pressure does not close the MSIVs.

4.1.5 Containment Pressure (ESF-Figure-4 & 5)4.1.5 Containment Pressure

SD-006

ESF

PATH-1-05 003

Given the following plant conditions:

- The Unit has just experienced a reactor trip
- Both turbine stop valves are shut
- Three turbine governor valves are shut
- RCS pressure is 1860 psig
- Tavg is 542°F
- S/G Pressures: A-895, B-915, C-835 psig
- Steam flows: A-0.1, B-0.1, C-1.3x10E6 lbm/hr
- No SI equipment has actuated

Which ONE (1) of the following contains the correct plant status and operator actions?

The reactor is tripped, the turbine is:

- ✓A. tripped, SI is not initiated or required; verify two charging pumps running.
 - B. not tripped, SI is not initiated or required; trip the turbine and verify two charging pumps running.
 - C. not tripped, SI is not initiated but is required; trip the turbine and initiate SI.
 - D. tripped, SI is not initiated but is required; initiate SI.

Question: 92

Given the following conditions:

- A reactor trip occurred due to a loss of offsite power.
- The plant is being cooled down on RHR per EPP-005, "Natural Circulation Cooldown."
- RVLIS upper range indicates greater than 100%.
- Both CRDM fans have been running during the entire cooldown.
- RCS cold leg temperatures are 190 °F.
- Steam generator pressures are 50 psig.

Steam should be dumped from all SGs to ensure

- a. boron concentration is equalized throughout the RCS prior to taking a sample to verify cold shutdown boron conditions.
- b. all inactive portions of the RCS are below 200 °F prior to complete RCS depressurization.
- c. RCS and SG temperatures are equalized prior to any subsequent RCP restart.
- d. RCS temperatures do **NOT** increase during the required 29-hour vessel soak period.

Answer:

b. all inactive portions of the RCS are below 200 °F prior to complete RCS depressurization.

							I	RNP NRC Written Examination Common Question Reference
QUESTION N TIER/GROUP K/A:	UMBER: : WE09/10EK3	92 .1	RO	1/1		SRO	1/1	
	Knowledge of Operations) F the effects of	the reasons fo acility characte temperature, p	er the follo eristics du ressure, a	owing re uring tra and rea	esponses nsient co ctivity	s as they a onditions,	apply t includ	o the (Natural Circulation ing coolant chemistry and
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.3 5	55.43(b	SRO) SRO	3.6	
OBJECTIVE:	EPP-005-03							
	EXPLAIN the	basis for selec	ted steps	, preca	utions, a	nd limitati	ons as	sociated with EPP-5.
REFERENCE	S:	EPP-005						
SOURCE:	New	Significa	ntly Mod	lified			Direct	t 🗙
	<u>ON</u> .		Bank N	umber	HNF	P-RO-199	8	53
a.		Plausible sinc be completed	e this act prior to d	ion wou Iepressi	lld have urizing th	been perf ne RCS be	formed elow 19	in this procedure, but must 900 psig.
b.	CORRECT	SG pressure a Depressurizin in the SG u-tu	above 0 p g the RC: bes.	osig indi S undei	cates the this cor	at the SG adition will	s are a l result	bove 200 °F. in additional void formation
с.		Plausible sinc be performed	e RCP op at this po	peration pint in th	through e proced	iout NC C dure.	ooldov	vn is desirable, but will not
d.		Plausible sinc CRDM fans ha	e a soak ad not be	period i en maii	s addres ntained.	ssed, but	only if	continued operation of both
DIFFICULTY: Comprehen	sive/Analysis	X Kno	wledge/l	Recall	Ra	ating	3	
	Application of requirements	plant conditior are met	is, using :	steam t	ables as	needed,	to dete	ermine if NC procedural

REFERENCES SUPPLIED: Steam Tables

EPP-5

Rev. 11

Page 21 of 22

	······]
STEP	INSTRUCTIONS	RESPONSE NOT OBTAINED
40.	Determine If RHR System Can Be Placed In Service:	
	a. Check RCS temperature – LESS THAN 350°F	a. <u>WHEN</u> RCS temperature is less than 350°F, <u>THEN</u> Go To Step 40.b.
	b. Check RCS pressure - LESS THAN 375 PSIG	b. <u>WHEN</u> RCS pressure is less than 375 psig, <u>THEN</u> Go To Step 40.c.
	c. Place RHR system in service using Supplement I	
41.	Continue RCS Cooldown To Cold Shutdown	
42.	Continue Cooldown Of Inactive Portions of RCS As Follows:	
	 a. Verify both CRDM Cooling Fans RUNNING HVH-5A HVH-5B b. Cool upper head region using Both CRDM Cooling Fans HVH-5A HVH-5B c. Cool S/G U-tubes by dumping 	 a. Perform the following: 1) Maintain RCS temperature less than 212°F for 29 hours. 2) Go To Step 42.c.
	c. Cool S/G U-tubes by dumping steam from all S/Gs until the S/Gs have stopped steaming	
43.	Check Cooldown Status - ALL REQUIREMENTS OF STEP 42 SATISFIE	WHEN all requirements met, <u>THEN</u> D observe <u>CAUTION</u> prior to Step 44 and Go To Step 44.

EPP-5 NATURAL CIRCUI			ATION	COOLDOWN	Rev. 11			
			Page 22					
STEP	Н		INSTRUCTIONS		RESI	PONSE NOT OBI	AINED	
***	***	* * * * *	**************************************	* * * * * EON	* * * * * * * * *	*****	****	
Dep in	void	suriz 1 for	ing the RCS before the enti- mation.	ire R	CS is les	s than 200°F	may result	
***	****	* * * * *	*****	****	* * * * * * * * *	*****	****	
44.	De De	eterm epres	nine If RCS ssurization Is Permitted:					
	a	. Che	eck entire RCS - LESS THAN		a. Do <u>NOI</u>	depressuriz	e RCS.	
		200	Υ <u>Γ</u>		Go To	Step 41.		
	b.	. Ret in Pla	curn to procedure and step effect as determined by ant Operations Staff					
			- 1	end -				

Question: 53

A reactor trip occurred due to a loss of offsite power. The plant is being cooled down on RHR per EPP-006, Natural Circulation Cooldown with Steam Void in Vessel with RVLIS.

- RCS cold leg temperatures are 190°F.
- Steam generator pressures are 50 psig.
- RVLIS upper range indicates greater than 100%.
- Three CRDM fans have been running during the entire cooldown.

Steam should be dumped from all SGs to ensure ...

- A. boron concentration is equalized throughout the RCS prior to taking a sample to verify cold shutdown boron conditions.
- B. all inactive portions of the RCS are below 200°F prior to complete RCS depressurization.
- C. RCS and SG temperatures are equalized prior to any subsequent RCP restart.
- D. RCS temperatures do not increase during the required 29 hour vessel soak period.

Answer:

B all inactive portions of the RCS are below 200°F prior to complete RCS depressurization.

- -

Question: 93

Given the following conditions:

- The unit is operating at 100% power.
- A release is in progress from Waste Gas Decay Tank 'A'.
- A loss of Instrument Bus 3 occurs, requiring termination of the release.

Which ONE (1) of the following describes how the release is terminated as a result of the loss of the Instrument Bus?

- a. Automatically due to the loss of R-14, Plant Vent Monitor
- b. Manually due to the loss of R-14, Plant Vent Monitor
- c. Manually due to the loss of power to the Waste Disposal Boron Recycle Panel
- d. Automatically due to the loss of power to the Waste Disposal Boron Recycle Panel

Answer:

a. Automatically due to the loss of R-14, Plant Vent Monitor

								RNP NRC Written Examination Common Question Reference
	IUMBER:	93	BO	0/4		SPO	2/4	
K/A:	071A2.05		RU	2/1		380	211	
	Ability to (a) p Disposal Syst Power failure	redict the impa em ; and (b) u to the ARM an	acts of t se proce d PRM	he follow edures to systems	ing malfu o correct,	nctions o control, c	or opei or miti	rations on the Waste Gas gate the consequences:
K/A IMPORT/ 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	2.5 11	55.43(b	SRO) SRO	2.6	
OBJECTIVE:	AOP-024-08							
	Given plant co Instrument Bu	onditions EVAL is as directed i	-UATE 1 n AOP-	the appro 024.	opriate ac	ctions to r	nitigat	te consequences of loss of an
REFERENCE	S:	AOP-024 EDP-008 SD-019 AOP-005 RMS Lesson	Plan					
SOURCE:	New	Significa	ntly Mo	odified			Dire	ct X
			Bank	Number	- AOF	P-024-08		001
JUSTIFICATI a.	ON: CORRECT	Instrument Bu 014 to close a	us 3 sup and tern	oplies por ninate the	wer to R1 e release	4. Loss .	of pov	ver to R14 will cause RCV-
b.		Plausible sinc terminate aut	ce Instru omatica	ıment Bu Illy.	ıs 3 supp	lies powe	er to R	14, but the release will
C.		Plausible sind WDBRP powe R14.	ce a WD er is los	BRP Tro t and the	ouble alar e release	m is rece terminate	eived, es auto	however no significant omatically due to the loss of
d.		Plausible sind automatically terminates du	ce a WE , howev ie to the	BRP Tro er no sig loss of	ouble alar Inificant V R14.	rm is rece VDBRP p	eived a oower	and the release is terminated is lost and the release
DIFFICULTY	: sivo/Analysis	X Ko	wleda	e/Recall		atina	3	
Comprehen	Sive/AndiySIS		swieug	-///ecall			0	1
	Comprehensi	on of the effec	t of a lo	ss of pov	ver during	g a gasec	ous re	lease

REFERENCES SUPPLIED:

Rev. 14

Page 50 of 92

CONTINUOUS USE ATTACHMENT 4 EXTENDED LOSS OF INSTRUMENT BUS 3 (AND 8) (Page 1 of 3) NOTE The following control functions/indications will be lost until Instrument Bus 3 and 8 are restored: PT-446, Turbine 1st Stage Pressure FCV-114A, PW to Blender (locked up full open) FRV A, B, & C Automatic Control FRV Bypass Valve A (FCV-479) PCV-455B, Spray Valve (Indication only) Safeguards Train B Sequencer FCV-1425 (AFW PUMP B inoperable) Charging Pump C Controller, SC-153A (locks up) ICCM - Channel II Steam Dump Steam Pressure Control RMS Racks 2 & 3 and R-32B PT-138 Excess Letdown Pressure Indication S/G A PORV Control TCV-1447 and TCV-1448 Exhaust Hood Spray Valves Solenoids for R-11/12 Skid (fail closed)

1. Place Turbine First Stage Pressure Selector Switch to PT-447 position.

NOTE

In the event that the Plant experiences a trip due to difficulty in maintaining all S/Gs in manual level control, feed flow to the S/Gs will be accomplished via the AFW Pumps <u>QR</u> FRV Bypass Valves.

- 2. Continue to operate FRVs A, B, & C in MAN.
- 3. Contact Operations Staff for availability of a dedicated FRV watch.

Section 8.0 Page 1 of 1

INSTRUMENT BUS NO. 8							
	Location: Safeguards Room, East Wall						
		4	Power Supply: Instrument Bus No. 3, Ckt 10 (fused panel)				
скт	FUSE SIZE	FUSE TYPE	LOAD				
1			Emergency Response Facility Instrumentation System "MUX Cabinet 2" (CWD 1499)				
2			RMS Console No. 1, 2, & 3 (NOTE 1) (CWD 83, 574)				
3			Hagan Rack 8 (CWD 417); PI-156A (CWD 475); FR-154A pen 1, FR-154B pen 1 (5379-3473); TI-116, PI-117 (CWD 473); PI-445 (CWD 455A); FI-156B (CWD 478); LR-477 pen 3 (5379-3517)				
4			Hagan Rack 14 (CWD 460); LI-461 (CWD 460); TI-432C, TI-432D (CWD 411); TI-432B (CWD 413); TI-432A (CWD 408);				
5			Hagan Rack 15 (CWD 457); FI-416 (CWD 463); FI-426 (CWD 464); FI-436 (CWD 465); PI-954, PI-955 (CWD 496, 5379-3504); PI-457 (CWD 457);				
6			Hagan Rack 16 (CWD 418); LI-476 (CWD 418); LI-486 (CWD 419); LI-496 (CWD 420, 5379- 3485/3515); FR-478 pen 3 (5379-3513); FR-488 pen 3 (5379-3514/3487); FR-498 pen 3 (5379- 3515/3485); PI-446 (CWD 428);				
7		-	Hagan Rack 17 (CWD 421); FI-474 (CWD 424); PI-475 (CWD 429); FI-477 (CWD 421); PI-485 (CWD 430); PI-495 (CWD 431); PI-466 (CWD 427)				
8			Hagan Rack 18 (CWD 422); FI-484 (CWD 425); FI-487 (CWD 422); FI-494 (CWD 426); FI-497 (CWD 423);				
9			RTGB receptacles, Sections A, C and D (CWD 114, 459, 479, 481, 963 , 964); TR-448 (CWD 114, 964)				
10			FT-110E/I Boric Acid Bypass Flow, FI-110 (CWD 474)				
11			Pressurizer Spray Valve PCV-455B position lights (CWD 470)				
12			TI-580, LI-802, PI-957, PI-8111-2 (CWD 533)				
13	N/A	N/A	SPARE				
14			FQ-958B CV Spray Flow, FI-958B (CWD 494B)				
15	N/A	N/A	SPARE				
16			V2 Safeguard relay (Rack 63) (CWD 397)				
17	N/A	N/A	SPARE				
18			Channel II CET/CCM Signal Processor Cabinet TM-578 (CWD 1700); TI-433 & pen 3 on TR-413 (5379-3502)				
19	N/A	N/A	SPARE				
20			FI-1425A, FI-1426B (AFW) (CWD 623A, 623B)				
21	N/A	N/A	SPARE				
22			Excore Neutron Flux Detector System Channel N-52, NI-52A, NI-52B, NR-53 pens 3&4(CWD450C&D)				
23	N/A	N/A	SPARE				
24	N/A	N/A	SPARE				
25			Boric acid heat trace Local Annunciator No 3 (CWD180C);				
26			Boric acid heat trace recorder No. 3 (CWD 180B)				
27			CV Ave Temp Channel TI-950, TI-950B (CWD 044)				
28			Aux. panel "GB" TB 5 and 6 (turbine auto stop trip) (CWD 711)				
29			Reactor Protection Rack 55 (CWD 438)				
30			Reactor Protection Rack 60 (CWD 438)				
31			Turbine oil temperature TT-2097, TI-2097A (CWD 726)				
32			PQ 4005 Turbine main oil pump discharge (CWD 726)				
33			Hydrogen control cabinet electronics, PI-1900 Gen H2 press, AI-1900 Gen H2 Purity (CWD-876)				

NOTE 1: RMS console No. 1: R-32B and ERFIS Multiplexers for RMS RMS console No. 2: R-11 & 12, R-14A-E digital displays, R-15, R-16, and the RMS recorder RMS console No. 3: R-17, R-18, R-19A-C digital displays, R-20, R-21, R-30, R-31A-C.

EDP-008	Rev. 12	Page 11 of 13
---------	---------	---------------

Rev. 19 AOP-005 RADIATION MONITORING SYSTEM Page 30 of 56 RESPONSE NOT OBTAINED STEP INSTRUCTIONS ATTACHMENT 13 PROCESS MONITOR R-14 - PLANT EFFLUENT (Page 1 of 2) NOTE When PLANT EFFLUENT NOBLE GAS LOW RANGE RI-14C reaches a predetermined high level, the monitor will default to 1M CPM and valid readings will only be displayed on RI-14D and RI-14E. 1. Check Waste Gas Decay Tank Go To Step 6. Release - IN PROGRESS 2. At The WDBRP Verify RCV-014, WASTE GAS DECAY TANK RELEASE ISOLATION Valve - CLOSED 3. Do Not Restart Release Until Cause Of High Radiation Alarm Is Determined And Corrective Actions Are Complete 4. Request E&RC To Perform The Following, As Applicable: Resample Waste Gas Decay Tank aligned for release Perform background radiation survey for Radiation Monitor R-14 5. Go To Step 10 6. Start One Of The Following AUX BLDG CHARCOAL EXH FANs: HVE-5A HVE-5B 7. At The WDBRP, Check All Waste Go To Step 10. Gas Decay Tank Pressure Indications - ANY UNEXPLAINED OR UNCONTROLLED DECREASE

- b. Control Room indications while in the Low Range Flow Path:
 - Digital readouts for R-14A, R-14B, and R-14C will be reading actual radiation levels.
 - Digital readouts for R-14D and R-14E will be defaulted to a minimum value (approximately 10 CPM).
- c. When the noble gas activity for R-14C exceeds a precalculated setpoint (well above the normal R-14C High radiation alarm setpoint) R-14 Skid sample flow will be diverted through channels R-14D and R-14E (High Range Flow Path). The value of this switch over setpoint, always in the upper decade of R-14C range, depends on the overlap of R-14C and R-14D. RCV-014 automatically closes as a result of an alarm on R-14C.
- NOTE: Grab samples results must be used from analysis of the Particulate and Iodine pre filter in the High Range Flow Path.
 - d. Control Room indications while in the High Range Flow Path:
 - Digital readouts for R-14A and R-14B will be erroneous since there will be no flow through these channels.
 - Digital readout for R-14C will default to a maximum value (approximately 1M).
 - Digital readout for R-14D should read 50 CPM or greater.
 - Digital readout for R-14E should read its true background or higher (10 CPM to 50 CPM).
 - R-14C HIGH Alarm light (auto functions will be activated).
 - e. When the noble gas activity for R-14D goes below a pre-calculated setpoint the R-14 Skid sample flow will be diverted back through channels R-14A, R-14B and R-14C (Low Range Flow Path). The value of this switch over setpoint, always in the lower decade of R-14D range, depends on the overlap of R-14C and R-14D.
- 6. Stack Isokinetic Flow Measurement

The purpose of isokinetic sampling is to draw a representative sample of particles in an air or gas stream at the same rate (velocity) at which the air or gas flow through the stack. Isokinetic sampling means that the R-14 skid flow is proportional to the flow rate in the plant stack (1:30,000 ratio).

HBR uses Kurz' unique eight-point, independent, individual velocity sensors mounted on two orthogonal 316 stainless steel bars to measure the Plant Stack flow. Two bars are used because of the geometry of the stack (i.e.elbow and feeder ducts). This design minimizes particle loss and optimizes sample flow

ATTACHMENT 10.2 Page 1 of 2

RMS INSTRUMENT CONTROL FUNCTIONS

MONITOR	MEDIUM MONITORED	FUNCTION			
R-1	Control Room Air	Switches Control Room ventilation into the emergency pressurization operating mode.			
R-11	CV Air or Stack Particulate	Closes C.V. purge supply and exhaust; pressure and vacuum relief valves.			
R-12	CV Air or Stack Gas	Same function as R-11			
R-14C	Stack Gas (Low Range)	Closes waste gas decay tank release valve (RCV-014); swaps R-14 Skid over to high range (two different setpoints).			
R-14D	Stack Gas (Mid Range)	Swaps R-14 Skid over to low range.			
R-18	Liquid Waste Disposal	Closes waste disposal system liquid release valve (RCV-018)			
NOTE The blowdown tank release isolation valve (V1-31) will close if all three SG monitors (R-19A, R-19B and R-19C) are in alarm.					
R-19A	SG "A" Blowdown	Closes; blowdown isolation valves FCV-1930A & FCV-1930B, sample isolation valves FCV-1933A & FCV-1933B, rate flow control valve FCV-4204A.			

Page 53 of 59

INFORMATION ONLY

RMS

LESSON BODY

I. GENERAL DESCRIPTION	
A. SYSTEM PURPOSE	RM-TP-1
1. Sections 2.1 of SD-019	UBJ. #1
B. SYSTEM FLOWPATHS AND BASIC OPERATION1. Section 2.2 and 2.3 of SD-019	RM-FIGURES-1,2,3, & 4
II. COMPONENT DESCRIPTION	
Components of the Radiation Monitoring System include: - Area Radiation Monitoring System - Process radiation Monitoring System - Accident Radiation Monitors	
A. AREA RADIATION MONITORING SYSTEM	OBJ. #4,5
1. Section 3.1 of SD-019	OBJ #6
2. Power Supply is IB #7	RM-FIGURES 5,6,&7
B. PROCESS MONITORS	RM-FIGURES-5, 8 thru 14
1. Section 3.2 of SD-019	
2. Section 3.2.4 of SD-019 for individual channels	RM-FIGURES-15 thru 22
3. Power Supply is IB #8	OBJ. #6
C. MISCELLANEOUS EQUIPMENT	RM-FIGURE-21
1. Section 3.3 of SD-019	
D. POWER SUPPLIES TO RMS COMPONENTS	
1. Instrumentation Bus 7A	

Question: 94

Which ONE (1) of the following conditions related to the Pressurizer would require entry into a Technical Specification action or a Technical Requirment Manual compensatory action, as applicable?

- a. Pressurizer level is 68% with the plant operating at 8% power
- b. Pressurizer pressure is 2184 psig with the plant operating at 2% power
- c. SST-2A Disconnect, used to supply emergency power to the pressurizer heaters from EDG 'A', is removed from service for maintenance with the plant operating at 35% power
- d. Auxiliary Spray, at 400 °F, is used to depressurize the RCS from 2235 psig, resulting in a cooldown rate of the Pressurizer of 135 °F per hour

Answer:

a. Pressurizer level is 68% with the plant operating at 8% power

								RNP NRC Written Examination Common Question Reference
	IUMBER:	94						
TIER/GROUP K/A:	9: 010 2.1.33		RO	2/2		SRO	2/2	
	Ability to reco for technical s	gnize indicatio specifications (ns for sy Pressuri:	vstem op zer Pres	erating ssure).	parameters	s whic	h are entry-level conditions
K/A IMPORTA 10CFR55 CO	ANCE: NTENT:	55.41(b)	RO RO	3.4 10	55.43(SRO b) SRO	4.0	
OBJECTIVE:	PZR-12							
	STATE the Te	echnical Speci	fication L	.imitatio	ns and e	explain the	bases	for the PZR and PRT.
REFERENCE	S:	TS 3.4.1 TS 3.4.9 TRMS 3.4 SD-059						
SOURCE:	New	X Significa	ntly Mo	dified			Direc	t 🔲
	ON-		Bank I	Number	•			NEW
a.	CORRECT	TS limit is 63. is operating a	3% for N t 8%, the	/lode 1 c e Mode	peratior 1 limit aj	n and 92% pplies.	for Mo	ode 2 and 3. Since the plant
b.		Plausible sind but at 2% pov	e this wo	ould req plant is ir	uire an e 1 Mode :	entry into T 2 where the	'S 3.4. e TS d	1 if the plant was in Mode 1, loes not apply.
с.		Plausible since at least 125 KW of heaters capable of being supplied by an emergency source are required, but this condition only renders one set of the heaters inoperable and the other can still provide > 125 KW.						
d.		Plausible sind and the stear and 200 °F pa	ce a limit n space : er hour c	exists for and a co cooldowr	or both t ooldown n) are m	he differen limit, but b et.	tial ter oth lin	nperature between spray nits (320 °F spray differential
DIFFICULTY: Comprehen	: sive/Analysis	X Kno	owledge	/Recall	F F	Rating	3	

Analysis of conditions to determine if TS and / or TRM limits for pressurizer are met

REFERENCES SUPPLIED:

RCS Pressure, Temperature, and Flow DNB Limits 3.4.1

3.4 REACTOR COOLANT SYSTEM (RCS)

- 3.4.1 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits
- LCO 3.4.1 RCS DNB parameters for pressurizer pressure, RCS average temperature, and RCS total flow rate shall be within the limits specified below:
 - a. Pressurizer pressure ≥ 2205 psig;
 - b. RCS average temperature \leq 579.4°F; and
 - c. RCS total flow rate \ge 97.3 x 10⁶ lbm/hr.

APPLICABILITY: MODE 1.

Pressurizer pressure limit does not apply during:

- a. THERMAL POWER ramp > 5% RTP per minute; or
- b. THERMAL POWER step > 10% RTP.

ACTIONS

	CONDITION		REQUIRED ACTION	COMPLETION TIME
Α.	One or more RCS DNB parameters not within limits.	A.1	Restore RCS DNB parameter(s) to within limit.	2 hours
В.	Required Action and associated Completion Time not met.	B.1	Be in MODE 2.	6 hours

3.4 REACTOR COOLANT SYSTEM (RCS)

- 3.4.9 Pressurizer
- LCO 3.4.9 The pressurizer shall be OPERABLE with:
 - a. Pressurizer water level $\leq 63.3\%$ in MODE 1;
 - b. Pressurizer water level $\leq 92\%$ in MODES 2 and 3; and
 - c. Pressurizer heaters OPERABLE with a capacity of ≥ 125 kW and capable of being powered from an emergency power supply.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

	CONDITION		REQUIRED ACTION	COMPLETION TIME
Α.	Pressurizer water level not within limit.	A.1	Be in MODE 3 with reactor trip breakers open.	6 hours
		AND		
		A.2	Be in MODE 4.	12 hours
В.	Capacity of required pressurizer heaters ≤ 125 kW.	B.1	Restore required pressurizer heaters to OPERABLE status.	72 hours
С.	Required pressurizer heaters not capable of being powered from an emergency power supply.	C.1	Restore capability to power the required pressurizer heaters from an emergency power supply.	72 hours.

(continued)

HBRSEP Unit No. 2

Amendment No. 176

Pressurizer Heatup and Cooldown Limits 3.4

3.4 PRESSURIZER HEATUP AND COOLDOWN LIMITS

TRMS 3.4	a.	The maximum heatup rate of the pressurizer shall be
(CTS		≤ 100°F/hr and the maximum cooldown rate of the
3.1.2.3)		pressurizer shall be ≤ 200°F/hr.

AND

b. Pressurizer spray shall not be used if the temperature between the pressurizer and the spray fluid is > $320^{\circ}F$.

APPLICABILITY: At all times.

COMPENSATORY MEASURES

	CONDITION	REQUIR	ED COMPENSATORY MEASURE	COMPLETION TIME
Α.	Requirements of TRMS not met.	A.1	Initiate action to restore compliance With the TRMS.	Immediately
		AND		
		A.2	Initiate a Condition Report in accordance with the Corrective Action Program.	Immediately

TEST REQUIREMENTS

TEST	FREQUENCY
None.	NA

....

I

condition requiring venting of non-condensable gases from the PZR, a connection to the High Point Vent System is provided.

3.0 COMPONENT DESCRIPTION

3.1 PZR (PZR-Figure 2)

Design pressure	2485 psig
Design temperature	680°F
Water Volume, full pwr.	780 ft^3 (60% of net interval Volume)
Steam Volume, full pwr.	520 ft ³
Shell I.D.	84 in.
Minimum Shell thickness	4.1 in.
Minimum Clad thickness	0.188 in.
Steady State heat losses	90 KW

The PZR is a vertical, cylindrical vessel with a surge line in the bottom from RCS loop C hot leg, and a spray line in the top from RCS loops B and C cold legs. Electrical immersion heaters penetrate the lower head. PORVs and safety valves are connected to the upper head.

3.2 PZR Heaters

Capacity total	1300 KW (Minimum KW required = 800)
Control Group	400 KW
Backup Group #1	450 KW
Backup Group #2	450 KW

The electrical heaters installed in the PZR are replaceable, direct immersion, tubular sheath type, that are hermetically sealed. Located in the lower portion of the vessel, they heat and maintain the steam and water contents at equilibrium (saturated) conditions. The heater bundle consists of 78 individual heater elements rated at 16.67 KW each.

The control heaters consist of eight banks with three heaters per bank (400 kW). The purpose of the control heaters is to make up for the ambient heat losses. The power to this group is controlled in inverse proportion to PZR pressure when they are on.

Two groups of backup heaters are provided. Each group consists of nine banks with three heaters per bank (450 kW) and are turned on and off by PZR pressure signals when in the automatic mode of operation. Controls are also provided for manual operation.

The control bank and both backup groups are operated from the RTGB. Power Supply: Control Bank - 480V BUS 2B

Page 6 of 27

Revision 2

INFORMATION USE ONLY

PZR

Backup Group A - 480V BUS 1 Backup Group B - 480V BUS 2A

The capability exists to power 150 kW of PZR heaters from Emergency Bus E1 and another 150 kW of heaters from emergency bus E2. This capability would be used during a loss of offsite power event to ensure proper RCS pressure control capability is maintained. The power supply must be manually transferred to the selected emergency bus following the loss of offsite power to ensure that the PZR temperature remains above the RCS temperature. Once the power supply is transferred, the heaters are controlled from the RTGB. If the PZR heaters are being powered from one of the emergency busses, they will automatically trip upon receipt of a Safety Injection Signal, to ensure the Emergency Diesel Generators are not overloaded by these non-safety related loads. This trip feature is enabled by the PZR Heater "Arm" switch in the E1/E2 room. PZR control group heaters can also be energized from the DS bus in the event of a loss of all AC power.

3.3 PZR Spray Lines

Spray nozzle press drop at max. flow	15.0 PSI at 70°F
Continuous spray rate	1 gpm
Pipe Diameter	4 in.
Pipe Schedule	160
Design Pressure	2485 psig
Design Temperature	650°F

The PZR spray system is designed to pass a total flow of 600 gpm, 300 gpm per valve. The driving force of the spray water is a combination of the differential pressure between the hot and cold legs and the velocity head obtained by using a scoop in the reactor coolant piping.

The spray nozzle, which is also protected with a thermal sleeve, is connected to the head of the PZR. It is designed to produce a narrow angle cone spray pattern which prevents cold water impingement on the PZR walls.

The spray water is drawn from cold legs of loops B and C. The two lines tie together downstream of the control valves, form a loop seal, and supply water through a single spray nozzle. The loop seal is provided to prevent the backup of steam into the piping when the spray valves are closed. A small continuous spray flow is provided, by means of the throttle valves (needle valves) which bypass the spray valves, to help ensure that the PZR liquid is in chemical equilibrium with the rest of the reactor coolant system(RCS) and to prevent thermal shock of the spray piping and the auxiliary spray connection.

PZR

Question: 95

Given the following conditions:

- The unit is operating at 70%.
- Rod Control is in AUTO.
- Bank 'D' control rods are at 195 steps.
- Tref is 566.9 °F.
- Loop Tavgs are:

LOOP	T-AVG
'A'	569 °F
'B'	567 °F
ΥĊ'	566 °F

Which ONE (1) of the following failures will cause control rods to step inward?

- a. Loop 1 Thot fails high
- b. Loop 1 Tcold fails low
- c. Loop 2 Tcold fails high
- d. Loop 3 Thot fails low

Answer:

c. Loop 2 Tcold fails high

					RNP NR Commo	C Written Examination on Question Reference				
QUESTION I	NUMBER:	95								
TIER/GROU	P: 016K3.01	R	O 2/2	SRO	2/2					
	Knowledge o	f the effect that a lo	oss or malfu	unction of the NNIS	will have on th	e following: RCS				
K/A IMPORT 10CFR55 CC	ANCE: DNTENT:	RO 55.41(b) RO	3 .4 6	SRO 55.43(b) SRO	3.6					
OBJECTIVE	: AOP-001-02									
	EXPLAIN the	basis of selected	steps, cauti	ions, and notes in A	OP-001.					
REFERENCE	ES:	SD-007								
SOURCE:	New	X Significanth	v Modified		Direct					
			,							
JUSTIFICAT	JUSTIFICATION:		and the Alexandra		N1(T) A/	Bank NUMBER NEW				
а.		Ba	ank Numbe	ər	NEW					
	ION:	Ba Plausible if misco increase, but me	ank Numbe onception is dian Tavg is	e r that average Tavg s used which will st	NEW is used as ave ill be loop 2.	rage Tavg will				
	ION:	Ba Plausible if misco increase, but mee	ank Numbe onception is dian Tavg is	er that average Tavg s used which will st	NEW is used as ave ill be loop 2.	rage Tavg will				
b.	ION:	Ba Plausible if misco increase, but med Plausible since th Tref so no rod me	ank Numbe onception is dian Tavg is nis will caus otion will oc	er that average Tavg s used which will st se loop 3 to be the r cour.	NEW is used as ave ill be loop 2. nedian Tavg, bu	rage Tavg will ut loop 3 is below				
b.	ION:	Ba Plausible if misco increase, but med Plausible since th Tref so no rod me	ank Numbe onception is dian Tavg is nis will caus otion will oc	er that average Tavg s used which will st se loop 3 to be the r cur.	NEW is used as ave ill be loop 2. nedian Tavg, bu	rage Tavg will ut loop 3 is below				
b. c.	ION: CORRECT	Ba Plausible if misco increase, but med Plausible since th Tref so no rod mo Rod control uses Tcold fails high, b	ank Number onception is dian Tavg is nis will caus otion will oc median Ta oop 2 will b	er that average Tavg s used which will st se loop 3 to be the r cur. vg. Currently, loop ecome the high cha	NEW is used as ave ill be loop 2. nedian Tavg, bu 2 is the mediar annel and loop	rage Tavg will ut loop 3 is below n. When loop 2 1 will be the median.				
b. c.	ION: CORRECT	Ba Plausible if misco increase, but med Plausible since the Tref so no rod med Rod control uses Tcold fails high, le Loop 1 is more the	ank Number onception is dian Tavg is nis will caus otion will oc median Ta oop 2 will b nan 2 degre	er that average Tavg s used which will st te loop 3 to be the r ccur. vg. Currently, loop ecome the high cha tes above Tref, so i	NEW is used as ave ill be loop 2. nedian Tavg, bu 2 is the median annel and loop nward rod motio	rage Tavg will ut loop 3 is below n. When loop 2 1 will be the median. on will occur.				
b. c. d.	ION: CORRECT	Ba Plausible if misco increase, but med Plausible since th Tref so no rod mo Rod control uses Tcold fails high, la Loop 1 is more th Plausible if misco	ank Number onception is dian Tavg is nis will caus otion will oc median Ta oop 2 will b nan 2 degre	er that average Tavg s used which will st e loop 3 to be the r cur. vg. Currently, loop ecome the high cha es above Tref, so i	NEW is used as ave ill be loop 2. nedian Tavg, bu 2 is the median annel and loop nward rod motio is used as ave	rage Tavg will ut loop 3 is below n. When loop 2 1 will be the median. on will occur. rage Tavg will				
b. c. d.	ION: CORRECT	Ba Plausible if misco increase, but med Plausible since th Tref so no rod mo Rod control uses Tcold fails high, la Loop 1 is more th Plausible if misco increase, but med	ank Number onception is dian Tavg is nis will caus otion will oc median Ta oop 2 will b nan 2 degre onception is dian Tavg is	er that average Tavg s used which will st e loop 3 to be the r cur. vg. Currently, loop ecome the high cha es above Tref, so i that average Tavg s used which will st	NEW is used as ave ill be loop 2. nedian Tavg, bu 2 is the mediar annel and loop nward rod motio is used as ave ill be loop 2.	rage Tavg will ut loop 3 is below n. When loop 2 1 will be the median. on will occur. rage Tavg will				
b. c. d. DIFFICULTY	ION: CORRECT	Bi Plausible if misco increase, but med Plausible since th Tref so no rod mo Rod control uses Tcold fails high, la Loop 1 is more th Plausible if misco increase, but med	ank Number onception is dian Tavg is nis will caus otion will oc median Ta oop 2 will b nan 2 degre onception is dian Tavg is	er that average Tavg s used which will st te loop 3 to be the r cur. vg. Currently, loop ecome the high cha tes above Tref, so i that average Tavg s used which will st	NEW is used as ave ill be loop 2. nedian Tavg, bu 2 is the mediar annel and loop nward rod motio is used as ave ill be loop 2.	rage Tavg will ut loop 3 is below n. When loop 2 1 will be the median. on will occur. rage Tavg will				
b. c. d. DIFFICULTY Comprehen	ION: CORRECT : sive/Analysis	Bi Plausible if misco increase, but med Plausible since the Tref so no rod mo Rod control uses Tcold fails high, le Loop 1 is more the Plausible if misco increase, but med	ank Number onception is dian Tavg is nis will caus otion will caus otion will caus otion will caus otion will caus onception is dian Tavg is edge/Recau	er that average Tavg s used which will st se loop 3 to be the r cur. vg. Currently, loop ecome the high cha es above Tref, so i that average Tavg s used which will st	NEW is used as aver ill be loop 2. nedian Tavg, bu 2 is the median annel and loop nward rod motion is used as aver ill be loop 2. 3	rage Tavg will ut loop 3 is below n. When loop 2 1 will be the median. on will occur. rage Tavg will				

REFERENCES SUPPLIED:

temperature. There is a direct relationship between RCCA position and power and it is this relationship which establishes the lower insertion limit calculated by the rod insertion limit monitor. There are two alarm setpoints to alert the operator to take corrective action in the event a control group approaches or reaches its lower limit.

Any unexpected change in the position of the control group under automatic control or a change in coolant temperature under manual control provides a direct and immediate indication of a change in the reactivity status of the reactor. In addition, periodic samples of coolant boron concentration are taken. The variation in concentration during core life provides a further check on the reactivity status of the reactor core depletion.

5.5.2 Shutdown Groups Rod Control

The shutdown groups of RCCAs together with the control groups are capable of shutting the reactor down. They are used in conjunction with the adjustment of chemical shim and the control groups to provide shutdown margin of at least one percent following reactor trip with the most reactive RCCA in the fully withdrawn position for all normal operating conditions.

The shutdown groups are manually controlled during normal operation and are moved at a constant speed. Any reactor trip signal causes them to fall into the core. They are fully withdrawn during power operations and are withdrawn first during startup. Criticality is always approached with the control groups after withdrawal of the shutdown groups.

5.5.3 Manual Control Group Rod Control

Manual rod control is used during plant operation below 15% power and may be used at anytime. With the bank selector switch in the manual position, the operator can move the rods in the out or in direction using the IN-HOLD-OUT switch. The control banks will move sequentially (in overlap) as long as the IN-HOLD-OUT switch is held in any position except HOLD.

5.5.4 Reactor Control System, T_{AVG} Control (Refer to RDCNT-Figure-22 & 23)

The automatic Rod Control System maintains the average reactor coolant temperature (T_{AVG}) by adjusting the RCCA positions. The Reactor Control System, T_{AVG} Control, is provided as part of the automatic Rod Control System to develop the necessary signals to provide automatic control of the RCCAs during power operation of the reactor. The system uses input signals including neutron flux, coolant temperature and pressure, and the plant turbine load. The Chemical and Volume Control System (CVCS) supplements the Reactor Control System by the addition and removal of

RDCNT

Revision 0

varying amounts of boric acid. The ultimate goal of the automatic Rod Control System is to manipulate the control rods in order to maintain the T_{AVG} consistent with the reference temperature (T_{REF}). The automatic withdrawal portion of the Rod Control System has been defeated.

The T_{AVG} Control Unit develops rod speed and direction demand signals for the Logic Cabinet (when in AUTOMATIC control) from two error signals, the sum of which is input to the rod speed programmer which produces a speed demand signal.

The two channels used to generate the total error signal are: the deviation of the median of the three reactor coolant system average temperatures (T_{AVG}) from the programmed average temperature (T_{REF}) and the mismatch between turbine load and nuclear power.

The programmed average temperature (T_{REF}) represents the desired reactor coolant system average temperatures (T_{AVG}) based on turbine load. The selected turbine first stage pressure channel, PT-446 or PT-447, provides the turbine load input to the T_{REF} program. The output of the T_{REF} program is a linear function as follows:

- 0% load = 547° F
- 100% load = 575.4°F
- High limit = 575.4° F
- Low limit = 547° F
- 0.284°F/% load

5.5.4.1 Average Temperature Channel

The T_{AVG} channel (T_{AVG} T_{REF}) functions to provide fine control during steady state operations. When power is essentially constant, the power mismatch channel provides no input. Under this condition the summing unit just compares T_{REF} to T_{AVG} and generates a corresponding error signal. If this error signal exceeds the prescribed dead band (+ 0.5, - 2.5°F) rod direction will be determined and motion will be initiated.

5.5.4.2 T_{AVG} Channel

The T_{AVG} Median Signal Selector (MSS) receives an isolated input from each protection grade loop T_{AVG} . The MSS selects the median of the three loop T_{AVG} measurements and supplies this signal to the automatic rod control program as well as to other control systems.

5.5.4.3 Power Mismatch Channel

This channel provides fast response to a change in load (by means of the turbine load feed-forward signal) as well as control stability (by means of the nuclear power feedback signal in cases where the moderator coefficient is zero or slightly negative).

RDCNT

Page 33 of 45

Revision 0

INFORMATION USE ONLY

TAVG CONTROL BLOCK DIAGRAM

RDCNT-FIGURE-22 (Rev. 0)



INFORMATION USE ONLY