

MAR 25 1983

DISTRIBUTION:

Docket File	Gray File-2	ACRS-10
NRC PDR	DEisenhut	TBarnhart-8
L PDR	RIngram	RDiggs
ORB#4 Rdg	GGears	CMiles
	OELD	LSchneider
Dockets Nos. 50-277AEOD		DBrinkman
and 50-278LHarmon-2		ASLAB
	EJordan	

Mr. Edward G. Bauer, Jr.  
 Vice President and General Counsel  
 Philadelphia Electric Company  
 2301 Market Street  
 Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

RE: PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3

On March 1, 1983, the Commission issued Amendments Nos. 88 and 88 to Facility Operating Licenses Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station, Units 2 and 3. These amendments revised the Technical Specifications (TSs) to provide limiting conditions for operation and surveillance requirements for scram discharge volume (SDV) vent and drain valves and reactor protection system and control rod block SDV limit switches.

In issuing these amendments, we incorrectly stated the Trip Level Setting for the Scram Discharge Volume High Level in TS Table 3.2.C. for each unit. Please correct this error by replacing the existing page 73 of the TSs for each unit with the enclosed pages 73. We regret any inconvenience caused by this oversight.

Sincerely,

ORIGINAL SIGNED BY  
 JOHN F. STOLZ

John F. Stolz, Chief  
 Operating Reactors Branch #4  
 Division of Licensing

Enclosures:

1. TS page 73 for Unit 2
2. TS page 73 for Unit 3

cc w/enclosures:

See nextpage

8304010635 830325  
 PDR ADDCK 05000277  
 P PDR

OFFICE	ORB#4:DL <i>W</i>	ORB#4:DL <i>W</i>	C-ORB#4:DL <i>W</i>				
SURNAME	RIngram/cb	GGears	JStolz				
DATE	3/24/83	3/24/83	3/24/83				

Philadelphia Electric Company

cc w/enclosure(s):

Eugene J. Bradley  
Philadelphia Electric Company  
Assistant General Counsel  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.  
1747 Pennsylvania Avenue, N.W.  
Washington, D. C. 20006

Thomas A. Deming, Esq.  
Assistant Attorney General  
Department of Natural Resources  
Annapolis, Maryland 21401

Philadelphia Electric Company  
ATTN: Mr. W. T. Ullrich  
Peach Bottom Atomic  
Power Station  
Delta, Pennsylvania 17314

Albert R. Steel, Chairman  
Board of Supervisors  
Peach Bottom Township  
R. D. #1  
Delta, Pennsylvania 17314

Allen R. Blough  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Peach Bottom Atomic Power Station  
P. O. Box 399  
Delta, Pennsylvania 17314

Mr. Ronald C. Haynes, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region I  
Office of Inspection and Enforcement  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Regional Radiation Representative  
EPA Region III  
Curtis Building (Sixth Floor)  
6th and Walnut Streets  
Philadelphia, Pennsylvania 19106

M. J. Cooney, Superintendent  
Generation Division - Nuclear  
Philadelphia Electric Company  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Mr. R. A. Heiss, Coordinator  
Pennsylvania State Clearinghouse  
Governor's Office of State Planning  
and Development  
P. O. Box 1323  
Harrisburg, Pennsylvania 17120

TABLE 3.2.C  
INSTRUMENTATION THAT INITIATES CONTROL ROD BLOCKS

Minimum No. of Operable Instrument Channels Per Trip System	Instrument	Trip Level Setting	Number of Instrument Channels Provided by Design	Action
2	APRM Upscale (Flow Biased)	$\leq (0.66W + 42 - 0.66\Delta W) \times \frac{FRP}{MFLPD} \quad (2)$	6 Inst. Channels	(1)
2	APRM Upscale (Startup Mode)	$\leq 12\%$	6 Inst. Channels	(1)
2	APRM Downscale	$\geq 2.5$ indicated on scale	6 Inst. Channels	(1)
1 (7)	Rod Block Monitor (Flow Biased)	$\leq (0.66W + 41 - 0.66\Delta W) \times \frac{FRP}{MFLPD} \quad (2)$	2 Inst. Channels	(1)
1 (7)	Rod Block Monitor Downscale	$\geq 2.5$ indicated on scale	2 Inst. Channels	(1)
3	IRM Downscale (3)	$\geq 2.5$ indicated on scale	8 Inst. Channels	(1)
3	IRM Detector not in Startup Position	(8)	8 Inst. Channels	(1)
3	IRM Upscale	$\leq 108$ indicated on scale	8 Inst. Channels	(1)
2 (5)	SRM Detector not in Startup Position	(4)	4 Inst. Channels	(1)
2 (5) (6)	SRM Upscale	$\leq 10^5$ counts/sec.	4 Inst. Channels	(1)
1	Scram Discharge Volume High Level	$\leq 25$ gallons	1 Inst. Channel	(9)

Unit 2

Amendment No. 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100  
 8304010637 830325  
 PDR ADDCK 05000277  
 PDR

TABLE 3.2.C  
INSTRUMENTATION THAT INITIATES CONTROL ROD BLOCKS

Minimum No. of Operable Instrument Channels Per Trip System	Instrument	Trip Level Setting	Number of Instrument Channels Provided by Design	Action
2	APRM Upscale (Flow Biased)	$\leq (0.66W + 42 - 0.66\Delta W) \times \frac{FRP}{MFLPD} \quad (2)$	6 Inst. Channels	(1)
2	APRM Upscale (Startup Mode)	$\leq 12\%$	6 Inst. Channels	(1)
2	APRM Downscale	$\geq 2.5$ indicated on scale	6 Inst. Channels	(1)
1 (7)	Rod Block Monitor (Flow Biased)	$\leq (0.66W + 41 - 0.66\Delta W) \times \frac{FRP}{MFLPD} \quad (2)$	2 Inst. Channels	(1)
1 (7)	Rod Block Monitor Downscale	$\geq 2.5$ indicated on scale	2 Inst. Channels	(1)
3	IRM Downscale (3)	$\geq 2.5$ indicated on scale	8 Inst. Channels	(1)
3	IRM Detector not in Startup Position	(8)	8 Inst. Channels	(1)
3	IRM Upscale	$\leq 108$ indicated on scale	8 Inst. Channels	(1)
2 (5)	SRM Detector not in Startup Position	(4)	4 Inst. Channels	(1)
2 (5) (6)	SRM Upscale	$\leq 10^5$ counts/sec.	4 Inst. Channels	(1)
1	Scram Discharge Volume High Level	$\leq 25$ gallons	1 Inst. Channel	(9)