

REGULATORY DOCKET FILE COPY

SEPTEMBER 19 1980

DISTRIBUTION:

Docket file	HDenton	RTedesco	RHartfield	JHeltemes
NRC PDR	ECase	TNovak	GBennington	SECY
L PDR	DEisenhut	GLainas	I&E (3)	Gray File (2) +4
TERA-2	RPurple	RReid	BJones (4)	RDiggs
Dockets Nos. 50-277 and	NSIC	JRoe	ORB#4 PM	B Scharf (10)
50-278	ORB#4 Rdg	RIngram	ACRS (16)	Hornstein
	NRR Rdg	OELD	CMiles	E Blackwood

Mr. Edward G. Bauer, Jr.
 Vice President & General Counsel
 Philadelphia Electric Company
 2301 Market Street
 Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

The Order for Modification of License dated August 29, 1980, contained incorrect references. We have accordingly revised the Order. In view of this revision, the date for which a hearing may be requested is also accordingly revised.

Sincerely,

Original signed by
 Darrell G. Eisenhut, Director
 Division of Licensing

Enclosure:
 Revised Order

cc w/enclosure:
 See next page

8010270 307

Mi 9/16/80

CP 3

OFFICE	ORB#4:DL 9/16/80	C-ORB#4:DL R Reid 9/16/80	ORB#2:DL M Williams 9/16/80	OELD 9/19/80	D:DL DE Eisenhut 9/19/80
SURNAME					
DATE					



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 19, 1980

Dockets Nos. 50-277 and
50-278

Mr. Edward G. Bauer, Jr.
Vice President & General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

The Order for Modification of License dated August 29, 1980, contained incorrect references. We have accordingly revised the Order. In view of this revision, the date for which a hearing may be requested is also accordingly revised.

Sincerely,

A handwritten signature in cursive script, appearing to read "Darrell G. Eisenhut".

Darrell G. Eisenhut, Director
Division of Licensing

Enclosure:
Revised Order

cc w/enclosure:
See next page

Mr. Edward G. Bauer, Jr.
Philadelphia Electric Company

cc:

Eugene J. Bradley
Philadelphia Electric Company
Assistant General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Raymond L. Hovis, Esquire
35 South Duke Street
York, Pennsylvania 17401

Warren K. Rich, Esquire
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Philadelphia Electric Company
ATTN: Mr. W. T. Ullrich
Peach Bottom Atomic
Power Station
Delta, Pennsylvania 17314

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
P. O. Box 1323
Harrisburg, Pennsylvania 17120

Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

Curt Cowgill
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Peach Bottom Atomic Power Station
P. O. Box 399
Delta, Pennsylvania 17314

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
US EPA
Crystal Mall #2
Arlington, Virginia 20460

Region III Office
ATTN: EIS COORDINATOR
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

M. J. Cooney, Superintendent
Generation Division - Nuclear
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Government Publications Section
State Library of Pennsylvania
Education Building
Commonwealth and Walnut Streets
Harrisburg, Pennsylvania 17126

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of
PHILADELPHIA ELECTRIC COMPANY, ET AL }
(Peach Bottom Atomic Power Station, }
Units Nos. 2 and 3) }

Dockets Nos. 50-277
and 50-278

REVISED ORDER FOR MODIFICATION OF LICENSE

I.

Philadelphia Electric Company (licensee) and three other co-owners are the holders of Facility Operating Licenses Nos. DPR-44 and DPR-56, which authorize the operation of the Peach Bottom Atomic Power Station, Units Nos. 2 and 3, at steady state reactor power levels not in excess of 3293 megawatts thermal (rated power) for each unit. The facilities consist of boiling water reactors located at the licensee's site in Peach Bottom, York County, Pennsylvania.

II.

On November 4, 1977, the Union of Concerned Scientists (UCS) filed with the Commission a "Petition for Emergency and Remedial Relief." The petition sought action in two areas: fire protection for electrical cables, and environmental qualification of electrical components. By Memorandum and Order dated April 13, 1978 (7 NRC 400), the Commission denied certain aspects of the petition and, with respect to other aspects, ordered the NRC staff to take several related actions. UCS filed a Petition for Reconsideration on May 2, 1978. By Memorandum and Order, dated May 23, 1980, the Commission reaffirmed its April 13, 1978 decision

regarding the possible shutdown of operating reactors. However, the Commission's May 23, 1980 decision directed licensees and the NRC staff to undertake certain actions.

With respect to environmental qualification of safety-related electrical equipment, the Commission determined that the provisions of the two staff documents - the Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class 1E Electrical Equipment in Operating Reactors" (DOR Guidelines) and NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979 "form the requirements which licensees and applicants must meet in order to satisfy those aspects of 10 CFR Part 50, Appendix A General Design Criterion (GDC-4), which relate to environmental qualification of safety-related electrical equipment." The Commission directed, for replacement parts in operating plants, "unless there are sound reasons to the contrary, the 1974 standard in NUREG-0588 will apply." The Commission also directed the staff to complete its review of the information sought from licensees by Bulletin 79-01B¹ and to complete its review of environmental qualification of safety-related electrical equipment in all operating plants, including the publication of Safety Evaluation Reports, by February 1, 1981. The Commission

¹ Bulletin 79-01B was not sent to licensees for plants under review as part of the staff's Systematic Evaluation Program. The information sought by Bulletin 79-01B was requested from these licensees by a series of letters and meetings during the months of February and March, 1980.

imposed a deadline that, "by no later than June 30, 1982 all safety-related electrical equipment in all operating plants shall be qualified to the DOR Guidelines or NUREG-0588." The Commission requested the staff to, "keep the Commission and the public apprised of any further findings of incomplete environmental qualification of safety-related electrical equipment, along with corrective actions taken or planned," and requested the staff to provide bi-monthly progress reports to the Commission.

The Commission further directed the staff to add certain documentation requirements to each license after the specific requirements were approved by the Commission. The Commission also pointed out that the various deadlines imposed in its Order, "do not excuse a licensee from the obligation to modify or replace inadequate equipment promptly."

III.

The information developed during this proceeding emphasizes the importance of adequate documentation, the prompt completion of the review of environmental qualification of safety-related electrical equipment, and the prompt completion of any plant modification needed to assure conformance with the DOR Guidelines or NUREG-0588. A significant aspect of this review is the timely submittal of environmental qualification information by the operating plant licensees to enable the staff to complete its review in accordance with the Commission's Order. The staff has a program presently underway to reevaluate, using the DOR Guidelines and NUREG-0588, the qualifications of safety-related electrical equipment exposed

to environments that may exist following postulated accidents. These accidents are Loss of Coolant Accident and Main Steam Line Break inside containment, and High Energy Line Breaks inside and outside containment.

In this connection the licensee was requested by I&E Bulletin 79-01B of January 14, 1980 to provide a detailed review of the environmental qualification of Class 1E electrical equipment. This review was to include all equipment required to function under postulated accident conditions, both inside and outside the primary containment, and recognize all conditions specified in the bulletin. Evidence of qualification together with methods and justification, was requested.

Clarification was provided by supplemental information, briefings, and in some cases, meetings with the licensee. Timely completion of the staff's review of environmental qualification of electrical equipment and timely completion of needed modifications by the licensee is required to provide continuing reasonable assurance of public health and safety. Such completion is dependent on the prompt receipt of a complete response by the licensee to the staff's requests for information. However, the licensee's response, to date, is incomplete.

Therefore, I have concluded that the public health, safety, and interest require that a firm schedule for the timely submission of all the information previously requested by the staff should be established by Order effective immediately.

IV.

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS ORDERED THAT EFFECTIVE IMMEDIATELY Facility Operating Licenses Nos. DPR-44 and DPR-56 are hereby amended to add the following provisions:


"Information which fully and completely responds to the staff's request as specified in I & E Bulletin 79-01B, shall be submitted to the Director, Region I, Office of Inspection and Enforcement, by the licensee not later than November 1, 1980."

An earlier response is encouraged to facilitate staff review and issuance of the safety evaluation report. The licensee or any person whose interest may be affected by this Order may request a hearing within 20 days of the date of publication of this Revised Order in the Federal Register. Any request for a hearing will not stay the effective date of this Order. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy of the request should also be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to Troy B. Conner, Jr., 1747 Pennsylvania Avenue, NW, Washington, DC 20006, attorney for the licensee.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether the licenses should be modified to require submission of information as set forth in Section IV. of the Order.

Operating of the facilities on terms consistent with this Order is not stayed by the pendency of any proceedings on the Order. This Order revises, in its entirety, the Order issued August 29, 1980, and published in the Federal Register September 11, 1980, (45 FR 60063).

FOR THE NUCLEAR REGULATORY COMMISSION


Darrell G. Eisselhut, Director
Division of Licensing

Effective Date: September 19, 1980
Bethesda, Maryland