

From: Glenn Kelly, *NRA*
To: Diane Jackson, Frank Akstulewicz, Joseph Stauden...
Date: Tuesday, July 11, 2000 09:07 AM
Subject: Re: SFP accident timing and probability table

The heading of the box should be "frequency", not "probability."

Use the following annual frequencies:

slow w/ off-site = $4.4E-8$

slow w/o off-site = $1.4E-7$

fast seismic = $< 4.5E-6$

fast load drop = $2.0E-7$

CC: George Hubbard

4/200