

Kewaunee Nuclear Power Plant N490, State Highway 42 Kewaunee, WI 54216-9511 920-388-2560



Operated by Nuclear Management Company, LLC

May 4, 2001

Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Ladies/Gentlemen:

DOCKET 50-305
OPERATING LICENSE DPR-43
KEWAUNEE NUCLEAR POWER PLANT
PROPOSED TECHNICAL SPECIFICATION AMENDMENT 165a PRA CORRECTION

Reference:

Letter From Mark E. Reddemann (NMC) To US NRC Document Control Desk, Proposed Amendment 165a to the Kewaunee Nuclear Power Plant Technical Specifications, Containment Isolation Devices, dated March 7, 2001.

In the referenced letter, Nuclear Management Company, LLC, (NMC) submitted proposed amendment (PA) 165a to the Kewaunee Nuclear Power Plant (KNPP) Technical Specifications (TS). This PA was submitted to revise TS section 3.6, "Containment," to add Limiting Condition for Operation (LCO) and Allowed Outage Times (AOT) for containment isolation devices.

During discussions with the NRC Staff, an error was uncovered in the value listed for the combined internal and external events Large Early Release Frequency (LERF). The total internal and external events LERF was given on Page 6 of Attachment 1, of the referenced letter, as  $7.2 \times 10^{-7}$ /year. The correct figure is  $7.6 \times 10^{-6}$ /year. This includes  $2.0 \times 10^{-6}$ /year for internal events and  $5.6 \times 10^{-6}$ /year for external events. This value remains below the Regulatory Guide 1.174 limit.

Please contact Mr. Ed Coen at (920) 388-8765 or Mr. Jerry Riste at (920) 388-8424, if you have any questions or require additional information.

Sincerely,

Kyle A. Hoops

Manager - Kewaunee Plant

GOR

cc - US NRC Region III

US NRC Senior Resident Inspector

40D) 1/D