



May 9, 2001

C0501-07
10 CFR 50.90

Docket No.: 50-316

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop O-P1-17
Washington, DC 20555-0001

Donald C. Cook Nuclear Plant Unit 2
SUPPLEMENT TO LICENSE AMENDMENT REQUEST
EXTENSION OF EMERGENCY DIESEL GENERATOR ENGINE
AND BATTERY SURVEILLANCE REQUIREMENTS
(TAC No. MB1082)

Reference: Letter from R. P. Powers, Indiana Michigan Power Company, to U. S. Nuclear Regulatory Commission (NRC) Document Control Desk, "License Amendment Request Extension of Emergency Diesel Generator Engine and Battery Surveillance Requirements," C0101-06, dated January 19, 2001.

This letter provides a supplement to Indiana Michigan Power Company's (I&M) request for a license amendment submitted by the referenced letter. In a telephone discussion with the members of the Nuclear Regulatory Commission staff on April 25, 2001, I&M committed to designate Cell #2 in Battery 2AB as a pilot cell during the weekly performance of Technical Specification (T/S) surveillance 4.8.2.3.2.a. I&M also committed to decrease the interval for T/S surveillance requirement 4.8.2.3.2.b for Batteries 2AB, 2CD and 4.8.2.5.2.b for 2N from quarterly to monthly. These commitments will be in effect during the extension period from June 27, 2001, until refueling outage 13, but no later than December 31, 2001. The attachment to this letter provides a listing of the commitments.

Additionally, I&M is revising the license condition proposed in the referenced letter to more accurately reflect the requested change. The proposed license condition would read:

A001

"The station battery service testing Technical Specification surveillance requirements 4.8.2.3.2.d and 4.8.2.5.2.d have been extended to allow them to be performed during the refueling outage 13, but no later than December 31, 2001."

Should you have any questions, please contact Mr. Ronald W. Gaston, Manager of Regulatory Affairs, at (616) 697-5020.

Sincerely,

A handwritten signature in dark ink, appearing to read 'S. A. Greenlee', with a long horizontal flourish extending to the right.

S. A. Greenlee
Director of Design Engineering and Regulatory Affairs

/dmb

Attachment

c: J. E. Dyer
MDEQ - DW & RPD, w/o attachment
NRC Resident Inspector
R. Whale, w/o attachment

ATTACHMENT TO C0501-07

COMMITMENTS

The following table identifies those actions committed to by Indiana Michigan Power Company (I&M) in this document. Any other actions discussed in this submittal represent intended or planned actions by I&M. They are described to the Nuclear Regulatory Commission (NRC) for the NRC's information and are not regulatory commitments.

| Commitment | Date |
|---|--|
| Battery 2AB, Cell #2 will be designated as a pilot cell during the performance of weekly surveillance tests in accordance with Unit 2 Technical Specification (T/S) surveillance requirement 4.8.2.3.2.a. | From June 27, 2001, until refueling outage 13 but no later than December 31, 2001. |
| Unit 2 T/S surveillance requirement 4.8.2.3.2.b for Batteries 2AB, 2CD and 4.8.2.5.2.b for 2N will be decreased from quarterly to monthly. | From June 27, 2001, until refueling outage 13 but no later than December 31, 2001. |