Lewis Sumner Vice President Hatch Project Support Southern Nuclear Operating Company, Inc. 40 Inverness Parkway Post Office Box 1295 Birmingham, Alabama 35201

Tel 205.992.7279 Fax 205.992.0341



May 4, 2001

Docket Nos. 50-321 50-366

HL-6081

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D. C. 20555

Edwin I. Hatch Nuclear Plant Monthly Operating Reports

Ladies and Gentlemen:

Enclosed are the April 2001 Monthly Operating Reports for Edwin I. Hatch Nuclear Plant Unit 1, Docket No. 50-321, and Unit 2, Docket No. 50-366. These reports are submitted in accordance with Technical Specifications 5.6.4.

Respectfully submitted,

eins Summer

H. L. Sumner, Jr.

IFL/eb

Enclosures:

- 1. April Monthly Operating Report for Plant Hatch Unit 1
- 2. April Monthly Operating Report for Plant Hatch Unit 2
- cc: <u>Southern Nuclear Operating Company</u> Mr. P. H. Wells, Nuclear Plant General Manager SNC Document Management (R-Type A02.001)

<u>U. S. Nuclear Regulatory Commission, Washington D. C.</u> Mr. L. N. Olshan, Project Manager - Hatch

U. S. Nuclear Regulatory Commission, Region II Mr. L. A. Reyes, Regional Administrator Mr. J. T. Munday, Senior Resident Inspector - Hatch

<u>Utility Data Institute, Inc.</u> Ms. Barbara Lewis - McGraw-Hill Companies

FERM

Enclosure 1

7

Plant Hatch Unit 1 Monthly Operating Report <u>April 2001</u>

Table of Contents

	Page
Operating Data Report	E1-1
Unit Shutdowns and Power Reductions	E1-2

OPERATING DATA REPORT

Docket No.:	50-321
Unit Name:	E. I. Hatch Unit 1
Date:	May 2, 2001
Completed By:	S. B. Rogers
Telephone:	(912) 367-7781 x2878

Operating Status

APRIL 2001 864.6 863		
This Month	<u>Year To Date</u>	Cumulative
719.0	2,828.1	176,633.4
719.0	2,808.5	170,812.6
0.0	0.0	0.0
613,084	2,407,635	122,815,598
	APRIL 2001 864.6 863 This Month 719.0 719.0 0.0 613,084	APRIL 2001 864.6 863 This Month Year To Date 719.0 2,828.1 719.0 2,808.5 0.0 0.0 613,084 2,407,635

CHALLENGES TO MAIN STEAM SAFETY / RELIEF VALVES

Date	Tag No.	Event Description
		No challenges this month.

UNIT SHUTDOWNS

Docket No.:	50-321
Unit Name:	E. I. Hatch Unit 1
Date:	May 2, 2001
Completed By:	S. B. Rogers
Telephone:	(912) 367-7781 x2878

Reporting Period: APRIL 2001

	_	Type F: Forced	Duration		Method of Shutting	Cause/Corrective Actions
No.	Date	S: Scheduled	(Hours)	Reason (1)	Down (2)	Comments
						No unit shutdowns occurred this month.

(1) Reason:

A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training/License Examination F-Administrative G-Operational Error (Explain) H-Other (Explain)

(2) METHOD

1-Manual 2-Manual Trip/Scram 3-Automatic Trip/Scram 4-Continuation 5-Other (Explain)

CAUSE/CORRECTIVE ACTION/COMMENTS:

NARRATIVE REPORT

Unit 1 began the month of April at approximately 24% of rated thermal power with surveillance testing in progress. Shift removed the "A" 5th Stage Feedwater Heater from service while at reduced load to repair a steam leak. Shift began power ascension following repair of the heater and the unit attained approximately 810 GMWe (~2485 CMWT) on 4/1/01. Shift reduced load to approximately 725 GMWe (~2210 CMWT), later on 4/1/01, due to a decrease in main condenser vacuum. Shift returned the unit to rated thermal power on 4/2/01. Shift reduced load to approximately 730 GMWe (~2210 CMWT) later that day for a rod pattern adjustment and returned the unit to rated thermal power on 4/3/01. Shift reduced load to approximately 890 GMWe (~2705 CMWT) on 4/7/01 to perform turbine stop valve testing. The unit was returned to rated thermal power later the same day. Shift reduced load to approximately 850 GMWe (~2630 CMWT) on 4/24/01 to remove the "B" Cooling Tower from service to facilitate repair of structural damage. Shift began a slow power ascension with the "B" Cooling Tower out of service. The power ascension was halted at approximately 865 GMWe (~2680 CMWT) on 4/24/01 due to condensate system parameters. Shift returned the unit to rated thermal power on 4/25/01. Shift maintained the unit to rated thermal power on 4/24/01 due to condensate system parameters. Shift returned the unit to rated thermal power on 4/25/01. Shift maintained the unit at rated thermal power, with the "B" Cooling Tower out of service, for the remainder of the month.

Enclosure 2

Plant Hatch Unit 2 Monthly Operating Report <u>April 2001</u>

Table of Contents

	Page
Operating Data Report	E2-1
Unit Shutdowns and Power Reductions	E2-2

OPERATING DATA REPORT

Docket No.:	50-366
Unit Name:	E. I. Hatch Unit 2
Date:	May 2, 2001
Completed By:	S. B. Rogers
Telephone:	(912) 367-7781 x2878

Operating Status

 Reporting Period: Design Electrical Rating (Net MWe): Maximum Dependable Capacity (Net MWe): 	APRIL 2001 859 878		
	This Month	Year To Date	Cumulative
4. Number of Hours Reactor Was Critical:	719.0	2,879.0	153,310.8
5. Hours Generator On Line:	719.0	2,879.0	149,035.8
6. Unit Reserve Shutdown Hours:	0.0	0.0	0.0
7. Net Electrical Energy Generated:	615,842	2,520,485	109,130,567

CHALLENGES TO MAIN STEAM SAFETY / RELIEF VALVES

Date	Tag No.	Event Description
		No challenges this month.

UNIT SHUTDOWNS

Docket No.:	50-366
Unit Name:	E. I. Hatch Unit 2
Date:	May 2, 2001
Completed By:	S. B. Rogers
Telephone:	(912) 367-7781 x2878

Reporting Period: APRIL 2001

		Type F: Forced	Duration		Method of Shutting	Cause/Corrective Actions
No.	Date	S: Scheduled	(Hours)	Reason (1)	Down (2)	Comments
						No unit shutdowns occurred this month.

(1) Reason:

A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training/License Examination F-Administrative G-Operational Error (Explain) H-Other (Explain)

(2) METHOD

1-Manual 2-Manual Trip/Scram 3-Automatic Trip/Scram 4-Continuation 5-Other (Explain)

CAUSE/CORRECTIVE ACTION/COMMENTS:

NARRATIVE REPORT

Unit 2 began the month of April operating at rated thermal power with the "A" 7th Stage Feedwater on high level control. Shift installed a temporary modification on 4/2/01 to route the "A" 7th Stage Feedwater Heater normal drain to the "A" 10th Stage Feedwater Heater. Shift began reducing load to approximately 665 GMWe (~2070 CMWT) on 4/27/01 to perform a control rod sequence exchange and scram time testing. Shift further reduced load to approximately 440 GMWe (~1380 CMWT) on 4/28/01 to perform inspection and maintenance activities in the Condenser Bay. Turbine control valve testing was also performed while at reduced load. The unit was returned to rated thermal power on 4/29/01. Shift reduced load to approximately 840 GMWe (~2485 CMWT) on 4/30/01 to perform a rod pattern adjustment. Ascension to rated thermal was in progress at the close of April with the unit at approximately 895 GMWe (~2665 CMWT).