



RECEIVED
REGION 1

01 MAY -8 -9 :13

May 4, 2001

Mr. Paul Bissett
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Paul,

Please consider the following two items. Both questions are valid, but I believe the answer key is incorrect.

Question 1 (RO)

This question is essentially identical to Question 29 on the SRO exam. The only difference is distracters a & c are swapped. The correct answer is to *Restore 34 RCP to operation OR be in MODE 3 within 6 hours*. On the SRO exam this is distracter a on the RO exam it is distracter c. The RO answer key identified a as the correct answer when c is the correct answer.

Question 82 (RO)

AP-10.1

The answer key for this question identifies distracter a as the correct answer. A review of AP-10.1 clearly identifies d as the only correct answer.

4.7.3.5 IF a Test & Maintenance tag is applied to a component, THEN no other tag may be hung on that component. (Pg 23)

4.7.2.4 Use of Hold and Cautions Tags on the same component is permissible. (Pg 22)

If you have any questions or require additional clarification, please let me know.

Thank you,

Frank R. Wilson
Operations Training Supervisor
Indian Point 3
914-788-2904