

**From:** Glenn Kelly, *NRR*  
**To:** Diane Jackson, George Hubbard, Mark Rubin, Tany...  
**Date:** Thursday, July 27, 2000 01:43 PM  
**Subject:** Re: DLPM Public Comment #15

We have an SDA that calls for the licensee to have a setpoint (e.g., 15 feet below the normal water level) at which they will automatically call in off-site help to reflood the spent fuel pool. We are also thinking about the need to have a setpoint about 3-5 feet above the fuel at which to declare a general emergency. We would need some sort of direct indication to be able to have these.

*L/236*