

From: Glenn Kelly, *NRR*
To: Diane Jackson, George Hubbard, Mark Rubin, Tany...
Date: Thursday, July 27, 2000 01:43 PM
Subject: Re: DLPM Public Comment #15

We have an SDA that calls for the licensee to have a setpoint (e.g., 15 feet below the normal water level) at which they will automatically call in off-site help to reflood the spent fuel pool. We are also thinking about the need to have a setpoint about 3-5 feet above the fuel at which to declare a general emergency. We would need some sort of direct indication to be able to have these.

L/236