



Britt T. McKinney
Vice President Plant Operations and
Plant Manager

MAY 10 2001

WO 01-0015

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: April, 2001, Monthly Operating Report

Gentlemen:

Attached to this letter is the April, 2001, Monthly Operating Report for the Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Wolf Creek Generating Station Technical Specification 5.6.4, "Monthly Operating Reports." This submittal also follows the guidance of Generic Letter 97-02, "Revised Contents of the Monthly Operating Report." If you have questions regarding this report, please contact me at (620) 364-4112, or Mr. Tony Harris at (620) 364-4038.

Very truly yours,

A handwritten signature in black ink that reads "Britt T. McKinney". The signature is stylized with a large, sweeping "B" and a long, trailing flourish at the end.

Britt T. McKinney

BTM/rir

Attachment

cc: J. N. Donohew (NRC), w/a
W. D. Johnson (NRC), w/a
E. W. Merschoff (NRC), w/a
Senior Resident Inspector (NRC), w/a

IE24

OPERATING DATA REPORT

Report Number: 194

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: May 5, 2001
COMPLETED BY: K. W. Hall
TELEPHONE: 620-364-4272

REPORT MONTH: April, 2001

1.	Design Electrical Rating (MWe - Net):	1170
2.	Maximum Dependable Capacity (MWe - Net):	1170

		This Month	Year to Date	Cumulative
3.	Number of Hours Reactor Critical:	719.0	2,879.0	116,483.7
4.	Number of Hours Generator On-Line:	719.0	2,850.8	115,369.2
5.	Unit Reserve Shutdown Hours:	0.0	0.0	339.8
6.	Net Electrical Energy Generated (MWH)	855,348	3,380,425	130,070,770

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: May 5, 2001
COMPLETED BY: K. W. Hall
TELEPHONE: 620-364-4272

No.	Date	Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

SUMMARY: The unit operated at approximately 100% power April 1, 2001, through April 30, 2001.

(1) REASON: A: EQUIPMENT FAILURE (EXPLAIN)
 B: MAINTENANCE OR TEST
 C: REFUELING
 D: REGULATORY RESTRICTION

E: OPERATOR TRAINING AND LICENSE EXAMINATION
 F: ADMINISTRATIVE
 G: OPERATIONAL ERROR (EXPLAIN)
 H: OTHER (EXPLAIN)

(2) METHOD: 1. MANUAL
 2. MANUAL SCRAM
 3. AUTOMATIC SCRAM
 4. CONTINUATION
 5. OTHER