March 18, 1985

DO NOT REMOVE

LICENSE AUTHORITY FILE COPY

Posted Correction to Amdt. 102 to DPR-44

Dockets Nos. 50-277
and 50-278

DISTRIBUTION
Docket File
NRC PDR
L PDR
ORB#4 Rdg
HThompson
OELD
EJordan
BGrimes
JPartlow
ACRS-10
RIngram
GGears
Gray File
CMiles
LHarmon
WJones
EButcher
RDiggs
TBarnhart-8

Mr. Edward G. Bauer, Jr.
Vice President and General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

On August 3, 1984, the Commission issued Amendments Nos. 102 and 104 to Facility Operating Licenses Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station, Units Nos. 2 and 3. These amendments authorized changes involving the Radiological Effluent Technical Specifications (RETS). These TSs became effective December 31, 1984.

Subsequent to the issuance of Amendments Nos. 102/104, the Commission issued other amendments to these licenses which impact some of the TS pages issued with Amendments Nos. 102/104. Therefore, to reflect the currently approved operating licenses, we have enclosed updated TS pages ii, iii, vi, vii and 84 for Unit 2 and pages ii, iii, iv, vi, vii and 84 for Unit 3. Please replace the appropriate Appendix A TS pages for each Unit with these updated pages as indicated.

In addition, TS page 207 for Unit 2 was missing from our copies of Amendment No. 102 and may also have been missing from your copy. To assure that all copies are consistent, we are reissuing this page.

Sincerely,

"ORIGINAL SIGNED BY"
Gerald E. Gears, Project Manager
Operating Reactors Branch #4
Division of Licensing

Enclosures:
Updated TS pages

cc w/enclosures:
See next page

ORB#4:DL
RIngram;cf
3/18/85

ORB#4:DL
GGears
3/19/85

Philadelphia Electric Company

cc w/enclosure(s):

Eugene J. Bradley
Philadelphia Electric Company
Assistant General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.
1747 Pennsylvania Avenue, N.W.
Washington, D. C. 20006

Regional Radiation Representative
EPA Region III
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

M. J. Cooney, Superintendent
Generation Division - Nuclear
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Thomas A. Deming, Esq.
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Philadelphia Electric Company
ATTN: Mr. R. Fleishmann
Peach Bottom Atomic
Power Station
Delta, Pennsylvania 17314

Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
P. O. Box 1323
Harrisburg, Pennsylvania 17120

Thomas Johnson
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Peach Bottom Atomic Power Station
P. O. Box 399
Delta, Pennsylvania 17314

Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P. O. Box 2063
Harrisburg, Pennsylvania 17120

Mr. Thomas E. Murley, Regional Administrator
U. S. Nuclear Regulatory Commission, Region I
Office of Inspection and Enforcement
631 Park Avenue
King of Prussia, Pennsylvania 19406

UPDATED TECHNICAL SPECIFICATION PAGES

FACILITY OPERATING LICENSE NO. DPR-44

DOCKET NO. 50-277

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed updated pages.

Remove	Insert
ii	ii
iii	iii
vi	vi
via	--
vii	vii
84	84
207	207

TABLE OF CONTENTS (Cont'd)

LIMITING CONDITIONS FOR OPERATION	SURVEILLANCE REQUIREMENT	Page
3.6 PRIMARY SYSTEM BOUNDARY	4.6	143
A. Thermal and Pressurization Limitations	A	143
B. Coolant Chemistry	B	145
C. Coolant Leakage	C	146
D. Safety and Relief Valves	D	147
E. Jet Pumps	E	148
F. Jet Pump Flow Mismatch	F	148
G. Structural Integrity	G	149
3.7 CONTAINMENT SYSTEMS	4.7	165
A. Primary Containment	A	165
B. Standby Gas Treatment System	B	175
C. Secondary Containment	C	176
D. Primary Containment Isolation Valves	D	177
3.8 RADIOACTIVE MATERIALS	4.8	203
A. General	A	203
B. Liquid Effluents	B	204
C. Gaseous Effluents	C	208
D. 40CFR190	D	216
E. Radiological Environmental Monitoring	E	216a-2
F. Solid Radioactive Waste	F	216a-5
G. Mechanical Vacuum Pump	G	216a-6
3.9 AUXILIARY ELECTRICAL SYSTEMS	4.9.	217
A. Auxiliary Electrical Equipment	A	217
B. Operation with Inoperable Equipment	B	219
C. Emergency Service Water System	C	221
3.10 CORE	4.10	225
A. Refueling Interlocks	A	225
B. Core Monitoring	B	227
C. Spent Fuel Pool Water Level	C	228
D. Heavy Loads Over Spent Fuel	D	228
E. Spent Fuel Decay Time	E	228
3.11 ADDITIONAL SAFETY RELATED PLANT CAPABILITIES	4.11	233
A. Main Control Room Ventilation	A	233
B. Alternate Heat Sink Facility	B	234
C. Emergency Shutdown Control Panel	C	234

Amendment No. 17, 49, 102

TABLE OF CONTENTS (Cont'd)

LIMITING CONDITIONS FOR OPERATION	SURVEILLANCE REQUIREMENT	Page
3.12 RIVER LEVEL	4.12	237
A. High River Water Level	A	237
B. Low River Water Level	B	237
C. Level Instrumentation	C	238
3.13 MISCELLANEOUS RADIOACTIVE MATERIALS SOURCE	4.13	240a
3.14 FIRE PROTECTION	4.14	240c
A. Water Fire Protection System	A	240c
B. CO2 Fire Protection System	B	240g
C. Fire Detection	C	240i
D. Fire Barrier Penetrations	D	240j
3.15 SEISMIC MONITORING INSTRUMENTATION	4.15	240n
5.0 MAJOR DESIGN FEATURES		241
6.0 ADMINISTRATIVE CONTROLS		243
6.1 Responsibility		243
6.2 Organization		243
6.3 Facility Staff Qualifications		246
6.4 Training		246
6.5 Review and Audit		246
6.6 Reportable Occurrence Action		253
6.7 Safety Limit Violation		253
6.8 Procedures		253
6.9 Reporting Requirements		254
6.10 Record Retention		260
6.11 Radiation Protection Program		261
6.12 Fire Protection Inspections		261
6.13 High Radiation Area		262
6.14 Integrity of Systems Outside Containment		263
6.15 Iodine Monitoring		264
6.16 Environmental Qualification		264
6.17 Offsite Dose Calculation Manual		265
6.18 Major Changes to Radioactive Waste Treatment Systems		265

LIST OF TABLES

Table	Title	Page
4.2.B	Minimum Test and Calibration Frequency for CSCS	81
4.2.C	Minimum Test and Calibration Frequency for Control Rod Blocks Actuation	83
4.2.D	Minimum Test and Calibration Frequency for Radiation Monitoring Systems	84
4.2.E	Minimum Test and Calibration Frequency for Drywell Leak Detection	85
4.2.F	Minimum Test and Calibration Frequency for Surveillance Instrumentation	86
4.2.G	Minimum Test and Calibration Frequency for Recirculation Pump Trip	88
3.5.K.2	Operating Limit MCPR Values for Various Core Exposures	133d
3.5.K.3	Operating Limit MCPR Values for Various Core Exposures	133e
4.6.1	In-Service Inspection Program for Peach Bottom Units 2 and 3	150
3.7.1	Primary Containment Isolation Valves	179
3.7.2	Testable Penetrations With Double O-Ring Seals	184
3.7.3	Testable Penetrations with Testable Bellows	184
3.7.4	Primary Containment Testable Isolation Valves	185
4.8.1	Radioactive Liquid Waste Sampling and Analysis	216b-1
4.8.2	Radioactive Gaseous Waste Sampling and Analysis	216c-1
4.8.3.a	Radiological Environmental Monitoring Program	216d-1
4.8.3.b	Reporting Levels for Radioactivity by Concentrations in Environmental Sample	216d-5

LIST OF TABLES

Table	Title	Page
4.8.3.c	Maximum Values for Minimum Detectable Levels of Activity	216d-6
3.11.D.1	Safety Related Shock Suppressors	234d
3.14.C.1	Fire Detectors	240k

TABLE 4.2.D

MINIMUM TEST & CALIBRATION FREQUENCY FOR RADIATION MONITORING SYSTEMS

Instrument Channels	Instrument Functional Test	Calibration	Instrument Check (2)
1) Refuel Area Exhaust Monitors - Upscale	(1)	Once/3 months	Once/day
2) Reactor Building Area	(1)	Once/3 months	Once/day

Logic System Functional Test (4) (6)	Frequency
1) Reactor Building Isolation	Once/6 months
2) Standby Gas Treatment System Actuation	Once/6 months

UPDATED TECHNICAL SPECIFICATION PAGES

FACILITY OPERATING LICENSE NO. DPR-56

DOCKET NO. 50-278

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed updated pages.

Remove	Insert
ii	ii
iii	iii
iv	iv
vi	vi
via	--
vii	vii
84	84

TABLE OF CONTENTS (Cont'd)

LIMITING CONDITIONS FOR OPERATION	SURVEILLANCE REQUIREMENT	Page
3.6 PRIMARY SYSTEM BOUNDARY	4.6	143
A. Thermal and Pressurization Limitations	A	143
B. Coolant Chemistry	B	145
C. Coolant Leakage	C	146
D. Safety and Relief Valves	D	147
E. Jet Pumps	E	148
F. Jet Pump Flow Mismatch	F	148
G. Structural Integrity	G	149
3.7 CONTAINMENT SYSTEMS	4.7	165
A. Primary Containment	A	165
B. Standby Gas Treatment System	B	175
C. Secondary Containment	C	176
D. Primary Containment Isolation Valves	D	177
3.8 RADIOACTIVE MATERIALS	4.8	203
A. General	A	203
B. Liquid Effluents	B	204
C. Gaseous Effluents	C	208
D. 40CFR190	D	216
E. Radiological Environmental Monitoring	E	216a-2
F. Solid Radioactive Waste	F	216a-5
G. Mechanical Vacuum Pump	G	216a-6
3.9 AUXILIARY ELECTRICAL SYSTEMS	4.9	217
A. Auxiliary Electrical Equipment	A	217
B. Operation with Inoperable Equipment	B	219
C. Emergency Service Water System	C	221
3.10 CORE	4.10	225
A. Refueling Interlocks	A	225
B. Core Monitoring	B	227
C. Spent Fuel Pool Water Level	C	228
D. Heavy Loads Over Spent Fuel	D	228
E. Spent Fuel Decay Time	E	228
3.11 ADDITIONAL SAFETY RELATED PLANT CAPABILITIES	4.11	233
A. Main Control Room Ventilation	A	233
B. Alternate Heat Sink Facility	B	234
C. Emergency Shutdown Control Panel	C	234

Amendment No. 78, 88, 104

TABLE OF CONTENTS (Cont'd)

LIMITING CONDITIONS FOR OPERATION	SURVEILLANCE REQUIREMENT	Page
3.12 RIVER LEVEL	4.12	237
A. High River Water Level	A	237
B. Low River Water Level	B	237
C. Level Instrumentation	C	238
3.13 MISCELLANEOUS RADIOACTIVE MATERIALS SOURCE	4.13	240a
3.14 FIRE PROTECTION	4.14	240c
A. Water Fire Protection System	A	240c
B. CO2 Fire Protection System	B	240g
C. Fire Detection	C	240i
D. Fire Barrier Penetrations	D	240j
3.15 SEISMIC MONITORING INSTRUMENTATION	4.15	240n
5.0 MAJOR DESIGN FEATURES		241
6.0 ADMINISTRATIVE CONTROLS		243
6.1 Responsibility		243
6.2 Organization		243
6.3 Facility Staff Qualifications		246
6.4 Training		246
6.5 Review and Audit		246
6.6 Reportable Occurrence Action		253
6.7 Safety Limit Violation		253
6.8 Procedures		253
6.9 Reporting Requirements		254
6.10 Record Retention		260
6.11 Radiation Protection Program		261
6.12 Fire Protection Inspections		261
6.13 High Radiation Area		262
6.14 Integrity of Systems Outside Containment		263
6.15 Iodine Monitoring		263
6.16 Environmental Qualification		264
6.17 Offsite Dose Calculation Manual		265
6.18 Major Changes to Radioactive Waste Treatment Systems		265

PBAPS

LIST OF FIGURES

Figure	Title	Page
1.1-1	APRM Flow Bias Scram Relationship To Normal Operating Conditions	16
4.1.1	Instrument Test Interval Determination Curves	55
4.2.2	Probability of System Unavailability vs. Test Interval	98
3.4.1	Required Volume and Concentration of Standby Liquid Control System Solution	122
3.4.2	Required Temperature vs. Concentration for Standby Liquid Control System Solution	123
3.5.K.1	MCPR Operating Limit vs. Tau, LTA	142
3.5.K.2	MCPR Operating Limit vs. Tau, PTA & P8X8R Fuel	142a
3.5.1.A	Deleted	
3.5.1.B	Deleted	
3.5.1.C	Deleted	
3.5.1.D	Deleted	
3.5.1.E	Kf Factor vs. Core Flow	142d
3.5.1.F	MAPLHGR vs. Planar Average Exposure, Unit 3, 8X8 PTA Fuel	142e
3.5.1.G	Deleted	
3.5.1.H	MAPLHGR vs. Planar Average Exposure, Unit 3, P8X8R Fuel (P8DRB284H)	142g
3.5.1.I	MAPLHGR vs. Planar Average Exposure, Unit 3, P8X8R LTA (P8DRB299)	142h
3.5.1.J	MAPLHGR vs. Planar Average Exposure, Unit 3, P8X8R Fuel (Generic	142i
3.5.1.K	MAPLHGR vs. Planar Average Exposure, Unit 3, P8X8Q LTA (P8DQB326)	142j
3.6.1	Minimum Temperature for Pressure Tests such as required by Section XI	164
3.6.2	Minimum Temperature for Mechanical Heatup or Cooldown following Nuclear Shutdown	164a
3.6.3	Minimum Temperature for Core Operation (Criticality)	164b
3.6.4	Transition Temperature Shift vs. Fluence	164c
3.8.1	Site Boundary and Effluent Release Points	216e
6.2-1	Management Organization Chart	244
6.2-2	Organization for Conduct of Plant Operation	245

Amendment No. 43, 46, 62, 79, 92, 104

LIST OF TABLES

Table	Title	Page
4.2.B	Minimum Test and Calibration Frequency for CSCS	81
4.2.C	Minimum Test and Calibration Frequency for Control Rod Blocks Actuation	83
4.2.D	Minimum Test and Calibration Frequency for Radiation Monitoring Systems	84
4.2.E	Minimum Test and Calibration Frequency for Drywell Leak Detection	85
4.2.F	Minimum Test and Calibration Frequency for Surveillance Instrumentation	86
4.2.G	Minimum Test and Calibration Frequency for Recirculation Pump Trip	88
3.5.K.2	Operating Limit MCPR Values for Various Core Exposures	133d
3.5.K.3	Operating Limit MCPR Values for Various Core Exposures	133e
4.6.1	In-Service Inspection Program for Peach Bottom Units 2 and 3	150
3.7.1	Primary Containment Isolation Valves	179
3.7.2	Testable Penetrations With Double O-Ring Seals	184
3.7.3	Testable Penetrations With Testable Bellows	184
3.7.4	Primary Containment Testable Isolation Valves	185
4.8.1	Radioactive Liquid Waste Sampling and Analysis	216b-1
4.8.2	Radioactive Gaseous Waste Sampling and Analysis	216c-1
4.8.3.a	Radiological Environmental Monitoring Program	216d-1
4.8.3.b	Reporting Levels for Radioactivity Concentrations in Environmental Samples	216d-5

LIST OF TABLES

Table	Title	Page
4.8.3.c	Maximum Values for Minimum Detectable Levels of Activity	216d-6
3.11.D.1	Safety Related Shock Suppressors	234d
3.14.C.1	Fire Detectors	240k

TABLE 4.2.D

MINIMUM TEST & CALIBRATION FREQUENCY FOR RADIATION MONITORING SYSTEMS

Instrument Channels	Instrument Functional Test	Calibration	Instrument Check (2)
1) Refuel Area Exhaust Monitors - Upscale	(1)	Once/3 months	Once/day
2) Reactor Building Area	(1)	Once/3 months	Once/day

Logic System Functional Test (4) (6)	Frequency
1) Reactor Building Isolation	Once/6 months
2) Standby Gas Treatment System Actuation	Once/6 months