

Enclosure 3

STPNOC Handout Material

**South Texas Project/Nuclear Regulatory
Commission Meeting**

**Remaining Open Issues on the Request for
Exemption from Special Treatment
Requirements**

Meeting of the
Risk-Informed Licensing Panel

April 24, 2001

South Texas Project Attendees

- Joe Sheppard, Vice President of Engineering & Technical Services
- Glen Schinzel, Exemption Request Project Manager
- Scott Head, Licensing Manager
- Rick Grantom, Risk Management Manager
- Steve Frantz, STP counsel

Background

- **STP Has a Robust Categorization Process**
 - PRA and Importance Measures
 - Deterministic Evaluation
 - Higher of PRA or Deterministic Category Is Used

- **LSS/NRS Components Have Little or No Safety Significance**
 - Typical examples include vents, drain valves, indicators, etc.
 - Little or no contribution to accident prevention or mitigation

Background

- **No Significant Impact on Reliability Expected from Use of Commercial Practices**
 - Commercial practices at STP have proven effective on BOP components
 - STP analysis of industry data shows commercial practices are effective
 - STP evaluated 33 component types (74 billion component hours)
 - 21 component types had lower failure rates for non-safety-related components than safety-related components
 - Only 1 component type had higher failures rates for non-safety-related components than safety-related components

Background

- **Decreases in Reliability of LSS/NRS Components Would Not Significantly Affect PRA Results**
 - STP sensitivity study postulated factor of 10 increase in failure rates of all LSS components
 - CDF and LERF increased by about 1%
 - Noted increase in CDF and LERF is small fraction of acceptance criteria in RG 1.174

Summary of Remaining Open Issues

- Open issues are detailed on attached pages - summary includes the STP concern, our perception of the staff's position, and the delta between these two positions.
- Open issues include:
 - Equipment Qualification
 - Seismic
 - Safety-related SSC testing
 - Overall detail in the FSAR
 - Categorization
 - Procurement
 - Management & Oversight

Summary of Remaining Open Issues

- Pressure boundary categorization
- Guidance provided in SER on what constitutes effective implementation

Environmental Qualification

- **STP Position**
 - Will use five-tiered procurement approach
 - One or more of the five options may be used
 - Will ensure that design functional requirements are met
- **Staff Position**
 - Official staff position has not been received
 - Design basis environmental parameters detailed in FSAR
 - NRC has indicated that a combination of calculations, multiple discipline analysis, test data, and operating experience must be used

Environmental Qualification

- **Delta**
 - The formal staff position is not known
 - It is not clear that the staff will permit procurement to be satisfied by vendor documentation, equivalency evaluations, engineering evaluations
 - Detail in the FSAR is too prescriptive

Seismic

- **STP Position**
 - Will use five-tiered procurement approach
 - One or more of the five options may be used
 - Design functional requirements to be met
- **Staff Position**
 - 5 OBE followed by 1 SSE criteria must be met/demonstrated
 - Detailed engineering analysis and testing viewed as only viable options
 - Is willing to grant exemption, but doesn't see how it could be effectively implemented

Seismic

- **Delta**
 - five-tiered approach viability
 - 13.7.3.3.2 language of ‘seismic (earthquake motion, as described in the design bases, including seismic inputs and design load combinations)’

Conclusions on Seismic and EQ

- Focus continues to be on “how” STP intends to qualify components with Low Safety Significance
- **STP’s Approach Is Commensurate with Safety**
 - Vendor documentation provides sufficient confidence as shown by commercial experience
 - Engineering evaluations provide sufficient confidence for like-for-like replacements and minor differences
 - STP will use more detailed engineering analysis and/or testing for more substantial differences

Conclusions on Seismic and EQ

- **Summary**
 - Reduced assurance is not apparent with respect to EQ and seismic qualification of LSS/NRS components
 - Absent relief, the exemption will provide essentially no cost savings for procurement

SSC Testing

- **STP Position**
 - LSS/NRS SSCs will be appropriately tested and inspected following commercial practices and insights
- **Staff Position**
 - LSS/NRS SSCs must continue to receive equivalent-type testing as currently required
 - Successful operation/testing does not provide sufficient assurance
 - Data gathering, trending, and evaluation is necessary

SSC Testing

- **Delta**
 - Whether data collection, trending, and evaluation should be performed

- **STP's Approach Is Commensurate with Safety**
 - STP has agreed to exercise ASME pumps and valves during normal operation or test periodically
 - These activities will demonstrate that the pumps and valves are functional
 - Any failures will be subject to STP's Appendix B Corrective Action Program

SSC Testing

- **Summary**
 - Reliance on commercial practices has not been fully accepted
 - Data collection, trending, and evaluation for LSS/NRS components is not warranted and is unduly burdensome
 - Specification of 'how' testing is to be accomplished is unnecessary for LSS/NRS components

Detail in the FSAR

- **STP Position**
 - New NRC guidance to focus on ‘whats’ and not the ‘hows’
 - Extensive detail had been provided to support closure of RAIs and Open Items
 - FSAR continues to become more detailed

- **Staff Position**
 - Current detail in FSAR 13.7 reflects the minimum detail needed to make a finding in the SER
 - Additional detail is needed on containment integrity sensitivity study, pressure boundary, etc.

Detail in the FSAR

- **Delta**
 - 13.7.2.4 - detail of numerical scores to answers and the definitions to support the categorization is unnecessary
 - 13.7.2.5 - defense in depth bulleted details are more appropriate for the SER rather than the FSAR
 - 13.7.3.2 - no need for technical evaluation for safety-related HSS/MSS components
 - 13.7.3.3.2 - the detailed ‘how’ that STP will use to procure replacement SSCs is unnecessary - detailing environmental and seismic attributes is not needed
 - 13.7.3.3.7 - details concerning personnel qualifications, procedures, M&TE programmatic approach is not needed

Detail in the FSAR

- **STP's Approach Is Commensurate with Safety**
 - STP's sensitivity studies show that substantial increases in failure rates of LSS components would have no significant impact on risk
 - Such increases are well beyond what may be reasonably expected to occur due to the change from special treatment to commercial practices
 - Given the large margins of safety shown by STP's sensitivity studies, the details of STP's commercial treatment are unimportant
 - E.g., changes in the details will not have any appreciable impact on risk and are bounded by the sensitivity studies

Detail in the FSAR

- **Summary**
 - There will be substantial future burden associated with managing the level of detail proposed in the FSAR
 - The details desired are not warranted for low safety significant components

Pressure Boundary Categorization

- **STP Position**
 - GQA approach conservatively categorizes pressure boundary
 - RI-ISI methodology supplements the ASME Class 1/2 categorization
 - Streamlined RI-ISI-type approach supplements ASME Class 3 categorization

- **Staff Position**
 - GQA categorization inadequate for pressure boundary
 - RI-ISI categorization must be used to supplement categorization for ASME Repair and Replacement for all ASME classes

Pressure Boundary Categorization

- **Delta**
 - Whether STP should be allowed to use alternate approach to supplement categorization for ASME Class 3 components
- **Class 3 components**
 - Class 3 components have the least important pressure boundary considerations
 - Currently, NRC regulations have only minimal inspection requirements for Class 3 components
 - Would impose substantial additional burden on STP with respect to categorization of Class 3 components

Pressure Boundary Categorization

- **STP's Approach Is Commensurate with Safety**
 - GQA approach considers impact on system functions from pressure boundary failure
 - STP's alternative approach considers spatial effects on other safety significant SSCs from pressure boundary failure
 - Reduced treatment of Class 3 components inside containment does not pose any new EQ or spatial effects concerns

Pressure Boundary Categorization

- **Summary**
 - Requires STP to use two categorization processes for pressure boundary
 - EPRI RI-ISI approach is viewed by NRC as only acceptable method
 - STP's approach adequately accounts for the risk of pressure boundary failure
 - STP believes that the GQA categorization process is adequate for all functions, including pressure boundary (based on comparison with RI-ISI results)
 - STP has agreed to supplement its process with alternate approach
 - No significant safety benefit to applying EPRI RI-ISI to Class 3 components

Implementation Guidance in SER

- **Staff Position**

- Implementation guidance is needed to give insight to STP on staff's expectations

- **STP Position**

- Commercial practices are sufficient
- Detailed guidance on what constitutes 'effective implementation' or 'ineffective implementation' in the SER will establish expectations that go beyond commercial practices
- Guidance becomes default 'commitments' that limit implementation

Implementation Guidance in SER

- STP will not have an opportunity to comment on the guidance before it appears in the final SER

- **Delta**

- Resolve whether guidance should be provided in the SER

- **Summary**

- It is inappropriate for NRC to place guidance in the SER without providing STP a prior opportunity to review and comment
- The staff's proposal threatens to impose new requirements that could impact the viability of the exemption

Future Activities

- What should be NRC's inspection approach to LSS/NRS components?
- Process should proceed as a pilot and learn from feedback that is received
- STP does not expect any significant changes in reliability of LSS/NRS components
- STP's sensitivity studies demonstrate that even a postulated 10 fold increase in failure rates would not significantly affect risk
- LSS/NRS components do not warrant substantial NRC inspection resources

Conclusions

- Significant progress has been made
- Few open issues remain
- Use of commercial practices for low safety significant components not fully accepted
- Level of detail in the FSAR is excessive given the low safety significance of the components
- Cost-effective implementation of the exemption is challenged