

Docket Nos. 50-277/278

JUN 10 1986

DISTRIBUTION

Docket File	GGears
NRC PDR	EJordan
Local PDR	JPartlow
PD#2 File	BGrimes
RBernero	ACRS (10)
SNorris	OELD

Mr. Edward J. Bauer, Jr.
Vice President and General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101


Dear Mr. Bauer:

On November 19, 1985 the Commission issued Amendment Nos. 113 and 117 to Facility Operating License Nos. DPR-44 and DPR-56 for the Peach Bottom Atlantic Power Station, Unit Nos. 2 and 3.

Table 3.2.B of the Technical Specifications for each unit cites Note 6 which was inadvertently omitted when the amendments were issued. Page 72 for each unit is enclosed for incorporation into the Technical Specifications.

We regret any inconvenience this omission may have created.

Sincerely,


Gerald E. Gears, Project Manager
BWR Project Directorate #2
Division of BWR Licensing

Enclosure:
As Stated

cc: See next page

DBL:PD#2
SNorris:vs
6/10/86

DBL:PD#2
GGears
6/10/86

DBL:PD#2
DMullen
6/10/86

B606200187 B60610
PDR ADOCK 05000277
P PDR

Mr. E. G. Bauer, Jr.
Philadelphia Electric Company

Peach Bottom Atomic Power Station,
Units 2 and 3

cc:

Mr. Eugene J. Bradley
Assistant General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy R. Conner, Jr., Esq.
1747 Pennsylvania Avenue, N.W.
Washington, D.C. 20006

Thomas A. Deming, Esq.
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Mr. R. Fleischmann, II, Manager
Peach Bottom Atomic Power Station
RD #1
Delta, Pennsylvania 17314

Mr. G. M. Leitch, Superintendent
Nuclear Generation Division
S7-1
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Mr. Anthony J. Pietrofitta, General Manager
Power Production Engineering
Atlantic Electric
P. O. Box 1500
1199 Black Horse Pike
Pleasantville, New Jersey 08232

Resident Inspector
U.S. Nuclear Regulatory Commission
Peach Bottom Atomic Power Station
P.O. Box 399
Delta, Pennsylvania 17314

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
P.O. Box 1323
Harrisburg, Pennsylvania 17120

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P.O. Box 2063
Harrisburg, Pennsylvania 17120

Mr. Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

PBAPS

Notes for Table 3.2.B

1. Whenever any CSCS subsystem is required by Section 3.5 to be operable, there shall be two operable trip systems. If the first column cannot be met for one of the trip systems, that trip system shall be placed in the tripped condition or the reactor shall be placed in the Cold Shutdown Condition within 24 hours.
2. Close isolation valves in RCIC subsystem.
3. Close isolation valves in HPCI subsystem.
4. Instrument set point corresponds to 378 inches above vessel zero.
5. HPCI has only one trip system for these sensors.
6. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement, place at least one inoperable channel in the tripped condition within one hour or declare the RCIC system inoperable.

Notes for Table 3.2.B

1. Whenever any CSCS subsystem is required by Section 3.5 to be operable, there shall be two operable trip systems. If the first column cannot be met for one of the trip systems, that trip system shall be placed in the tripped condition or the reactor shall be placed in the Cold Shutdown Condition within 24 hours.
2. Close isolation valves in RCIC subsystem.
3. Close isolation valves in HPCI subsystem.
4. Instrument set point corresponds to 378 inches above vessel zero.
5. HPCI has only one trip system for these sensors.
6. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement, place at least one inoperable channel in the tripped condition within one hour or declare the RCIC system inoperable.