

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.8.3.1	Verify each fuel oil storage tank contains: <ul style="list-style-type: none"> a. \geq 68,744 gal of fuel for DGs 11 and 12; and b. \geq 44,616 gal of fuel for DG 13. 	31 days
SR 3.8.3.2	Verify lube oil inventory is: <ul style="list-style-type: none"> a. \geq 205 gal for DGs 11 and 12; and b. \geq 101 gal for DG 13. 	31 days
SR 3.8.3.3	Verify fuel oil properties of new and stored fuel oil are tested in accordance with, and maintained within the limits of, the Diesel Fuel Oil Testing Program.	In accordance with the Diesel Fuel Oil Testing Program
SR 3.8.3.4	Verify each required DG air start receiver pressure is: <ul style="list-style-type: none"> a. \geq 160 psig for DGs 11 and 12; and b. \geq 175 psig for DG 13. 	31 days
SR 3.8.3.5	Check for and remove accumulated water from each fuel oil storage tank.	92 days

(continued)

3.8 ELECTRICAL POWER SYSTEMS

3.8.3 Diesel Fuel Oil, Lube Oil, and Starting Air

LCO 3.8.3 The stored diesel fuel oil, lube oil, and starting air subsystem shall be within limits for each required diesel generator (DG).

APPLICABILITY: When associated DG is required to be OPERABLE.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each DG.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more DGs with fuel oil level:</p> <p>1. For DG 11 or 12, < 68,744 gal and ≥ 59,173 gal; and</p> <p>2. For DG 13, < 44,616 gal and ≥ 38,280 gal.</p>	<p>A.1 Restore fuel oil level to within limits.</p>	<p>48 hours</p>
<p>B. One or more DGs with lube oil inventory:</p> <p>1. For DG 11 or 12, < 205 gal and ≥ 176 gal; and</p> <p>2. For DG 13, < 101 gal and ≥ 87 gal.</p>	<p>B.1 Restore lube oil inventory to within limits.</p>	<p>48 hours</p>

(continued)