


Supporting Data for Report

F/2



Air Cooled Heatup Times

PWR W 17x17

Heatup Time oxidation model				Decay Time	Burnup	Building Flow	
nur1h	nur1l	ait1	noox				
1.6	2.0	1.8	2.3	2 months	60	full	1.8
4.1	5.3	4.6	6.7	1 year	60	full	4.7
4.1	5.3	4.6	6.6	1 year	60	half	4.7
4.9	6.5	5.6	8.5	1 year	50	full	5.7
7.7	11.1	9.0	17.5	2 years	60	full	10.3
T < 800 C				5 years	60	full	—
27.3	T<800	38.6	T<800	5 years	60	half	33
Adiabatic noox				1 year	60	14.5	

Air Cooled Heatup Times

PWR W 17x17

Heatup Time
oxidation model

nur1h	nur1l	ait1	noox
1.6	2.0	1.8	2.3

4.1	5.3	4.6	6.7
-----	-----	-----	-----

4.1	5.3	4.6	6.6
-----	-----	-----	-----

4.9	6.5	5.6	8.5
-----	-----	-----	-----

7.7	11.1	9.0	17.5
-----	------	-----	------

T < 800 C

27.3	T<800	38.6	T<800
------	-------	------	-------

Decay Time

2 months

1 year

1 year

1 year

2 years

5 years

5 years

Burnup

60

60

60

50

60

60

60

Building Flow

full

full

half


full

full

full

half


for
BWR 7.0 hrs



Decay Heat Following 3 Years of Operation

ANS 5.1 - 1993


7-17-00



Time (yr)	Decay Heat (MW)
10 ⁻²	3.6
10 ⁻¹	1.75
10 ⁰	1.0
10 ¹	1.0


Decay H_i at Following 3 Years of Operation

ANS 5.1 - 1993




Day Heat following 3 Years of Operation

ANS 5.1 - 1993



Decay Rate following 3 Years of Operation

ANS 5.1 - 1993



Time to reach 800°C

(EP)

Air Cooling

DETAILED
TIME
BU
OPERATION
MODELS
OLD
A/D

AC-1	1 yr	60	A	A
AC-2	1 yr	60	B	A
AC-3	11	60	A	B
AC-4	1 yr	60	B	B
AC-5	1 yr	50	A	A ?
AC-6	2 yr	60	A	A
AC-7	2 yr	60	A	A
AC-8	5 yr	60	A	A

AC-9
AC-10
AC-11

Backdoor Cases

Human Error
Sensitivity

BD-1	2 mo	60	N/A	N/A
------	------	----	-----	-----

STEAM Cooling

Show Importance of
ADVERSE ASSUMPTION

SC-1	1 yr	60	A-steam	N/A
------	------	----	---------	-----


Critical DEGRY TIME (EASUREMENT)

COT-1	Air	60	A	A
-2	Air	60	B	A
-3	Air	60	B	B
-4	Air	60	A	B
-5	Air	50	A	A } 17
-6	Air	70	A	A } ?
-7	STEAM	60	A-steam	A

-8

-10

Indemnity Decision Plot



Risk metric could be: person rem/year
 curies/year released
 cancer deaths



Key Questions:

Is operating reactor insurance sufficient to cover claims from a major accident?
 If not, then how much insurance may not be sufficient basis for decision? If the damages could still ~~be~~ exceed the limit of liability, maybe insurance should be maintained.

18 MONTH CYCL

batch	AGE	Decat	Rate heat heat
1a	1	1.0	
1b	1	1.0	
1c	1	1.0	
2	2.5	~3.0	
3	4.0		
4	5.5y	0.2	
5	7.0		
6	8.5		
7	10.0	0.1	

Hours
30-700



For Expected
Amplitude
(55-70)


Years	Time
1	8-10 h
2	13-14 h
5	30-35 h
10	43-53 h

$\frac{1}{1} = 1.0$
 $\frac{1}{17} \times .5 = .29$
 $\frac{1}{17} = .0588$
 $\frac{1}{17} \times .4 = .0235$

Decay Heat Following Shutdown for TMI

Estimated Values

Time (yr)	P/Full Power
35	1
7	.2
4	.11
3.5	.10
2.5	.07



=> After 10 years you have about a factor of 10 lower decay heat than you have at 1 year

=> after 5 years you have 1/5 the decay heat you have at 1 year
 => after 10 years you have 1/10 the decay heat you have at 1 year
 => after 20 years not much different than 10 years

The times calculated are in hours for an adiabatic heatup from 30 C to 800 C with no oxidation heat source. Adiabatic Heatups are based on a Peaking Factor of 1.1 for PWRs and 1.2 for BWRs. The decay heats at these burnup values are interpolations or extrapolations of the decay heat from NUREG/CR-5625. The thermal mass of the BWR fuel is modeled as 9x9 fuel assemblies and the associated fuel rack structure. The mass per assembly is 170 kg UO2, 97.5 kg Zirconium and 42.4 kg stainless steel. The thermal mass PWR fuel is modeled 17x17 fuel assemblies and the associated rack structure. The mass per assembly is kg UO2, 101 kg Zirconium, and 68.6 kg stainless steel. Temperature dependent values of the specific heat are used for steel, zircaloy, and UO2.

Adiabatic Heatup Time at 1 Year

Burnup	PWR	BWR
50	6.1	10.1
55	5.6	9.2
60	5.2	8.5
70	4.4	7.2
80	3.8	6.4

Adiabatic Heatup Time at 2 Years

Burnup	PWR	BWR
50	11.2	17.9
55	10.2	16.1
60	9.4	14.9
70	8.0	12.8
80	7.1	11.1

Adiabatic Heatup Time at 5 Years

Burnup	PWR	BWR
50	28.0	40.0
55	25.4	36.4
60	23.3	33.4
70	19.9	28.5
80	17.4	25.0

Adiabatic Heatup Time at 10 Years

Burnup	PWR	BWR
50	42.8	58.0
55	38.9	52.9
60	35.6	48.4
70	30.5	41.5
80	26.7	36.2

8-21-00

Decay Time in Years for a 10 Hour Adiabatic Heatup Time

Burnup	PWR	BWR
50	1.8	1.0
55	2.0	1.2
60	2.2	1.3
70	2.6	1.6
80	2.9	1.9


Decay Time in Years for a 24 Hour Adiabatic Heatup Time

Burnup	PWR	BWR
50	4.3	2.8
55	4.8	3.2
60	5.1	3.5
70	6.6	4.1
80	8.4	4.9

Spent Fuel Pool Heatup and Boiloff Time in hours to 3 feet Above Active Fuel. Fuel Burnup is 62.5 Gwd/MTU with a 2 year cycle time. The decay heat at this value of burnup is an extrapolation of the decay heat from NUREG/CR-5625. The BWR pool holds 4200 9x9 fuel assemblies. The pool surface area is 105.7 square meters. The PWR pool holds 965 17x17 fuel assemblies. The pool surface area is 61.3 square meters. The pools have a water depth of 11.54 meters and are assumed to be at an initial temperature of 30 C. An estimated volume fraction of 0.5 of water in the racks and assemblies was used. Errors in this value can impact the heatup time portion of the heatup and boiloff calculation. The specific heat of water was assumed to be constant at 4200 J/kg for the heatup calculation. Temperature dependent properties were used for steel, zircaloy, and UO2. The enthalpy change due to vaporization used in the boiloff calculation is 2257 KJ/kg.

Decay Time	PWR	BWR
1 year	195	253
2 year	272	337
5 year	400	459
10 year	476	532


ADIABATIC
 PEAKING = 1.1 PWR
 1.2 BWR



AIR MAIL HEAD

Price = 1.25

THE PRICE IS 6.000 C (1.000)



Sensitivity of Early Fatality Risk to Emergency Planning -- Cask Drop Event

(Conditional upon: High Ruthenium Source Term)




Figure 3.7-5

Sensitivity of Societal (Person-rem) Risk to Emergency Planning -- Cask Drop Event

(Conditional upon: High Ruthenium Source Term)




Figure 3.7-6

Individual Early Fatality Risk Within 1 Mile




Figure ES-1

Individual Latent Cancer Fatality Risk Within 10 Miles





Figure ES-2


Activity Contribution per Refueling Batch for Ru-106 and Cs-137 (6 months after shutdown for an 18 month fuel cycle)




Approx B

Approx B

Activity Contribution per Refueling Batch for Ru-106 and Cs-137 (2 years after shutdown for an 18 month fuel cycle)




Incremental Contribution from Ru-106 and Cs-137, etc., 6 Months After SD (18 month fuel cycle)



Incremental Contribution from Ru-106 and Cs-137, etc., 2 Years After SD (18 month fuel cycle)

- - - I-131 Activity at SD (use left y-scale only)
 ■ Cs-137 (use left y-scale, both x-scales)
 ▲ Ru-106 (use left y-scale, both x-scales)
 -x- Spent Fuel Relative Decay Heat Power (use right y-scale, top x-scale)



*Batch
number*




Table C-1

Fission product inventories (Ci/MWe)

SHUTDOWN

A/A

Fission product	Release Fraction	t _{1/2}	Inventory (Ci/MWe)	40 days	6 months	1 yr	3 yr
Kr-85		10.72Y	560	1			
Kr-85m		4.48H	24,000	-			
Kr-87		76.5M	47,000	-			
Kr-88		2.87H	68,000	-			
Sr-89		50.6D	94,000	.578	.085	-	
Sr-90		28.6Y	3,700	1			
Sr-91		9.5H	110,000	-			
Y-91		58.5D	120,000	.623	.12	-	
Mo-99		46.1H	160,000	-			
Ru-103		39.4D	110,000	.494	.042	-	
Ru-106		360.2D	25,000	.93	.713	.50	
Te-129m		33.6D	5,300	.47	.02	-	
Te-131m		30.1H	13,000	-			
Te-132		78.4H	120,000	-			
Sb-127		3.85D	6,100	-			
Sb-129		4.41H	33,000	-			
I-131		8.0D	85,000	.03	-		
I-132		2.3H	120,000	-			
I-133		20.8H	170,000	-			
I-134		52.6M	190,000	-			
I-135		6.61H	150,000	-			
Xe-131m		11.74D	1,000	.1	-		
Xe-133		5.2D	170,000	-			
Xe-133m		2.19D	6,000	-			
Xe-135		9.11H	34,000	-			
Xe-138		14.3M	170,000	-			
Cs-134		2.0Y	7,500	.96	.84	.71	
Cs-136		13.16D	3,000	-			
Cs-137		30.2Y	4,700	1.0	.99	.98	
Ba-140		12.9D	160,000	.11			
La-140		40.22H	160,000	-			
Ce-144		284D	85,000	.9	.64	.41	
Np-239		2.36D	1.64E+6	-	-	-	

Why is CE-144 NOT important? →

Source: WASH-1400

For end of cycle core, only the fission products with half lives greater than 1/2 hour.

September 5, 2000

1. Below is a table containing the dose conversion factors you requested. MACCS calculates the early fatality risk as a combination of the dose to the lungs and red marrow.

2. Iodine is important for reactor accidents, because of its high inventory in the core and its high thyroid dose conversion factor. Table 4.1 of NUREG/CR-4982 shows the following inventories (in Curies) for an equilibrium core for Millstone 1:

I-131 4.74E7
 Ru-106 2.48E7
 Cs-137 5.84E6

3. One of your health physicists (e.g., Steve LaVie) might be able to provide further insight into the importance of iodine.

Dose Conversion Factors for I-131, Ru-106, and Cs-137*

	organ	cloud-shine (Sv sec/ Bq m ³)	ground-shine (Sv sec/ Bq m ²)	inhalation/ acute (Sv/Bq)	inhalation/ chronic (Sv/Bq)	ingestion (Sv/Bq)
I-131	lungs	1.41E-14	2.97E-16	4.54E-10	6.57E-10	1.02E-10
	red marrow	1.45E-14	3.06E-16	3.52E-11	6.26E-11	9.44E-11
Ru-106	lungs	7.90E-15	1.58E-16	2.09E-08	1.04E-06	1.44E-09
	red marrow	8.05E-15	1.61E-16	8.74E-11	1.77E-09	1.48E-09
Cs-137	lungs	2.18E-14	4.35E-16	8.29E-10	8.80E-09	1.27E-08
	red marrow	2.22E-14	4.41E-16	5.63E-10	8.30E-09	1.32E-08
Ratio of Ru-106 to Cs-137	lungs	.4	.4	25	118	.1
	red marrow	.4	.4	.2	.2	.1

*The dose conversion factors are from the MACCS input file DOSDATA.INP.

Acute Lung

$$\frac{Ru-106}{I-131} = \frac{2.1E-08}{4.5E-10} = 47$$

$$\frac{1.04E-06}{6.57E-10}$$

$$\frac{10.4E-7}{6.57E-10}$$

$$\frac{17.7E-10}{6.3E-11}$$

$$S = 18.5$$

0

1, 2, 3, 7

NURGE - 1150 (1982)

	<u>Early for data/yr</u>	<u>Latest for data/yr</u>
Se g	3.5×10^{-6} to 3.1×10^{-4}	3×10^{-2} to 5.1×10^{-1}
Zion	3.5×10^{-6} to 8.3×10^{-4}	3.0×10^{-3} to 1.2×10^{-1}
Servy	3.7×10^{-8} to 1.4×10^{-5}	8.0×10^{-4} to 3.0×10^{-2}
PR	8.5×10^{-9} to 8.1×10^{-6}	6.5×10^{-4} to 1.1×10^{-1}
GC	1.4×10^{-5} to 6.5×10^{-6}	1.4×10^{-3} to 5.2×10^{-1}




Figure ES-1

Individual Latent Cancer Fatality Risk Within 10 Miles





Figure ES-2

Activity Contribution per Refueling Batch for Ru-106 and Cs-137

(1 year after shutdown for an 18 month fuel cycle)



SPENT FUEL POOL ACCIDENT CONSEQUENCES

Event Freq ~ 1×10^{-6} per year

60 Mwd +Oxidation+full aircooling						
Decay Time	Early Fatalities		Time Delay		LC at 100 miles	
	Evacuation Model		PWR	BWR	Evacuation Model	
	Early	Late			Early	Late
30 days						
30 days	7	192	1	3	15400	21100
60 days						
60 days	4	162	2	5	14300	20000
1 year						
1 year	1	77	5	7	11500	17400
2 years						
2 years	0.1	19	9	17	9480	15400
5 years						
5 years	0.02	1	33?	inf	7620	12600
10 years						
10 years	0.01	-		inf	6490	11400
Source Term:						
XXXXXXXXXXXX						
Red = Ruthenium Rich Upper Bound						