Januar 11, 1996

Mr. George A. Hunger Director-Licensing, Mc 62A-1 PECO Energy Company Nuclear Group Headquarters Correspondence Control Desk P.O. Box No. 195 Wayne, PA 19087-0195

SUBJECT: CONTROL ROD DRIVE ACCUMULATOR TECHNICAL SPECIFICATIONS, PEACH BOTTOM ATOMIC POWER STATION, UNIT NOS. 2 AND 3 (TAC NOS. M94180 AND M94181)

Dear Mr. Hunger:

The Commission has issued the enclosed Amendments Nos. 211 and 216 to Facility Operating License Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station, Unit Nos. 2 and 3. These amendments consist of changes to the Technical Specifications (TS) in response to your application dated November 30, 1995.

These amendments change the minimum allowable control rod scram accumulator pressure and charging water header pressure from a value of 955 psig to a value of 940 psig. The amendments revise the Peach Bottom Technical Specifications as issued in Amendments 210 and 214 on August 30, 1995. Amendments 210 and 214 have not yet been implemented; the enclosed amendments are expected to be implemented concurrently with the implementation of Amendments 210 and 214.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly <u>Federal Register</u> Notice.

Sincerely, /S/ Joseph W. Shea, Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket Nos. 50-277/278

Enclosures:	1.	Amendment No.	211	to	DPR-44
	2.	Amendment No.	216	to	DPR-56
	3.	Safety Evaluat	ion		

cc w/encls: See next page

DISTRIBUTION:

Docket File	MO'Brien
PUBLIC	JShea
PDI-2 Reading	OGC
SVarga	GHill(4)
JStolz	

OFFICE PDI SRXB/C POI NAME MO' Brien JSh RJones JStolz '05/9€O ⁷/95 Ŋ, /95 <u>v/v/</u>95 VIV DATE 12/20/95 DOCUMENT NAME: G:\SHEA\PEACH\PB94180.AMD OFFICIAL RECORD COPY

CGrimes

RJones ACRS

WPasciak, RGN-I

9601180376 960111 PDR ADOCK 05000277 P PDR

120080



\$

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001 Januarv 11, 1996

Mr. George A. Hunger, Jr. Director-Licensing, MC 62A-1 PECO Energy Company Nuclear Group Headquarters **Correspondence Control Desk** P.O. Box No. 195 Wayne, PA 19087-0195

SUBJECT: CONTROL ROD DRIVE ACCUMULATOR TECHNICAL SPECIFICATIONS, PEACH BOTTOM ATOMIC POWER STATION, UNIT NOS. 2 AND 3 (TAC NOS. M94180 AND M94181)

Dear Mr. Hunger:

The Commission has issued the enclosed Amendments Nos. 211 and 216 to Facility Operating License Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station, Unit Nos. 2 and 3. These amendments consist of changes to the Technical Specifications (TS) in response to your application dated November 30, 1995.

These amendments change the minimum allowable control rod scram accumulator pressure and charging water header pressure from a value of 955 psig to a value of 940 psig. The amendments revise the Peach Bottom Technical Specifications as issued in Amendments 210 and 214 on August 30, 1995. Amendments 210 and 214 have not yet been implemented; the enclosed amendments are expected to be implemented concurrently with the implementation of Amendments 210 and 214.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

94.725C

Joseph W. Shea, Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket Nos. 50-277/278

Enclosures:	1.	Amendment	No.	211	to	DPR-44
	2.	Amendment	No.	216	to	DPR-56

- 3. Safety Evaluation

cc w/encls: See next page

Mr. George A. Hunger, Jr. PECO Energy Company

Peach Bottom Atomic Power Station, Units 2 and 3

cc:

J. W. Durham, Sr., Esquire Sr. V.P. & General Counsel PECO Energy Company 2301 Market Street, S26-1 Philadelphia, Pennsylvania 19101

PECO Energy Company ATTN: Mr. G. R. Rainey, Vice President Peach Bottom Atomic Power Station Route 1, Box 208 Delta, Pennsylvania 17314

PECO Energy Company ATTN: Regulatory Engineer, A4-5S Peach Bottom Atomic Power Station Route 1, Box 208 Delta, Pennsylvania 17314

Resident Inspector U.S. Nuclear Regulatory Commission Peach Bottom Atomic Power Station P.O. Box 399 Delta, Pennsylvania 17314

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

Mr. Roland Fletcher Department of Environment 201 West Preston Street Baltimore, Maryland 21201

A. F. Kirby, III External Operations - Nuclear Delmarva Power & Light Company P.O. Box 231 Wilmington, DE 19899 Mr. Rich R. Janati, Chief
Division of Nuclear Safety
Pennsylvania Department of
Environmental Resources
P. O. Box 8469
Harrisburg, Pennsylvania 17105-8469

Board of Supervisors Peach Bottom Township R. D. #1 Delta, Pennsylvania 17314

Public Service Commission of Maryland Engineering Division Chief Engineer 6 St. Paul Centre Baltimore, MD 21202-6806

Mr. Richard McLean Power Plant and Environmental Review Division Department of Natural Resources B-3, Tawes State Office Building Annapolis, Maryland 21401

Dr. Judith Johnsrud National Energy Committee Sierra Club 433 Orlando Avenue State College, PA 16803



ADOCK 05000277

PDR

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

PECO ENERGY COMPANY

PUBLIC SERVICE ELECTRIC AND GAS COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-277

PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.211 License No. DPR-44

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by PECO Energy Company, et al. (the licensee) dated November 30, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I.
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. DPR-44 is hereby amended to read as follows:

(2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 211, are hereby incorporated in the license. PECO Energy Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and is to be implemented concurrently with Amendment 210, issued August 30, 1995.

FOR THE NUCLEAR REGULATORY COMMISSION

John F. Stolz, Director Rrøject Directorate 1-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: January 11, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 211

4

FACILITY OPERATING LICENSE NO. DPR-44

DOCKET NO. 50-277

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised areas are indicated by marginal lines.

Remove	<u>Insert</u>
3.1-16	3.1-16
3.1-17	3.1-17
3.9-8	3.9-8
3.10-23	3.10-23
83.1-31	B3.1-31
B3.1-32	B3.1-32
B3.1-33	B3.1-33
B3.9-14	B3.9-14
B3.9-15	B3.9-15
B3.10-36	B3.10-36

Ĩ

I

1

ACTIONS (continued)

.

`*

1

	CONDITION		REQUIRED ACTION	COMPLETION TIME
B.	Two or more control rod scram accumulators inoperable with reactor steam dome pressure ≥ 900 psig.	B.1	Restore charging water header pressure to ≥ 940 psig.	20 minutes from discovery of Condition B concurrent with charging water header pressure < 940 psig
		AND		
		B.2.1	Only applicable if the associated control rod scram time was within the limits of Table 3.1.4-1 during the last scram time Surveillance.	
			Declare the associated control rod scram time "slow."	1 hour
		<u>OR</u>		
		B.2.2	Declare the associated control rod inoperable.	1 hour

(continued)

Amendment No. 210, 211

ACTIONS (continued)

	CONDITION		REQUIRED ACTION	COMPLETION TIME
C.	One or more control rod scram accumulators inoperable with reactor steam dome pressure < 900 psig.	C.1	Verify all control rods associated with inoperable accumulators are fully inserted.	Immediately upon discovery of charging water header pressure < 940 psig
		AND		
		C.2	Declare the associated control rod inoperable.	1 hour
D.	Required Action B.1 or C.1 and associated Completion Time not met.	D.1	Not applicable if all inoperable control rod scram accumulators are associated with fully inserted control rods.	
			Place the reactor mode switch in the shutdown position.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE		
SR 3.1.5.1	Verify each control rod scram accumulator pressure is ≥ 940 psig.	7 days	

Amendment No. 210, 211

3.9 REFUELING OPERATIONS

3.9.5 Control Rod OPERABILITY-Refueling

LCO 3.9.5 Each withdrawn control rod shall be OPERABLE.

APPLICABILITY: MODE 5.

ACTIONS

CONDITION			REQUIRED ACTION	COMPLETION TIME
Α.	One or more withdrawn control rods inoperable.	A.1	Initiate action to fully insert inoperable withdrawn control rods.	Immediately

SURVEILLANCE REQUIREMENTS

	······	SURVEILLANCE	FREQUENCY
SR	3.9.5.1	Not required to be performed until 7 days after the control rod is withdrawn.	
		Insert each withdrawn control rod at least one notch.	7 days
SR	3. 9.5 .2	Verify each withdrawn control rod scram accumulator pressure is ≥ 940 psig.	7 days

Amendment No.210, 211

SDM Test-Refueling 3.10.8 1.00

I

+		SURVEILLANCE	FREQUENCY
SR	3.10.8.5	Verify each withdrawn control rod does not go to the withdrawn overtravel position.	Each time the control rod is withdrawn to "full out" position
			AND
			Prior to satisfying LCO 3.10.8.c requirement after work on control rod or CRD System that could affect coupling
SR	3.10.8.6	Verify CRD charging water header pressure ≥ 940 psig.	7 days

SURVEILLANCE REQUIREMENTS (continued)

BASES

ACTIONS

<u>A.1 and A.2</u> (continued)

control rod is declared inoperable (Required Action A.2) and LCO 3.1.3 is entered. This would result in requiring the affected control rod to be fully inserted and disarmed, thereby satisfying its intended function, in accordance with ACTIONS of LCO 3.1.3.

The allowed Completion Time of 8 hours is reasonable, based on the large number of control rods available to provide the scram function and the ability of the affected control rod to scram only with reactor pressure at high reactor pressures.

<u>B.1. B.2.1. and B.2.2</u>

With two or more control rod scram accumulators inoperable and reactor steam dome pressure \geq 900 psig, adequate pressure must be supplied to the charging water header. With inadequate charging water pressure, all of the accumulators could become inoperable, resulting in a potentially severe degradation of the scram performance. Therefore, within 20 minutes from discovery of charging water header pressure < 940 psig concurrent with Condition B, adequate charging water header pressure must be restored. The allowed Completion Time of 20 minutes is reasonable, to place a CRD pump into service to restore the charging water header pressure, if required. This Completion Time is based on the ability of the reactor pressure alone to fully insert all control rods.

The control rod may be declared "slow," since the control rod will still scram using only reactor pressure, but may not satisfy the times in Table 3.1.4-1. Required Action B.2.1 is modified by a Note indicating that declaring the control rod "slow" only applies if the associated control scram time is within the limits of Table 3.1.4-1 during the last scram time test. Otherwise, the control rod would already be considered "slow" and the further degradation of scram performance with an inoperable accumulator could result in excessive scram times. In this event, the associated control rod is declared inoperable (Required Action B.2.2) and LCO 3.1.3 entered. This would

(continued)

PBAPS UNIT 2

Amendment No. 211

BASES

ACTIONS

<u>B.1. B.2.1. and B.2.2</u> (continued)

result in requiring the affected control rod to be fully inserted and disarmed, thereby satisfying its intended function in accordance with ACTIONS of LCO 3.1.3.

The allowed Completion Time of 1 hour is reasonable, based on the ability of only the reactor pressure to scram the control rods and the low probability of a DBA or transient occurring while the affected accumulators are inoperable.

C.1 and C.2

With one or more control rod scram accumulators inoperable and the reactor steam dome pressure < 900 psig, the pressure supplied to the charging water header must be adequate to ensure that accumulators remain charged. With the reactor steam dome pressure < 900 psig, the function of the accumulators in providing the scram force becomes much more important since the scram function could become severely degraded during a depressurization event or at low reactor pressures. Therefore, immediately upon discovery of charging water header pressure < 940 psig, concurrent with Condition C, all control rods associated with inoperable accumulators must be verified to be fully inserted. Withdrawn control rods with inoperable accumulators may fail to scram under these low pressure conditions. The associated control rods must also be declared inoperable within 1 hour. The allowed Completion Time of 1 hour is reasonable for Required Action C.2, considering the low probability of a DBA or transient occurring during the time that the accumulator is inoperable.

<u>D.1</u>

The reactor mode switch must be immediately placed in the shutdown position if either Required Action and associated Completion Time associated with the loss of the CRD charging pump (Required Actions B.1 and C.1) cannot be met. This ensures that all insertable control rods are inserted and that the reactor is in a condition that does not require the

(continued)

PBAPS UNIT 2

Amendment No. 211

I

BASES	
ACTIONS	<u>D.1</u> (continued)
	active function (i.e., scram) of the control rods. This Required Action is modified by a Note stating that the action is not applicable if all control rods associated with the inoperable scram accumulators are fully inserted, since the function of the control rods has been performed.
	<u>SR 3.1.5.1</u>
	SR 3.1.5.1 requires that the accumulator pressure be checked every 7 days to ensure adequate accumulator pressure exists to provide sufficient scram force. The primary indicator of accumulator OPERABILITY is the accumulator pressure. A minimum accumulator pressure is specified, below which the capability of the accumulator to perform its intended function becomes degraded and the accumulator is considered inoperable. The minimum accumulator pressure of 940 psig is well below the expected pressure of approximately 1450 psig (Ref. 1). Declaring the accumulator inoperable when the minimum pressure is not maintained ensures that significant degradation in scram times does not occur. The 7 day Frequency has been shown to be acceptable through operating experience and takes into account indications available in the control room.
REFERENCES	1. UFSAR, Section 3.4.5.3 and Figure 3.4.10.
	2. UFSAR, Appendix K, Section VI.
	3. UFSAR, Chapter 14.

- Adda

B 3.9 REFUELING OPERATIONS

B 3.9.5 Control Rod OPERABILITY-Refueling

BASES

BACKGROUND	Control rods are components of the Control Rod Drive (CRD) System, the primary reactivity control system for the reactor. In conjunction with the Reactor Protection System, the CRD System provides the means for the reliable control of reactivity changes during refueling operation. In addition, the control rods provide the capability to maintain the reactor subcritical under all conditions and to limit the potential amount and rate of reactivity increase caused by a malfunction in the CRD System.
	UFSAR design criteria require that one of the two required independent reactivity control systems be capable of holding the reactor core subcritical under cold conditions (Ref. 1). The CRD System is the system capable of maintaining the reactor subcritical in cold conditions.
APPLICABLE SAFETY ANALYSES	Prevention and mitigation of prompt reactivity excursions during refueling are provided by refueling interlocks (LCO 3.9.1 and LCO 3.9.2), the SDM (LCO 3.1.1), the intermediate range monitor neutron flux scram (LCO 3.3.1.1), and the control rod block instrumentation (LCO 3.3.2.1).
	The safety analyses for the control rod withdrawal error during refueling (Ref. 2) and the fuel assembly insertion error (Ref. 3) evaluate the consequences of control rod withdrawal during refueling and also fuel assembly insertion with a control rod withdrawn. A prompt reactivity excursion during refueling could potentially result in fuel failure with subsequent release of radioactive material to the environment. Control rod scram provides protection should a prompt reactivity excursion occur.
•	Control rod OPERABILITY during refueling satisfies Criterion 3 of the NRC Policy Statement.
LCO	Each withdrawn control rod must be OPERABLE. The withdrawn control rod is considered OPERABLE if the scram accumulator pressure is \geq 940 psig and the control rod is capable of
	(continued)

PBAPS UNIT 2

Amendment No. 211

BASES	
LCO (continued)	being automatically inserted upon receipt of a scram signal. Inserted control rods have already completed their reactivity control function, and therefore, are not required to be OPERABLE.
APPLICABILITY	During MODE 5, withdrawn control rods must be OPERABLE to ensure that in a scram the control rods will insert and provide the required negative reactivity to maintain the reactor subcritical.
	For MODES 1 and 2, control rod requirements are found in LCO 3.1.2, "Reactivity Anomalies," LCO 3.1.3, "Control Rod OPERABILITY," LCO 3.1.4, "Control Rod Scram Times," and LCO 3.1.5, "Control Rod Scram Accumulators." During MODES 3 and 4, control rods are not able to be withdrawn since the reactor mode switch is in shutdown and a control rod block is applied. This provides adequate requirements for control rod OPERABILITY during these conditions.
ACTIONS	<u>A.1</u>
	With one or more withdrawn control rods inoperable, action must be immediately initiated to fully insert the inoperable control rod(s). Inserting the control rod(s) ensures the shutdown and scram capabilities are not adversely affected. Actions must continue until the inoperable control rod(s) is fully inserted.
SURVEILLANCE	SR 3.9.5.1 and SR 3.9.5.2
KEQUIREMENTS	During MODE 5, the OPERABILITY of control rods is primarily required to ensure a withdrawn control rod will automatically insert if a signal requiring a reactor shutdown occurs. Because no explicit analysis exists for automatic shutdown during refueling, the shutdown function is satisfied if the withdrawn control rod is capable of automatic insertion and the associated CRD scram accumulator pressure is \geq 940 psig.
	The 7 day Frequency takes into consideration equipment reliability, procedural controls over the scram accumulators, and control room alarms and indicating lights that indicate low accumulator charge pressures.
	(continued)

نه الا^ک

Amendment No. 211

SURVEILLANCE REQUIREMENTS (continued)	<u>SR 3.10.8.6</u> CRD charging water header pressure verification is performed to ensure the motive force is available to scram the control rods in the event of a scram signal. Since the reactor is depressurized in MODE 5, there is insufficient reactor pressure to scram the control rods. Verification of charging water header pressure ensures that if a scram were required, capability for rapid control rod insertion would exist. The minimum pressure of 940 psig is well below the expected pressure of approximately 1450 psig while still ensuring sufficient pressure for rapid control rod insertion. The 7 day Frequency has been shown to be acceptable through operating experience and takes into account indications available in the control room.
REFERENCES	 NEDE-24011-P-A-US, General Electric Standard Application for Reactor Fuel, Supplement for United States, February 1991.
	 Letter from T. Pickens (BWROG) to G.C. Lainas, NRC, "Amendment 17 to General Electric Licensing Topical Report NEDE-24011-P-A," August 15, 1986.

PBAPS UNIT 2

1

1



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

PECO ENERGY COMPANY

PUBLIC SERVICE ELECTRIC AND GAS COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-278

PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 216 License No. DPR-56

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by PECO Energy Company, et al. (the licensee) dated November 30, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I.
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health or safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. DPR-56 is hereby amended to read as follows:

(2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 216 , are hereby incorporated in the license. PECO shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and is to be implemented concurrently with Amendment 214, issued August 30, 1995.

FOR THE NUCLEAR REGULATORY COMMISSION

John F. Stolz, Director Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: January 11, 1996

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO. 216

うせ

FACILITY OPERATING LICENSE NO. DPR-56

DOCKET NO. 50-278

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised areas are indicated by marginal lines.

Remove	Insert
3.1-16	3.1-16
3.1-17	3.1-17
3.9-8	3.9-8
3.10-23	3.10-23
B3.1-31	B3.1-31
B3.1-32	B3.1-32
B3.1-33	B3.1-33
B3.9-14	B3.9-14
B3.9-15	B3.9-15
B3.10-36	B3.10-36

I

ľ

ACTIONS (continued)

; ; ;

CONDITION			REQUIRED ACTION	COMPLETION TIME
Β.	Two or more control rod scram accumulators inoperable with reactor steam dome pressure ≥ 900 psig.	B.1	Restore charging water header pressure to ≥ 940 psig.	20 minutes from discovery of Condition B concurrent with charging water header pressure < 940 psig
		AND		•
		B.2.1	Only applicable if the associated control rod scram time was within the limits of Table 3.1.4-1 during the last scram time Surveillance.	
			Declare the associated control rod scram time "slow."	l hour
		<u>or</u>		
		B.2.2	Declare the associated control rod inoperable.	1 hour

(continued)

ACTIONS (continued)

CONDITION			REQUIRED ACTION	COMPLETION TIME
С.	One or more control rod scram accumulators inoperable with reactor steam dome pressure < 900 psig.	C.1	Verify all control rods associated with inoperable accumulators are fully inserted.	Immediately upon discovery of charging water header pressure < 940 psig
		AND		
		C.2	Declare the associated control rod inoperable.	1 hour
D.	Required Action B.1 or C.1 and associated Completion Time not met.	D.1	NOTE Not applicable if all inoperable control rod scram accumulators are associated with fully inserted control rods. Place the reactor mode switch in the shutdown position.	Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY.
SR 3.1.5.1	Verify each control rod scram accumulator pressure is ≥ 940 psig.	7 days

.

3.9 REFUELING OPERATIONS

3.9.5 Control Rod OPERABILITY-Refueling

LCO 3.9.5 Each withdrawn control rod shall be OPERABLE.

APPLICABILITY: MODE 5.

ACTIONS

CONDITION	DITION REQUIRED ACTION		
A. One or more withdrawn control rods inoperable.	A.1	Initiate action to fully insert inoperable withdrawn control rods.	Immediately

SURVEILLANCE REQUIREMENTS

		SURVEILLANCE	FREQUENCY
SR	3.9.5.1	NOTENOTENOTENOTENOTENOTENOTENOTE	
		Insert each withdrawn control rod at least one notch.	7 days
SR	3.9.5.2	Verify each withdrawn control rod scram accumulator pressure is ≥ 940 psig.	7 days

SDM Test-Refueling 3.10.8

and a

SURVEILLANCE REQUIREMENTS (contin	nued)
-----------------------------------	-------

		SURVEILLANCE	FREQUENCY
SR	3.10.8.5	Verify each withdrawn control rod does not go to the withdrawn overtravel position.	Each time the control rod is withdrawn to "full out" position
			AND
			Prior to satisfying LCO 3.10.8.c requirement after work on control rod or CRD System that could affect coupling
SR	3.10.8.6	Verify CRD charging water header pressure ≥ 940 psig.	7 days

ACTIONS

<u>A.1 and A.2</u> (continued)

control rod is declared inoperable (Required Action A.2) and LCO 3.1.3 is entered. This would result in requiring the affected control rod to be fully inserted and disarmed, thereby satisfying its intended function, in accordance with ACTIONS of LCO 3.1.3.

The allowed Completion Time of 8 hours is reasonable, based on the large number of control rods available to provide the scram function and the ability of the affected control rod to scram only with reactor pressure at high reactor pressures.

B.1. B.2.1. and B.2.2

With two or more control rod scram accumulators inoperable and reactor steam dome pressure \geq 900 psig, adequate pressure must be supplied to the charging water header. With inadequate charging water pressure, all of the accumulators could become inoperable, resulting in a potentially severe degradation of the scram performance. Therefore, within 20 minutes from discovery of charging water header pressure < 940 psig concurrent with Condition B, adequate charging water header pressure must be restored. The allowed Completion Time of 20 minutes is reasonable, to place a CRD pump into service to restore the charging water header pressure, if required. This Completion Time is based on the ability of the reactor pressure alone to fully insert all control rods.

The control rod may be declared "slow," since the control rod will still scram using only reactor pressure, but may not satisfy the times in Table 3.1.4-1. Required Action B.2.1 is modified by a Note indicating that declaring the control rod "slow" only applies if the associated control scram time is within the limits of Table 3.1.4-1 during the last scram time test. Otherwise, the control rod would already be considered "slow" and the further degradation of scram performance with an inoperable accumulator could result in excessive scram times. In this event, the associated control rod is declared inoperable (Required Action B.2.2) and LCO 3.1.3 entered. This would

(continued)

PBAPS UNIT 3

ACTIONS

BASES

<u>B.1. B.2.1. and B.2.2</u> (continued)

result in requiring the affected control rod to be fully inserted and disarmed, thereby satisfying its intended function in accordance with ACTIONS of LCO 3.1.3.

The allowed Completion Time of 1 hour is reasonable, based on the ability of only the reactor pressure to scram the control rods and the low probability of a DBA or transient occurring while the affected accumulators are inoperable.

<u>C.1 and C.2</u>

With one or more control rod scram accumulators inoperable and the reactor steam dome pressure < 900 psig, the pressure supplied to the charging water header must be adequate to ensure that accumulators remain charged. With the reactor steam dome pressure < 900 psig, the function of the accumulators in providing the scram force becomes much more important since the scram function could become severely degraded during a depressurization event or at low reactor pressures. Therefore, immediately upon discovery of charging water header pressure < 940 psig, concurrent with Condition C, all control rods associated with inoperable accumulators must be verified to be fully inserted. Withdrawn control rods with inoperable accumulators may fail to scram under these low pressure conditions. The associated control rods must also be declared inoperable within 1 hour. The allowed Completion Time of 1 hour is reasonable for Required Action C.2, considering the low probability of a DBA or transient occurring during the time that the accumulator is inoperable.

<u>D.1</u>

The reactor mode switch must be immediately placed in the shutdown position if either Required Action and associated Completion Time associated with the loss of the CRD charging pump (Required Actions B.1 and C.1) cannot be met. This ensures that all insertable control rods are inserted and that the reactor is in a condition that does not require the

(continued)

PBAPS UNIT 3

BASES	
ACTIONS	<u>D.1</u> (continued)
	active function (i.e., scram) of the control rods. This Required Action is modified by a Note stating that the action is not applicable if all control rods associated with the inoperable scram accumulators are fully inserted, since the function of the control rods has been performed.
SURVEILLANCE	<u>SR 3.1.5.1</u>
	SR 3.1.5.1 requires that the accumulator pressure be checked every 7 days to ensure adequate accumulator pressure exists to provide sufficient scram force. The primary indicator of accumulator OPERABILITY is the accumulator pressure. A minimum accumulator pressure is specified, below which the capability of the accumulator to perform its intended function becomes degraded and the accumulator is considered inoperable. The minimum accumulator pressure of 940 psig is well below the expected pressure of approximately 1450 psig (Ref. 1). Declaring the accumulator inoperable when the minimum pressure is not maintained ensures that significant degradation in scram times does not occur. The 7 day Frequency has been shown to be acceptable through operating experience and takes into account indications available in the control room.
REFERENCES	1. UFSAR, Section 3.4.5.3 and Figure 3.4.10.
	2. UFSAR, Appendix K, Section VI.
	3. UFSAR, Chapter 14.

B 3.9 REFUELING OPERATIONS

B 3.9.5 Control Rod OPERABILITY-Refueling

BASES

BACKGROUND	Control rods are components of the Control Rod Drive (CRD) System, the primary reactivity control system for the reactor. In conjunction with the Reactor Protection System, the CRD System provides the means for the reliable control of reactivity changes during refueling operation. In addition, the control rods provide the capability to maintain the reactor subcritical under all conditions and to limit the potential amount and rate of reactivity increase caused by a malfunction in the CRD System.
	UFSAR design criteria require that one of the two required independent reactivity control systems be capable of holding the reactor core subcritical under cold conditions (Ref. 1). The CRD System is the system capable of maintaining the reactor subcritical in cold conditions.
APPLICABLE SAFETY ANALYSES	Prevention and mitigation of prompt reactivity excursions during refueling are provided by refueling interlocks (LCO 3.9.1 and LCO 3.9.2), the SDM (LCO 3.1.1), the intermediate range monitor neutron flux scram (LCO 3.3.1.1), and the control rod block instrumentation (LCO 3.3.2.1). The safety analyses for the control rod withdrawal error during refueling (Ref. 2) and the fuel assembly insertion error (Ref. 3) evaluate the consequences of control rod withdrawal during refueling and also fuel assembly insertion during refueling could potentially result in fuel failure with subsequent release of radioactive material to the environment. Control rod scram provides protection should a prompt reactivity excursion occur.
· -	Control rod OPERABILITY during refueling satisfies Criterion 3 of the NRC Policy Statement.
LCO	Each withdrawn control rod must be OPERABLE. The withdrawn control rod is considered OPERABLE if the scram accumulator pressure is \geq 940 psig and the control rod is capable of

(continued)

PBAPS UNIT 3

Amendment No. 216

 $\mathcal{T}_{\mathcal{T}}$

BASES	
LCO (continued)	being automatically inserted upon receipt of a scram signal. Inserted control rods have already completed their reactivity control function, and therefore, are not required to be OPERABLE.
APPLICABILITY	During MODE 5, withdrawn control rods must be OPERABLE to ensure that in a scram the control rods will insert and provide the required negative reactivity to maintain the reactor subcritical.
	For MODES 1 and 2, control rod requirements are found in LCO 3.1.2, "Reactivity Anomalies," LCO 3.1.3, "Control Rod OPERABILITY," LCO 3.1.4, "Control Rod Scram Times," and LCO 3.1.5, "Control Rod Scram Accumulators." During MODES 3 and 4, control rods are not able to be withdrawn since the reactor mode switch is in shutdown and a control rod block is applied. This provides adequate requirements for control rod OPERABILITY during these conditions.
ACTIONS	A.1
	With one or more withdrawn control rods inoperable, action must be immediately initiated to fully insert the inoperable control rod(s). Inserting the control rod(s) ensures the shutdown and scram capabilities are not adversely affected. Actions must continue until the inoperable control rod(s) is fully inserted.
SURVEILLANCE REQUIREMENTS	SR 3.9.5.1 and SR 3.9.5.2
	During MODE 5, the OPERABILITY of control rods is primarily required to ensure a withdrawn control rod will automatically insert if a signal requiring a reactor shutdown occurs. Because no explicit analysis exists for automatic shutdown during refueling, the shutdown function is satisfied if the withdrawn control rod is capable of automatic insertion and the associated CRD scram accumulator pressure is \geq 940 psig.
	The 7 day Frequency takes into consideration equipment reliability, procedural controls over the scram accumulators, and control room alarms and indicating lights that indicate low accumulator charge pressures.
	(continued)

Ċ

B 3.9-15

Amendment No. 216

SURVEILLANCE REQUIREMENTS (continued)	<u>SR 3.10.8.6</u> CRD charging water header pressure verification is performed to ensure the motive force is available to scram the control rods in the event of a scram signal. Since the reactor is depressurized in MODE 5, there is insufficient reactor pressure to scram the control rods. Verification of charging water header pressure ensures that if a scram were required, capability for rapid control rod insertion would exist. The minimum pressure of 940 psig is well below the expected pressure of approximately 1450 psig while still ensuring sufficient pressure for rapid control rod insertion. The 7 day Frequency has been shown to be acceptable through operating experience and takes into account indications available in the control room.
REFERENCES	 NEDE-24011-P-A-US, General Electric Standard Application for Reactor Fuel, Supplement for United States, February 1991.
	 Letter from T. Pickens (BWROG) to G.C. Lainas, NRC, "Amendment 17 to General Electric Licensing Topical Report NEDE-24011-P-A," August 15, 1986.

BASES



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 211 AND 216 TO FACILITY OPERATING

LICENSE NOS. DPR-44 and DPR-56

PECO ENERGY COMPANY PUBLIC SERVICE ELECTRIC AND GAS COMPANY DELMARVA POWER AND LIGHT COMPANY ATLANTIC CITY ELECTRIC COMPANY

PEACH BOTTOM ATOMIC POWER STATION, UNIT NOS. 2 AND 3

DOCKET NOS. 50-277 AND 50-278

1.0 INTRODUCTION

By letter dated November 30, 1995, the PECO Energy Company (the licensee) submitted a request for changes to the Peach Bottom Atomic Power Station, Unit Nos. 2 and 3, Technical Specifications (TS). The requested changes would revise the minimum allowable control rod scram accumulator pressure and charging water header pressure from a value of 955 psig to a value of 940 psig.

2.0 EVALUATION

Control rods are provided in a boiling water reactor as part of the reactivity controls systems. The safety objective of the control rods is to rapidly shut down the reactor to prevent fuel damage from any abnormal operating transient. Positioning of the control rods within the reactor, including rapid insertion, is performed with control rod drive mechanisms and the associated control rod drive hydraulic system. A scram accumulator is provided as part of the hydraulic control unit for each control rod. The scram accumulator stores energy in the form of pressurized water to insert a control rod independent of any other form of energy. Pressure in the accumulator is maintained with a supply of pressurized nitrogen. Pressurized water is provided to the accumulators via the control rod drive hydraulic system charging header.

When reactor pressure is greater than 900 psig, the reactor pressure alone is sufficient to fully insert all control rods if required. However, when reactor pressure is less than 900 psig, reactor pressure alone may not be sufficient to fully insert all control rods. Under these conditions, the pressure in the scram accumulators provides assurance that the rods will insert as required. In order to ensure that accumulator pressure is

9601180384 960111 PDR ADOCK 05000277 P PDR adequately maintained at all times, technical specification requirements are imposed on minimum accumulator pressure and minimum charging header pressure.

During the licensee's development of its submittal for improved technical specifications (Technical Specification Change Request (TSCR) 93-16, submitted September 29, 1994), the licensee proposed a value of 955 psig as the TS limit on scram accumulator and charging water header minimum pressure in TS 3.1.5.B.1, surveillance requirement (SR) 3.1.5.1, SR 3.9.5.2, SR 3.10.8.6 and in the associated TS Bases. The 955 psig value represented a nominal value for the accumulator and charging water header. The staff issued the improved technical specifications as Amendments 210 and 214 to the Peach Bottom Atomic Power Station operating licenses on August 30, 1995.

The licensee subsequently reviewed General Electric (GE) Service Information Letter (SIL) 429 Revision 1. GE SIL 429 Revision 1, recommends that licensees amend the TS to allow the accumulator pressure switch setpoint to 940 psig or greater. The accumulator pressure switch causes an alarm to activate in the control room if accumulator pressure drops below the setpoint. The licensee has proposed to change the TS requirement for scram accumulator minimum pressure and charging water header minimum pressure to 940 psig or greater to be consistent with the SIL recommendations, to take full advantage of the setpoint range and to provide more margin to the Technical Specification limits during normal operation. The licensee stated that the minimum pressure of the accumulator water required to provide sufficient stored energy to complete a reactor scram is 940 psig.

The staff has reviewed the licensee's application. The proposed changes are consistent with the GE recommendations for the Peach Bottom boiling water reactor product line and are adequate to ensure that control rods fully insert into the core under required conditions. Therefore, the staff finds the proposed changes acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Pennsylvania State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards

consideration, and there has been no public comment on such finding (60 FR 63073). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 <u>CONCLUSION</u>

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: J. Shea

Date: January 11, 1996

Ċ,