Technical Requirements Manual

Appendix J

(Amendment 46)

LaSalle Unit 2 Cycle 9

Core Operating Limits Report

and

Reload Transient Analysis Results

May 2001

Technical Requirements Manual - Appendix J

/

Section 1

LaSalle Unit 2 Cycle 9

Core Operating Limits Report

May 2001

Issuance of Changes Summary

Affected Section	Affected Pages	Summary of Changes	Date
All	All	Original Issue (Cycle 9)	11/00
References; 6	iii; 6-1	Revised Requirements for Use of SUBTIP Methodology	12/00
All	All	ITS changes, RBM trip setpoint and allowable value changes, TIP symmetry Chi-Squared testing, incorporated results of revised thermal limits with correct thermal conductivities, and other necessary administrative changes	5/01

Table of Contents

Refer	ences		iii
1.	Avera	ge Planar Linear Heat Generation Rate (3.2.1)	1-1
	1.1	Tech Spec Reference	1-1
	1.2	Description	1-1
2.	Minin	num Critical Power Ratio (3.2.2)	2.1
	Tech	Spec Reference	2-1
	2.2	Description	2-1
3.	Linea	r Heat Generation Rate (3.2.3)	3-1
	3.1	Tech Spec Reference	3-1
	3.2	Description	3-1
4.	Cont	rol Rod Withdrawal Block Instrumentation (3.3.2.1)	4-1
	4.1	Tech Spec Reference	4-1
	4.2	Description	4-1
5.	Allov	ved Modes of Operation (B 3.2.2, B 3.2.3)	5-1
6.	Trave	ersing In-Core Probe System (3.2.1, 3.2.2, 3.2.3)	6-1
	6.1	Tech Spec Reference	6-1
	6.2	Description	6-1
	6.3	Bases	6-1

References

- 1. Letter from D. M. Crutchfield to All Power Reactor Licensees and Applicants, Generic Letter 88-16; Concerning the Removal of Cycle-Specific Parameter Limits from Tech Specs, dated October 4, 1988.
- 2. LaSalle Unit 2 Cycle 9 Neutronics Licensing Report (NLR), NFM ID#0000115, October 2000.
- 3. LaSalle Unit 2 Cycle 9 Reload Analysis, EMF-2437, Revision 0, October 2000.
- 4. LaSalle Unit 2 Cycle 9 Plant Transient Analysis, EMF-2440, Revision 0, October 2000.
- 5. LOCA Break Spectrum Analysis for LaSalle Units 1 and 2, EMF-2174(P), March 1999.
- 6. LaSalle LOCA-ECCS Analysis MAPLHGR Limits for ATRIUM-9B fuel, EMF-2175(P), March 1999.
- LaSalle Extended Operating Domain (EOD) and Equipment Out of Service (EOOS) Safety Analysis for ATRIUM-9B Fuel, EMF-95-205(P), Rev. 2, June 1996.
- ARTS Improvement Program analysis for LaSalle County Station Units 1 and 2, NEDC-31531P, December 1993 and Supplement 1, June 1998 (Removal of Direct Scram Bypassed Limit).
- 9. Lattice-Dependent MAPLHGR Report for LaSalle County Station Unit 2 Reload 6 Cycle 7, 24A5162AA, Revision 0, December 1994.
- 10. "Project Task Report, LaSalle County Station, Power uprate Evaluation, Task 407: ECCS Performance," GE report number GE-NE-A1300384-39-01, Revision 0, Class 3, dated September 1999.
- 11. Evaluation of a Postulated Slow Turbine Control Valve Closure Event for LaSalle County Station, Units 1 and 2, GE-NE-187-13-0792, Revision 2, July 1998.
- 12. Transient Analysis Evaluation for LaSalle 3 TCV Operation at Power Uprate and MELLLA Conditions, NFM:BSA:00-025, R.W. Tsai to D. Bost, April 13, 2000.
- "Updated Transient Analysis: Abnormal Start-up of an Idle Recirculation Loop for LaSalle County Nuclear Station, Units 1 and 2", B33-00296-03P, March 1998 and "LaSalle Unit 2 Cycle 8 Abnormal Idle Recirculation Loop Startup Analysis", DEG:99:070, D. Garber to R. Chin, March 8, 1999.
- 14. "TIP Symmetry Testing", J.H. Riddle to R. Chin, January 20, 1997 and "TIP Symmetry Testing", DEG:99:085, D. Garber to R. Chin, March 8, 1999
- 15. "POWERPLEX-II CMSS Startup Testing", DEG:00:254, D. Garber to R. Chin, December 5, 2000.
- "On-Site and Off-Site Reviews of the GE Turbine Control Valve Slow Closure Analysis", T.Rieck to G.Spedl, NFS:BSS:93-117, May 19, 1993.
- 17. "LaSalle Units 1 and 2 Operating Limits with Multiple Equipment Out of Service (EOOS)", NFS:BSA:95-024, April 6, 1995.
- 18. NFM Calculation No. BSA-L-99-07, MAPFACf Thermal Limit Multiplier for 105% Maximum Core Flow
- 19. "ComEd GE9/GE10 LHGR Improvement Program" J11-03692-LHGR, Revision 1, February 2000.
- 20. "LaSalle County Station Power Uprate Project", Task 201: Reactor Power/Flow Map, GE-NE-A1300384-07-01, Revision 1, September 1999.
- 21. "Evaluation of CBH Effects on Fresh Fuel for LaSalle Unit 2 Cycle 9", DEG:00:232, D. Garber to R. Chin, October 2000.
- 22. DEG:00:091, "Revised Measured Nodal Power Distribution Uncertainty for POWERPLEX Operation with Uncalibrated LPRMs", David Garber to Dr. R. J. Chin, April 5, 2000.
- 23. "POWERPLEX-II CMSS Startup Testing", DEG:00:256, D. Garber to R. Chin, December 6, 2000.
- 24. "Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications", NEDO-32465-P-A, August 1996.

May 2001

- 25. "ANFB Critical Power Correlation", ANF-1125(P)(A) and Supplements 1 and 2, Advanced Nuclear Fuels Corporation, April 1990.
- 26. Letter, Ashok C. Thadani (NRC) to R. A. Copeland (SPC), "Acceptance for Referencing of ULTRAFLOW[™] Spacer on 9X9-IX/X BWR Fuel Design," July 28, 1993.
- 27. Advanced Nuclear Fuels Corporation Critical Power Methodology for Boiling Water Reactors/Advanced Nuclear Fuels Corporation Critical Power Methodology for Boiling Water Reactors: Methodology for Analysis of Assembly Channel Bowing Effects/NRC Correspondence, XN-NF-524(P)(A) Revision 2 and Supplement 1 Revision 2, Supplement 2, Advanced Nuclear Fuels Corporation November 1990.
- 28. COTRANSA 2: A Computer Program for Boiling Water Reactor Transient Analysis, ANF-913(P)(A), Volume 1, Revision 1 and Volume 1 Supplements 2, 3, and 4, Advanced Nuclear Fuels Corporation, August 1990.
- 29. HUXY: A Generalized Multirod Heatup Code with 10CFR50, Appendix K Heatup Option, ANF-CC-33(P)(A), Supplement 1 Revision 1; and Supplement 2, Advanced Nuclear Fuels Corporation, August 1986 and January 1991, respectively.
- Advanced Nuclear Fuels Methodology for Boiling Water Reactors, XN-NF-80-19(P)(A), Volume 1, Supplement 3, Supplement 3 Appendix F, and Supplement 4, Advanced Nuclear Fuels Corporation, November 1990.
- Exxon Nuclear Methodology for Boiling Water Reactors: Application of the ENC Methodology to BWR Reloads, XN-NF-80-19(P)(A), Volume
 Revision 1, Exxon Nuclear Company, June 1986.
- Exxon Nuclear Methodology for Boiling Water Reactors THERMEX: Thermal Limits Methodology Summary Description, XN-NF-80-19(P)(A), Volume 3, Revision 2, Exxon Nuclear Company, January 1987.
- 33. Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel, XN-NF-85-67(P)(A) Revision 1, Exxon Nuclear Company, September 1986.
- Advanced Nuclear Fuels Corporation Generic Mechanical Design for Advanced Nuclear Fuels Corporation 9X9-IX and 9X9-9X BWR Reload Fuel, ANF-89-014(P)(A), Revision 1 and Supplements 1 and 2, October 1991.
- 35. Volume 1 STAIF A Computer Program for BWR Stability Analysis in the Frequency Domain, Volume 2 STAIF A Computer Program for BWR Stability Analysis in the Frequency Domain, Code Qualification Report, EMF-CC-074(P)(A), Siemens Power Corporation, July 1994.
- RODEX2 Fuel Rod Thermal-Mechanical Response Evaluation Model, XN-NF-81-58(P)(A), Revision 2 Supplements 1 and 2, Exxon Nuclear Company, March 1984.
- 37. XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis, XN-NF-84-105(P)(A), Volume 1 and Volume 1 Supplements 1 and 2; Volume 1 Supplement 4, Advanced Nuclear Fuels Corporation, February 1987 and June 1988, respectively.
- 38. Advanced Nuclear Fuels Corporation Methodology for Boiling Water Reactors EXEM BWR Evaluation Model, ANF-91-048(P)(A), Advanced Nuclear Fuels Corporation, January 1993.
- 39. Exxon Nuclear Methodology for Boiling Water Reactors Neutronic Methods for Design and Analysis, XN-NF-80-19(P)(A) Volume 1 and Supplements 1 and 2, Exxon Nuclear Company, Richland, WA 99352, March 1983.
- 40. Exxon Nuclear Plant Transient Methodology for Boiling Water Reactors, XN-NF-79-71(P)(A), Revision 2 Supplements 1, 2, and 3, Exxon Nuclear Company, March 1986.
- 41. Generic Mechanical Design Criteria for BWR Fuel Designs, ANF-89-98(P)(A), Revision 1 and Revision 1 Supplement 1, Advanced Nuclear Fuels Corporation, May 1995.
- 42. NEDE-24011-P-A, "General Electric Standard Application for Reactor Fuel," Rev. 14, June 2000.

- 43. Commonwealth Edison Topical Report NFSR-0085, "Benchmark of BWR Nuclear Design Methods," November 1990, Revision 0.
- 44. Commonwealth Edison Topical Report NFSR-0085, Supplement 1, "Benchmark of BWR Nuclear Design Methods Quad Cities Gamma Scan Comparisons," April 1991, Revision 0.
- 45. Commonwealth Edison Topical Report NFSR-0085, Supplement 2, "Benchmark of BWR Nuclear Design Methods Neutronic Licensing Analyses," April 1991, Revision 0.
- 46. Commonwealth Edison Topical Report NFSR-0091, "Benchmark of CASMO/MICROBURN BWR Nuclear Design Methods," Revision 0, Supplements 1 and 2, December 1991, March 1992, and May 1992, respectively; SER letter dated March 22, 1993.
- 47. BWR Jet Pump Model Revision for RELAX, ANF-91-048(P)(A), Supplement 1 and Supplement 2, Siemens Power Corporation, October 1997.
- 48. ANFB Critical Power Correlation Application for Coresident Fuel, EMF-1125(P)(A), Supplement 1, Appendix C, Siemens Power Corporation, August 1997.
- 49. ANFB Critical Power Correlation Determination of ATRIUM-9B Additive Constant Uncertainties, ANF-1125(P)(A), Supplement 1, Appendix E, Siemens Power Corporation, September 1998.
- 50. Commonwealth Edison Company Docket No. 50-374, LaSalle County Station, Unit 2 Facility Operating License, License No. NPF-18.
- 51. "LaSalle Unit 2 Cycle 9 Operating Limits for Proposed ITS Scram Times and Corrected Fuel Thermal Conductivities", DEG:01:046, D. Garber to R. Chin, March 22, 2001.
- 52. "LaSalle Unit 1 and Unit 2 Rod Block Monitor COLR Setpoint Change", NFM:MW:01-0106, Anthony Giancatarino to Jeff Nugent, April 3, 2001.

1. Average Planar Linear Heat Generation Rate (APLHGR) (3.2.1)

1.1 <u>Tech Spec Reference:</u> Tech Spec 3.2.1

1.2 Description:

For operation without a full TIP set from BOC to 500 MWd/MT a penalty of 11.01% must be applied to all APLHGR limits.

1.2.1 GE Fuel

The MAPLHGR Limit is determined using the applicable Lattice-Type MAPLHGR limits from Tables 1.2-1 and 1.2-2. For Single Reactor Recirculation Loop Operation, the MAPLHGR limits in Tables 1.2-1 and 1.2-2 are multiplied by the MAPFAC multipliers provided in Figures 1.2-1 and 1.2-2.

1.2.2 SPC Fuel

The MAPLHGR Limit is the Lattice-Type MAPLHGR Limit. The Lattice-Type MAPLHGR limits are determined from the table given below:

Fuel Type	Cycle First Inserted
SPCA9-381B-13GZ7-80M	8
SPCA9-384B-11GZ6-80M	8
SPC-A9-391B-14G8.0-100M	9
SPC-A9-410B-19G8.0-100M	9
SPC-A9-383B-16G8.0-100M	9
SPC-A9-396B-12GZ-100M	9
(References 2 and 3)	
Planar Average Exposure	MAPLHGR (kW/ft)
(GWd/MTU)	(all Siemens fuel
	types)
0.0	13.5
20.0	13.5
61.1	9.39
(Reference	es 3 and 6)

For single loop operation, the MAPLHGR limits from the table above are multiplied by the MAPLHGR multiplier. The MAPLHGR multiplier for SPC fuel is 0.90. (References 3, 5 and 6)

Table 1.2-1

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR)

VS.

Average Planar Exposure for Fuel Type GE9B-P8CWB322-11GZ-100M-150-CECO (Reference 9 and 19)

Exposure Exposure (MWD/ST) (MWD/MT)

Lattice-Type MAPLHGR (kW/ft)

		P8CWL07	P8CWL345	P8CWL362	P8CWL362	P8CWL345	P8CWL071
		1 NOG	5G5.0/4G4.0	9G4.0	2G5.0/9G4.0	9G4.0	11GE
0	0	12.74	12.09	11.65	11.25	12.11	12.74
200	220.5	12.67	12.13	11.70	11.32	12.15	12.67
1000	1102.3	12.48	12.22	11.83	11.46	12.25	12.48
2000	2204.6	12.42	12.35	12.00	11.61	12.39	12.42
3000	3306.9	12.41	12.48	12.14	11.77	12.54	12.41
4000	4409.2	12.44	12.62	12.28	11.94	12.70	12.44
5000	5511.6	12.46	12.77	12.43	12.11	12.86	12.46
6000	6613.9	12.49	12.90	12.58	12.29	13.02	12.49
7000	7716.2	12.51	13.03	12.73	12.46	13.19	12.51
8000	8818.5	12.54	13.16	12.88	12.64	13.33	12.54
9000	9920.8	12.55	13.30	13.01	12.82	13.43	12.55
10000	11023.1	12.57	13.42	13.12	12.98	13.44	12.57
12500	13778.9	12.41	13.41	13.08	13.04	13.40	12.41
15000	16534.7	12.04	13.05	12.78	12.77	13.06	12.04
20000	22046.2	11.27	12.38	12.16	12.16	12.40	11.27
25000	27557.8	10.49	11.74	11.51	11.51	11.76	10.49
27215.6	30000	12.314	12.314	12.314	12.314	12.314	12.314
48080.8	53000	10.800	10.800	10.800	10.800	10.800	10.800
58967.1	65000	6.000	6.000	6.000	6.000	6.000	6.000
Lattice No.		733	1817	1818	1819	1820	1821

1

Table 1.2-2

Maximum Average Planar Linear Heat Generation Rate (MAPLHGR)

VS.

Average Planar Exposure for Fuel Type GE9B-P8CWB320-9GZ3-100M-150-CECO (Reference 9 and 19)

Exposure Exposure (MWD/ST) (MWD/MT)

Lattice-Type MAPLHGR (kW/ft)

		P8CWL07	P8CWL346	P8CWL358	P8CWL358	P8CWL346	P8CWL071
		1 NOG	4G5.0/3G4.0	7G4.0	2G5.0/7G4.0	7G4.0	9GE2
0	0	12.74	12.05	11.62	11.10	12.09	12.74
200	220.5	12.67	12.09	11.64	11.15	12.14	12.67
1000	1102.3	12.48	12.19	11.73	11.27	12.25	12.48
2000	2204.6	12.42	12.32	11.86	11.44	12.39	12.42
3000	3306.9	12.41	12.44	11.99	11.62	12.53	12.41
4000	4409.2	12.44	12.57	12.13	11.80	12.67	12.44
5000	5511.6	12.46	12.70	12.27	11.96	12.81	12.46
6000	6613.9	12.49	12.83	12.42	12.09	12.89	12.49
7000	7716.2	12.51	12.97	12.54	12.23	12.98	12.51
8000	8818.5	12.54	13.07	12.62	12.37	13.07	12.54
9000	9920.8	12.55	13.15	12.70	12.51	13.15	12.55
10000	11023.1	12.57	13.20	12.77	12.66	13.22	12.57
12500	13778.9	12.41	13.19	12.70	12.67	13.20	12.41
15000	16534.7	12.04	12.89	12.40	12.40	12.90	12.04
20000	22046.2	11.27	12.29	11.82	11.82	12.30	11.27
25000	27557.8	10.49	11.69	11.25	11.25	11.70	10.49
27215.6	30000	12.314	12.314	12.314	12.314	12.314	12.314
48080.8	53000	10.800	10.800	10.800	10.800	10.800	10.800
58967.1	65000	6.000	6.000	6.000	6.000	6.000	6.000
					<u> </u>		
Lattice No.		733	1812	1813	1814	1815	1816

1 0.95 0.9 Power-Dependent SLO MAPLHGR Multiplier, MAPFAC_P 0.85 0.8 0.75 For 25 > P: No Thermal Limits Monitoring Required; If Official 0.7 Monitoring is Desired, the Equations for $\geq 25\%$ Power 0.65 May Be Extrapolated for 25 > P, provided the Official 0.6 monitoring is only performed with the TCV/TSV closure scrams and RPT enabled. 0.55 0.5 For $25 \le P \le 100$ 0.45 MAPFACp = 1.0+0.005224 (P-100) 0.4 For 100 < P, MAPFACp = 1.00 0.35 0.3 P = % Rated Core Thermal Power 0.25 0.2 0.15 0.1 0.05 0 90 100 85 95 55 60 65 70 75 80 50 25 30 35 40 45 **Core Thermal Power (% Rated)**

Figure 1.2-1 Power-Dependent SLO MAPLHGR Multipliers for GE Fuel (MAPFAC,) (References 8 and 19)

LaSalle Unit 2 Cycle 9

Figure 1.2-2 Flow-Dependent SLO MAPLHGR Multiplier (MAPFAC _F) for GE Fuel (References 8, 18, and 19)



2. Minimum Critical Power Ratio (3.2.2)

2.1 Tech Spec Reference:

Tech Spec 3.2.2.

2.2 <u>Description:</u>

Prior to initial scram time testing for an operating cycle, the MCPR operating limit is based on the Technical Specification Scram Times. For Technical Specification requirements refer to Technical Specification table 3.1.4-1.

TIP Symmetry Chi-squared testing shall be performed prior to reaching 500 MWd/MTU to validate the MCPR calculation.

MCPR limits from BOC to Coastdown are applicable up to a core average exposure of 30,266.2 MWd/MTU (which is the licensing basis exposure used by SPC). (Reference 3)

2.2.1 Manual Flow Control MCPR Limits

The Governing MCPR Operating Limit while in Manual Flow Control is either determined from 2.2.1.1 or 2.2.1.2, whichever is greater at any given power, flow condition.

- 2.2.1.1 Power-Dependent MCPR (MCPRp)*
 - 2.2.1.1.1 GE Fuel

Table 2-1 gives the MCPR_P limit as a function of core thermal power for Tech Spec Scram Times.

2.2.1.1.2 Siemens Fuel

Table 2-2 gives the MCPRp limit as a function of core thermal power for Tech Spec Scram Times.

2.2.1.2 Flow-Dependent MCPR (MCPRF)

Table 2-3 gives the MCPR_F limit as a function of flow.

2.2.2 Automatic Flow Control MCPR Limits

Automatic Flow Control MCPR Limits are not provided for L2C9.

* For thermal limit monitoring at greater than 100%P, the 100% power MCPRp limits should be applied.

Table 2-1 MCPR_P for GE Fuel (References 2, 3, and 51)

Operation from BOC to Coastdown**

Percent Core Thermal Power*

EOOS Combination	0	25	25	60	80	80	100
No EOOS	2.70	2.20	2.01	1.53			1.51
Single RR Loop only	2.71	2.21	2.02	1.54			1.52
EOOS***	2.85	2.35	2.24		1.96	1.86	1.63
EOOS***/Single RR Loop	2.86	2.36	2.25		1.97	1.87	1.64

* Values are interpolated between relevant power levels. For operation at exactly 25% or 80% CTP, the more limiting value is used. 3489 MWt is rated power

- ** Coastdown thermal limits are not provided in this COLR
- *** Allowable EOOS conditions are listed in Section 5.

Table 2-2 MCPR_P for Siemens Fuel (References 2, 3, 21, and 51)

For all Siemens fuel EXCEPT Fuel Type 18 in 10B cell locations from BOC to Coastdown**.

EOOS Combination	0	25	25	60	80	80	100
No EOOS	2.70	2.20	1.93	1.48			1.41
Single RR Loop only	2.71	2.21	1.94	1.49			1.42
EOOS***	2.85	2.35	2.17		1.70	1.62	1.53
EOOS***/Single RR Loop	2.86	2.36	2.18		1.71	1.63	1.54

Percent Core Thermal Power*

For <u>ONLY</u> Siemens Fuel Type 18 in 10B cell locations for operation with rod pattern targeted from BOC to Coastdown**

	Pe	rcent Co	e Therma	al Power*			
EOOS Combination	0	25	25	60	80	80	100
No EOOS	2.72	2.22	1.95	1.50			1.43
Single RR Loop only	2.73	2.23	1.96	1.51			1.44
EOOS***	2.87	2.37	2.19		1.72	1.64	1.55
EOOS***/Single RR Loop	2.88	2.38	2.20		1.73	1.65	1.56

* Values are interpolated between relevant power levels. For operation at exactly 25% or 80% CTP, the more limiting value is used. 3489 MWt is rated power.

** Coastdown thermal limits are not provided in this COLR

*** Allowable EOOS conditions are listed in Section 5.

Table 2-3 MCPR_F for GE and Siemens Fuel (Reference 3)

MCPR_F limits for 105% Maximum Attainable Core Flow

Flow (% rated)	MCPR _E ATRIUM-9B	MCPR _F GE9
0	1.60	1.66
30	1.60	1.66
105	1.11	1.11

The MCPR_F limits are applicable from BOC through coastdown and in all EOOS scenarios.

Linear Heat Generation Rate (3.2.3) 3.

Tech Spec Reference: 3.1

Tech Spec 3.2.3.

3.2 Description:

> For operation without a full TIP set from BOC to 500 MWd/MT a penalty of 11.01% must be applied to all LHGR limits.

3.2.1 GE Fuel

> The LHGR Limit is the product of the LHGR Limit in the following tables and the minimum of either the power dependent LHGR Factor*, LHGRFAC_P, or the flow dependent LHGR Factor, LHGRFAC_F. The LHGR Factors (LHGRFAC_P and LHGRFAC_F) for the GE fuel are determined from Figures 3.2-1 through 3.2-3. The following GE LHGR limits apply for the entire cycle exposure range: (References 2, 8, 10 and 19)

GE9B-P8CWB322-11GZ-100M-150-CECO (bundle 3861 in Reference 2) 1.

Nodal Exposure (GWd/MT)	LHGR Limit (KW/ft)
0	13.75
13.06	13.75
27.80	11.75
50.31	10.31
60.89	6.00

Nodal Exposure (GWd/MT)	LHGR Limit (KW/ft)
0.00	14.25
12.14	14.25
26.19	12.18
48.16	10.80
59.93	6.00

GE9B-P8CWB320-9GZ-100M-150-CECO (bundle 3860 in Reference 2)

3.2.2 Siemens Fuel

2.

The LHGR Limit is the product of the Steady-State LHGR Limit (given below from Reference 3) and the minimum of either the power dependent LHGR Factor*, $LHGRFAC_{P}$, or the flow dependent LHGR Factor, $LHGRFAC_{P}$. $LHGRFAC_{P}$ is determined from Table 3-1. LHGRFAC_F is determined from Table 3-2. SPC LHGRFAC multipliers from BOC to Coastdown are applicable up to a core average exposure of 30,266.2 MWd/MTU (which is the licensing basis exposure used by SPC). (Reference 3)

Planar Average Exposure (GWd/MTU)	LHGR limit (kW/ft)
0.0	14.4
15.0	14.4
61.1	8.32

* For thermal limit monitoring at greater than 100%P, the 100% power LHGRFACp limits should be applied.

1 0.95 0.9 0.85 Power-Dependent LHGR Multiplier, LHGRFACP 0.8 For 25 > P: 0.75 No Thermal Limits Monitoring Required; If Official 0.7 Monitoring is Desired, the Equations for $\geq 25\%$ Power May Be Extrapolated for 25 > P, provided the Official 0.65 monitoring is only performed with the TCV/TSV closure 0.6 scrams and RPT enabled. 0.55 For $25 \le P \le 100$ 0.5 LHGRFACp = 1.0+0.005224 (P-100) 0.45 0.4 For 100 < P, LHGRFACp = 1.00 0.35 P = % Rated Core Thermal Power 0.3 0.25 0.2 0.15 0.1 0.05 0 95 90 100 85 75 65 70 80 55 60 40 45 50 25 30 35 Core Thermal Power (% Rated)

Technical Requirements Manual - Appendix J L2C9 Core Operating Limits Report

Figure 3.2-1 Power-Dependent LHGR Multipliers for GE Fuel (Formerly MAPFAC_P) (References 8 and 19)

LaSalle Unit 2 Cycle 9

Figure 3.2-2 Power-Dependent LHGR Multiplier for GE Fuel (TCV(s) Slow Closure) (formerly MAPFAC_P)

(References 11 and 19)





Figure 3.2-3 Flow-Dependent LHGR Multiplier for GE Fuel (formerly MAPFACF)

Table 3-1 LHGRFAC_P for Siemens Fuel (References 3 and 51)

Operation from BOC to Coastdown**

EOOS Combination

Single RR Loop only

No EOOS

EOOS***

Percent Core Thermal Power"							
 0	25	25	60	80	80	_	
0.77	0.77	0.77	1.00				

0.77

0.67

0.77

0.67

0.77

0.67

0.67

1.00

0.85

0.85

0.89

0.89

EOOS***/Single RR Loop	0.67	0.67	0.67	0.85	0.89	0.89

Values are interpolated between relevant power levels. For operation at exactly 25% or 80% CTP, the * more limiting value is used. 3489 MWt is rated power.

** Coastdown thermal limits are not provided in this COLR

*** Allowable EOOS conditions are listed in Section 5.

100

1.00

1.00

0.89

0.89

Table 3-2 LHGRFAC_F for Siemens Fuel (Reference 3)

Values Applicable for up to 105% Maximum Attainable Core Flow

Flow (% rated)	LHGRFAC _F ATRIUM-9B
0	0.69
30	0.69
76	1.00
105	1.00

These LHGRFAC_f multipliers apply from BOC through coastdown and in all EOOS scenarios.

4. Control Rod Withdrawal Block Instrumentation (3.3.2.1)

4.1 <u>Tech Spec Reference:</u>

Tech Spec Table 3.3.2.1-1.

4.2 <u>Description:</u>

The Rod Block Monitor Upscale Instrumentation Setpoints are determined from the relationships shown below:

ROD BLOCK MONITOR UPSCALE TRIP FUNCTION	TRIP SETPOINT	ALLOWABLE VALUE
Two Recirculation Loop Operation*	0.66 W + 51%**	0.66 W + 54%**
Single Recirculation Loop Operation*	0.66 W + 45.7%**	0.66 W + 48.7%**

- * This setpoint may be lower/higher and will still comply with the RWE Analysis, because RWE is analyzed unblocked.
- ** Clamped, with an allowable value not to exceed the allowable value for recirculation loop flow (W) of 100%.

5. Allowed Modes of Operation (B 3.2.2, B 3.2.3)

Equipment Out of Service Ontione1	Standard			Coastdo
	*********	OPERATING RE	GION	
The Allowed Modes of Operation with combinations of Equ	ipment Out-of-Se	rvice are as des	cribed below	

Equipment Out of Service Options ¹	Standard	MELLLA	ICF/	Coastdown ^s
None	Yes	Yes	Yes	No
Feedwater Heaters ² (Reference 8)	Yes	No ³	Yes	No
Single RR Loop ¹⁰ (Reference 8)	Yes	No ⁸	N/A	No
Turbine Bypass Valves (Reference 8)	Yes	Yes	Yes	No
EOC Recirculation Pump Trip (Reference 8)	Yes	Yes	Yes	No
TCV Slow Closure/EOC Recirculation Pump Trip (Reference11)	Yes	Yes	Yes	No
TCV Slow Closure/EOC Recirculation Pump Trip / Feedwater Heaters ² (References 11, 16, and 17)	Yes	No ³	Yes	No
Turbine Bypass Valves / Feedwater Heaters ² (Reference 8)	No	No	No⁵	No
EOC Recirculation Pump Trip / Feedwater Heaters ² (Reference 8)	Yes⁴	No ³	Yes⁴	Νο
TCV Stuck Closed ⁶ (Reference 12)	Yes	Yes	Yes	No

- Each EOOS condition may be combined with one SRV OOS, up to two TIP Machines OOS or the equivalent number of TIP channels (100% available at startup from a refuel outage), a 20°F reduction in feedwater temperature (without Feedwater Heaters considered OOS), cycle startup with uncalibrated LPRMs (BOC to 500 MWd/MTU), and/or up to 50% of the LPRMs out of service.
- 2. Up to 100°F Reduction in Feedwater Temperature Allowed with Feedwater Heaters Out-of-Service. Feedwater Heaters OOS may be an actual OOS condition, or an intentionally entered mode of operation to extend the cycle energy.
- 3. If operating with Feedwater Heaters Out-of-Service, operation in MELLLA is supported by current transient analyses, but administratively prohibited due to core stability concerns.
- EOC Recirculation Pump Trip OOS/Feedwater Heaters OOS is allowed during non-coastdown operation using the TCV Slow Closure/EOC Recirculation Pump Trip OOS/Feedwater Heaters OOS operating limits.
- 5. Only when operating in coastdown, otherwise this combination is not allowed.
- 6. Operation is only allowed when less than 10.5 million lbm/hr steam flow and when average position of 3 open TCVs is less than 50% open, with FCL <103%, and the MCFL setpoint ≥ 120%. TCV Stuck Closed may be in combination with any EOOS except TBVOOS or TCV Slow Closure. If in combination with other EOOS(s), thermal limits may require adjustment for the other EOOS(s) as designated in Sections 1, 2, and 3.</p>
- 7. ICF is analyzed for up to 105% core flow.
- 8. The SLO boundary was not moved up with the incorporation of MELLLA. The flow boundary for SLO at uprated conditions remains the ELLLA boundary for pre-uprate conditions. (Reference 20)
- 9. Coastdown is defined to begin at a core average exposure of 30,266.2 MWd/MTU (which is the licensing basis exposure used by SPC). (Reference 3)
- 10. Single loop operation is allowed with any of the EOOS options listed in this table.

LaSalle Unit 2 Cycle 9

May 2001

6. Traversing In-Core Probe System (3.2.1, 3.2.2, 3.2.3)

6.1 Tech Spec Reference:

Tech Spec Sections 3.2.1, 3.2.2, 3.2.3 for thermal limits require the TIP system for recalibration of the LPRM detectors and monitoring thermal limits.

6.2 Description:

When the traversing in-core probe (TIP) system (for the required measurement locations) is used for recalibration of the LPRM detectors and monitoring thermal limits, the TIP system shall be operable with the following:

- 1. movable detectors, drives and readout equipment to map the core in the required measurement locations, and
- 2. indexing equipment to allow all required detectors to be calibrated in a common location.

For BOC to BOC + 500 MWD/MT, cycle analyses support thermal limit monitoring without the use of the TIPs.

Following the first TIP set (required prior to BOC + 500 MWD/MT), the following applies for use of the SUBTIP methodology:

With one or more TIP measurement locations inoperable, the TIP data for an inoperable measurement location may be replaced by data obtained from a 3-dimensional BWR core monitoring software system adjusted using the previously calculated uncertainties, provided the following conditions are met:

- 1. All TIP traces have previously been obtained at least once in the current operating cycle when the reactor core was operating above 20% power, (References 14, 15 and 23) and
- 2. The total number of simulated channels (measurement locations) does not exceed 42% (18 channels).

Otherwise, with the TIP system inoperable, suspend use of the system for the above applicable monitoring or calibration functions.

6.3 Bases:

The operability of the TIP system with the above specified minimum complement of equipment ensures that the measurements obtained from use of this equipment accurately represent the spatial neutron flux distribution of the reactor core. The normalization of the required detectors is performed internal to the core monitoring software system.

Substitute TIP data, if needed, is 3-dimensional BWR core monitoring software calculated data which is adjusted based on axial and radial factors calculated from previous TIP sets. Since uncertainty could be introduced by the simulation and adjustment process, a maximum of 18 channels may be simulated to ensure that the uncertainties assumed in the substitution process methodology remain valid.

Technical Requirements Manual - Appendix J

Section 2

LaSalle Unit 2 Cycle 9

Reload Transient Analysis Results

May 2001

Technical Requirements Manual - Appendix J L2C9 Reload Transient Analysis Results

Table of Contents

Attachment	Preparer	Document
1	ComEd	Neutronics Licensing Report
2	Siemens Power Corporation	Reload Analysis Report
3	Siemens Power Corporation	Plant Transient Analysis
4	General Electric	ARTS Improvement Program Analysis, Supplement 1 (Excerpts)
5	General Electric	TCV Slow Closure Analysis (Excerpts)
6	Framatome ANP	LaSalle Unit 2 Cycle 9 Operating Limits for Proposed ITS Scram Times and Corrected Fuel Thermal Conductivity

Technical Requirements Manual - Appendix J L2C9 Reload Transient Analysis Results

Attachment 1

LaSalle Unit 2 Cycle 9

Neutronics Licensing Report

	TI	NUCLEAR FUEL MA RANSMITTAL OF DESIG	NAGEMENT N INFORMATION	I
SAFETY RELATED	ED TED	Originating Organ	nization ent	NFM ID# NFM000011 Sequence 0 Page 1 of 21
Station: <u>LaSalle</u> To: Jeffery K. Nugent (LS)		Unit: <u>2</u> C	ycle: 9	Generic:
Subject: LaSalle Unit Ming-Yuan Hsiao Preparer	2 Cycle 9 Neutronic Prepa	es Licensing Report 	ao	<u>9-15-00</u> Date
Peter A. Weggeman Reviewer	Kat	wer's Signature		<u>9,15-00</u> Date
Adelmo S. pallotta NFM Department Head	Appro	over's Signature	<u>}</u>	 Date
Status of Information:	ethod and Schedul	/erified Inverified Engineering Judgement	rified	
DESIGN INFORMATION :	Provide the station a	nd BSS group LaSalle Unit 2	Cycle 9 Neutronics	Licensing Report (NLR).
Purpose of Information: Seq. 0: Provide the station ar	d BSS group LaSall	e Unit 2 Cycle 9 Neutronics	Licensing Report (N	LR).
Source of Information: As re	ferenced	· · · · · · · · · · · · · · · · · · ·	- <u></u>	
Supplemental Distribution:	Danny Bost (LS) Thomas J. Rausch LaSalle Central Fi	John J. Reimer (LS) R. W. Tsai Downers Grove Centra	Amy Goss (LS) Adelmo S. Pallotta I File	Edward A. McVey Ming Y. Hsiao

۰.

 $\left(\right)$

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 2 of 21	

COMMONWEALTH EDISON COMPANY NUCLEAR FUEL SERVICES

NEUTRONICS LICENSING REPORT

for

LaSalle Unit 2 Cycle 9

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 3 of 21	

Licensing Basis

This document, in conjunction with the references 1, 2 and 4 in Section VIII provide the licensing basis for LaSalle Unit 2 Reload 8, Cycle 9.

Table of Contents

- I. Nuclear Design Analysis
 - I.1 Fuel Bundle Nuclear Design Analysis
 - I.2 Core Nuclear Design Analysis
 - I.2.1 Core Configuration and Licensing Exposure Limits
 - I.2.2 Core Reactivity Characteristics

II. Control Rod Withdrawal Error

III. Fuel Loading Error

- III.1 Fuel Mislocation Error
- III.2 Fuel Misrotation Error
- IV. Control Rod Drop Accident
- V. Loss of Feedwater Heating
- VI. Maximum Exposure Limit Compliance
- VII. Spent Fuel Pool and Fresh Fuel Vault Criticality Compliance

VII.1 Fresh Fuel Vault Criticality Compliance

VII.2 L1 Spent Fuel Pool Criticality Compliance

VII.3 L2 Spent Fuel Pool Criticality Compliance

VIII. References

preparer: mYH, 8-31-00

reviewer PAW 8.31-07

		NUCLEAR FUEL MANAGEMENT TRANSMITTAL OF DESIGN INFORMATION	NFM ID# Seq. No. Page 4 of 21	NFM0000115 0
I.	Nucle	ear Design Analysis		
	I.1	Fuel Bundle Nuclear Design Analysis		
		Assembly Average Enrichment (ATRIUM-9B), w/o U-23	5	
		SPCA9-391B-14G8.0-100M		3.91
		SPCA9-410B-19G8.0-100M		4.10
		SPCA9-383B-16G8.0-100M		3.83
		SPCA9-396B-12GZ-100M		3.96
		Axial Enrichment and Burnable Poison Distribution		
		SPCA9-391B-14G8.0-100M		Figure 1
		SPCA9-410B-19G8.0-100M		Figure 1
		SPCA9-383B-16G8.0-100M		Figure 2
		SPCA9-396B-12GZ-100M		Figure 2
	·	Radial Enrichment and Burnable Poison Distribution		
		SPCA9-4.53L-11G8.0-100M		Figure 3
		SPCA9-4.56L-12G8.0-100M		Figure 4
		SPCA9-4.21L-13G8.0-100M		Figure 5
		SPCA9-4.27L-12G8.0-100M		Figure 6
		SPCA9-3.96L-8G5.0-100M		Figure 7
		SPCA9-4.58L-8G6.0-100M		Figure 8
		SPCA9-4.58L-8G6.0/4G3.0-100M		Figure 9

preparer: myH, 8-31-00

•

Į

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 5 of 21	

I.2 Core Nuclear Design Analysis

I.2.1 Core Configuration and Licensing Exposure Limits

Bundle Type	Cycle <u>Loaded</u>	Number <u>in Core</u>
GE9B-P8CWB322-11GZ-100M-150-CECO	7	84
GE9B-P8CWB320-9GZ-100M-150-CECO	7	76
SPCA9-381B-13GZ7-80M	8	128
SPCA9-384B-11GZ6-80M	8	128
SPCA9-391B-14G8.0-100M	9	40
SPCA9-410B-19G8.0-100M	9	120
SPCA9-383B-16G8.0-100M	9	132
SPCA9-396B-12GZ-100M	9	56

Licensing Exposure Limits

Value of Interest	Core Average Exposure (MWD/MT)	Cycle Incremental Exposure (MWD/MT)
Nominal EOC 8 Exposure	27892	13750
Short EOC 8 Exposure	27392	13250
Minimum EOC 8 Energy for which C9 Neutronic Licensing Analyses are Valid	27392	13250
BOC 9 Exposure (assuming nominal EOC 8 energy)	11799	0
BOC 9 Exposure (assuming short EOC 8 energy)	11470	0
Nominal EOC 9 Exposure (assuming nominal EOC 8 energy)	29598	17800

Core UO₂ Weights

Cycle of Interest	UO ₂ Total Weight (MT)
Cycle 8	135.11
Cycle 9	133.50

i

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 6 of 21	

I.2.2 Core Reactivity Characteristics

All values reported below are with zero xenon and are for 68°F moderator temperature. The MICROBURN-B cold BOC best estimate K-effective bias is 1.004 at BOC. The shutdown margin calculations are based on the short EOC8 energy given in Section I.2.1.

BOC Cold K-Effective, All Rods Out	1.11257
BOC Cold K-Effective All Rods In	0.95674
BOC Cold K-Effective, Strongest Rod Out	0.99360
BOC Shutdown Margin, % ΔK	1.040
Minimum Shutdown Margin, % ΔK	1.020
Reactivity Defect (R-value), $\% \Delta K$	0.020
Cycle Incremental Exposure Corresponding to Minimum Shutdown Margin R-Value (MWD/MTU)	250
Standby Liquid Control System Shutdown	. – .
Margin, Cold Condition, $(\% \Delta K)$	17.8

LaSalle station has upgraded its Standby Liquid Control System so that the B-10 enrichment has been increased from 18.9% to 45%. The above SBLC analysis assumes 660 ppm with the boron enriched to 45% B-10.

preparer: m1H, 9-15-00

Ĩ

reviewer PAW 9.15.00

NFM ID#	NFM0000115
Page 7 of 21	0

II. Control Rod Withdrawal Error

The control rod withdrawal error event is analyzed at 100% of rated power, 100% of rated flow and unblocked conditions only.

Distance	
<u>Withdrawn (ft)</u>	<u>∆CPR</u>
12 (Unblocked)	0.30

The design complies with the SPC 1% plastic strain and centerline melt criteria via conformance to the PAPT (Protection Against Power Transient) LHGR limits. The design complies with the GE centerline melt criteria via conformance to the GE thermal overpower protection (TOP) criteria. The design complies with the GE 1% plastic strain criteria via conformance to the GE mechanical overpower protection (MOP) criteria.

III. <u>Fuel Loading Error</u>

The Fuel Loading Error, including fuel mislocation and misorientation, is classified as an accident. By demonstrating that the Fuel Loading Error meets the more stringent Anticipated Operational Occurrence (AOO) requirements, the offsite dose requirement is assured to be met. Because the events listed below result in a Δ CPR value that is less than that of the limiting transient, the AOO requirements and hence off-site dose requirements are met for the Fuel Loading Error.

III.1 Fuel Mislocation Error

The following value bounds both the SPC and the co-resident GE fuel types.

Event	<u>∆CPR</u>
Mislocated Bundle	0.23

III.2 Fuel Misrotation Error

The following value bounds both the SPC and the co-resident GE fuel types.

Event	
Misoriented Bundle	

<u>∆CPR</u>

0.15

reviewer PAW 9-1-00

	NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
1	TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
Ì		Page 8 of 21	

IV. Control Rod Drop Accident

LaSalle is a banked position withdrawal sequence plant. In order to allow the site the option of inserting control rods using the simplified control rod sequence shown in Table 1, a control rod drop accident analysis was performed for the simplified sequence. The results from this simplified sequence analysis bound those where BPWS guidelines are followed. The results demonstrate that the simplified shutdown sequence meets the Technical Specification limit of 280 cal/g for a control rod drop accident. Therefore, the simplified sequence is valid for for control rod insertion for shutdown.

An adder of 0.32 % ΔK is incorporated in this analysis (for other than 00 to 48 control rod drops) to account for possible rod mispositioning errors as well as clumping effects.

Maximum Dropped Control Rod Worth, %∆K	1.375
Doppler Coefficient, Δk/k/°F	-9.50E-06
Effective Delayed Neutron Fraction used	0.0053
Four-Bundle Local Peaking Factor	1.281
Maximum Deposited Fuel Rod Enthalpy, (cal/g)	222
Number of Rods Greater than 170 cal/g	266

Note that the limit on maximum deposited fuel rod enthalpy is 280 cal/g and the limit on the number of rods greater than 170 cal/g (failed rods) is 770 for the GE 8x8 fuel and 850 for the SPC ATRIUM-9B fuel (in LaSalle UFSAR).

V. Loss of Feedwater Heating

The loss of feedwater heating event is analyzed at 100% of rated power for 81%, 100% and 105% of rated flow and an assumed inlet temperature decrease of 145°F. The event was analyzed from BOC to EOC. The \triangle CPR value reported below is bounding for both the SPC and the co-resident GE fuel types and all the analyzed flows.

Event	<u>ACPR</u>
Loss of Feedwater Heating	0.23

The design complies with the SPC 1% plastic strain and centerline melt criteria via conformance to the PAPT (Protection Against Power Transient) LHGR limits. The design complies with the GE

reviewer PAW 10.4-00

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 9 of 21	

1% plastic strain criteria via conformance to the mechanical overpower protection (MOP) limit. The design does not meet the GE thermal overpower protection (TOP) criteria during a loss of feedwater heating event; hence, the LHGR values in the COLR for the affected lattice are adjusted accordingly (References 9, 13 and 14) as follows:

GE9B-P8CWB322-11GZ-100M-150-CECO Bundle (Fuel Type 1) LHGR Limits for L2C9

Nodal Exposure (GWD/ST)	Nodal Exposure (GWD/MT)	LHGR Limit
0	0	13.75
11.8459	13.06	13.75
25.2182	27.80	11.75
45.6410	50.31	10.31
55.2370	60.89	6.00

GE9B-P8CWB320-9GZ-100M-150-CECO Bundle (Fuel Type 2) LHGR Limits for L2C9

Nodal Exposure (GWD/ST)	Nodal ExposureNodal Exposure(GWD/ST)(GWD/MT)		
0	0	14.25	
11.0152	12.14	14.25	
23.7593	26.19	12.18	
43.6866	48.16	10.80	
54.3675	59.93	6.00	

VI. Maximum Exposure Limit Compliance

Note that the following exposures are based on a nominal Cycle 8 EOC exposure of 13750 MWD/MT and a nominal Cycle 9 exposure of 17800 MWD/MT. If Cycle 9 reaches it's long window (approximately 500 MWD/MTU beyond the nominal Cycle 9 energy), the exposure limits will still be met.

	GE9B	GE9B	ATRIUM-9B	ATRIUM-9B
Exposure	Projected	Limit	Projected	Limit*
(MWD/MT)	(MWD/MT)	(MWD/MT)	(MWD/MT)	(MWD/MT)
Peak Batch	39989	42000	36794	NA
Peak Assembly	45399	NA	39460	48000
Peak Rod	NA	NA	43243	55000
Peak Pellet	62595	65000	54918	66000

*The ATRIUM-9B exposure limits identified are not applicable until document EMF-85-74 is added to the Technical Specifications (Tech Specs). Until this document is added to the Tech Specs, the ATRIUM-9B exposure limits are 48.0 GWD/MT for Peak Fuel Assembly (no change), 50.0 GWD/MT for Peak Fuel Rod and 60.0 GWD/MT for Peak Fuel Pellet.

reviewer PAW 9.6-00

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 10 of 21	

VII. Spent Fuel Pool and Fresh Fuel Vault Criticality Compliance

For the L2C9 reload, there are four new SPC ATRIUM-9B assembly types consisting of seven unique enriched lattices, as identified in **I.1 Fuel Bundle Nuclear Design Analysis.**

VII.1 Fresh Fuel Vault Criticality Compliance

The fuel storage vault criticality analysis that is detailed in Reference 5 remains valid for the above lattices. All the new (ATRIUM-9B) assemblies comply with the fresh fuel vault criticality limits, i.e., all lattices have an enrichment of less than 5.00 wt % U-235 and a gadolinia content that is greater than 6 rods at 3.0 wt% Gd_2O_3 .

Note that the new fuel vault is a moderation-controlled area which implies that hydrogenous materials will be limited within the new fuel storage array. Administrative controls as generally defined in GE SIL No. 152 (dated March 31,1976) must be incorporated for the area.

VII.2 L1 Spent Fuel Pool Criticality Compliance

The LaSalle Unit 1 spent fuel pool criticality analysis that is detailed in Reference 6 remains valid for the above lattices. All the new (ATRIUM-9B) assemblies comply with the spent fuel pool criticality limits, i.e., all lattices have an enrichment of less than 4.60 wt % U-235 and a gadolinia content that is greater than 8 rods at 3.0 wt% Gd₂O₃.

VII.3 <u>L2 Spent Fuel Pool Criticality Compliance</u>

The LaSalle Unit 2 spent fuel pool criticality analysis that is detailed in Reference 7 remains valid for the above lattices. As shown below, all the new (ATRIUM-9B) assemblies comply with the LaSalle Unit 2 spent fuel pool criticality limit of k-eff < 0.95.

Lattice Type	Maximum k-inf*	Maximum in-Rack k-eff**	Spent Fuel Pool k-eff Limit
SPCA9-4.21L-13G8.0-100M	1.169	< 0.85	0.95
SPCA9-4.27L-12G8.0-100M	1.180	< 0.85	0.95
SPCA9-4.53L-11G8.0-100M	1.192	< 0.85	0.95
SPCA9-4.56L-12G8.0-100M	1.187	< 0.85	0.95
SPCA9-3.96L-8G5.0-100M	1.231	< 0.86	0.95
SPCA9-4.58L-8G6.0/4G3.0-100M	1.233	< 0.86	0.95
SPCA9-4.58L-8G6.0-100M	1.236	< 0.86	0.95

* From 68 °F, uncontrolled CASMO-3G results.

****** From Figure 6.1 of Reference 7.

reviewer MW 9.15.00

ſ	NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
i	TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
ł		Page 11 of 21	

VIII. <u>References</u>

- 1. "LaSalle Unit 2 Cycle 9 Reload Analysis", Siemens Power Corporation, EMF-2437, Latest Revision.
- 2. "LaSalle Unit 2 Cycle 9 Plant Transient Analysis", Siemens Power Corporation, EMF-2440, Latest Revision.
- 3. "LaSalle 2 cycle 9 Core Design," NDIT NFM0000056 Seq. 1, April 7, 2000 and "L2C9 FLLP," BNDL:00-005, Revision 0, 4/7/2000.
- 4. Commonwealth Edison, Nuclear Fuel Services, NFSR-0091, "Benchmark of CASMO/MICROBURN BWR Nuclear Design Methods", as supplemented and approved.
- 5. "Criticality Safety Analysis for ATRIUM-9B Fuel, LaSalle Units 1 and 2 New Fuel Storage Vault," Siemens Power Corporation, EMF-95-134(P), December 1995. [NDIT 960089, Rev. 0]
- 6. "Criticality Safety Analysis for ATRIUM-9B Fuel, LaSalle Unit 1 Spent Fuel Storage Pool (BORAL Rack)," Siemens Power Corporation, EMF-96-117(P), April 1996. [NDIT 960087, Rev. 0]
- 7. "Criticality Safety Analysis for ATRIUM-9B Fuel, LaSalle Unit 2 Spent Fuel Storage Pool (Boraflex Rack)," Siemens Power Corporation, EMF-95-088(P), February 1996. [NDIT 960088, Rev. 0]
- 8. "L2C9 Standby Liquid Control System Worth Calculations," BNDL:00-028, Revision 0, July 14, 2000.
- 9. "L2C9 Loss of Feedwater Heating Licensing Analysis," BNDL:00-024, Revision 0, July 13, 2000.
- 10. "LaSalle Unit 2 Cycle 9 RWE delta CPR," BNDL:00-026, Revision 0, August 23, 2000.
- 11. "L2C9 Rod Withdrawal Error MOP/TOP Analysis," BNDL:00-023, Revision 0, August 17, 2000.
- 12. "LaSalle Unit 2 Cycle 9 Neutronic Licensing Shutdown Margin Calculation," BNDL:00-032, Revision 0, August 17, 2000.
- 13. "LaSalle 2 Cycle 9 LFWH TOP Violation and LHGR Limit Calculation," Letter NFM:BND:00-050, July 13, 2000.
- 14. "LaSalle 2 Cycle 9 GE9 Curve Adjustment for LFWH TOP Violation," GE Letter KF-00-063, August 24, 2000.
- 15. "LaSalle 2 Cycle 9 LFWH TOP Violation and LHGR Limit Calculation," Letter NFM:BND:00-050, July 13, 2000.
- 16. "L2C9 Mislocation Licensing Analysis," BNDL:00-025, September 2000.
- 17. "L2C9 Bundle Misorientation Analysis," BNDL:00-030, September 2000.

reviewer PAW 8.31-00

	the second se	
NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 12 of 21	

Table 1

L2C9 Simplified Shutdown Sequence

Shutdown From an A1 Sequence

Rod Group*	Insertion (Bank)	Comments**
7 or 8	48-00	Either Group 7 or 8 may be inserted first.
10	48-00	Groups 7 and 8 must be fully inserted prior to inserting any Group 10 rod.
9	48-00	Group 10 must be fully inserted prior to inserting any Group 9 rod.
5 or 6	48-00	Groups 5 and 6 may be inserted without banking anytime after Groups 7 and 8 have been inserted and before Group 4 is inserted.
4	48-00	Groups 5 through 10 must be fully inserted prior to inserting any Group 4 rod.
3	48-00	Group 4 must be fully inserted prior to inserting any Group 3 rod.
2	48-00	Group 3 must be fully inserted prior to inserting any Group 2 rod.
1	48-00	Group 2 must be fully inserted prior to inserting any Group 1 rod.

Shutdown from an A2 Sequence

	Insertion	
Rod Group*	(Bank)	Comments**
9 or 10	48-00	Either Group 9 or 10 may be inserted first.
8	48-00	Groups 9 and 10 must be fully inserted prior to inserting any Group 8 rod.
7	48-00	Group 8 must be fully inserted prior to inserting any Group 7 rod.
5 or 6	48-00	Groups 5 and 6 may be inserted without banking anytime after Groups 9 and 10 have been inserted and before Group 4 is inserted.
4	48-00	Groups 5 through 10 must be fully inserted prior to inserting any Group 4 rod.
3	48-00	Group 4 must be fully inserted prior to inserting any Group 3 rod.
2	48-00	Group 3 must be fully inserted prior to inserting any Group 2 rod.
1	48-00	Group 2 must be fully inserted prior to inserting any Group 1 rod.

*Group definitions are from LAP-100-13 Revision 21.

** The standard BPWS rules concerning out-of-service rods apply to the shutdown sequences.

reviewer PAW 9.1.00

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 13 of 21	



SPCA9-391B-14G8.0-100M

SPCA9-410B-19G8.0-100M

Figure 1. L2C9 Bundle Design (Fuel Types 16 and 17)

reviewer PAW 8.31.00



SPCA9-383B-16G8.0-100M

SPCA9-396B-12GZ-100M

Figure 2. L2C9 Bundle Design (Fuel Types 18 and 19)

preparer: M7H, 8-31-00

reviewer PAW 8-31-00

NUCLEAR FUEL MANAGEMENT TRANSMITTAL OF DESIGN INFORMATION

NFM ID# Seq. No. Page 15 of 21

NFM0000115 0

	Watter and the	an a				<u>ब</u>		
1 3.00	2 3.60	3 4.40	5 4.70	4 4.95	5 4.70	3 4.40	2 3.60	1 3.00
2 3.60	8 4.40 	4 4.95	4 4.95	8 4.40 - 8.00	4 4.95	4 4.95	8 4.40 - 8.00	2 3.60
3 4.40	4 4.95	4 4.95	4 4.95	4 4.95	4 4.95	4 4.95	4 4.95	3 4.40
5 4.70	4 4.95	4 4.95				8 4:40 8:00	` 4 4.95	4 4.95
4 4.95	8 440 8:00	4 4.95		-Internal Water Channel -		, 4 4.95	8 4.40 8.00	4 4.95
5 4.70	4 4.95	4 4.95				4 4.95	4 4.95	4 4.95
3 4.40	4 4.95	4 4.95	8 4:40 8:00	4 4.95	4 4.95	8 4:40 8:00	4 4.95	3 4.40
2 3.60	38 4:40 = 8.00	4 4.95	4 4.95	-8 -4!40 	4 4.95	4 4.95	8 4:40 8:00	2 3.60
1 3.00	2 3.60	3 4.40	4 4.95	4 4.95	4 4.95	3 4.40	2 3.60	1 - 3.00
		TYPE 1 2 3 4 5 6 7 8 9	# 4 8 37 4 0 0 11 0	ENR 3.00 3.60 4.40 4.95 4.70 4.40 0.00	GD 0 0 0 0 0 0 8.00 0	•	- -	

Figure 3. SPCA9-4.53L-11G8.0-100M Lattice Enrichment Distribution

preparer: MYH, 8-31=00

reviewer PAW 8.3/-00

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 16 of 21	

	1	2	3	4	4	- 4	3	2 ·	1
	3.00	4.00	4.70	4.95	4.95	4.95	4.70	4.00	3.00
	2	2	G1.	4	G2	4	.G1-	2	2
	4.00	4:00	4.20	4.95	4.70	4.95	4.20	4.00	4.00
and the second s	3	G1	4	4	4	4	4	G1	3
	4.70	4:20	4.95	4.95	4.95	4.95	4.95	420	4.70
and the second	4 . 4.95	4 4.95	4 4.95				4 4.95	4 4.95	4 4.95
	4 4.95	G2 470	4 4.95		Internal Water Channel		4 - 4.95	G2 4:70	4 4.95
New York	4 4.95	4 4.95	4 4.95				4 4.95	4 4.95	4 4.95
	3	G1	4	4	4	4	4	G1	3
	4.70	4.20	4.95	4.95	4.95	4.95	4.95	4:20	4.70
	2	2	G1	4	G2	4	G1	2	2
	4.00	4.00	4.20	4.95	4.70	4.95	4.20	4.00	4.00
1	1	2	3	4	4	4	3	2	1
	3.00	4.00	4.70	4.95	4.95	4.95	4.70	4.00	3.00

1	Rods (4)	3.00 w/o U-235
2	Rods (12)	4.00 w/o U-235
3	Rods (8)	4.70 w/o U-235
4	Rods (36)	4.95 w/o U-235
G1	Rods (B)	4.20 w/o U-235+8.0 w/o Gd2O3
G2	Rods (4)	4.70 w/o U-235+8.0 w/o Gd2O3

Figure 4. SPCA9-4.56L-12G8.0-100M Lattice Enrichment Distribution

preparer: MYH, 8-31-00

reviewer PAW 8.31.00

NUCLEAR FUEL MANAGEMENT TRANSMITTAL OF DESIGN INFORMATION

NFM ID# Seq. No. Page 17 of 21 NFM0000115 0

1000	1999 (C. 1997)								
unita unita da	1 2.60	2 3.20	3 4.00	3 4.00	5 4.40	3 4.00	3 4.00	2 3.20	1 2.50
	2 3.20	8 4:40 8:00	4 4.70	4 4.70	8 4:40 = 8:00 _	4 4.70		3 4.00	2 [.] 3.20
AT THE AT A CONTRACT OF A CONT	3 4.00	4 4.70	4 4.70	4 4.70	4 4.70	4 4.70	4 4.70	8 4.40, 8.00	3 4.00
	3 4.00	4 4.70	4 4.70				8 4:40 8:00	4 4.70	4 4.70
	5 4.40	8 4,40 8,00	4 4.70		Watar Watar Ghannal		4 4.70	8 4:40 8:00	4 4.70
4	3 1.00	4 4.70	4 4.70				4 4.70	4 4.70	4 4.70
4	3 .00	83 4:40 8:00	4 4.70		4 4.70	4 4.70	18 4.40 8.00	4 4.70	3 4.00
3.	2 .20	3 4.00	8 4:40 8:00	4 4.70	8 4 40 38 00	4 4.70	4 4.70	8 4:40 8:00	2 3.20
2.	1 60	2 3.20	3 4.00	4 4.70	4 4.70	4 4.70	3 4.00	2 3.20	1 2.60
			ТҮРЕ	#-	ENR	GD			
			1	4	2.60	0			
			2	8	3.20	0		•	
			3	14	4.00	0	•		
			4	31	4.70	0			
			6	0	4.40	n			
			7	õ		0			
			8	13	4.40	8.00			
			9	0	0.00	0			

Figure 5. SPCA9-4.21L-13G8.0-100M Lattice Enrichment Distribution

preparer: myH, 8-31-00

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 18 of 21	

aniza aniany	and want wat Dress	and the second	and the second			<u> </u>		
1 2.50	2 3.20	3 4.00	5 4.40	4 4.70	··· 5 4.40	3 4.00	·· 2 3.20	1 2.60
2 3.20	8 4.40 5	4 4.70	4 4.70	8 4.40 # 8.00	4 4.70	4 4.70	283 283 4,40 528	2 3.20
3 4.00	4 4.70	8 4,40 -8,00	4 4.70	4 4.70	4 4.70	4 4.70	4 4.70	3 4.00
5 4.40	4 4.70	4 4.70				-8 -4,40 -8:00	4 4.70	4 4.70
4 4.70	4.40 6.00	4 4.70		Cinternal Water Channel		4 4.70	8 4 4 40 8 00 70	4 4.70
5 4.40	4 4.70	4 4.70				4 4.70	4 4.70	4 4.70
3 4.00	4 4.70	4 4.70	8: 4:40 8:00	4 4.70	4 4.70	8 4.40 8.00	4 4.70	3 4.00
2 3.20	8 4 40 - 8.00	4 4.70	4 4.70	6 4.40 8.00	4 4.70	4 4.70		2 3.20
1 2.60	2 3.20	3 4,00	4 4.70	4 4.70	4 4.70	3 4.00	2 3.20	1 2.60
		TYPE 1 2 3 4 5	# 4 8 8 36 4	ENR 2.60 3.20 4.00 4.70 4.40	GD 0 0 0 0	· · · · · · · · · · · · · · · · · · ·		
		5 6 7 8	4 0 0 12	4.40	0 0 8.00		•	

Figure 6. SPCA9-4.27L-12G8.0-100M Lattice Enrichment Distribution

0.00

0

0

preparer: MYH, 8-31-00

9

reviewer PAW 8.31-60

NUCLEAR FUEL MANAGEMENT	NFM ID#	NFM0000115
TRANSMITTAL OF DESIGN INFORMATION	Seq. No.	0
	Page 10 of 21	

	1 2.60	2 3.40	3 3.80	4 4.40	4 4.40	4 4.40	3 3.80	2 · 3.40	1 2.60	
	2 3.40	2 3.40	· 4 4.40	G1 3.40	4 4.40	G1 3:40	4 4.40	2 3.40	2 3.40	
	3 3.80	4 4.40	4 4.40	. 4 4.40	4 4.40	4 4.40	4 4.40	4 4.40 ·	3 3.80	
NULL NULL	4 4.40	G1 3/40	4 4.40				4 4.40	Gil 3.402	4 4.40	
	4 4.40	4 4.40	4 4.40		Internal Water Channel		4 4.40	4 4.40	4 4.40	
NAMES OF A	ب ب 4.40	G1 3.40	4 4.40				4 4.40	G1 - 3:40	4 4.40	
	3 3.80	4 4.40	4 4.40	4 4.40	4 4.40	4 4.40	4 4.40	4 4.40	3 3.80	
	2 3.40	2 3.40	4 4.40	G1 3:40	4 4.40	G1 3:40	4 4.40	2 3.40	2 3.40	
	1 2.60	2 3.40	3 3.80	4 4.40	4 4.40	4 4.40	3 3.80	2 3.40	1 2.60	

1	Rods (4)	2.60 w/o U-235
2	Rods (12)	3.40 w/o U-235
3	Rods (8)	3.80 w/o U-235
4	Rods (40)	4.40 w/o U-235
G1	Rods (8)	3.40 w/o U-235+5.0 w/o Gd2O3

Figure 7. SPCA9-3.96L-8G5.0-100M Lattice Enrichment Distribution

preparer: MYH, 8-31-00

.

.:(

NUCLEAR FUEL MANAGEMENT TRANSMITTAL OF DESIGN INFORMATION

NFM ID# Seq. No. Page 20 of 21 NFM0000115

0

	S	States and		ter and	at state and		<u>a</u>		
CHARTER STATE	1	2	3	. 4	. <u>4</u>	4	3	2	. 1
	3.00	4.00	4.70	4.95	4.95	4.95	4.70	4.00	3.00
No. A. C. C. C.	2	2	- 4	G1	4	G1	4	2	2
	4.00	4.00	4.95	4.20	4.95	-4.20	4.95	4.00	4.00
	3	4	4	4	4	4	4	4	3
	4.70	4.95	4.95	4.95	4.95	4.95	4.95	4.95 ·	4.70
Manandan	4 4.95	- G15 4.20	4 4.95				4 4.95	G1 4.20	4 4.95
N. S.	4 [°] 4.95	4 4.95	4 4.95		Internal Water Channel		4 4.95	4 4.95	4 4.95
	4 4.95	G110 420 421	4 4.95				4 4.95	<u>G</u> 17 4-20	4 4.95
	3	4	4	4	4	4	4	4	3
	4.70	4.95	4.95	4.95	4.95	4.95	4.95	4.95	4.703
	2	2	4	G1	4	G1	4	2	2
	4.00	4.00	4.95	4:20	4.95	4.20	4.95	4.00	4.00
	1	2	3	4	4	4	3	2	1
	3.00	4.00	4.70	4.95	4.95	4.95	4.70	4.00	3.00

1	Rods (4)	3.00 w/o U-235
2	Rods (12)	4.00 w/o U-235
3	Rods (8)	4.70 w/o U-235
4	Rods (40)	4.95 w/o U-235
G1	Rods (8)	4.20 w/o U-235+6.0 w/o Gd2O3

Figure 8. SPCA9-4.58L-8G6.0-100M Lattice Enrichment Distribution

preparer: m7H,8-31-00

ĩ

1			
	NUCLEAR FUEL MANAGEMENT	NEM ID#	NEM0000115
			11110000110
	TRANSMITTAL OF DESIGN INFORMATION	Sea No	n ·
		004.140.	Ū
	1	Page 21 of 21	

8	S.S. S.S. 2973								
A THE REAL PROPERTY IN	1	2	3	4	4	4	3	2	. 1
	3.00	4.00	4.70	4.95	4.95	4.95	4.70	4.00	3.00
A. M. Martin	2	G2	- 4	<u>G1</u>	4	G1	4	G2	2
	4.00	4.00	4.95	4.20	4.95	4.20	4.95		4.00
	3 4.70	4 4.95	4 4.95	4 4.95	4 4.95	4 4.95	4 4.95	4 4.95	3 4.70
	4 4.95	-iG1 -iG1 -i4.20	4 4.95				4 4.95	- G1 - 420	4 4.95
	4 4.95	4 4.95	4 4.95		Internal Water Channel		4 4.95	4 4.95	4 4.95
Will States	4 4.95	G1. 4.20	4 4.95				4 4.95	G1 :420	4 4.95
	3	4	4	4	4	4	4	4	3 ⁶ ,
	4.70	4.95	4.95	4.95	4.95	4.95	4.95	4.95	4.70 ⁴
	2	G2 22	4	G1	4	G1	4	G2	2
	4.00	4.00	4.95	4:20	4.95	4:20	• 4.95	4.00	4.00
	1	2	3	4	4	4	3	2	1
	3.00	4.00	4.70	4.95	4.95	4.95	4.70	4.00	3.00

7	Rods (4)	3.00 w/o U-235
2	Rods (8)	4.00 w/o U-235
3	Rods (8)	4.70 w/o U-235
4	Rods (40)	4.95 w/o U-235
G1	Rods (8)	4.20 w/o U-235+6.0 w/o Gd2O3
G2	Rods (4)	4.00 w/o U-235+3.0 w/o Gd2O3

Figure 9. SPCA9-4.58L-8G6.0/4G3.0-100M Lattice Enrichment Distribution

preparer: m7H, 8-31-00

reviewer PAW 8-31-00